

General Disclaimer

One or more of the Following Statements may affect this Document

- This document has been reproduced from the best copy furnished by the organizational source. It is being released in the interest of making available as much information as possible.
- This document may contain data, which exceeds the sheet parameters. It was furnished in this condition by the organizational source and is the best copy available.
- This document may contain tone-on-tone or color graphs, charts and/or pictures, which have been reproduced in black and white.
- This document is paginated as submitted by the original source.
- Portions of this document are not fully legible due to the historical nature of some of the material. However, it is the best reproduction available from the original submission.



NASA

ANALYSIS AND EVALUATION
of
SPACECRAFT BATTERY
LIFE TEST DATA
(PHASE 2)

N70-12539

(ACCESSION NUMBER) 115
(THRU) /
(PAGES) 9
(CODE) Q3
(NASA CR OR TMX OR AD NUMBER)
04107119

PACILITTY FORM 602

prepared for
GODDARD SPACE FLIGHT CENTER
Naval Ammunition Dept
S-23404 11



QUALITY EVALUATION LABORATORY
NAD CRANE, INDIANA

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
LIST OF TABLES	iii
LIST OF ILLUSTRATIONS	vi
ABSTRACT	vii
I. INTRODUCTION	1
A. GENERAL	1
B. APPROACH	1
C. ORGANIZATION	1
II. CONCLUSIONS	2
A. PREDICTION	2
B. ACCEPTANCE TESTING	2
C. FAILURE ANALYSIS	3
III. RECOMMENDATIONS	4
A. PREDICTION	4
B. ACCEPTANCE TESTING	5
C. FAILURE ANALYSIS	5
IV. DATA ANALYSIS AND SUMMARY	6
A. PREDICTION	6
1. Discussion	6
2. Summary	6
a. Comparison of Prediction Methods	6
(1) Average Time To Discharge	7
(2) Average Time To Charge	9
(3) Regression Analysis	9
b. Reliability Improvement By Overspecifying Need	12

<u>SECTION</u>	<u>PAGE</u>
B. ACCEPTANCE TESTING	15
1. The Data	15
2. Summary	15
C. EVALUATION OF FAILURE ANALYSIS CHARACTERISTICS	26
1. Failure Analysis Results	26
2. Correlations Among Failure Characteristics	34
3. Failure Time Dependency On Failure Characteristics	49
4. A Proposed Bayesian Approach To Evaluation Of Failure Analysis Results	79

APPENDIXES

A. PROCEDURE FOR PREDICTION OF CELL FAILURE TIME USING TIME TO DISCHARGE	83
B. PROCEDURE FOR PREDICTION OF CELL FAILURE TIME USING TIME TO CHARGE	85
C. PROCEDURE FOR PREDICTION OF CELL FAILURE TIME USING LINEAR REGRESSION	86
D. FAILURE ANALYSIS RESULTS - NAD CRANE LIFE CYCLING PROGRAM	87

LIST OF TABLES

<u>TABLE</u>		<u>PAGE</u>
1	Percentage of Correct and Incorrect Decisions Using The Average Time To Discharge	8
2	Evaluations Of Predictions - Time To Discharge Method	10
3	Comparison Of Predictions Of 15 Selected 10-Cell Packs Using Charge and Discharge Data	11
4	Percentage of Correct and Incorrect Decisions Made Using The Linear Regression Procedure With 1000 Test Cycles	13
5	Evaluation Of Predictions - Regression Method	14
6	Multiple Regression Correlation Coefficients	17
7	Simple Correlation Coefficients (Selected Variables) .	18
8	General Electric 3.0 A.H. - Simple Correlation Coefficient	19
9	General Electric 12.0 A.H. - Simple Correlation Coefficient	20
10	Gould 3.5 A.H. - Simple Correlation Coefficient . . .	21
11	Gould 20.0 A.H. - Simple Correlation Coefficient . . .	22
12	Gulton 6.0 A.H. - Simple Correlation Coefficient . . .	23
13	Gulton 20.0 A.H. - Simple Correlation Coefficient . .	24
14	Sonotone 5.0 A.H. - Simple Correlation Coefficient . .	25
15	Frequencies Of Failure Characteristics And Levels Of Each From Original Cycling Test - General Electric .	27
16	Frequencies Of Failure Characteristics And Levels Of Each From Original Cycling Test - Gould	28
17	Frequencies Of Failure Characteristics And Levels Of Each From Original Cycling Test - Gulton	29
18	Frequencies Of Failure Characteristics And Levels Of Each From Original Cycling Test - Sonotone	30

<u>TABLE</u>	<u>PAGE</u>
19 Frequencies Of Failure Characteristics And Levels Of Each From Non-Standard Packs - General Electric And Gulton	31
20 Frequencies Of Failure Characteristics And Levels Of Each From Non-Standard Packs - Gulton and Sonotone	32
21 Frequencies of Occurrence Of Failure Characteristics .	33
22 Combination Frequencies Of Characteristics Occurring Jointly - General Electric	37
23 Combination Frequencies Of Characteristics Occurring Jointly - Gould	38
24 Combination Frequencies Of Characteristics Occurring Jointly - Gulton	39
25 Combination Frequencies Of Characteristics Occurring Jointly - Sonotone	40
26 Combination Frequencies Of Characteristics Occurring Jointly - 0°C.	41
27 Combination Frequencies Of Characteristics Occurring Jointly - 25°C	42
28 Combination Frequencies Of Characteristics Occurring Jointly - 40°C	43
29 Combination Frequencies Of Characteristics Occurring Jointly - 15% Depth Of Discharge	44
30 Combination Frequencies Of Characteristics Occurring Jointly - 25% Depth Of Discharge	45
31 Combination Frequencies Of Characteristics Occurring Jointly - 40% Depth Of Discharge	46
32 Combination Frequencies Of Characteristics Occurring Jointly - 1.5 Hour Orbit Time	47
33 Combination Frequencies Of Characteristics Occurring Jointly - 3.0 Hour Orbit Time	48

<u>TABLE</u>	<u>PAGE</u>
34 Mean Failure Times And Range Of Failures For Manufacturer-Orbit Time Combinations - General Electric	75
35 Mean Failure Times And Range Of Failures For Manufacturer-Orbit Time Combinations - Gould	76
36 Mean Failure Times And Range Of Failures For Manufacturer-Orbit Time Combinations - Gulton	77
37 Mean Failure Times And Range Of Failures For Manufacturer-Orbit Time Combinations - Sonotone	78

LIST OF ILLUSTRATIONS

<u>FIGURE</u>		<u>PAGE</u>
1	Combination Frequencies Of Failure Characteristics	50
2	General Electric - 1.5 Hour Orbit Time Characteristic Code 2-4	53
3	General Electric - 1.5 Hour Orbit Time Characteristic Code 14-16	54
4	General Electric - 3.0 Hour Orbit Time Characteristic Code 3, 11, 14	55
5	General Electric - 3.0 Hour Orbit Time Characteristic Code 16.	56
6	Gould - 1.5 Hour Orbit Time-Characteristic Code 2-4 . . .	57
7	Gould - 1.5 Hour Orbit Time-Characteristic Code 6, 8, 9 .	58
8	Gould - 1.5 Hour Orbit Time-Characteristic Code 14, 16 .	59
9	Gould - 3.0 Hour Orbit Time-Characteristic Code 2-4 . . .	60
10	Gould - 3.0 Hour Orbit Time-Characteristic Code 6, 8, 14. .	61
11	Gould - 3.0 Hour Orbit Time-Characteristic Code 15-16 . . .	62
12	Gulton - 1.5 Hour Orbit Time-Characteristic Code 2-4. . . .	63
13	Gulton - 1.5 Hour Orbit Time-Characteristic Code 5, 6, 9. .	64
14	Gulton - 1.5 Hour Orbit Time-Characteristic Code 11, 13, 14	65
15	Gulton - 1.5 Hour Orbit Time-Characteristic Code 15-16. . .	66
16	Gulton - 3.0 Hour Orbit Time-Characteristic Code 2-4. . . .	67
17	Gulton - 3.0 Hour Orbit Time-Characteristic Code 5, 13, 14.	68
18	Gulton - 3.0 Hour Orbit Time-Characteristic Code 15-16. . .	69
19	Sonotone - 1.5 Hour Orbit Time-Characteristic Code 3, 4, 6.	70
20	Sonotone - 1.5 Hour Orbit Time-Characteristic Code 9, 10, 13	71
21	Sonotone - 1.5 Hour Orbit Time-Characteristic Code 14-16 . .	72
22	Sonotone - 3.0 Hour Orbit Time-Characteristic Code 3, 6, 10.	73
23	Sonotone - 3.0 Hour Orbit Time-Characteristic Code 14, 16. .	74

ABSTRACT

This report presents the findings from the mathematical/statistical analysis of data generated by life tests on 660 nickel-cadmium spacecraft battery cells. The tests were conducted at NAD Crane beginning in 1963.

Three major objectives of the analysis were to: (1) determine the reliability of methods of predicting the useful life of the cells, (2) determine the statistical meaning of data collected during present acceptance testing and whether the acceptance data can be used in making life predictions, and (3) determine if particular failure characteristics or combinations thereof could be related to specific environmental factors.

Results of the analysis indicate: (1) about 85% accuracy in predicting the useful life of a cell, (2) the addition of acceptance data to the prediction model is of little value, and (3) failure characteristics were found to be highly correlated with specific environmental factors in several instances.

The improved automated data acquisition system to be installed will generate precise data which will yield more accurate predictions from more meaningful test results. Also important is the consideration that the improved data acquisition will permit earlier predictions of cell quality in a period of time known to be nondestructive to cells of reasonable quality.

i. INTRODUCTION

A. GENERAL

This is a summary report on mathematical/statistical analyses of spacecraft battery data conducted by the Naval Ammunition Depot, Crane, Indiana for the National Aeronautics and Space Administration from January 1968 to July 1969. The work was performed in accordance with NASA Defense Purchase Request No. S-23404-G, Amendment No. A-24 of 17 January 1968.

The report deals primarily with three topics:

- a. The reliability of NAD Crane's prediction techniques,
- b. The relationship of acceptance test parameters to life test data and prediction,
- c. The evaluation of failure analysis data.

B. APPROACH

A technique for predicting cell life (failure time) of spacecraft battery cells was outlined in NAD Crane Report QE/C 67-592 of November 1967. The technique was devised and predictions were made for 170 of 660 standard nickel-cadmium cells which were placed on life test at NAD Crane beginning in 1963. This report presents the results of applying the prediction methods to all 660 cells.

Using the techniques of multiple linear regression, possible relationships between failure times of the various cells and the data generated during acceptance testing were investigated.

All NAD Crane failure analysis data were transferred to IBM data cards for subsequent computer processing; failure characteristics or combinations of characteristics were related to specific environmental factors where possible.

C. ORGANIZATION

The following sections of this report give in the order listed: the conclusions which were derived from the data analysis; recommendations based on the conclusions; and a summary of the data analysis performed on each of the topics listed above.

II. CONCLUSIONS

Based on the analysis of the test results, the following conclusions are drawn with regard to:

A. PREDICTION

The average cell-times to selected charge and discharge voltage levels are effective parameters for predicting cell life of spacecraft batteries using a relatively small number of test cycles (300) and all available failure data. Hence, these parameters may be used as bases for a cell screening procedure to assure that higher quality cells will be used in space missions. There were no significant differences in the percentage of correct decisions due to the number of cycles (300, 1000 or 2000) used in making the predictions.

The overall accuracy in predicting cell failures is better when using "time to discharge data" rather than "time to charge" data. However, use of the charge data yielded slightly better results with regard to the percentage of unreliable cells retained when using 300 cycles.

The reliability of cells selected for space missions could be improved substantially (about 7% when 300 cycles of data are available) over the proposed prediction and screening procedure by over-specifying the cell lifetime requirements of the missions. This over-specification would be somewhat more costly since an increased number of good cells would inadvertently be rejected. (See page 15, Section IV).

B. ACCEPTANCE TESTING

The purpose of the acceptance tests conducted by the manufacturer and NAD Crane were to screen battery cells for the life test which was performed subsequently and hence to remove catastrophic or short life failures from the life test group. The Crane acceptance tests, analyzed in this report, accomplished this end and, in addition, allowed a comparison between the acceptance test parameters measured and the eventual failure time of the cell. The latter is an important consideration since the Crane tests include most acceptance test measurements used to qualify cells for spacecraft use.

Parameters measured during acceptance tests (as they are presently being performed) are of little value in predicting the cell life of nickel-cadmium spacecraft batteries since they are not, in general, significantly correlated with the cell failure time. Furthermore, specifications are not generally established and used. If specifications can not be placed on acceptance test parameters and these parameters do not relate significantly to cell life, their value must be seriously questioned and re-evaluated.

QE/C 69-665

A more accurate profile of cell quality could be obtained by increasing the number of cycles for performing acceptance tests. Presently acceptance tests are performed on only three charge-discharge cycles.

C. FAILURE ANALYSIS

Statistical examination of the data showed that it was possible to associate different failure characteristics:

- (1) to source of manufacture,
- (2) to one another by examining the correlations or rates of simultaneous occurrence,
- (3) to propensities to fail under certain ambient temperature levels within manufacturer, and
- (4) with deterioration rates across temperature.

For example, the results show that migration of the plate material and separator deterioration are highly correlated (correlation coefficient, $r = .95$); this result implies that it should not be necessary to distinguish between these characteristics during future failure analysis for battery types of similar design.

The failure characteristics observed and recorded, while informative and useful in correcting manufacturing design and quality control deficiencies, appear to need examination and re-structuring in the light of correlations and information now available. The fact that battery designs were not standard and little was known about the interiors of the battery types subjected to test reduces the amount of meaningful information that may be gleaned from the available failure data.

A proposed Bayesian technique to quantitatively (probabilistically) analyze failure analysis data was derived and is given in this report. (See page 79). Additional information from manufacturers pertaining to battery cell structure and, hopefully, from future sampling of new procurements (so that their initial characteristics could be studied by dissecting the interior) may later be incorporated into a Bayesian model for quantitative analysis.

This technique will systematically review the failure information (stored on magnetic tape and updated when new failures occur), and will give the project engineers a readable computer printout illustrating the cell failure characteristics and their associations with different test conditions and manufacturers.

III. RECOMMENDATIONS

Based on the battery reliability needs for space vehicles and on the data analysis of the cycling test results, it is recommended that:

A. PREDICTION

All spacecraft batteries which now or will in the near future be put on life test be continued until failure or until 10,000 successful cycles have been completed. If it becomes necessary that life testing of certain cells be discontinued at any point prior to failure, these cells should undergo the same examination as failed cells. This would allow a comparison between the characteristics noted in good cells and those noted in cells that have failed.

Voltage and temperature data be collected via the new automated data acquisition system every cycle for the first 500 cycles at two minute intervals. After 500 cycles, less frequent monitoring, such as every five or ten cycles, will be sufficient from a prediction point of view.

Failure times be predicted after 50, 100, and 200 cycles of testing on the new automated data acquisition system using the methods described herein and the results compared with the actual failure times.

Frequent measurements of internal cell pressure be made early in the life of the battery. The frequency of measurement should approach that given above for voltage and temperature if economy permits. Many cells in the Crane life tests have failed because of high internal pressure. Hence, it is logical to conjecture that some empirical relationship, as well as physical, exists between the cell's internal pressure and voltage. It has already been established that the cell's discharge time to 1.25 volts is correlated with failure time. Such a relationship could form the basis for a highly reliable prediction and screening method when combined with present knowledge.

Time to charge and time to discharge profiles and prediction methods be examined for cells of more recent manufacture so that prediction and screening methods might be tailored to any battery type of interest to NASA. Even if such studies should result in conclusions that cell life predictions are consistently high or low for some newer battery types (where the manufacturer has significantly modified construction), then it will still be possible to accurately rank a test group of batteries by quality. In other words, if times to discharge and charge data were determined for a lot of batteries during some pre-use stage, the 50% with the best quality could be accurately segregated from the remainder.

QE/C 69-665

B. ACCEPTANCE TESTING

A complete re-evaluation of present acceptance tests be made by battery experts. In light of possible reliable life prediction techniques, it may be advisable to combine acceptance and prediction tests in order to minimize the early stressing placed on new procurements.

Specifications be established for use with future acceptance tests. Where specifications cannot be established, definite reasons for conducting a particular test should be documented along with the characteristics of interest which the test is designed to reveal.

A list of internal cell characteristics which are desirable or undesirable for extended cell quality be established so that for future procurements a small sample of cells could be dissected and inspected internally for these characteristics. Too many undesirable characteristics should be a criterion for rejecting the cells even if variable measurements are acceptable.

C. FAILURE ANALYSIS

NASA select a working group to review failure analysis results and conclusions from the Crane tests and other related tests and to recommend a newly structured failure analysis scheme for use on dissected cells of new procurement and cells that have failed during the cycling life test. Such a study should examine cause and effect relationships, correlations of cell failure characteristics, etc. and finally list all important known characteristics in categories such as failure modes, and failure mechanisms. Work presently being done by Battelle for NASA Goddard and the Air Force (WPAFB) could help serve as a basis for this approach.

When major expected failure mechanisms are pinpointed and defined, methods should be developed to monitor the characteristics of these mechanisms as the cell degenerates to failure.

The Bayesian failure evaluation technique described in this report be applied to failure analysis data available on existing battery test programs and refined for future use on test results that will be obtained from the NASA accelerated test which is presently in the planning stages.

IV. DATA ANALYSIS AND SUMMARY

A. PREDICTION

1. Discussion

Three methods of predicting cell life have been developed and used with good success. This report compares the three and presents results of their application to the 660 cells.

The three methods used in predicting the cell lives are as follows:

Average Time To Discharge: Assuming the failure times of the cells are log-normally distributed, the failures were predicted using the average time for the cell to discharge to a pre-specified voltage. This average time to discharge (\bar{t}_1) was used with the actual failure times to make the predictions. This method is described in detail in Appendix A of this report.

Average Time To Charge: The procedure here is the same as that described in the preceding paragraph except that an average time to charge (\bar{t}'_1) to a pre-specified voltage rather than the time to discharge was utilized. The details of this procedure are given in Appendix B.

Linear Regression: This method uses standard regression techniques with the \bar{t}_1 as the independent variable and the logarithm of the failure time as the dependent variable. Details of this procedure are given in Appendix C.

Using average time to discharge, a failure time was predicted for each of the 660 nickel-cadmium cells originally put on test (480 in 10-cell packs and 180 in 5-cell packs). Predictions were made based on data available after 300, 1000, and 2000 cycles of life testing.

Using average time to charge, fifteen 10-cell packs were analyzed and predictions based on 300, 1000, and 2000 cycles of life testing were made.

Using linear regression, predictions were made for each of the 660 cells based on the first 1000 cycles of life testing.

This section also includes a brief study on the cell reliability improvement noted by making cell screening requirements greater than the aerospace requirements.

2. Summary

a. Comparison of Prediction Methods

Evaluations and comparisons of the methods are as follows:

(1) Average Time To Discharge

Using the first method and 300, 1000, and 2000 test cycles, a failure time was predicted for each of the 660 nickel-cadmium cells originally put on test. Based on the predicted failure time and a 5000 (10,000) cycle minimum acceptable life (MAL) each cell was classified as good or defective. A cell classified as good would be retained for a 5000 (10,000) cycle mission. A cell classified as defective would be discarded, or used in some lesser capacity.

The predicted failure times were then compared with the actual failure times (where available) to see if a correct decision had been made. Approximately 100 cells could not be evaluated for a 5000 cycle MAL and approximately 150 cells could not be evaluated for a 10,000 cycle MAL. Evaluations could not be made for these 250 cells because testing was discontinued after 6 cell failures in the 10-cell packs and 3 failures in the 5-cell packs. For example, a cell might have a predicted failure time of 15,000 cycles. However, if testing was discontinued after 4,500 cycles, the prediction could not be classified as correct or incorrect.

Predictions on the 5-cell packs resulted in a significantly higher percentage of correct decisions than those on the 10-cell packs as shown below.

<u>No. Test Cycles</u>	<u>MAL</u>	<u>Percentage of Correct Decisions</u>	
		<u>5-Cell Packs</u>	<u>10-Cell Packs</u>
300	5,000	93.4%	84.9%
	10,000	94.2%	85.2%
1000	5,000	97.4%	84.7%
	10,000	94.2%	87.9%
2000	5,000	95.3%	86.9%
	10,000	95.6%	88.0%

Also illustrated in the above table, no significant differences in the percentage of correct decisions were noted between the 5000 cycle MAL and the 10,000 MAL.

No significant differences in the percentage of correct decisions were noted between the results based on the first 300, 1000 or 2000 cycles of life testing.

A more detailed breakdown of these comparisons is given in Table 1.

TABLE I
PERCENTAGE OF CORRECT AND INCORRECT DECISIONS USING THE AVERAGE TIME TO DISCHARGE (\bar{t}_1)

No. Test Cycles	No. MAL	5 Cell Packs				10 Cell Packs				Total			
		No. Cells	Bad Cells Retained	Good Cells Discarded	Correct Decision	No. Cells	Bad Cells Retained	Good Cells Discarded	Correct Decision	No. Cells	Bad Cells Retained	Good Cells Discarded	Correct Decision
300 Cycles	5000 Cycle MAL	152	<u>5</u> <u>3.9%</u>	<u>4</u> <u>2.6%</u>	<u>142</u> <u>93.4%</u>	404	<u>45</u> <u>11.1%</u>	<u>16</u> <u>4.0%</u>	<u>343</u> <u>84.9%</u>	556	<u>51</u> <u>9.2%</u>	<u>20</u> <u>3.6%</u>	<u>485</u> <u>87.2%</u>
	10,000 Cycle MAL	138	<u>3</u> <u>2.2%</u>	<u>5</u> <u>3.6%</u>	<u>130</u> <u>94.2%</u>	372	<u>35</u> <u>9.4%</u>	<u>20</u> <u>5.4%</u>	<u>317</u> <u>85.2%</u>	510	<u>38</u> <u>7.5%</u>	<u>25</u> <u>4.9%</u>	<u>447</u> <u>87.6%</u>
1000 Cycles	5000 Cycle MAL	152	<u>3</u> <u>2.0%</u>	<u>1</u> <u>0.7%</u>	<u>148</u> <u>97.4%</u>	404	<u>46</u> <u>11.4%</u>	<u>16</u> <u>4.0%</u>	<u>342</u> <u>84.7%</u>	556	<u>49</u> <u>8.8%</u>	<u>17</u> <u>3.1%</u>	<u>490</u> <u>88.1%</u>
	10,000 Cycle MAL	138	<u>3</u> <u>2.2%</u>	<u>5</u> <u>3.6%</u>	<u>130</u> <u>94.2%</u>	372	<u>27</u> <u>7.3%</u>	<u>18</u> <u>4.8%</u>	<u>327</u> <u>87.9%</u>	510	<u>30</u> <u>5.9%</u>	<u>23</u> <u>4.5%</u>	<u>457</u> <u>89.6%</u>
2000 Cycles	5000 Cycle MAL	149	<u>6</u> <u>4.0%</u>	<u>1</u> <u>0.7%</u>	<u>142</u> <u>95.3%</u>	198	<u>41</u> <u>10.3%</u>	<u>11</u> <u>2.8%</u>	<u>346</u> <u>86.9%</u>	547	<u>47</u> <u>8.6%</u>	<u>12</u> <u>2.2%</u>	<u>488</u> <u>89.2%</u>
	10,000 Cycle MAL	135	<u>2</u> <u>1.5%</u>	<u>4</u> <u>3.0%</u>	<u>129</u> <u>95.6%</u>	366	<u>24</u> <u>6.6%</u>	<u>20</u> <u>5.5%</u>	<u>322</u> <u>88.0%</u>	501	<u>26</u> <u>5.2%</u>	<u>24</u> <u>4.8%</u>	<u>451</u> <u>90.0%</u>

The failure time for each cell for which a correct decision was made was then examined to determine the magnitude of the prediction error. The correct decisions were classified according to an error of ≤ 2000 cycles, > 2000 cycles, or not known. In some cases the decision to retain or discard could be made although the magnitude of error could not be determined (usually due to early failures which caused discontinuance of pack testing). These cells were classified "not known." The most prevalent type of error is one which would result in classifying a cell as acceptable for a mission it could not complete. Further study is needed to try to alleviate this problem. These results are shown in Table 2.

(2) Average Time To Charge

The second method was used on fifteen (15) ten-cell packs, and a prediction for failure time was made for each cell. For these particular 15 packs there was a significant difference between the percentage of correct decisions for a 5000 cycle MAL versus a 10,000 cycle MAL using the time to discharge data.

The percentage of correct decisions obtained using the "time to charge" data did not differ significantly from that obtained using the "time to discharge" data and a 5000 cycle MAL. However, the percentage of correct decisions obtained using the "time to charge" data was significantly lower than that obtained using the "time to discharge" data and a 10,000 cycle MAL. The following table summarizes the data for the 15 packs.

<u>Method</u>	5,000 Cycle MAL			10,000 Cycle MAL				
	<u>Number of Test Cycles</u>	<u>300</u>	<u>1000</u>	<u>2000</u>	<u>Number of Test Cycles</u>	<u>300</u>	<u>1000</u>	<u>2000</u>
Time to Charge	69.8%	69.1%	66.9%		73.1%	74.8%	73.1%	
Time to Discharge	69.8%	71.2%	75.5%		79.8%	84.9%	84.0%	

The number of test cycles used did not significantly affect the percentage of correct decisions obtained using the "time to charge" data.

A complete breakdown of the percentage of correct decisions is given in Table 3.

(3) Regression Analysis

The third method used to predict failure times of spacecraft batteries was a linear regression method. In this method the \bar{t}_i (average time to discharge to a specified voltage) was used as the independent variable and the natural logarithm of the failure time as the dependent variable. Failure times were predicted using 1000 test cycles.

TABLE 2
EVALUATION OF PREDICTIONS - TIME TO DISCHARGE METROD

Test Time	Pack Type	Minimum Acceptable Life (MAL)	No. of Cells Prediction System Would Discard	Total Cells That Could Be Evaluated	Frequency Of Wrong Decisions		Frequency of Correct Decisions When Magnitude of Prediction Error Is:		
					Retain	Discard Good Cell	< 2000 Cycles		Not Known
							Bad Cell	Good Cell	
300 Cycles	5 Cell	5000 Cycles	80	100	1.52	6	4	72	7
		10,000 Cycles	119	61	1.38	3	5	74	9
	10 Cell	5000 Cycles	196	284	4.04	45	16	134	47
		10,000 Cycles	292	188	3.72	35	20	142	48
1000 Cycles	5 Cell	5000 Cycles	80	100	1.52	3	1	75	8
		10,000 Cycles	119	61	1.38	3	5	78	6
	10 Cell	5000 Cycles	197	283	4.04	46	16	139	40
		10,000 Cycles	291	189	3.72	27	18	151	48
2000 Cycles	5 Cell	5000 Cycles	73	102	1.49	6	1	71	6
		10,000 Cycles	113	62	1.35	2	4	76	6
	10 Cell	5000 Cycles	183	287	3.98	41	11	168	34
		10,000 Cycles	186	284	3.66	24	20	159	36

TABLE 3

COMPARISON OF PREDICTIONS OF 15 SELECTED 10 CELL PACKS USING CHARGE AND DISCHARGE DATA						
No. of Test Cycles	Minimum Acceptable Life (MAL)	Type of Data Used	No. Packs Tested	No. Cells For Which Prediction Made	Bad Cells Retained	Good Cells Discarded
300 Cycles	Charge	15	139	25 18.0%	17 12.2%	97 69.8%
	Discharge	15	139	30 21.6%	12 8.6%	97 69.8%
10,000 Cycles	Charge	15	119	11 9.2%	21 17.6%	87 73.1%
	Discharge	15	119	14 11.8%	10 8.4%	95 79.8%
1000 Cycles	Charge	15	139	26 18.7%	17 12.2%	96 69.1%
	Discharge	15	139	28 20.1%	12 8.6%	99 71.2%
10,000 Cycles	Charge	15	119	11 9.2%	19 16.0%	89 74.8%
	Discharge	15	119	10 8.4%	8 6.7%	101 84.9%
2000 Cycles	Charge	15	139	28 20.1%	18 12.9%	93 66.9%
	Discharge	15	139	25 18.0%	9 6.5%	105 75.5%
10,000 Cycles	Charge	15	119	14 11.8%	18 15.1%	87 73.1%
	Discharge	15	119	10 8.4%	9 7.6%	100 84.0%

QE/C 69-665

The percentage of correct decisions for a 5000 cycle MAL did not differ significantly from that for a 10,000 cycle MAL.

The 5-cell packs yielded a significantly higher percentage of correct decisions than the 10-cell packs (95.9% versus 88.5%).

A comparison between the first and third prediction methods revealed no significant differences.

These results along with the percentage of correct decisions are given in Table 4.

As with the first method, each cell, for which a prediction was made, was examined to determine the magnitude of the prediction error. Each correct decision was classified according to an error of ≤ 2000 cycles, > 2000 cycles or not known. These results are shown in Table 5.

b. Reliability Improvement Noted by Making Cell Screening Requirements Greater than Aerospace Requirements

It is informative to consider what added reliability is obtained if the required mission time of the batteries is over-specified during the proposed screening process. For example, if NASA would require that cells be screened so that those inserted into space vehicles would last at least 5000 cycles, predictions could be made after the cells were cycled for 300 cycles or less. If the cells with a predicted life of at least 10,000 cycles were screened or selected, then 91.8% of these cells would last at least 5000 cycles. Contrast this with the case where cells with a predicted life of over 5000 cycles were selected for use and the reliability of these cells in completing 5000 cycles would fall to 84.9%. The following table gives the percentage of reliable cells (i.e., the number of cells that survived 5000 cycles by actual test that would have been retained by screening -- divided by the number of cells that would have been retained by screening process) for each category as indicated.

Number Of Test Cycles Used
To Make Predictions

	300	1000	2000
Cell Predictions	$\frac{343}{404}$ (84.9%)	$\frac{342}{404}$ (84.7%)	$\frac{346}{398}$ (86.9%)
	$\frac{190}{212}$ (86.9%)	$\frac{195}{214}$ (91.1%)	$\frac{196}{211}$ (92.8%)
	$\frac{169}{184}$ (91.8%)	$\frac{172}{182}$ (94.5%)	$\frac{166}{179}$ (92.7%)

TABLE 4

PERCENTAGE OF CORRECT AND INCORRECT DECISIONS MADE USING THE LINEAR REGRESSION PROCEDURE WITH 1000 TEST CYCLES

5,000 Cycle MAL				10,000 Cycle MAL				
	No. Cells	Bad Cells Retained	Good Cells Discarded	Correct Decisions	No. Cells	Bad Cells Retained	Good Cells Discarded	Correct Decisions
5 Cell Packs	152	2 1.3%	1 0.7%	149 98.0%	138	4 2.9%	5 3.6%	129 93.5%
10 Cell Packs	404	36 8.9%	6 1.5%	362 89.6%	372	27 7.3%	20 5.4%	325 87.4%

TAB 5

EVALUATION OF PREDICTIONS - REGRESSION METHOD				Frequency of Correct Decisions When Magnitude of Prediction Error Is:					
Pack Type	Minimum Acceptable Life (MAL)	No. Cells Prediction System Would: Discard Retain		Total Cells That Could Be Evaluated	Wrong Decisions	Discard Good Cell	<2000 Cycles >2000 Cycles		
		Retain	Discard				Not Known		
5 Cell	5,000 Cycles	82	98	152	2	1	78	7	64
	10,000 Cycles	118	62	138	4	5	79	3	47
10 Cell	5,000 Cycles	203	277	404	36	6	161	29	172
	10,000 Cycles	297	183	372	27	20	167	32	126

It is realized that 1000 or 2000 cycles of testing is too long for a screening process, but these portions of the table do illustrate that more voltage information does yield more reliable predictions. Hence, it is logical to assume that more accurate selection of superior cells will be possible with more frequent data monitoring early in the lives of the cells.

The method of over-specifying reliability as given above is effective and could be used to improve the quality of cells for space missions. This method would also be more costly since a larger number of good cells would be rejected. For example, consider the case where cells with a predicted life of over 5000 cycles were selected for use after testing for 300 cycles; only 18 (7.8%) good cells from 230 under consideration would be discarded. But for the case where cells with a predicted life of over 10,000 cycles were selected for use after 300 cycles of testing, 61 (26.5%) good cells would be discarded while 169 would be retained. In summary, use of this method to increase the reliability of units selected or retained for space missions, increases the likelihood that good units will be discarded or used for purposes where the reliability requirements are not so large.

B. ACCEPTANCE TESTING

1. The Data

All spacecraft battery cells received at NAD Crane are subjected to acceptance tests prior to being placed on life test. However, specifications are not placed on the parameters measured for these tests. Only those cells with catastrophic failure and those with test results displaying extreme departure from the usual range of values are excluded from the life test. The tests include measurements on physical dimensions, capacity, cell short, leakage, overcharge, and internal resistance. Since there were no specifications, cells were rejected only if they were leaking badly or completely shorted. A finer breakdown of the acceptance data shows that it included: physical dimensions (height, length, width, weight), capacity (three readings), cell short, leakage (immersion seal and litmus), overcharge (three readings: c/20, c/10, c/5, and internal resistance. These data were readily available for any analysis and were placed on data processing cards for future study. Also included on the cards are: cell serial number, number of pack in which cell is located, location of cell in pack (cell number), average time for a cell to discharge to 1.25 volts using 1000 cycles of life testing, and the actual failure time for cells that failed. Using the acceptance data already available, an attempt was made to relate one or more of these parameters to the failure time of the cell.

2. Summary

An attempt was made to relate the failure time of a cell to one or more of the parameters measured during the acceptance tests for each manufacturer-ampere hour subgroup. A multiple regression technique was

used. The purpose of the regression approach was to obtain an equation whereby the failure time of the cell could be accurately predicted using the acceptance data. The regression equation was of the following form.

$$T = \alpha + \beta_1 X_1 + \beta_2 X_2 + \dots + \beta_n X_n,$$

where T = failure time of the cell,

α = a constant generated by the regression,

β_i = coefficient of the i th prediction (acceptance) parameter,

X_i = i th prediction parameter,

where $i = 1, 2, 3, \dots, n$.

The independent variables used in deriving the prediction equation were: capacity (three readings), cell short, overcharge (three readings), internal resistance, and \bar{t} . The \bar{t} 's were not a part of the acceptance data, but as was mentioned in Report QE/C 67-592 of November 1967, these appeared to be good predictors of cell life and so were included as one of the independent variables. The dependent variable, of course, was the failure time. Since failure time was the dependent variable, only those cells which were tested to failure were used to develop the model.

A stepwise multiple regression computer program was used to determine what the prediction model (equation) should be. With this program the independent variable which has the greatest simple linear correlation with the dependent variable is entered into the model first. Of the remaining independent variables the one which has the highest first order partial correlation with the dependent variable is entered second.

In all cases, except where the cells were manufactured by Sonotone, the first variable entered into the model was the \bar{t}_i . And in each case the simple correlation between the \bar{t}_i and the failure time was relatively high. However, this was expected as it was known that the \bar{t}_i was a good predictor of the failure time. The addition of other variables added little to the model as can be seen in Table 6.

TABLE 6

MULTIPLE REGRESSION CORRELATION COEFFICIENTS

Mfr.	Ampere Hour Rating	Variable Entered	Multiple Correlation Coefficient	Ampere Hour Rating	Variable Entered	Multiple Correlation Coefficient
General Electric	3.0	\bar{t}_i	.615	12.0	\bar{t}_i	.802
		Overcharge (C/10)	.677		Capacity (3)	.839
		Capacity (1)	.715		Short Test Overcharge (C/20)	.865
		Short Test	.727			.868
Gould	3.0	\bar{t}_i	.685	20.0	\bar{t}_i	.722
		Internal Resistance	.717		Overcharge (C/20)	.791
		Capacity (1)	.739		Capacity (2)	.799
		Overcharge (C/20)	.742		Capacity (1)	.804
		\bar{t}_i	.730		\bar{t}_i	.605
Gulton	6.0	Capacity (3)	.747	20.0	Short Test Overcharge (C/20)	.638
		Internal Resistance	.751		Internal Resistance	.650
		Overcharge (C/5)	.752			.653
		\bar{t}_i	.393			
Sonotone	5.0	Internal Resistance	.503			
		Overcharge (C/10)	.528			
		Capacity (2)	.539			
		\bar{t}_i				

This indicated that, except for Sonotone, after the \bar{t}_i , the other variables are of little value in predicting cell life (failure time).

Table 7 shows the simple correlation coefficient between failure time and \bar{t}_i and also the simple correlation coefficient between failure time and the variable which had the second highest simple correlation. In the case of Sonotone the second value is the largest correlation (although correlated negatively). This indicates which variable would have been first in the model and the correlation between the variable and the failure time had the \bar{t}_i not been included as one of the independent variables.

TABLE 7
SIMPLE CORRELATION COEFFICIENTS

Manufacturer	Ampere-Hour Rating	r (\bar{t}_1)	r (second)	Variable
General Electric	3.0	.615	.258	Overcharge (c/20)
General Electric	12.0	.802	.238	Overcharge (c/10)
Gould	3.5	.685	.284	Internal Resistance
Gould	20.0	.722	.445	Overcharge (c/20)
Gulton	6.0	.730	.246	Capacity (2)
Gulton	20.0	.605	.434	Capacity (3)
Sonotone	5.0	.241	-.393	Capacity (3)

Tables 8 through 14 show the simple correlation coefficients between each pair of variables for each manufacturer - ampere hour subgroup. We would normally expect good correlation within the three capacities, and the three overcharges. We also would expect good correlation between the \bar{t}_1 and the failure time. This was true in most cases although there were some discrepancies.

It was necessary to inspect individual readings carefully for unusually high or low values which can affect correlations drastically. For example, two Gulton 20.0 A. H. voltage results of 1.56 volts each at the c/5 overcharge rate were removed from the analysis to obtain the tabled correlations of .791 and .901 with c/20 and c/10 overcharge rates, respectively. All other readings for the three overcharges were in the 1.39 - 1.45 voltage range. With the data for these two cells included in the analysis, the correlations were -.020 and .311 for c/5 correlated with c/20 and c/10, respectively. High positive correlations were expected between the overcharge rates. There were other illogical results in the correlations for which no reasons could be found.

TABLE 8

SIMPLE CORRELATION COEFFICIENTS
GENERAL ELECTRIC 3.0 A. H.

<u>Variable Code</u>	<u>Variables</u>									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	.316	.586	-.185	.152	-.093	-.104	-.334	.059	-.216	
3. Capacity (3)	2	.633	-.306	.029	-.220	-.008	-.248	.310	.062	
4. Short Test	3	-.483	.178	-.213	.046	-.124	.285	-.076		
5. Overcharge, (c/20)	4	-.170	.199	.051	-.023	.004	-.027			
6. Overcharge, (c/10)	5	.594	.241	.170	.052	.258				
7. Overcharge, (c/5)	6	.612	.207	-.240	.128					
8. Internal Resistance	7		.061	-.149	.059					
9. Time to Discharge (\bar{t}_1)	8		.005	.046						
10. Failure Time	9		.615							

TABLE 9

SIMPLE CORRELATION COEFFICIENTS
GENERAL ELECTRIC 12.0 A. H.

<u>Variable Code</u>	<u>Variables</u>									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)	.450	.366	.097	.157	.283	.608	-.258	.156	-.037	
2. Capacity (2)	1	-.123	.224	.312	.253	.366	-.052	-.015	.008	
3. Capacity (3)	2	3	-.558	-.194	.144	.010	.095	.153	-.118	
4. Short Test	3	4	.220	-.294	.197	-.212	-.133	-.149		
5. Overcharge (c/20)	4	5	.550	.418	.548	.021	.107			
6. Overcharge (c/10)	5	6	.497	.232	.235	.238				
7. Overcharge (c/5)	6	7	.063	-.114	-.218					
8. Internal Resistance	7	8	-.222	-.100						
9. Time to Discharge (\bar{t}_1)	8	9	.802							
10. Failure Time	9									

TABLE 1C

SIMPLE CORRELATION COEFFICIENTS
COULD 3.5 A. H.

<u>Variable Code</u>	<u>Variables</u>									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	.807	.551	.417	-.186	-.308	-.117	-.553	.088	.088	
3. Capacity (3)		.554	.209	-.275	-.381	-.090	-.374	.125	.136	
4. Short Test			.406	.119	-.079	.035	-.408	-.225	-.266	
5. Overcharge (c/20)				.217	.073	-.131	-.427	-.206	-.217	
6. Overcharge (c/10)					.798	.452	.122	-.370	-.169	
7. Overcharge (c/5)						.611	.202	-.237	-.138	
8. Internal Resistance							.026	.067	.052	
9. Time to Discharge (\bar{t}_1)								.107	.284	
10. Failure Time										.685

TABLE 11

SIMPLE CORRELATION COEFFICIENTS
GOULD 20.0 A. H.

<u>Variable Code</u>	<u>Variables</u>									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	1	.624	-.029	.345	-.306	-.322	-.117	.501	.086	-.040
3. Capacity (3)	2	.223	.012	-.159	-.125	-.117	.259	.069	-.120	
4. Short Test	3	-.237	.578	.675	.587	.642	.446	.413		
5. Overcharge (c/20)	4	-.398	-.456	-.456	-.392	.337	.065	-.134		
6. Overcharge (c/10)	5	.887	.802	.802	-.655	.176	.445			
7. Overcharge (c/5)	6	.887	-.650	-.650	.112	.361				
8. Internal Resistance	7	-.560	.160	.160	.413					
9. Time to Discharge (\bar{t}_1)	8	-.276	-.364							
10. Failure Time	9	.722								

TABLE 12

SIMPLE CORRELATION COEFFICIENTS
GULTON 6.0 A. H.

Variable Code	Variables									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	.152	.385	-.330	.201	.092	.030	.247	-.025	-.091	
3. Capacity (3)		.429	.025	.183	.291	-.049	.172	.382	.246	
4. Short Test			.3	-.298	.122	-.023	-.191	.407	.476	.212
5. Overcharge (c/20)				4	.271	.291	-.102	-.026	-.082	-.047
6. Overcharge (c/10)					5	.618	.253	.281	.181	.097
7. Overcharge (c/5)						6	.451	.103	.084	.015
8. Internal Resistance							7	-.059	-.026	-.037
9. Time to Discharge (\bar{t}_1)								8	.241	.052
10. Failure Time									9	.730

TABLE 13

SIMPLE CORRELATION COEFFICIENTS
GULTON 20.0 A. H.

Variable Code	Variables									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	1	.526	.448	-.129	.285	.139	-.159	-.440	.419	.225
3. Capacity (3)	2		.364	-.134	-.042	-.212	-.122	-.395	.614	.420
4. Short Test	3		-.104	-.072	-.158	-.212	.101			
5. Overcharge (c/20)	4			.023	.094	.117	-.114	.145		
6. Overcharge (c/10)	5				.918	.791	.136	.018		
7. Overcharge (c/5)	6					.901	.145	-.077		
8. Internal Resistance							7	-.094		
9. Time to Discharge (\bar{t}_1)									-.061	-.093
10. Failure Time										-.144
										.605

TABLE 14

SIMPLE CORRELATION COEFFICIENTS
SONOTONE 5.0 A. H.

<u>Variable Code</u>	<u>Variables</u>									
	1	2	3	4	5	6	7	8	9	10
1. Capacity (1)										
2. Capacity (2)	.731	.562	-.385	-.116	.229	.233	.058	.008	-.266	
3. Capacity (3)		.847	-.441	-.000	.182	.158	-.008	-.130	-.390	
4. Short Test			.3	-.278	.153	.099	.170	.047	-.165	-.393
5. Overcharge (c/20)				4	-.209	-.140	-.257	-.033	.238	.034
6. Overcharge (c/10)					5	-.065	.394	.229	-.245	-.052
7. Overcharge (c/5)						6	.055	-.031	-.178	-.188
8. Internal Resistance							7	-.034	.168	-.014
9. Time to Discharge (\bar{t}_1)								8	-.246	-.333
10. Failure Time									9	.241

C. EVALUATION OF FAILURE ANALYSIS CHARACTERISTICS

1. Failure Analysis Results

As failures occurred in the Crane life test, the failed cells were given a comprehensive internal inspection. Characteristics or observations made by the Crane battery analysts were recorded. The failure analysis observations were categorized under major classifications (i.e., separator deterioration, migration of active material, high internal pressure, depositing, etc.) and then a more descriptive observation was made elaborating on the major classification. For example, if separator deterioration was noted, a further observation would describe whether general decomposition was noted, whether shorting between the plates occurred, and, if so, whether it occurred at the center of the core or on the outermost portion, etc. All failure observations for the standard 660 Ni-Cd cells originally on test are given in Tables 15-18. Tables 19-20 describe failures to date for additional cells placed on test. The frequencies given in the tables represent the number of times a given level of the major classification (i.e., separator deterioration) occurred. All failure analysis information available (by April 1969) has been coded and placed on IBM cards for any subsequent data processing. For a complete listing of failure characteristics for each cell of each pack see Appendix D. For a more detailed description of the failure classifications and levels of each see NAD Crane Report QE/C 69-244, "Cycle Life Test of Secondary Spacecraft Cells" of 7 April 1969.

By condensing Tables 15-18 to give frequencies of the major failure classifications within each manufacturer-ambient temperature combination, as in Table 21, several overall conclusions may be easily derived from the failure information.

(1) All failed cells had an end of charge voltage recorded; hence the frequencies given here are not meaningful. Consult Tables 15-18 to determine the frequency of cells with low, normal or high end of charge voltage.

(2) Cell weight loss is most common in Gould and Gulton cells; a total of 88 failures experienced weight loss and 80 of these were among these manufacturers' cells.

(3) Concave sides are typical only of cells with rectangular construction (Gulton in this case). This deficiency occurs more frequently at the lower temperatures as shown by the table below:

0°C	25°C	40°C
16/28(57.1%)	6/39(15.4%)	4/37(10.8%)

(4) Evidence of weak or inadequate welds are characteristic of Sonotone and Gould cells.

TABLE 15
FREQUENCIES OF FAILURE CHARACTERISTICS AND LEVELS OF EACH-GENERAL ELECTRIC

Capacity Rating Temperature	3.0 AMP.-HR.										12.0 AMP.-HR.										
	0°C		25°C		25%		40°C		40%		0°C		25°C		25%		40°C		40%		
	15%	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5%	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	
Depth of Discharge	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5%	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	
Orbit Time (Hrs.)	6.5A	6.7A	6.8A	15A	19A	16A	20A	39A	43A	40A	44A	110A	111A	124A	125A	82A	83A	96A	97A	85A	86A
No. Cells in Each Pack	10	10	10	10	10	10	10	10	10	10	10	5	5	5	5	5	5	5	5	5	5
Charge Voltage (End of)	Shorted	0	0	0	0	0	0	J	0	1	0	0	1	0	0	0	0	0	0	0	0
Low Normal High	0	1	0	1	4	0	3	4	0	1	1	1	1	0	0	1	2	3	1	2	1
Open Circuit	0	0	0	0	0	0	0	0	0	3	1	1	1	0	0	1	0	2	0	2	0
Weight Loss	Low Medium High	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0
Deposits	Around Terminal Around Seam Around Both	1	1	0	0	1	1	0	3	3	0	2	3	0	0	1	0	0	0	0	1
High Pressure	Bulged Gas Present Both	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	1	0	0
Concave Sides	Present Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Weak Weld	Tab to Plate Tab to Case Tab to "P" Tab to Plated Case Tab to Plated Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Loosened Active Material	Present Caused Short	1	0	0	0	0	0	0	0	0	0	1	2	0	0	0	0	0	0	0	0
Extraneous Active Material	Present Caused Short	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0	0	0
Pierced Separator	Grid Wire Tab to Plate	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0
Excess Scoring	Present Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Burned Positive Tab	Present Broken Caused Short	0	0	0	0	0	0	0	1	5	1	4	1	0	0	0	0	0	0	0	0
Short Separator	Present Caused Short	0	0	0	0	0	0	0	0	2	1	0	0	0	0	0	0	0	0	0	0
Ceramic Short	One Terminal Two Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Migration	General Sm. Area Penetration Shorting Penetration Positive Plate Short Around Tab Short Around Scoring	2	1	0	1	3	1	0	3	2	0	0	1	0	0	1	0	1	2	0	2
Blister:	Present Caused Short	1	0	0	0	6	0	0	6	0	0	0	2	0	0	1	0	0	0	2	0
Separator Deterioration	General Permitted Short Center of Case Permitted Short	2	1	0	1	6	1	0	4	3	3	0	5	0	0	1	0	1	0	3	0

TABLE 16
FREQUENCIES OF FAILURE CHARACTERISTICS AND LEVELS OF EACH-GOULD

Capacity Rating	3.5 AMP.-HR.												20.0 AMP.-HR.												
	Temperature						0°C						25°C						0°C						
	15%	25%	25%	40%	15%	25%	15%	25%	25%	40%	15%	25%	15%	25%	25%	40%	15%	25%	25%	40%	15%	25%	25%	40%	
Depth of Discharge																									
Orbit Time (Hrs.)	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	
Pack Number	51A	55A	52A	56A	3A	7A	4A	8A	27A	31A	28A	32A	84A	80A	98A	94A	106A	105A	118A	119A	112A	108A	126A	122A	
No. Cells In Each Pack	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	10	5	5	5	5	5	5	5	5	5
Charge Voltage (End of)	Shorted	0	0	1	0	0	1	0	0	0	0	0	1	0	0	0	0	0	0	0	0	2	0	0	0
Low Normal High	2	0	3	0	1	2	5	4	1	5	4	2	1	0	1	0	3	3	3	1	3	1	3	3	3
Open Circuit	0	0	1	0	1	0	0	0	1	2	3	1	0	0	0	0	0	0	0	0	0	0	0	0	0
Weight Loss	Low Medium High	1	0	0	0	0	3	1	2	2	1	0	2	0	0	0	0	0	0	0	0	0	0	0	0
Deposits	Around Terminal Around Seam Around Both	2	0	2	0	5	6	5	7	5	5	5	5	0	0	0	0	0	1	0	0	0	0	0	0
High Pressure	Bulged Gas Present Both	0	0	0	0	0	0	2	0	1	0	0	2	1	0	0	2	0	0	0	0	0	0	0	0
Concave Side Present Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Weak Weld	Tab to Plate Tab to Case Tab to Terminal Tab to Plate & Case Tab to Plate & Terminal	0	0	1	0	2	5	0	2	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Loosened Active Material	Present Caused Short	0	0	3	0	0	2	6	3	2	0	0	0	0	0	0	0	0	0	0	0	1	0	0	0
Extraneous Active Material	Present Caused Short	0	0	0	1	0	1	0	0	0	1	4	0	1	0	0	1	1	1	0	0	0	0	0	0
Pierced Grid Wire Separator	Grid Wire Tab to Plate	0	0	0	0	0	0	0	0	0	1	0	1	0	0	0	2	0	2	0	0	0	1	0	0
Excess Scoring	Present Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Burned Positive Tab	Present Broken Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Separator	Present Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ceramic Short	One Terminal Two Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Migration	General Sm. Area Penetration Shorting Penetration Positive Plate Short Around Tab Short Around Scoring	2	0	5	0	4	1	1	4	1	2	0	0	1	0	2	1	0	2	0	2	0	1	0	3
Blisters	Present Caused Short	0	0	0	0	1	0	0	0	0	1	0	0	0	0	0	0	1	0	2	1	2	1	3	0
Separator Deterioration	General Permitted Short Center of Case Permitted Short	1	0	5	0	3	6	3	4	3	7	0	0	0	0	2	1	0	2	0	0	3	1	2	

TABLE 17
FREQUENCIES OF FAILURE CHARACTERISTICS AND LEVELS OF EACH-GULTON

Capacity Rating	Temperature	6.0 AMP.-HR.								20.0 AMP.-HR.								
		0°C	25°C	25°C	40°C	0°C	25°C	25°C	40°C	0°C	25°C	25°C	40°C	0°C	25°C	25°C	40°C	
Depth of Discharge		15%	25%	25%	40%	15%	25%	25%	40%	15%	25%	25%	40%	15%	25%	25%	40%	
Orbit Time (Hrs.)	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0
Pack Number	61A	63A	62A	66A	13A	17A	14A	18A	37A	41A	38A	42A	101A	102A	115A	116A	73A	74A
No. Cells In Each Pack	10	10	10	10	10	10	10	10	10	10	5	5	5	5	5	5	5	5
Charge Voltage (End of)	Shorted	0	0	0	0	0	0	0	0	1	0	0	1	0	0	0	3	1
Low	5	4	3	2	4	4	2	3	0	2	3	0	0	2	1	2	1	0
Normal	0	0	0	2	0	1	2	2	5	2	0	0	1	0	1	2	0	1
High	1	0	1	2	2	3	2	1	1	1	3	0	2	0	0	3	0	0
Open Circuit	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Weight Loss	Low	0	0	0	1	0	0	0	1	0	0	0	0	0	0	0	0	0
Medium	1	0	0	0	0	0	0	1	1	0	3	1	0	1	1	0	0	1
High	1	0	1	2	2	0	3	1	1	0	2	2	0	1	1	2	4	3
Deposits	Around Terminal	1	1	1	3	1	0	1	1	0	1	1	3	0	0	0	1	3
Around Seam	0	0	0	0	0	0	0	0	0	0	2	0	0	0	0	0	0	0
Around Both	0	0	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0
High Pressure	Bulged	4	0	3	5	3	2	3	2	0	0	1	1	2	1	1	0	3
Gas Present	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
Both	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	1
Concave Sides	Present	1	1	0	3	0	0	1	1	0	0	0	1	0	0	0	2	0
Caused Short	1	3	0	2	0	0	0	0	0	1	0	1	3	0	0	1	0	0
Weak Weld	Tab to Plate	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Case	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Plate & Case	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Plate & Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Loosened Active Material	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Extraneous Active Material	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0
Pierced Separator	Grid to Wire	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Plate	0	1	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Excess Scoring	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Burned Positive Tab	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Broken	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Separator	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ceramic Short	One Terminal	5	0	2	3	4	6	3	5	6	6	4	4	0	0	0	1	0
Two Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1
Migration	General	4	1	1	1	1	1	0	0	1	0	0	0	1	2	1	0	0
Sm. Area Penetration	0	3	0	1	0	1	0	0	0	0	1	0	0	0	0	0	0	0
Shorting	Penetration	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	2	0
Positive Plate	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Around Tab	Short Around Tab	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Around Scoring	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Blisters	Present	4	4	4	2	4	3	0	1	4	0	0	1	1	0	2	1	0
Caused Short	0	0	0	1	0	0	0	0	0	0	0	0	0	1	0	0	0	0
Separator	General	2	1	1	0	2	0	0	0	2	0	0	1	0	0	0	0	1
Deterioration	Permitted Short	0	2	0	0	0	1	0	0	0	0	1	0	1	2	0	0	1
Center of Case	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Permitted Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0

TABLE 18
FREQUENCIES OF FAILURE CHARACTERISTICS AND LEVELS OF EACH-SONOTONE

		5.0 AMP.-HR.											
		0°C				25°C				40°C			
Capacity Rating	Temperature	15%	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0	1.5	3.0
		49A	53A	50A	54A	1A	5A	2A	6A	25A	29A	26A	30A
No. Cells In Each Pack		10	10	10	10	10	10	10	10	10	10	10	10
Charge Voltage (End of)	Shorted	1	0	0	0	0	0	1	1	0	1	3	2
	Low	1	0	3	1	0	1	2	1	2	1	1	4
	Normal	0	0	0	0	4	1	3	4	3	4	2	0
	High	0	0	0	0	2	1	0	0	1	0	0	0
	Open Circuit	0	0	0	0	0	0	0	0	0	0	0	0
Weight Loss	Low	0	0	1	0	0	0	0	0	0	1	0	1
	Medium	0	0	0	0	0	0	0	0	0	0	0	0
	High	0	0	0	0	0	0	0	0	0	0	0	0
Deposits	Around Terminal	0	0	1	1	4	2	4	0	5	4	2	4
	Around Seam	0	0	0	0	0	0	0	0	0	0	0	0
	Around Both	0	0	0	0	0	0	0	0	0	0	0	0
High Pressure	Bulged	1	0	0	0	0	0	4	1	1	0	3	0
	Gas Present	0	0	0	0	0	1	0	0	0	1	1	0
	Both	0	0	0	0	0	0	0	0	0	0	0	0
Concave Sides	Present	0	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	0	0	0	0	0
Weak Weld	Tab to Plate	1	0	1	1	3	2	4	3	1	5	3	2
	Tab to Case	0	0	0	0	0	0	0	0	0	0	0	0
	Tab to Terminal	0	0	0	0	0	0	0	0	0	0	0	0
	Tab to Plate & Case	0	0	0	0	0	0	0	0	0	0	0	0
	Tab to Plate & Terminal	0	0	0	0	0	0	0	0	0	0	0	0
Loosened Active Material	Present	0	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	0	0	0	0	0
Extraneous Active Material	Present	1	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	1	1	0	0	0
Pierced Separator	Grid Wire	0	0	1	0	0	0	2	2	1	1	1	1
	Tab to Plate	0	0	0	0	0	0	0	1	0	0	0	1
Excess Scoring	Present	0	0	3	0	4	2	3	2	1	3	1	0
	Caused Short	1	0	0	0	1	1	0	1	2	1	1	3
Burned Positive Tab	Present	0	0	0	0	0	0	0	0	0	0	0	0
	Broken	0	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	0	0	0	0	0
Short Separator	Present	0	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	0	0	0	0	0
Ceramic Short	One Terminal	0	0	0	0	0	0	0	0	0	0	0	0
	Two Terminal	0	0	0	0	0	0	0	0	0	0	0	0
Migration	General	1	0	3	1	5	3	3	3	3	3	1	2
	Sm. Area Penetration	0	0	0	0	0	0	0	0	0	1	0	1
	Shorting	0	0	0	0	0	0	0	0	0	0	0	0
	Penetration	0	0	0	0	0	0	0	0	0	0	0	0
	Positive Plate	0	0	0	0	0	0	0	0	1	0	0	0
	Short Around Tab	1	0	0	0	0	0	0	0	1	0	0	1
	Short Around Scoring	0	0	0	0	0	0	0	0	0	1	0	0
Blisters	Present	0	0	0	0	0	0	0	0	0	0	0	0
	Caused Short	0	0	0	0	0	0	0	0	0	0	0	0
Separator Deterioration	General	0	0	0	0	0	2	4	1	1	0	5	1
	Permitted Short	0	0	1	1	4	1	0	2	3	3	0	5
	Center of Case	0	0	0	0	1	0	0	0	0	0	0	0
	Center of Case Short	0	0	0	0	0	0	0	0	1	1	0	0

TABLE 19
FREQUENCIES OF FAILURE CHARACTERISTIC AND LEVELS OF EACH FROM NON-STANDARD PACKS

TABLE 20
PERCENTAGES OF FAILURE CHARACTERISTICS AND LEVELS OF EACH FROM NON-STANDARD PACKS

Manufacturer	GULFON	GULFON	GULFON	GULFON	GULFON	GULFON	GULFON	SUNTON							
Capacity Rating (deg. Hr.)	6.0	6.0	6.0	12.0	12.0	12.0	12.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	20.0
Temperature (°C)	50	60	70	25	35	45	55	-20	-20	-20	-20	-20	-20	-20	25.0
Depth of Discharge	40%	40%	40%	25%	35%	45%	55%	25%	35%	45%	55%	65%	75%	85%	4.0
Circuit Time (hrs.)	1.5	1.5	1.5	2.5	3.5	4.5	5.5	1.5	2.5	3.5	4.5	5.5	6.5	7.5	1.5
Fuse Shutter	7.1A	4.5B	11A	7.1A	10.1B	11.1B	12.1B	7.1B	10.1B	11.1B	12.1B	13.1B	14.1B	15.1B	2.5
No. Cells In Each Pack	5	5	5	5	5	5	5	5	5	5	5	5	5	5	1.0
Charge Voltage (End of)	0	0	1	0	0	0	0	1	0	0	0	0	0	0	0
Normal	2	5	1	3	0	2	2	2	0	1	2	2	2	1	0
High	2	0	1	0	1	0	1	1	0	1	0	1	1	1	0
Open Circuit	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0
Weight Loss	Low	0	0	1	0	0	0	0	0	0	0	0	0	0	0
Medium	3	0	0	0	0	0	0	0	0	0	0	0	0	0	0
High	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Departs	Around Terminal	2	2	1	0	0	0	0	1	0	0	0	0	0	0
Around Seam	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0
Around Both	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Bulged	1	4	0	0	2	1	1	1	0	2	0	2	0	0	0
Gas Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Both	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Concave Sides	Present	0	0	3	0	0	0	0	0	0	0	0	0	0	0
Causes Short	0	0	0	3	0	0	0	0	0	0	0	0	0	0	0
Weak Weld	Tab to Plate	0	0	0	0	0	0	0	0	0	1	0	1	0	1
Tab to Case	0	2	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Plate & Case	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Tab to Plate & Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Loosened Active Material	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Extraneous Active Material	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Caused Short	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Placed Separator	Grid Wire Tab to Plate	0	0	0	0	0	0	0	0	0	0	1	0	0	0
Excess Scoring	Present	0	0	0	0	0	0	0	0	0	0	1	0	0	0
Burned Positive Tab	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Separator	Present	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Ceramic Short	One Terminal	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Short Two Terminal	0	0	1	2	0	0	0	0	0	0	0	0	0	0	0
Migration	General	3	3	2	1	1	1	3	2	1	2	0	3	1	3
Small Area Penetration	0	0	0	1	0	0	0	0	0	0	0	0	0	0	0
Shorting	Penetration	1	0	2	0	0	0	0	0	0	0	0	0	0	0
Positive Plate Short Around Tab	0	0	2	0	0	0	0	0	0	0	0	0	0	0	0
Scorings	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Blisters	Present	4	5	3	1	0	0	1	0	2	0	0	0	0	0
Separation	General	3	0	2	4	1	0	0	0	0	0	0	2	0	0
Deterioration	Permitted Short Center of Case	0	5	1	0	1	0	0	0	0	0	0	3	0	1
Permitted Short	0	3	0	0	0	0	0	0	0	0	0	0	0	0	0

TABLE 21
FREQUENCIES OF OCCURRENCE OF FAILURE CHARACTERISTICS FOR STANDARD NICD CELLS

Major Failure Modes	Manufacturer												Totals
	General Electric			Gould			Gulton			Sonotone			
0°C	25°C	40°C	0°C	25°C	40°C	0°C	25°C	40°C	0°C	25°C	40°C	0°C	Totals
End of Charge Voltage	6	30	37	13	38	41	28	39	37	6	21	24	320
Weight Loss	2	1	2	1	21	18	10	20	10	1	0	2	88
Deposits	3	7	10	4	24	20	9	11	12	2	10	15	127
High Pressure	2	4	6	14	15	19	17	11	1	6	6	6	109
Concave Sides	0	0	0	0	0	16	6	4	0	0	0	0	26
Weak Weld	0	0	0	1	12	14	0	0	3	12	11	11	53
Loosened Active Material	1	0	3	3	2	3	0	0	0	0	0	0	12
Extraneous Active Material	0	0	2	3	4	6	0	0	1	1	1	1	19
Pierced Separator	0	1	0	1	5	6	2	0	0	1	5	5	26
Excess Scoring	0	0	0	0	0	0	0	0	4	14	12	12	30
Burned Positive Tab	2	3	17	0	0	0	0	0	0	0	0	0	22
Short Separator	0	0	8	0	0	0	0	0	0	0	0	0	8
Ceramic Short Migration	0	0	0	0	0	0	10	23	22	0	0	0	55
Blisters	6	28	20	13	21	17	12	6	12	6	16	15	172
Separator Deterioration	2	14	3	0	4	8	18	1	9	0	0	0	69
No. Failed Cells	6	30	37	13	38	41	28	39	37	6	21	24	320

QE/C 69-665

(5) Loosened active material which separates from the grid of the positive plate was found only for cells of Gould and G. E.

(6) The occurrence of extraneous active material is primarily attributed to Gould since there were only 6 instances, of the total 19, where cells of other manufacturers displayed this deficiency.

(7) Pierced separator occurrences are attributed mostly to Sonotone and Gould as 23 of the observed 26 cases were for these manufacturers.

(8) The presence of excess scoring alludes only to the Sonotone cells.

(9) Burned positive tabs occur only for G. E. cells (more specifically G. E. 3.0 A. H.); 17 of the 22 instances of burned positive tabs occurred at 40°C.

(10) Shorted separators occur only in G. E. cells; all eight occurrences were noted at 40°C. The occurrence of this characteristic is always associated with the burned positive tab. But the burned tab does not necessarily result in the separator short.

(11) Ceramic shorts or shorting across the ceramic insulator at the terminal is a characteristic of Gulton cells only and occur in a higher percentage of failures at the higher ambient temperatures.

(12) Only Sonotone cells exhibited an absence of blisters. This deficiency was noted in a significantly higher proportion of failures at the lower temperatures for G. E. and Gulton. This trend was reversed for Gould cells (see the following table for fractions and percents).

	0°C	25°C	40°C
G. E.	2/6(33.3%)	14/30(46.7%)	3/37(8.1%)
Gulton	18/28(64.3%)	11/39(28.2%)	9/37(24.3%)
Gould	0/13(0.0%)	4/38(10.5%)	8/41(19.5%)

2. Correlation or Frequency of Occurrence of One Failure Characteristic with Another

A major aspect of failure analysis is determining when and under what conditions specified failure characteristics occur. This information is essential so that problem areas may be defined and designers and suppliers of batteries may avoid such deficiencies in future productions. Other major aspects which should be given more emphasis are (i) the establishment of cause and effect relationships between failure characteristics and (ii) the periodic establishment of a more meaningful list of cell failure characteristics to adhere to during failure analysis. In order that correlations (or rates of joint occurrence) might be quickly determined between any two failure characteristics for any manufacturer and for any tested level of temperature, depth of discharge or orbit time, Tables 22-33 have been constructed.

Codes representing each of the 15 major failure characteristics have been used in these tables. Code 1 has been omitted from these tables since every cell had an end of charge voltage of some sort. The list of codes are defined as follows:

- 1 - End of Charge Voltage (either low or high)
- 2 - Cell Weight Loss
- 3 - Deposits on (+) and/or (-) Terminals
- 4 - High Pressure
- 5 - Concave Sides
- 6 - Weak Weld
- 7 - Loosened Active Material from Grid of (+) Plate
- 8 - Extraneous Active Material
- 9 - Pierced Separator
- 10 - Excess Scoring
- 11 - Burned Positive Tabs
- 12 - Shorted Separator
- 13 - Ceramic Short
- 14 - Migration of (+) and/or (-) Plate Material
- 15 - Blistering on (+) Plate
- 16 - Separator Deterioration

These tables make it possible to quickly determine the frequency of occurrence of each major failure characteristic alone and with other characteristics. Use of the plastic overlay, page 36, allows one to compare the rate of occurrence at a given stress level or manufacturer to the overall rate for all standard Ni-Cd cells. Placing the overlay above any of Tables 22 thru 33 displays the fraction of simultaneous occurrence for any two major failure characteristics. Using Table 24 (manufacturer--Gulton), for example, we observe that high pressure (4) occurs jointly with ceramic shorts (13) sixteen times. However, this is not a high correlation since ceramic shorts occurred with a total frequency of 55 for Gulton cells. Use of the overlay reveals that over all manufacturers the frequencies are still 16 and 55 so the data verifies the absence of ceramic shorts in other manufacturers.

Numerous conclusions may be drawn by examination of the tables and overlay. Some of these are as follows:

- (1) From Table 22 we can see that shorted separators (12) always occur with burned positive tabs (11) and G. E. cells.
- (2) From Table 28 we further see that shorted separators (12) always occurred under 40°C ambient temperature.
- (3) Tables 22 (G. E.) and 23 (Gould) show that in the 12 instances where loosened active material (7) was found separator deterioration (16) had occurred 11 times (91.7%).

NASA - FAILURE ANALYSIS
ALL NI-CD DATA

QE/C 69-665

Failure Characteristics

	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	67	28	12	20	4	4	1	3	2	0	14	37	10	39
3	32	12	32	8	7	8	15	7	2	8	75	18	81	
4	13	10	1	6	12	6	0	0	0	16	55	33	55	
5	0	0	0	1	0	0	0	0	6	13	13	13	9	
6	1	5	6	15	0	0	0	0	0	35	0	37		
7	1	1	0	0	0	0	0	0	9	3	11			
8	2	1	1	0	0	0	0	0	6	0	9			
9	3	0	0	0	0	0	0	0	5	12				
10	0	0	0	0	25	0	0	0	0	0	26			
11	8	0	8	1	9									
12	0	1	0	0										
13	12	21	10											
14	45	134												
15	42													

88 126 109 26 53 12 19 26 30 22 8 55 171 69 169

QE/C 69-665

TABLE 22
GENERAL ELECTRIC (73 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	0	2	0	0	0	0	0	0	2	0	0	4	1	5
3.....	2	0	0	3	0	0	0	0	7	2	0	13	7	14
4.....	0	0	0	0	0	0	0	0	0	0	0	12	3	14
5.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
7.....	0	0	0	0	0	0	0	0	0	0	3	2	3	
8.....	0	0	1	0	0	0	0	1	0	0	0	0	0	
9.....	0	0	0	0	0	0	0	0	0	1	0	1		
10.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
11.....	8	0	8	1	9									
12.....	0	1	0	1										
13.....	0	0	0											
14.....												17	44	
15.....													19	

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
5	19	14	0	0	4	2	1	0	22	8	0	33	17	48

Number of Occurrences for Each Failure Code

QE/C. 69-665

TABLE 23
GOULD (92 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2.....	40	5	0	19	4	4	1	0	0	0	0	22	0	25
3.....	6	0	21	5	5	1	0	0	0	0	0	29	0	32
4.....	0	2	1	6	9	0	0	0	0	0	0	16	9	18
5.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6.....	1	4	1	0	0	0	0	0	0	0	0	17	0	16
7.....	1	1	0	0	0	0	0	0	0	6	1	8		
8.....	1	0	0	0	0	0	0	0	0	5	0	8		
9.....	0	0	0	0	0	0	0	0	2	3	4			
10.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
11.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
12.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
13.....	0	0	0	0	0	0	0	0	0	0	0	0	0	0
14.....	9	41												
15.....	8													

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
40	48	35	0	27	8	11	13	0	0	0	0	51	12	56

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 24
GULTON (104 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	21	21	12	0	0	0	0	0	0	0	14	8	9	7
3.....	17	12	0	0	1	1	0	0	0	8	14	11	11	
4.....	13	0	0	0	1	0	0	0	0	16	17	21	13	
5.....	0	0	0	1	0	0	0	0	0	6	13	13	9	
6.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
7.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
8.....	0	0	0	0	0	0	0	0	0	0	0	0	1	
9.....	0	0	0	0	0	0	0	0	1	2	1			
10.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
11.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
12.....	0	0	0	0	0	0	0	0	0	0	0	0	0	
13.....	0	0	0	0	0	0	0	0	12	21	10			
14.....	0	0	0	0	0	0	0	0	19	21				
15.....	0	0	0	0	0	0	0	0	0	0	15			

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
40	32	47	26	0	0	1	2	0	0	0	55	30	38	28

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 25
SONOTONE (51 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	3	0	0	1	0	0	0	3	0	0	0	3	0	2
3	7	0	11	0	1	6	15	0	0	0	0	19	0	21
4	0	8	0	0	2	6	0	0	0	0	10	0	10	
5	0	0	0	0	0	0	0	0	0	0	0	0	0	0
6	0	1	5	15	0	0	0	0	0	0	18	0	21	
7	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	1	1	0	0	0	0	0	0	0	0	1	0	0	
9	3	0	0	0	0	0	0	4	0	0	0	0	6	
10	0	0	0	0	0	0	0	25	0	0	26	0	0	
11	0	0	0	0	0	0	0	0	0	0	0	0	0	
12	0	0	0	0	0	0	0	0	0	0	0	0	0	
13	0	0	0	0	0	0	0	0	0	0	0	0	0	
14	0	0	0	0	0	0	0	0	0	0	0	28	0	
15	0	0	0	0	0	0	0	0	0	0	0	0	0	

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
3	27	13	0	26	0	3	11	30	0	0	0	37	0	27

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 26
0°C (53 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	10	8	7	0	0	0	0	1	1	0	2	7	6	5
3	8	5	2	1	1	1	1	2	0	1	13	6	9	
4	10	1	0	2	2	0	0	0	8	17	15	9		
5	0	0	0	1	0	0	0	0	4	8	10	5		
6	0	0	0	1	0	0	0	0	4	0	3			
7	1	0	0	0	0	0	0	0	4	1	4			
8	0	1	0	0	0	0	0	0	4	0	3			
9	1	0	0	0	0	0	0	3	2	2				
10	0	0	0	0	0	0	0	4	0	1				
11	0	0	0	0	0	0	0	2	0	2				
12	0	0	0	0	0	0	0	0	0	0				
13	5	7	1											
14	11	26												
15	7													

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
14	18	28	16	4	4	4	4	4	2	0	10	37	20	27

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 27
25°C (128 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	31	15	5	11	2	1	1	0	0	0	4	17	2	16
3	13	4	15	2	1	3	6	1	0	2	31	7	31	
4	1	4	0	2	6	3	0	0	6	15	7	16		
5.....	0	0	0	0	0	0	0	0	2	2	1	1		
6.....	1	1	5	9	0	0	0	0	15	0	19			
7.....	0	0	0	0	0	0	0	0	2	0	2			
8.....	2	0	0	0	0	0	0	0	0	0	0	1		
9.....	1	0	0	0	0	0	3	0	3					
10.....	0	0	0	0	12	0	0	14						
11.....	0	0	2	1	2									
12.....	0	0	0	0	0	0	0	0	0	0	0	0		
13.....	4	9	4											
14.....	22	51												
15.....	20													
Failure Characteristic Code														
2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
42	51	41	6	24	2	5	11	14	3	0	23	70	29	62
Number of Occurrences for Each Failure Code														

QE/C 69-665

TABLE 28
40°C (139 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	26	5	0	9	2	3	0	2	1	0	8	13	2	18
3	11	3	15	5	5	4	8	4	2	5	31	5	38	
4	2	5	1	2	4	3	0	0	0	2	23	11	30	
5	0	0	0	0	0	0	0	0	0	0	3	2	3	
6	0	4	1	5	0	0	0	0	0	16	0	15		
7	0	1	0	0	0	0	0	0	3	2	5			
8	0	0	1	0	0	0	0	0	2	0	5			
9	0	0	0	0	0	0	0	0	2	3	7			
10	0	0	0	0	0	0	0	9	0	0	11			
11	8	0	4	0	0	0	0	0	0	0	5			
12	0	1	0	0	0	0	0	0	0	0	1			
13	3	5	5	0	0	0	0	0	0	0	0			
14	12	57	0	0	0	0	0	0	0	0	0			
15	15	0	0	0	0	0	0	0	0	0	0			

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
32	57	40	4	25	6	10	11	12	17	8	22	64	20	80

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 29
DEPTH OF DISCHARGE-15% (89 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	17	4	3	6	2	2	0	1	2	0	4	11	3	17
3	6	4	9	2	4	3	5	5	2	1	21	3	28	
4	4	3	1	2	3	2	0	0	0	4	19	9	19	
5	0	0	0	1	0	0	0	0	1	7	6	6		
6	0	3	1	3	0	0	0	0	11	0	10			
7	0	1	0	0	0	0	0	0	2	2	4			
8	0	1	0	0	0	0	0	0	3	0	5			
9	0	0	0	0	0	0	0	0	3	3	4			
10	0	0	0	0	0	0	0	0	7	0	7			
11	5	0	6	0	0	0	0	0	0	0	0	7		
12	0	1	0	0	0	0	0	0	0	0	0	1		
13	4	8	3	0	0	0	0	0	0	0	0	0	0	
14	11	43	0	0	0	0	0	0	0	0	0	0	0	
15	11	0	0	0	0	0	0	0	0	0	0	0	0	

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
22	36	29	9	13	4	8	6	8	13	5	17	49	18	58

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 30
 DEPTH OF DISCHARGE-25% (161 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	34	12	6	10	2	1	1	2	0	0	6	21	7	16
3	15	6	17	6	2	3	9	2	0	6	43	11	36	
4	8	5	0	3	5	2	0	0	9	29	21	21	30	
5	0	0	0	0	0	0	0	0	4	6	7	3		
6	1	1	1	8	0	0	0	0	19	0	19			
7	1	0	0	0	0	0	0	0	7	1	7			
8	1	0	1	0	0	0	0	0	3	0	3			
9	2	0	0	0	0	0	0	0	3	2	6			
10	0	0	0	0	0	0	0	13	0	13				
11	3	0	1	0	0	0	0	0	0	1	0	1		
12	0	0	0	0	0	0	0	0	0	0	0	0		
13	8	12	7											
14	25	73												
15	23													
Failure Characteristic Code														
2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
43	64	55	14	29	8	8	13	16	7	3	26	90	40	86
Number of Occurrences for Each Failure Code														

QE/C 69-665

TABLE 31
DEPTH OF DISCHARGE-40% (70 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	16	12	3	4	0	1	0	0	0	0	4	5	0	6
3	11	2	6	0	1	2	1	0	0	0	1	11	4	14
4	1	2	0	1	4	2	0	0	0	3	7	3	6	
5	0	0	0	0	0	0	0	0	0	1	0	0	0	
6	0	1	4	4	0	0	0	0	0	5	0	8		
7	0	0	0	0	0	0	0	0	0	0	0	0	0	0
8	1	0	0	0	0	0	0	0	0	0	0	0	1	
9	1	0	0	0	0	0	0	0	2	0	2			
10	0	0	0	0	5	0	0	6						
11	0	0	1	1	1									
12	0	0	0	0	0									
13	0	1	0											
14	9	18												
15		8												

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
23	26	26	3	11	0	3	7	6	2	0	12	32	11	25

Number of Occurrences for Each Failure Code

QE/C 69-665

TABLE 32
ORBIT TIME-1.5 HRS. (177 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	31	18	7	4	2	1	1	1	2	0	9	15	6	17
3	18	5	12	4	4	4	8	5	2	4	31	6	33	
4	5	6	0	4	10	3	0	0	10	25	16	27		
5	0	0	0	0	0	0	0	0	2	3	5	3		
6	0	0	4	7	0	0	0	0	12	0	13			
7	1	0	0	0	0	0	0	0	4	1	6			
8	1	1	1	0	0	0	0	0	3	0	4			
9	2	0	0	0	0	0	0	4	3	9				
10	0	0	0	0	13	0	0	13	0	13				
11	5	0	3	0	3									
12	0	0	0	0	0	0	0	0	0	0	0	0		
13	7	15	7											
14	19	60												
15	20													

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
48	62	63	11	22	7	12	19	17	12	5	29	83	35	82

Number of Occurrences for Each Failure Code

QE/C 69-365

TABLE 33
ORBIT TIME-3.0 HRS. (143 CELL FAILURES)
COMBINATION FREQUENCIES OF CHARACTERISTICS OCCURRING JOINTLY

Failure Characteristic	3	4	5	6	7	8	9	10	11	12	13	14	15	16
2	26	10	5	16	2	3	0	2	0	0	5	22	4	22
3	14	7	20	4	3	4	7	2	0	4	44	12	48	
4	8	4	1	2	2	3	0	0	6	30	17	23		
5	0	0	0	1	0	0	0	4	10	8	6			
6	1	5	2	8	0	0	0	0	23	0	26			
7	0	1	0	0	0	0	0	5	2	5				
8	1	0	0	0	0	0	0	3	0	5				
9	1	0	0	0	0	0	4	2	3					
10	0	0	0	0	12	0	13							
11	3	0	5	1	6									
12	0	1	0	1										
13	5	6	3											
14	26	74												
15	22													

Failure Characteristic Code

2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
40	64	46	15	31	5	7	7	13	10	3	26	88	34	87

Number of Occurrences for Each Failure Code

(4) Table 25 (Sonotone) shows that when excess scoring (10) occurs, migration (14) also occurs 83.3% (25 of 30) of the time.

(5) Table 25 also shows that separator deterioration (16) occurs with excess scoring (10) 86.6% (26 of 30) of the time.

(6) The previous items imply a correlation between migration (14) and separator deterioration (16); summing across all manufacturers shows that separator deterioration occurred with migration during 78.4% (134 of 171) of the cases where migration occurred. Separator deterioration occurred 169 times. The correlation coefficient between these two characteristics is very high at .951 and implies that it is not really necessary to refer to both characteristics during failure analysis.

A computer program has been written for the Honeywell 2200 to determine the frequency of cell failure involving each of the various possible combinations of failure characteristics (up to four at a time). For example, the frequency of failure characteristic A and the combinations AB, ABC, and ABCD for any specified set of test conditions may be readily obtained for failure characteristic codes A, B, C, and D. Figure 1 is a sample of the computer output with the frequencies indicated for only a sampling of the possible combinations of numerical codes 2, 3, , 17. For instance, the 3rd combination listed, 2-3-4-0 (weight loss-depositing-high pressure) is a triple combination. The frequency, 5, indicates that these three characteristics occurred in combination in five of the cells that failed at 40°C.

This computer program will also sum frequencies for the possible combinations of failure characteristics when the various levels of the characteristics are included. For example, if the major failure characteristic is weight loss, the levels are low, medium and high. If deposits occurred, the levels would be deposits around the terminal, around the seam or both. See Tables 15-20 or Appendix D for a complete listing of the failure characteristic breakdowns.

3. Failure Time Dependency on Failure Characteristic

It has been noted that some failure characteristics tend to occur in certain time intervals when tested under certain conditions. For example blistering of the positive platen never occurred on G. E. cells until after about 4,000 cycles for the 3.0 hour orbit time and after 8,000 cycles for the 1.5 hour orbit time.

Graphs (Figures 2-23) showing the cell degradation rates by ambient temperature (cell life is plotted vs temperature) are given for each manufacturer, orbit time and failure characteristic combination where at least two points were available for plotting.

Figure 1

COMBINATION FREQUENCIES OF FAILURE CHARACTERISTICS (UP TO FOUR CODES PER COMBINATION)

Failure Characteristic Combination Codes	Number of Occurrences	Failure Characteristic Combination Codes	Number of Occurrences
2- 3- 4- 16	1	2- 3- 15- 0	1
2- 3- 4- 17	5	2- 3- 16- 0	16
2- 3- 4- 0	5	2- 3- 16- 0	16
2- 3- 6- 8	3	2- 3- 17- 0	26
2- 3- 6- 10	1	2- 3- 0- 0	26
2- 3- 6- 14	6	2- 4- 13- 17	1
2- 3- 6- 16	6	2- 4- 13- 0	1
2- 3- 6- 17	9	2- 4- 16- 17	1
2- 3- 6- 0	9	2- 4- 16- 0	1
2- 3- 7- 16	2	2- 4- 17- 0	5
2- 3- 7- 17	2	2- 4- 0- 0	5
2- 3- 7- 0	2	2- 6- 8- 14	1
2- 3- 8- 14	1	2- 6- 8- 16	2
2- 3- 8- 16	2	2- 6- 8- 17	3
2- 3- 8- 17	2	2- 6- 8- 0	3
2- 3- 8- 0	3	2- 6- 10- 14	1
2- 3- 10- 14	2	2- 6- 10- 16	1
2- 3- 10- 16	2	2- 6- 10- 17	1
2- 3- 10- 17	2	2- 6- 10- 0	1
2- 3- 10- 0	2	2- 6- 14- 16	5
2- 3- 13- 14	2	2- 6- 14- 17	6
2- 3- 13- 15	1	2- 6- 14- 0	6
2- 3- 13- 16	2	2- 6- 16- 17	6
2- 3- 13- 17	4	2- 6- 16- 0	6
2- 3- 13- 0	4	2- 6- 17- 0	9
2- 3- 14- 15	1	2- 6- 0- 0	9
2- 3- 14- 16	11	2- 7- 16- 17	2
2- 3- 14- 17	12	2- 7- 16- 0	2
2- 3- 14- 0	12	2- 7- 17- 0	2
2- 3- 15- 16	1	2- 7- 0- 0	2
2- 3- 15- 17	1	2- 8- 14- 16	1

All graphs utilize data for only 25% depth of discharge since this is the only rate represented at all three temperatures (0°, 25° and 40°C). Two lines were drawn for each failure characteristic; one line represents the data available for all failure characteristics combined and the other represents the data available for cases where the specified characteristic is involved. The line representing all the characteristics ignores any individual consideration of the characteristics and thus reflects the average temperature effect on the cycle life of the cells. By comparing the slopes and relative positions of the two lines for each failure characteristic, failure characteristics that cause the cells to fail more rapidly at specific temperatures or at all temperatures may be detected. This method, however, does not totally solve the problem if important interactions among the failure characteristics are existent.

These lines were determined from either two or three points (or averages per temperature). The points are determined from calculated averages using all the cell failure times available at each temperature. Then the averages were used to determine the best linear or straight line fit by linear regression. Thus the actual averages do not usually fall exactly on the lines. These actual averages are indicated by "o" for the overall case and by "x" for the case of the individual characteristic. No plots were made for end of charge voltage or for other characteristics where failure times were available at only one temperature.

For illustrative purposes consider Figure 2 for manufacturer General Electric, 1.5 hour orbit time, and the failure characteristic, deposits on the terminals. The failure times and means for each temperature are given as follows:

0°C	25°C	40°C
13,218	5,164	2,073
25,786	7,527	2,182
	8,065	2,182
	8,254	2,446
	8,714	2,461
	10,123	2,509
<hr/>	<hr/>	<hr/>
	10,382	2,509
$\bar{x} = 19,502$	$\bar{x} = 9,477$	$\bar{x} = 3,790$

The equation of best linear fit for these three averages is $L(\text{cycle life}) = 19,450 - 394 T$ (Temperature). Substituting temperatures back into $L = 19,450 - 394 T$ yields the following cycle life estimates:

$$\begin{aligned} L \text{ (for } 0^\circ\text{C)} &= 19,450 \text{ cycles} \\ L \text{ (for } 25^\circ\text{C)} &= 9,600 \text{ cycles} \\ L \text{ (for } 40^\circ\text{C)} &= 3,690 \text{ cycles} \end{aligned}$$

Plotting these three values yields the line of Figure 2 and it is readily seen that the actual means at each temperature are very close to the estimated values.

To obtain the other line for the deposits graphs of Figure 2, we use only the failure times (expressed in cycles) that involved depositing as a deficiency.

0°C	25°C	40°C
13,218	8,714	2,182
	10,463	2,182
	10,878	2,509
	13,149	2,509
		3,841
		3,841
$\bar{x} = 13,218$	$\bar{x} = 10,800$	$\bar{x} = 2,844$

From these points we get the equation $L = 14,210 - 243 T$ which estimates the points at each temperature to be:

$$\begin{aligned} L(0^{\circ}\text{C}) &= 14,210 \text{ cycles} \\ L(25^{\circ}\text{C}) &= 8,135 \text{ cycles} \\ L(40^{\circ}\text{C}) &= 4,510 \text{ cycles} \end{aligned}$$

Here it is seen that the equation does not fit so well as before (The location of these means are indicated on the graphs by "x" to give one an indication whether the fit is good or poor).

Tables 34-37 give the mean and range for each combination of manufacturer, orbit time, failure characteristic and temperature where at least one failure time was available (all combinations included 25% depth of discharge only).

Some of the observations that may be made from inspection of the plots and their slopes are as follows:


(1) General Electric, 1.5 hour orbit time (Figures 2-3)

The graphs show that cells with the characteristics of weight loss, deposits and blistering have lower average failure times at 0°C than do all failed cells with any set of failure characteristics. High pressure and blistering failures exhibit comparably higher average failure times at 40°C .


(2) General Electric, 3.0 hour orbit time (Figures 4-5)

The linear fit to the failure time averages for these graphs is not good.

Figure 2
GENERAL ELECTRIC-1,5 HOUR ORBIT TIME-CHARACTERISTIC CODE 2-4



GENERAL ELECTRIC-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 14-16



GENERAL ELECTRIC-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 3, 11, 14




Figure 5
GENERAL ELECTRIC-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 16




Figure 6
GOULF-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 2-4






Figure 7
GOULD-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 6, 8, 9




GOULD-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 14-16


Figure 8



GOULD-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 2-4



GOULD-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 6, 8, 14



GOULD-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 15, 16

Figure 11




Figure 12
GULTO4-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 2-4




Figure 1.3
GULTON-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 5, 6, 9






Figure 14
GULTON-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 11, 13, 14




GULTON-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 15, 16

Figure 15




Blisters (15)



Separator Deterioration (16)

Figure 10
GULTON-3.0 HOUR ORBIT TIME-C-HARACTERISTIC CODE 2-4



GULTON-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 5, 13, 14





Figure 18
GUILTON-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 15, 16



SON STONE-1, 5 HOUR ORBIT TIME-CHARACTERISTIC CODE 3, 4, 6




Figure 20
SONOTONE-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 9, 10, 13





Figure 21
SONOTONE-1.5 HOUR ORBIT TIME-CHARACTERISTIC CODE 14-16



SONOTONE-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 3, 6, 10





Figure 23
SONOTONE-3.0 HOUR ORBIT TIME-CHARACTERISTIC CODE 14, 16



**TABLE 34—GENERAL ELECTRIC
MEAN FAILURE TIMES AND RANGE OF FAILURES FOR MANUFACTURER-ORBIT TIME COMBINATIONS**

Failure Characteristic	Ambient Temperature	ORBIT TIME 1.5			ORBIT TIME 3.0		
		Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)	Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)
Overall	0°	2	19502	13218-25786	1	7054	7054
	25°	12	9477	5164-13149	1	8572	8572
	40°	13	3790	2073- 8273	9	3906	1672- 4424
2	0°	1	13218	13218	0	-	-
	25°	2	7844	5164-10624	0	-	-
	40°	0	-	-	0	-	-
3	0°	1	13218	13218	0	-	-
	25°	4	10801	8714-13149	1	8572	8572
	40°	3	2844	2182- 3841	2	4276	3854- 4487
4	0°	2	19502	13218-25786	0	-	-
	25°	2	11806	10463-13149	0	-	-
	40°	3	6797	6C-3- 8273	1	4264	4170- 4358
5	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
6	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
7	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	1	2182	2182	2	4487	4487- 4487
8	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	2	2454	2446- 2461	0	-	-
9	0°	0	-	-	0	-	-
	25°	2	10338	7537-13149	0	-	-
	40°	0	-	-	0	-	-
10	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
11	0°	0	-	-	0	-	-
	25°	0	-	-	1	8572	8572
	40°	5	2344	2073- 2509	1	1672	1672
12	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	3	2255	2073- 2509	0	-	-
13	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
14	0°	2	19502	13218-25786	1	7054	7054
	25°	12	9478	5164-13149	1	8572	8572
	40°	5	5485	3841- 8273	7	4187	3848- 4487
15	0°	1	13218	13218	0	-	-
	25°	6	9320	8065-10382	0	-	-
	40°	1	8273	8273	3	4168	3848- 4170
16	0°	2	19502	13218-25786	1	7054	7054
	25°	12	9478	5164-13149	1	8572	8572
	40°	5	5813	3841- 8273	8	4185	3848- 4487

**TABLE 35-GOULD
MEAN FAILURE TIMES AND RANGE OF FAILURES FOR MANUFACTURER-ORBIT TIME COMBINATIONS**

Failure Characteristic	Ambient Temperature	ORBIT TIME 1.5			ORBIT TIME 3.0		
		Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)	Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)
Overall	0°	9	9246	3556-13730	1	9110	9110
	25°	10	3663	2672- 4751	10	4268	3007- 5690
	40°	13	1303	408- 1811	9	749	138- 983
2	0°	0	-	-	0	-	-
	25°	5	4122	3090- 4751	6	3569	3007- 4173
	40°	4	539	408- 860	5	304	495- 974
3	0°	2	12362	10994-13730	0	-	-
	25°	5	4122	3090- 4751	7	3856	3007- 5580
	40°	-	809	408- 1811	5	804	495- 974
4	0°	4	8871	7858-10641	1	9110	9110
	25°	3	2826	2672- 2980	4	5317	4306- 5690
	40°	5	1064	484- 1569	4	865	801- 983
5	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
6	0°	1	13730	13730	0	-	-
	25°	2	3586	3090- 4081	6	3870	3007- 5690
	40°	5	1427	408- 1811	3	662	138- 974
7	0°	3	10147	6724-10994	0	-	-
	25°	0	-	-	2	3507	3130- 3884
	40°	0	-	-	0	-	-
8	0°	2	9807	8619-10994	1	9110	9110
	25°	2	2806	2785- 2826	0	-	-
	40°	0	-	-	1	974	974
9	0°	0	-	-	0	-	-
	25°	3	3193	2672- 4081	0	-	-
	40°	4	1541	1273- 1811	0	-	-
10	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
11	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
12	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
13	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
14	0°	9	9246	3556-13730	1	9110	9110
	25°	4	4548	429- 4751	10	4268	3007- 5690
	40°	1	1811	1811	5	852	800- 983
15	0°	0	-	-	0	-	-
	25°	1	4751	4751	2	4998	4306- 5690
	40°	2	1660	1509- 1811	3	862	801- 963
16	0°	8	9356	3556-13730	1	9110	9110
	25°	4	4105	2980- 4751	10	4268	3007- 5690
	40°	1	1509	1509	3	801	800- 801

TABLE 36-GULTON
MEAN FAILURE TIMES AND RANGE OF FAILURES FOR MANUFACTURER-ORBIT TIME COMBINATIONS

Failure Characteristics	Ambient Temperature	ORBIT TIME 1.5			ORBIT TIME 3.0		
		Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)	Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)
Overall	0°	14	7074	2107-16325	7	2812	1045- 8274
	25°	24	7084	308-15711	9	1675	721- 2885
	40°	34	4177	37-10360	10	2434	96- 4480
2	0°	6	7269	2107-14863	3	1528	1045- 2122
	25°	10	5439	308-15711	3	1413	1184- 1754
	40°	9	1630	114- 3795	4	2775	484- 4133
3	0°	5	11970	2995-16325	3	2591	1237- 4414
	25°	11	7734	308-15711	3	1413	1184- 1754
	40°	11	4271	187- 6537	7	2920	382- 4480
4	0°	7	4187	2203- 8590	6	3085	1045- 8274
	25°	6	5966	308-14250	2	1803	721- 2885
	40°	11	3795	1196- 7900	4	3207	484- 4480
5	0°	3	2200	2107- 2291	5	2034	1045- 4414
	25°	2	4770	1776- 7763	1	1754	1754
	40°	1	1333	1333	1	4480	4480
6	0°	0	-	-	0	-	-
	25°	4	5867	2743- 8108	0	-	-
	40°	9	5598	1195-10360	0	-	-
7	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
8	0°	1	10830	10830	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
9	0°	1	4066	4066	0	-	-
	25°	0	-	-	0	-	-
	40°	1	6345	6345	0	-	-
10	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
11	0°	0	-	-	0	-	-
	25°	7	5808	2025- 9791	0	-	-
	40°	7	3623	1196- 5766	0	-	-
12	0°	1	10803	10803	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
13	0°	2	6516	441- 8590	3	2335	1173- 4414
	25°	5	4287	2969- 7763	6	1807	721- 2885
	40°	9	2780	37- 5888	5	1598	96- 4133
14	0°	7	10018	3202-16325	3	4937	2122- 8274
	25°	15	8149	2743-15711	3	7028	1754-16881
	40°	23	5303	1195-10360	6	3827	2862- 4480
15	0°	9	6655	2203-14863	3	1592	1237- 2122
	25°	10	7991	2969-15711	4	2052	1184- 2885
	40°	10	4555	2824- 5766	3	4364	4133- 4480
16	0°	6	10400	4066-14863	1	8274	8274
	25°	18	8345	2025-10592	1	721	721
	40°	27	5034	1195-10360	6	3827	2862- 4480

TABLE 37-SOMOTONE
MEAN FAILURE TIMES AND RANGE OF FAILURES FOR MANUFACTURER-ORBIT TIME COMBINATIONS

Failure Characteristic	Ambient Temperature	ORBIT TIME 1.5			ORBIT TIME 3.0		
		Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)	Number of Failures	Mean Failure Time (Cycles)	Range of Failures (Cycles)
Overall	0°	7	10262	5788-15294	0	-	-
	25°	15	6340	1136-11745	3	6338	3771- 9971
	40°	12	3865	2487- 5625	6	3160	855- 4141
2	0°	2	11137	8774-13500	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	1	3684	3684
3	0°	5	8894	5788-13500	0	-	-
	25°	7	7446	2773-11745	2	6871	3771- 9971
	40°	5	3596	2993- 4388	4	3759	3068- 4141
4	0°	2	7281	5788- 8774	0	-	-
	25°	2	7531	3742-11319	1	5272	5272
	40°	5	3146	2902- 3625	0	-	-
5	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
6	0°	5	9253	5788-15294	0	-	-
	25°	6	6128	2342-11745	2	7622	5272- 9971
	40°	7	3860	2902- 5625	2	1962	855- 3068
7	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
8	0°	0	-	-	0	-	-
	25°	1	1179	1179	0	-	-
	40°	0	-	-	0	-	-
9	0°	1	12069	12069	0	-	-
	25°	2	10489	9658-11319	0	-	-
	40°	1	2487	2487	2	3605	3068- 4141
10	0°	6	10510	5788-15294	0	-	-
	25°	8	6989	2342-11745	3	6338	3771- 9971
	40°	7	4450	2993- 5625	3	3273	3068- 3684
11	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	2	4388	4388	0	-	-
12	0°	0	-	-	0	-	-
	25°	0	-	-	0	-	-
	40°	0	-	-	0	-	-
13	0°	3	7779	5788- 8774	0	-	-
	25°	1	2773	2773	0	-	-
	40°	0	-	-	0	-	-
14	0°	7	10262	5788-15294	0	-	-
	25°	13	6885	1136-11745	3	6338	3771- 9971
	40°	9	4172	2902- 5625	4	3490	3068- 4141
15	0°	0	-	--	0	-	-
	25°	1	1179	1179	0	-	-
	40°	1	3216	3216	0	-	-
16	0°	2	12034	8774-15294	0	-	-
	25°	10	8584	2342-11745	3	6338	3771- 9971
	40°	10	3864	2487- 5625	6	3160	855- 4141

(3) Gould, 1.5 hour orbit time (Figures 6-8)

Depositing and weak weld type failures have higher averages at 0°C. Cells with pierced separators were indicated to have lower failure times at 0°C by extrapolation from the plot, but no actual failure times were recorded for this characteristic.

(4) Gould, 3.0 hour orbit time (Figures 9-11)

Cells with blistering were indicated to have higher failure times at 0°C, but again no failure times occurred at this temperature.

(5) Gulton, 1.5 hour orbit time (Figures 12-15)

Cells with weight loss had lower averages at 40°C. Cells with deposits, migration and separator deterioration have higher averages at 0°C. High pressure, concave sides, and pierced separator characteristics have lower averages at 0°C. In general, the means do not show a good linear fit for the Gulton data.

(6) Gulton, 3.0 hour orbit time (Figures 16-18)

Cells with migration have higher averages across all temperature levels. Those with separator deterioration failures had a much higher average at 0°C.

(7) Sonotone, 1.5 hour orbit time (Figures 19-21)

High pressure cells have lower values at 0°C. Pierced separator cells have higher averages at 0°C and 25°C. The occurrence of ceramic shorts yields lower averages at 0°C and 25°C while blisters exhibit lower averages at 25°C; lower values for blisters at 0°C are indicated but no such failures had occurred.

(8) Sonotone, 3.0 hour orbit time (Figures 22-23)

No differences between failure characteristic plots and the overall plots were noted. However, a difference was indicated at 0°C for weak welds, but no actual failures occurred.

4. A Proposed Bayesian Approach to Evaluation of Failure Analysis Results

a. Discussion

In many real-life situations it is desirable to quantify the likelihood or probability of an occurrence when the available information surrounding the occurrence deals mostly with effects noted previously. If information prior to the occurrence is so lacking that the occurrence can not be prepared for or prevented, then it is certainly useful to be able to identify when it occurs and act accordingly. In the real world the identification or diagnosis is not always a sure thing, hence decision-making assistance is needed. Use of Bayesian techniques is one way to attain this assistance in the form of probabilities. The method proposed here is similar

to that used in the medical area where, with symptoms known, Bayes Theorem is used to diagnose diseases. However, the application here is battery cells and the symptoms are failure characteristics and levels of failure characteristics.

b. An Example

A total of 20 battery cell failures resulted from tests conducted under two different environments, E_1 and E_2 . The following table shows the failure symptoms or characteristics, S_1 , S_2 , and S_3 , and the levels of each. For example, S_2 might be concerned with weight loss and the levels might be no weight loss (0), low (1), medium (2) or high (3) weight loss. S_3 might represent separator deterioration and the levels could describe whether general decomposition was noted, whether shorting between the plates occurred, etc.

Symptoms	Level of Symptom	$f(E_1) = 8$	$f(E_2) = 12$
S_1	0	5	2
	1	3	0
	2	0	10
S_2	0	0	6
	1	2	0
	2	2	0
	3	4	6
S_3	0	0	4
	1	1	2
	2	0	4
	3	2	0
	4	5	2

To systematically study the failure characteristics and their associations to test environment, a Bayesian approach shows possibilities. Suppose one is asked to compute the probability that one of the 20 cells with a failure symptom set, $S = S_1 = 2$, $S_2 = 0$, $S_3 = 3$, failed under environmental conditions E_1 ; $P[E_1|S]$. If we ignore, for the moment, the fact that we can easily determine the true failure environment, the best answer would depend upon the history of failure characteristics for the 20 cells.

To compute $P[E_1|S]$ we resort to Bayes Equation,

$$P[E_1|S] = \frac{P[E_1]P[S|E_1]}{\sum_{i=1}^2 P[E_i]P[S|E_i]}$$

The prior probabilities are easily determined from inspection of the table:

$$P[E_1] = 8/20 \text{ and } P[E_2] = 12/20$$

However, $P[S|E_1] = P[S_1=2, S_2=0, S_3=3|E_1]$
 $= P[S_1=2|E_1]P[S_2=0|E_1]P[S_3=3|E_1]$, assuming that symptoms are independent.

We now use an extension of Laplace's Rule,

$$P = \frac{m_o + m}{n_o + n}, \text{ to compute the necessary probabilities.}$$

This method combines the prior estimate, $P = \frac{m_o}{n_o}$, with the historical data or sample MLE, $P = \frac{m}{n}$, and is preferred to the usual maximum likelihood estimate (MLE) since it (1) yields a reasonable compromise between the extremes of the prior and the maximum likelihood estimate, and (2) yields desirable non-zero probabilities as opposed to frequent maximum likelihood probabilities of zero.

$$\text{Then } P[S_1 = 2|E_1] = \frac{1+0}{3+8} = \frac{1}{11}$$

where $n_o = \# \text{ levels of } S_1$

$m = \# \text{ failures in } E_1 \text{ that exhibited symptom level 2 in } S_1$
 $n = \# \text{ failures in } E_1$

$$\text{Similarly, } P[S_2 = 0|E_1] = \frac{1+0}{4+8} = \frac{1}{12}$$

$$\text{and } P[S_3 = 3|E_1] = \frac{1+2}{5+8} = \frac{3}{13}$$

$$\begin{aligned} \text{Then } P[S|E_1] &= P[S_1 = 2|E_1]P[S_2 = 0|E_1]P[S_3 = 3|E_1] \\ &= \left(\frac{1}{11}\right) \left(\frac{1}{12}\right) \left(\frac{3}{13}\right) \end{aligned}$$

and similarly,

$$\begin{aligned} P[S|E_2] &= P[S_1 = 2|E_2]P[S_2 = 0|E_2]P[S_3 = 3|E_2] \\ &= \left(\frac{1+10}{3+12}\right) \left(\frac{1+6}{4+12}\right) \left(\frac{1+0}{5+12}\right) \\ &= \left(\frac{11}{15}\right) \left(\frac{7}{16}\right) \left(\frac{1}{17}\right) \end{aligned}$$

Now substituting back into Bayes Equation,

$$P[E_1|S] = \frac{\left(\frac{8}{20}\right) \left(\frac{1}{11} \cdot \frac{1}{12} \cdot \frac{3}{13}\right)}{\left(\frac{8}{20}\right) \left(\frac{1}{11} \cdot \frac{1}{12} \cdot \frac{3}{13}\right) + \left(\frac{12}{20}\right) \left(\frac{11}{15} \cdot \frac{7}{16} \cdot \frac{1}{17}\right)}$$

we finally obtain:

$$P[E_1 | S] = .051644 \quad P[E_2 | S] = .948356.$$

c. Summary

So we are quite confident that the failure with symptoms, $S = [2, 0, 3]$ did fail under test conditions E_2 and not E_1 since the probability is .948, the risk of being wrong is approximately five percent. By putting many different failure characteristics or symptom sets through a computer program written for this purpose, we can systematically:

- (1) determine which failure analysis information is inconsistent or misleading,
- (2) determine the associations of failure mechanisms with stress levels, and
- (3) determine to some extent which failure mechanisms and characteristics remain unchanged for varying stress levels.

This method, or any method, will require that the listing of failure characteristics be meaningful and that the data recording is done in a consistent fashion (i.e., with definitions basically unchanged for a specified life test). The method also requires that significantly high correlations do not exist between failure characteristics. Computer programs are available whereby one may determine inter-correlations and segregate the data accordingly.

APPENDIX AProcedure For Prediction of Cell Failure Time Using Time To Discharge

The following procedures were used for each pack:

1. The \bar{t}_i represents the average time for the i th cell of a pack to discharge to 1.25 volts. The voltage was arbitrarily chosen and other values may yield varying degrees of success.

2. The \bar{t}_i 's for the cells of a pack were assumed to be normally distributed and the mean and variance of the pack were estimated as follows:

$$\hat{\mu}_t = \frac{\sum_{i=1}^n \bar{t}_i}{n} \quad \hat{\sigma}_t^2 = \frac{\sum_{i=1}^n (\bar{t}_i - \hat{\mu}_t)^2}{n-1}$$

3. Since the actual failure times of several of the packs were distributed approximately lognormal (i.e., the logarithms of the failure times tend to give a normal distribution), the logarithms of the actual failure times (T_i 's) were obtained. Where the number of failure times were sufficient, a mean ($\hat{\mu}_{F.T.}$) and variance ($\hat{\sigma}_{F.T.}^2$) were estimated from the natural logarithms of the actual failure times:

$$\hat{\mu}_{F.T.} = \frac{\sum_{i=1}^n (\ln T_i)}{n} \quad \hat{\sigma}_{F.T.}^2 = \frac{\sum_{i=1}^n (\ln F.T. - \hat{\mu}_{F.T.})^2}{n-1}$$


In instances where the number of failure times were insufficient for estimates of μ and σ^2 , conservative estimates were made.

4. Now for any calculated \bar{t}_i the number of standard normal deviates from the mean could be determined from the distribution of discharge times and mapped to the failure time distribution. The number of standard normal deviates (Z_i) is found by

$$Z_i = \frac{\bar{t}_i - \hat{\mu}_t}{\hat{\sigma}_t}$$

and the cumulative probability or area under the normal curve (P_i) for the i th battery is given by

$$P_i = \frac{1}{\sqrt{2\pi}} \int_{-\infty}^{Z_i} e^{-x^2/2} dx$$

Area Under The Normal Curve

5. After determining each of the Z_i , they were mapped to the failure time distributions. From this mapping a predicted failure time was obtained such that the cumulative probabilities or areas on each distribution were equal. That is, let $P_i(\bar{t}_i) = P_i(\ln T_i)$ and $Z_i(\bar{t}_i) = Z_i(\ln T_i)$. The Z_i then was used to determine a unique $\ln T_i$ for each \bar{t}_i and hence, a unique T_i , the predicted or estimated failure time for the i th cell having an average time to discharge of \bar{t}_i .

$$Z_i = \frac{\text{Est } \ln T_i - \hat{\mu}_{F.T.}}{\hat{\sigma}_{F.T.}}$$

$$\text{Est. } \ln T_i = Z_i \hat{\sigma}_{F.T.} + \hat{\mu}_{F.T.}$$

$$\text{Est. } T_i = \text{antilog } (Z_i \hat{\sigma}_{F.T.} + \hat{\mu}_{F.T.})$$

APPENDIX B

Procedures For Prediction Of Cell Failure Time Using Time To Charge

The following procedures were used for the packs evaluated.

1. The \bar{t}' represents the average time for the ith cell of a pack to charge to 1.35 volts.

2. The predictions for each cell were then made following the procedures of Appendix A but with \bar{t}' substituted for \bar{t}_i .

APPENDIX CProcedures For Prediction Of Cell Failure Time Using Linear Regression

A linear regression analysis in conjunction with the time to discharge was used to make predictions of cell failures.

1. The \bar{t}_i represents the average time for the i th cell of a pack to discharge to 1.25 volts.

2. A simple linear regression equation was generated using the natural logarithm of the available failure times as the dependent variable and the \bar{t}_i as the independent variable.

$$\ln FT_i = \alpha + \beta \bar{t}_i$$

3. The \bar{t}_i 's for all cells of the pack were then substituted into the regression equation and a failure time was estimated for each cell.

$$\text{Est. } \ln F.T. _i = \alpha + \beta \bar{t}_i$$

$$\text{Est. } F.T. _i = \text{antilog} (\alpha + \beta \bar{t}_i)$$

QE/C 69-665

APPENDIX D

Failure Analysis Results-NAD Crane Life Cycling Program

Numerical codes were developed for the NASA-NAD Crane Failure Analysis Program so that data processing facilities could be used for analysis of the data. Following are (1) coding sheets with individual cell information and (2) computer output sheets identifying each failed cell, listing failure characteristics and cycle failure time, and indicating the test conditions (orbit time, temperature, and depth of discharge) for any cell that has failed.

CODING FOR DATA PROCESSING ON
NASA--NAD CRANE FAILURE ANALYSIS PROGRAM (APRIL 1969)

<u>NOMENCLATURE</u>	<u>CODES</u>	<u>COLUMN</u>
Pack Number	xxxA	1-4
Manufacturer	xx 01 - General Electric 02 - Gould 03 - Gulton 04 - Sonotone 05 - Yardney 06 - Delco 07 - C & D 08 - NIFE	5-6
Rated Capacity	xxx.xx (Capacity indicated by actual numerical rating--decimal assumed after 9th column)	7-11
Depth of Discharge	xx 01 - 15% 06 - 20% 11 - 31% 02 - 25% 07 - 10% 12 - 42% 03 - 40% 08 - 16% 13 - 43% 04 - 50% 09 - 27% 14 - 75% 05 - 60% 10 - 30%	12-13
Orbit Time	xx 01 - 1.5 hrs. 02 - 3.0 hrs. 03 - 8.0 hrs. 04 - 24.0 hrs.	14-15
Ambient Temperature	xx 01 - -20°C 02 - 0°C 03 - 25°C 04 - 40°C 05 - 50°C 06 - 0°/40°C (stepped from 0° to 40° every 48 hrs.)	16-17
Cycles Completed	xxxxx (Give actual number of cycles completed)	18-22
Position in Pack	xx	23-24
Shape	xx 01 - Round or cylindrical (Unless specified as Nimbus) 02 - Rectangular 03 - Nimbus	25-26

FAILURE MODES

Charge Voltage	<u>01xx</u> 01 - Shorted 02 - Low 03 - Normal 04 - High 05 - Open Circuit
Weight Loss	<u>02xx</u> 01 - Low 02 - Medium (Rated capacity $\pm 50\%$ Rated) 03 - High
Deposits	<u>03xx</u> 01 - Around Terminal 02 - Around Seam 03 - Around Both
High Pressure	<u>04xx</u> 01 - Bulged 02 - Gas Present 03 - Both
Concave Side	<u>05xx</u> 01 - Present 02 - Caused Short
Weak Weld	<u>06xx</u> 01 - Tab to Plate 02 - Tab to Case 03 - Tab to Terminal 04 - Tab to Plate & Case 05 - Tab to Plate & Terminal
Loosened Active Material	<u>07xx</u> 01 - Present 02 - Caused Short
Extraneous Active Material	<u>08xx</u> 01 - Present 02 - Caused Short
Pierced Separator	<u>09xx</u> 01 - Grid Wire 02 - Tab to Plate 03 - Foreign Pieces of Metal
Excess Scoring	<u>10xx</u> 01 - Present 02 - Caused Short

Burned Positive Tab 11xx
 01 - Present
 02 - Broken
 03 - Caused Short

Short Separator 12xx
 01 - Present
 02 - Caused Short

Ceramic Short 13xx
 01 - One Terminal
 02 - Two Terminal

Migration 14xx
 01 - General
 02 - Small Area Penetration
 03 - Shorting Penetration
 04 - Positive Plate
 05 - Short Around Tab
 06 - Short Around Scoring
 07 - General with Shorting

Blisters 15xx
 01 - Present
 02 - Caused Short

Separator Deterioration 16xx
 01 - General
 02 - Permitted Short
 03 - Center of Case
 04 - Permitted Short

Weight Loss 17xx
 xx - Amount of Loss in Grams if measurable
 (Usually in the Range of 1 - 27 gms)

**Computer Printout Of Failure
Analysis Results**

Pack Number	Manufacturer	Capacity Rating	Depth Of Discharge	Orbit Time	Temperature	Failure Time	Pack Position	Shape	Failure Characteristics And Levels						Number of Characteristics Per Cell	
									1	2	3	4	5	6		
1A 04	5.0	020103	2995				4	01	0104	0301	1401				3	
1A 04	5.0	020103	4423				1	01	0104	0601	1001	1603			4	
1A 04	5.0	020103	7782				6	01	0103	0301	1002	1401	1602		5	
1A 04	5.0	020103	11361				5	01	0103	0301	1001	1401	1602		5	
1A 04	5.0	020103	11745				3	01	0103	0601	1001	1401	1602		5	
1A 04	5.0	020103	11745				10	01	0103	0301	0601	1001	1401	1602	6	
2A 04	5.0	030103	3155				10	01	0101	0301	0401	0601	0401		5	
2A 04	5.0	030103	3992				5	01	0103	0301	0401	1401			4	
2A 04	5.0	030103	4411				2	01	0102	0601	1001	1601			4	
2A 04	5.0	030103	5262				6	01	0103	0301	0401	0601	0602	1601	5	
2A 04	5.0	030103	5262				7	01	0102	0601	0901	1001	1401	1601	5	
2A 04	5.0	030103	6671				1	01	0103	0301	0401	1001	1401	1601	5	
2B 04	3.0	030103	1272				3	01	0104						1	
2B 04	3.0	030103	5113				4	01	0103	0605	1001	1407	1601		5	
2B 04	3.0	030103	5399				5	01	0103	0601	1002	1401	1601		5	
3A 02	3.5	020103	2785				5	01	0104	0802					2	
3A 02	3.5	020103	3090				2	01	0102	0202	0301	0601	1702		5	
3A 02	3.5	020103	4081				9	01	0103	0202	0301	0601	0502	1702	5	
3A 02	3.5	020103	4289				6	01	0104	0203	0301	1401	1601	1702	5	
3A 02	3.5	020103	4401				7	01	0103	0203	0301	1401	1601	1702	5	
3A 02	3.5	020103	4751				4	01	0103	1401	1501	1601			4	
3A 02	3.5	020103	4751				10	01	0103	0202	0301	1401	1702		5	
3B 04	3.0	020103	4658				2	01	0102	0401	1401	1601			4	
3B 04	3.0	020103	11319				1	01	0102	0402	0902	1401	1602		5	
3B 04	3.0	020103	11726				4	01	0102	0302	1401	1602			4	
4A 02	1.5	030103	1699				7	01	0102	0203	0301	0401	1703		5	
4A 02	3.5	030103	1827				8	01	0102	0203	0301	0401	1703		5	
4A 02	3.5	030103	2110				1	01	0102	0402	1603			3		
4A 02	3.5	030103	2954				6	01	0102	0201	0301	1401	1601	1701	6	
4A 02	3.5	030103	3029				3	01	0103	0301	1601			3		
4A 02	3.5	030103	3164				10	01	0102	0202	0301	0801	1601	1702	6	
5A 04	5.0	020203	3771				2	01	0104	0301	1002	1401	1601		5	
5A 04	5.0	020203	5272				3	01	0103	0402	0601	1001	1401	1601	5	
5A 04	5.0	020203	9971				1	01	0102	0301	0601	1001	1401	1602	6	
6A 04	5.0	030203	1069				8	01	0103	1401					2	
6A 04	5.0	030203	1136				10	01	0102	0401	1404				3	
6A 04	5.0	030203	1161				4	01	0101	0601	0802	0901			4	
6A 04	5.0	030203	3798				9	01	0103	0401	1001	1401	1602		5	
6A 04	5.0	030203	4608				7	01	0103	0601	1002	1405	1601		5	
6A 04	5.0	030203	5211				6	01	0103	0601	1001	1401	1602		5	
7A 02	3.5	020203	3007				2	01	0102	0203	0301	0601	1401	1601	1704	
7A 02	3.5	020203	3130				1	01	0103	0201	0401	0601	0701	1402	1601	1701
7A 02	3.5	020203	3483				6	01	0102	0202	0301	0601	1402	1601	1702	
7A 02	3.5	020203	3736				5	01	0101	0201	0301	0601	1402	1601	1701	
7A 02	3.5	020203	3884				7	01	0103	0202	0301	0701	1402	1601	1702	
7A 02	3.5	020203	4173				3	01	0103	0201	0301	0601	1402	1601	1701	
8A 02	3.5	030203	1346				6	01	0102	0201	0301	1401	1702		5	
8A 02	3.5	030203	1704				8	01	0103	0202	0301	0604	1702		3	
8A 02	3.5	030203	1985				1	01	0103	0301	1401	1601			1	
8A 02	3.5	030203	2494				4	01	0102	0202	0301	0601	1401	1601	1702	
8A 02	3.5	030203	2138				10	01	0103	0202	0301	0602	1401	1601	1701	
8A 02	3.5	030203	2424				9	01	0102	0202	0301	1400	1601	1702	5	
11A 03	6.0	030103	2755				3	02	0103	0201	1302	1501	1601	1701	6	
11A 03	6.0	030103	7743				1	02	0101	0301	1401	1501	1602		5	
11A 03	6.0	030103	7743				2	02	0104	0301	1401	1501	1601		5	
13A 02	6.0	020103	308				1	02	0104	0203	0301	0401	1712		5	
13A 02	6.0	020103	502				10	02	0104	0203	0401	1710			4	

13A	03	6.0	020103	2969	5 02 0102 1301 1501	3
13A	03	6.0	020103	3084	7 02 0102 1301 1501	3
13A	03	6.0	020103	3598	4 02 0102 1301 1501 1601	4
13A	03	6.0	020103	4021	2 02 0102 0401 1301 1401 1501 1601	6
14A	03	6.0	030103	262	4 02 0104 0203 0301 0401 0501 1702	4
14A	03	6.0	030103	262	5 02 0102 0203 0301 0401 0501 1702	0
14A	03	6.0	030103	450	1 02 0104 0203 0401 1702	4
14A	03	6.0	030103	1113	2 02 0104 1301	2
14A	03	6.0	030103	1618	3 02 0102 1301	2
14A	03	6.0	030103	2086	7 02 0103 1301	2
14B	03	4.0	030103	7564	3 02 0101 0402 0501 0603 1407 1602	6
14B	03	4.0	030103	8474	1 02 0102 0403 0603 1407 1501 1602	0
14B	03	4.0	030103	8474	5 02 0102 0403 1407 1501 1602	0
14D	04	5.0	020103	1136	1 02 0104 1403	2
14D	04	5.0	020103	1179	4 02 0103	1
14D	04	5.0	020103	1179	5 02 0104 0802 1401 1502	4
15A	01	3.0	020103	8065	7 01 0102 1401 1501 1601	4
15A	01	3.0	020103	8254	8 01 0102 1401 1501 1601	4
15A	01	3.0	020103	8714	5 01 0103 0301 1401 1501 1601	5
15A	01	3.0	020103	10123	10 01 0103 1403 1501 1601	4
15A	01	3.0	020103	10342	4 01 0102 1403 1501 1601	4
15A	01	3.0	020103	10342	9 01 0102 1403 1501 1601	4
16A	01	3.0	030103	3985	7 01 0103 1103	2
16A	01	3.0	030103	4473	6 01 0103 1402	2
16A	01	3.0	030103	4741	1 01 0103 1402	2
16A	01	3.0	030103	4917	5 01 0102 1402	2
16A	01	3.0	030103	4917	10 01 0102 1402	2
16A	01	3.0	030103	5013	4 01 0102 1403	2
17A	03	6.0	020203	1688	10 02 0102 1301 1401 1501	4
17A	03	6.0	020203	721	3 02 0104 0401 1301 1602	4
17A	03	6.0	020203	721	5 02 0104 1301	0
17A	03	6.0	020203	2375	1 02 0102 1301	0
17A	03	6.0	020203	2449	2 02 0102 1301 1402 1501	4
17A	03	6.0	020203	2885	9 02 0102 0401 1301 1501	4
18A	03	6.0	030203	365	6 02 0103 0202 0501 1301 1703	5
18A	03	6.0	030203	608	3 02 0103 0203 0301 0401 1705	5
18A	03	6.0	030203	643	7 02 0104 0401 1301	3
18A	03	6.0	030203	643	9 02 0104 1301	2
18A	03	6.0	030203	1145	5 02 0102 1301	0
18A	03	6.0	030203	1550	1 02 0102 1301 1501	3
18B	03	6.0	030103	5364	2 02 0102 1302 1402 1501 1601	5
18B	03	6.0	030103	7577	3 02 0103 1401 1501 1601	4
18B	03	6.0	030103	7577	4 02 0103 1401 1501 1601	4
19A	01	4.0	020203	8572	1 01 0103 0301 1103 1401 1601	5
20A	01	3.0	030203	3704	5 01 0102 1401 1501 1601	4
20A	01	3.0	030203	4485	2 01 0102 1101 1403 1501 1601	5
20A	01	3.0	030203	4485	6 01 0102 0301 1403 1501 1601	5
20A	01	3.0	030203	4889	3 01 0101 0301 1403 1501 1601	5
20A	01	3.0	030203	5410	6 01 0103 0301 1401 1501 1601	5
20A	01	3.0	030203	5410	9 01 0102 1401 1501 1602	4
23A	03	6.0	020103	16338	5 02 0101 0301 1407 1502 1602	5
23A	03	6.0	020103	15711	1 02 0103 0301 1401 1501 1602	5
23A	03	6.0	020103	15711	4 02 0103 0201 0301 1407 1502 1602 1703	7
25A	04	5.0	010104	6348	5 01 0104 1002 1402 1604	4
25A	04	5.0	010104	7052	4 01 0103 0301 0401 1002 1401 1602	5
25A	04	5.0	010104	7758	1 01 0102 0301 1001 1401 1602	5
25A	04	5.0	010104	9070	3 01 0103 0301 0401 1602	4
25A	04	5.0	010104	9220	6 01 0103 0301 0802	3
25A	04	5.0	010104	9328	2 01 0102 0301 0601 1401 1601	5
26A	04	5.0	020104	2487	1 01 0101 0901 1401	3
26A	04	5.0	020104	2902	3 01 0101 0402 0601 1401 1601	5
26A	04	5.0	020104	2993	6 01 0103 0301 0401 0601 1401 1601	5
26A	04	5.0	020104	2993	7 01 0103 0301 0401 0601 1001 1601	5
26A	04	5.0	020104	3344	3 01 0101 1002	2
26A	04	5.0	020104	3625	4 01 0102 0401 1402 1601	4
26B	04	3.0	010104	5959	3 01 0103 0605 1001 1407 1602	5
26B	04	3.0	010104	6289	1 01 0102 0302 0605 1001 1407 1602	6
26B	04	3.0	010104	6289	5 01 0103 0701 1001 1407 1602	5
27A	02	3.5	010104	2901	3 01 0102 0201 0301 0701 1601 1702	6
27A	02	3.5	010104	2901	8 01 0103 0203 0301 0701 1604 1704	6
27A	02	3.5	010104	2908	7 01 0103 0401 0802	3
27A	02	3.5	010104	3270	10 01 0103 0202 0301 0602 1403 1603 1702	07
27A	02	3.5	010104	4102	9 01 0104 0201 0301 1405 1601 1701	6
27A	02	3.5	010104	4445	2 01 0103 0301 1401 1601	4
27H	03	12.0	020103	10592	3 02 0104 0401 1401 1501 1602	5
27H	03	12.0	020103	14250	2 02 0103 1401 1602	3
27H	03	12.0	020103	14250	5 02 0103 0402 1401 1602	4
26A	02	3.0	020104	484	7 01 0103 0202 0301 0401 1702	5
26A	02	3.0	020104	484	8 01 0103 0202 0301 0401 1702	5
26A	02	3.0	020104	860	5 01 0104 0203 0301 1704	4
26A	02	3.5	020104	1293	10 01 0104 0602	2
26A	02	3.5	020104	1811	1 01 0102 0901	2
26A	02	3.5	020104	1811	3 01 0104 0602	2
26A	02	3.5	020104	1811	4 01 0102 1405 1501	3

28A 02	1..5	020104	1811	6	01	0102	0602	1403	3
28A 02	3..5	020104	1811	9	01	0102	0301	0602	1403
28A 02	3..5	020104	408	2	01	0103	0202	0301	0602
28B 03	4..0	010104	17021	1	02	0103	0401	0603	1401
28B 03	4..0	010104	20227	3	02	0102	0403	0603	1401
28B 03	4..0	010104	20227	4	02	0101	0403	1401	1602
29A 04	5..0	010204	1418	1	01	0101	0601	1406	3
29A 04	5..0	010204	4340	8	01	0103	0301	1002	1602
29A 04	5..0	010204	4635	7	01	0102	0301	0601	0901
29A 04	5..0	010204	4964	9	01	0103	0402	0601	1001
29A 04	5..0	010204	5581	5	01	0103	0301	0601	1001
29A 04	5..0	010204	5975	6	01	0103	0201	0301	0601
30A 04	5..0	020204	855	7	01	0101	0601	1602	3
30A 04	5..0	020204	3068	4	01	0102	0601	1002	1405
30A 04	5..0	020204	3068	9	01	0102	0301	0901	1002
30A 04	5..0	020204	3684	8	01	0102	0201	0301	1002
30A 04	5..0	020204	4141	1	01	0101	0301	0902	1602
30A 04	5..0	020204	4141	10	01	0102	0301	1401	1602
30H 03	5..6	020104	1195	5	01	0102	0201	0302	0603
30H 03	5..6	020104	1196	3	01	0104	0201	0402	1102
30H 03	5..6	020104	1275	1	01	0104	0201	0402	1103
31A 02	3..5	010204	1500	9	01	0102	0203	0301	1601
31A 02	3..5	010204	1500	10	01	0102	0201	0301	0601
31A 02	3..5	010204	1696	2	01	0104	0802	1601	3
31A 02	3..5	010204	2411	3	01	0102	0202	0301	0601
31A 02	3..5	010204	2477	8	01	0104	0202	0301	0602
31A 02	3..5	010204	2517	1	01	0102	0202	0301	0601
31A 02	3..5	010204	2517	6	01	0102	0402	0605	0802
31A 02	3..5	020102	7636	5	01	0102	0301	0601	1002
32A 02	3..5	020204	800	1	01	0102	0203	0301	1403
32A 02	3..5	020204	875	4	01	0102	0202	0301	0602
32A 02	3..5	020204	875	7	01	0101	0203	0301	0401
32A 02	3..5	020204	974	9	01	0104	0201	0301	0604
32A 02	3..5	020204	138	6	01	0103	0602		2
32A 02	3..5	020204	495	3	01	0103	0201	0301	1702
32H 03	5..6	020101	13846	2	01	0104	0303	0603	1101
34H 04	20..0	030103	512	8	02	0101	0403	0601	1407
34H 04	20..0	030103	877	2	02	0101	0302	0403	1602
34H 04	20..0	030103	877	3	02	0101	0302	0403	1603
35A 03	6..0	010104	11471	4	02	0103	0301	0403	1401
35A 03	6..0	010104	12224	5	02	0103	0402	1401	1602
35A 03	6..0	010104	12511	2	02	0103	0301	0403	1401
37A 03	6..0	010104	1566	8	02	0102	0203	1301	1710
37A 03	6..0	010104	2819	4	02	0102	1301	1501	3
37A 03	6..0	010104	2991	10	02	0103	1301	1501	3
37A 03	6..0	010104	4897	7	02	0103	0201	1301	1501
37A 03	6..0	010104	6064	6	02	0104	0301	1301	1401
37A 03	6..0	010104	238	3	02	0102	0202	1301	1704
37B 04	3..0	020104	4903	5	01	0104	0605	1001	1401
37B 04	3..0	020104	5510	2	01	0103	1001	1407	1602
37B 04	3..0	020104	5625	4	01	0103	0605	1001	1407
38A 03	6..0	020104	187	9	02	0103	0202	0301	1301
38A 03	6..0	020104	225	3	02	0104	0202		3
38A 03	6..0	020104	1333	5	02	0103	0602		2
38A 03	6..0	020104	1377	2	02	0102	0401	1301	3
38A 03	6..0	020104	37	8	02	0101	1301		2
38A 03	6..0	020104	114	6	02	0102	0202	1301	1704
38B 03	6..0	020104	5184	2	02	0102	0301	1101	1302
38B 03	6..0	020104	4350	5	02	0102	0402	1101	1401
38B 03	6..0	020104	5766	4	02	0103	1101	1301	1502
39A 01	3..0	010104	2083	6	01	0104	0301	1101	1202
39A 01	3..0	010104	2532	7	01	0104	1101		2
39A 01	3..0	010104	7213	1	01	0103	0301	1101	1401
39A 01	3..0	010104	8109	5	01	0103	0203	1101	1401
39A 01	3..0	010104	8109	8	01	0103	1402	1601	3
39A 01	3..0	010104	779	2	01	0104	0301	1101	1202
40A 01	3..0	020104	2073	3	01	0104	1101	1202	3
40A 01	3..0	020104	2162	7	01	0104	1102	1202	3
40A 01	3..0	020104	2162	8	01	0103	0301	0701	3
40A 01	3..0	020104	2446	5	01	0104	0801	1101	3
40A 01	3..0	020104	2461	10	01	0104	0801		2
40A 01	3..0	020104	2509	2	01	0104	0301	1101	3
40A 01	3..0	020104	2509	6	01	0102	1101	1202	3
40B 03	4..0	020104	7900	4	02	0101	0402	0603	1401
40B 03	4..0	020104	10360	2	02	0103	0603	1401	1602
40B 03	4..0	020104	10360	3	02	0103	0603	1401	1602
40B 03	4..0	020104	10360	5	02	0103	1401	1602	3
41A 03	6..0	010204	649	9	02	0104	1301		2
41A 03	6..0	010204	1062	6	02	0103	1301		2
41A 03	6..0	010204	1132	2	02	0103	1301		2
41A 03	6..0	010204	1157	7	02	0103	1301		2
41A 03	6..0	010204	1157	8	02	0103	1301		2
42A 03	6..0	020204	96	8	02	0103	1301		2

42A 03	6,0	020204	342	7	02	0102	0302		2
42A 03	6,0	020204	416	9	02	0104	1301		2
42A 03	6,0	020204	484	1	02	0102	0202	0302	6
42A 03	6,0	020204	3619	6	02	0103	0203	0303	6
42A 03	6,0	020204	4133	4	02	0102	0203	0301	8
42A 03	6,0	020104	3625	3	01	0103	0204	0303	7
42B 03	6,6	020104	3795	5	01	0103	0202	0303	8
42C 03	6,6	020104	3795	5	01	0103	0202	0303	8
42D 03	6,6	020104	3795	5	01	0103	0202	0303	8
42E 03	6,6	020104	3795	5	01	0103	0202	0303	8
42F 03	6,6	020104	3795	5	01	0103	0202	0303	8
42G 03	6,6	020104	3795	5	01	0103	0202	0303	8
42H 03	6,6	020104	3795	5	01	0103	0202	0303	8
42I 03	6,6	020104	3795	5	01	0103	0202	0303	8
42J 03	6,6	020104	3795	5	01	0103	0202	0303	8
42K 03	6,6	020104	3795	5	01	0103	0202	0303	8
42L 03	6,6	020104	3795	5	01	0103	0202	0303	8
42M 03	6,6	020104	3795	5	01	0103	0202	0303	8
42N 03	6,6	020104	3795	5	01	0103	0202	0303	8
42O 03	6,6	020104	3795	5	01	0103	0202	0303	8
42P 03	6,6	020104	3795	5	01	0103	0202	0303	8
42Q 03	6,6	020104	3795	5	01	0103	0202	0303	8
42R 03	6,6	020104	3795	5	01	0103	0202	0303	8
42S 03	6,6	020104	3795	5	01	0103	0202	0303	8
42T 03	6,6	020104	3795	5	01	0103	0202	0303	8
42U 03	6,6	020104	3795	5	01	0103	0202	0303	8
42V 03	6,6	020104	3795	5	01	0103	0202	0303	8
42W 03	6,6	020104	3795	5	01	0103	0202	0303	8
42X 03	6,6	020104	3795	5	01	0103	0202	0303	8
42Y 03	6,6	020104	3795	5	01	0103	0202	0303	8
42Z 03	6,6	020104	3795	5	01	0103	0202	0303	8
43A 01	3,0	010204	1182	4	01	0102	1101	1202	3
43A 01	3,0	010204	1515	3	01	0104	1102	1202	3
43A 01	3,0	010204	1911	6	01	0105	1102		2
43A 01	3,0	010204	2298	9	01	0105	1102	1201	6
43A 01	3,0	010204	2615	7	01	0105	1102	1601	3
43A 01	3,0	010204	2656	10	01	0105	1102	1402	4
43A 01	3,0	020204	1672	6	01	0105	1101		2
43A 01	3,0	020204	3448	8	01	0104	1402	1501	4
43A 01	3,0	020204	3854	1	01	0101	0301	1402	4
43A 01	3,0	020204	3854	3	01	0103	1401	1601	3
43A 01	3,0	020204	4487	2	01	0104	0301	0701	6
43A 01	3,0	020204	4487	10	01	0102	0301	0701	5
43A 03	6,0	020104	6200	5	02	0101	0301	0402	6
43A 03	6,0	020104	5223	2	02	0101	0301	0601	6
43A 03	6,0	020104	5502	1	02	0101	0601	1401	5
43A 03	6,0	020104	5463	2	02	0101	0402	1401	4
43A 03	6,0	020104	5801	3	02	0103	0402	1401	4
43A 03	6,0	020104	6537	1	02	0103	0301	0401	5
43A 03	6,0	030106	3669	1	02	0103	1401	1501	4
43A 03	6,0	030106	6139	4	02	0103	0302	0401	8
43B 03	6,0	030106	6156	2	02	0103	0301	0401	5
43B 03	6,0	030106	6156	3	02	0103	0301	0401	5
43B 03	6,0	030106	6156	5	02	0103	0401	1402	5
43C 04	6,0	010102	2010	9	01	0102	0401	0601	4
43C 04	6,0	010102	10073	3	01	0101	0801	1002	2
50A 04	6,0	020102	12069	5	01	0102	0901	1001	4
50A 04	6,0	020102	13500	3	01	0102	0201	0301	6
50A 04	6,0	020102	1294	4	01	0102	0601	1001	4
51A 02	3,5	010102	17373	4	0102	0301	1401	1601	4
51A 02	3,5	010102	14738	10	01	0102	0201	0301	6
52A 02	3,5	020102	7858	8	01	0102	0402	1401	5
52A 02	3,5	020102	8367	10	01	0103	0402	1407	3
52A 02	3,5	020102	9724	7	01	0104	0701	1401	4
52A 02	3,5	020102	9724	9	01	0102	0701	1401	4
52A 02	3,5	020102	10294	3	01	0101	0301	0701	6
52A 02	3,5	020102	13730	2	01	0102	0301	0601	5
54A 04	7,0	020202	11331	3	01	0102	0301	0601	5
59A 03	6,0	020102	3202	3	02	0103	0201	0403	5
59A 03	6,0	020102	14663	2	02	0102	0202	0301	7
59A 03	6,0	020102	14863	5	02	0103	0201	0301	7
61A 03	6,0	010102	2762	5	02	0102	1301		2
61A 03	6,0	010102	4094	4	02	0102	0401	1301	5
61A 03	6,0	010102	4285	10	02	0102	0401	1301	4
61A 03	6,0	010102	4413	5	02	0102	0401	1301	4
61A 03	6,0	010102	9760	3	02	0102	0202	0401	9
61A 03	6,0	010102	10146	1	02	0104	0203	0301	7
62A 03	6,0	020102	2995	10	02	0104	0203	0301	6
62A 03	6,0	020102	4066	4	2	0102	0902	1501	4
62A 03	6,0	020102	4441	5	02	0102	0401	1301	4
62A 03	6,0	020102	8590	7	02	0102	0401	1301	5
63A 01	3,0	010102	14917	6	01	0103	0701	1408	5
63A 01	3,0	010102	20126	4	01	0104	0201	0301	7
65A 03	6,0	020102	5012	4	02	0102	0301	0402	7
65A 03	6,0	020102	5706	6	02	0102	0502	1402	5
65A 03	6,0	020102	6186	8	02	0102	0502	1402	5
65A 03	6,0	020102	9431	5	0102	0502	1402	1501	5
66A 03	6,0	020202	1045	6	02	0104	0203	0401	5
66A 03	6,0	020202	1173	4	02	0102	0501	1301	3
66A 03	6,0	020202	1237	5	02	0104	0301	0401	4
66A 03	6,0	020202	1417	3	02	0103	0201	0401	7
66A 03	6,0	020202	2122	7	02	0102	0203	0301	6
66A 03	6,0	020202	4414	4	02	0103	0401	0502	6
67A 01	3,0	010202	9980	3	01	0102	0301	1103	5
68A 01	3,0	020202	7054	9	01	0102	1401	1601	3
71A 03	6,0	030102	2993	5	02	0104	0202	0301	4
71A 03	6,0	030102	5070	4	02	0104	0202	1401	5
71A 02	3,0	030102	5753	1	02	0103	0202	0301	4
71A 03	6,0	030102	5753	3	02	0103	1401	1501	4
71B 03	12,0	030102	9991	2	02	0104	0401	1401	4
73A 03	20,0	020103	1776	3	02	0103	0203	0501	4
73A 03	20,0	020103	6120	1	02	0102	0202	0401	7
73A 03	20,0	020103	7763	4	02	0102	0301	0501	7
73B 04	6,0	020103	2342	2	01	0103	0603	1001	5
73B 04	6,0	020103	2773	1	01	0104	0301	0603	6
73B 04	6,0	020103	3742	5	01	0103	0301	0401	7
73C 03	3,5	030103	6940	3	01	0102	0301	1401	4

73C	03	5,5	030103	9406	2	01	0103	0402	1401	1602	4
73C	03	5,5	030103	9978	1	01	0103	0301	0402	1401	1602
74A	03	20,0	020203	1184	4	02	0102	0202	0301	1501	1714
74A	03	20,0	020203	1302	3	02	0103	0203	0301	1722	4
74A	03	20,0	020203	1754	2	02	0103	0203	0301	0502	1401
75C	04	5,0	020101	353	1	01	0104	0203	0301	0401	0601
75C	04	5,0	020101	1448	3	01	0102	0203	0301	0401	0601
75C	04	5,0	020101	1601	4	01	0102	0203	0301	0401	0601
75D	03	5,5	030101	3426	2	01	0102	0401	1401	1601	4
76A	03	20,0	010104	7697	2	02	0101	0301	0402	1602	4
76A	03	20,0	010104	7698	4	02	0101	0403	1403	1602	4
76A	03	20,0	010104	9348	3	02	0101	0403	1403	1501	1602
76B	03	5,5,6	020103	2025	2	01	0104	0302	1103	1601	4
76B	03	5,5,6	020103	6637	5	01	0103	0202	0303	1602	5
76B	03	5,5,6	020103	11154	4	01	0103				1
77A	03	20,0	010204	5510	2	02	0101	0301	0501	1401	1602
77A	03	20,0	010204	5684	1	02	0101	0403	1401	1602	4
77A	03	20,0	010204	6012	4	02	0101	0301	0401	1401	1602
78A	03	12,0	010104	1307	4	02	0104				1
78A	03	12,0	010104	10426	3	02	0103	0401	1401	1602	4
78A	03	12,0	010104	11081	2	02	0103	0402	1401	1502	1602
79A	03	6,0	040403	149	1	02	0103	0301	0402	1302	1401
79A	03	6,0	040403	164	3	02	0102	0402	1302	1402	1501
79A	03	6,0	040403	545	2	02	0103	1403	1501	1601	4
79A	03	6,0	040403	545	4	02	0103	1403	1501	1601	4
82A	01	12,0	020103	7527	2	02	0102	0902	1401	1601	4
82A	01	12,0	020103	10674	5	02	0103	0203	1403	1602	5
82A	01	12,0	020103	10878	1	02	0103	0301	1403	1602	1
83A	01	12,	020203	12822	4	02	0102	0402	1401	1602	4
83A	01	12,	020203	12316	3	02	0102	0403	1401	1602	4
84A	02	20,0	010102	17040	5	02	0102	0402	0601	1401	1602
85A	01	12,0	010104	8888	4	02	0102	0401	1401	1601	4
85A	01	12,0	010104	8947	3	02	0102	0401	1401	1601	4
85A	01	12,0	010104	9710	2	02	0103	0402	1401	1601	4
86A	01	12,0	010204	10661	4	01	0102	0403	1401	1602	4
86A	01	12,0	010204	8948	3	02	0103	0201	0301	0403	1602
86A	01	12,0	010204	10575	5	02	0103	0403	1401	1601	4
87A	03	20,0	030103	164	1	02	0104	0202	0401	1707	4
87A	03	20,0	030103	208	2	02	0104	0203	1301	1727	4
87A	03	20,0	030103	627	3	02	0104	0203	0301	0501	1716
87A	03	20,0	030103	627	4	02	0102	0203	0301	0502	1742
87A	03	20,0	030103	627	5	02	0102	0203	0401	1301	1716
87B	04	5,0	030103	948	2	01	0103	0201	0301	0401	0601
87B	04	5,0	030103	1513	3	01	0103	0301	0401	0601	1401
87B	04	5,0	030103	2302	1	01	0103	0201	0301	0401	0601
87B	04	5,0	030103	2392	4	01	0103	0301	0601	1001	1408
88A	03	20,0	030203	161	1	02	0104	0203	0301	0601	1725
88A	03	21,0	030203	151	2	02	0104	0203	0301	0601	1725
88A	03	20,0	030203	358	3	02	0104	0203	0401	1716	4
88A	03	20,0	030203	358	5	02	0102	1301			2
88D	03	1,25020101	1897	5	02	0104	0203	0701	1401	1502	1703
89B	04	5,0	030101	111	5	01	0103	0401	0601	1001	1401
89B	04	5,0	030101	495	3	01	0104	0201	0301	0401	0601
89B	04	5,0	030101	1530	4	01	0102	0401	0601	1001	4
90A	03	20,0	020104	2824	4	02	0102	0403	1602		3
90A	03	20,0	020104	2824	5	02	0103	0403	1601		3
90A	03	20,0	020104	4045	3	02	0101	1301	1601		3
90B	03	12,0	020104	3060	4	02	0102	0201	1403	1501	1602
90B	03	12,0	020104	3118	3	02	0101	1403	1501	1602	4
90B	03	12,0	020104	5124	5	02	0102	1403	1501	1602	4
90C	03	5,5	020102	16325	5	01	0103	0301	1407	1601	4
91A	03	20,0	020204	2862	4	02	0101	0201	0301	1301	1401
91A	03	20,0	020204	3345	3	02	0101	0401	1401	1602	4
91A	03	20,0	020204	4480	1	02	0101	0301	0402	0501	1403
91A	03	20,0	020204	4480	2	02	0101	0301	0401	0501	1403
92A	04	5,0	020102	5784	5	01	0104	0301	0401	0601	1001
92A	04	5,0	020102	8774	3	01	0103	0201	0301	0401	0601
92A	04	5,0	020102	8774	4	01	0102	0301	0601	1002	1301
93A	01	12,0	040104	349	1	02	0103	0301	1403	1601	4
93A	01	12,0	040104	349	3	02	0103	0301	1401	1601	4
93A	01	12,0	040104	349	4	02	0103	0301	1402	1601	4
93A	01	12,0	040104	349	5	02	0103	0301	1401	1601	4
94A	02	20,0	020202	9110	3	02	0103	0402	0801	1400	1601
95A	01	12,0	030103	4020	4	02	0102	1403			2
95A	01	12,0	030103	3822	3	02	0102	1403			2
95A	01	12,0	030103	4020	2	02	0102	1403			2
96B	03	12,0	030103	6036	4	02	0103	0801	1403	1501	1602
96B	03	12,0	030103	6152	2	02	0101	0201	0401	1501	1602
96B	03	12,0	030103	6152	3	02	0102	0301	0401	1401	1602
96C	03	5,5	020103	2743	1	01	0104	0202	0302	0602	1102
96C	03	5,5	020103	5934	2	01	0104	0202	0303	1101	1401
96C	03	5,5	020103	9791	3	01	0103	0202	0303	1101	1407
97A	01	12,0	030203	3894	2	02	0102	0303	1501	1601	4
97A	01	12,0	030203	3946	3	02	0103	0403	1401	1501	5

97A	01	12,0	010203	5002	4	02	0103	0401	1401	1601	4			
98A	02	20,0	020102	3596	5	02	0102	1401	1601		3			
98A	02	20,0	020102	6019	1	02	0103	0401	0801	1403	1601			
98A	02	20,0	020102	10641	4	02	0103	0401	1401	1602	4			
98B	03	12,0	02050104	6033	5	02	0104	0401	1401	1501	4			
98A	03	12,0	02050102	5513	4	02	0103	0401	1401	1501	4			
98B	03	12,0	02050102	12247	2	02	1003				1			
99A	01	12,0	020104	3841	2	02	0102	1401	1601		3			
99A	01	12,0	020104	3841	3	02	0102	0301	1402		3			
99A	01	12,0	020104	4835	1	02	0102	1401	1601		3			
99B	04	5,0	020104	3216	4	01	0103	0301	0401	0603	1501	1602		
99H	04	5,0	020104	4388	3	01	0101	0301	0601	1001	1101	1401	1601	
99H	04	5,0	020104	4388	5	01	0102	0301	1001	1101	1401		5	
100A	01	12,0	020204	4170	3	02	0101	0403	1501	1602	4			
100A	01	12,0	020204	4358	2	02	0101	0403	1401	1601	4			
100A	01	12,0	020204	4424	1	02	0101	1401	1601		3			
101A	03	12,0	020102	5586	4	02	0104	0203	0401	1401	1501	1601		
101A	03	20,0	010102	3111	2	02	0104	0203	0301	0401	1725	5		
101A	03	20,0	010102	3111	5	02	0104	0203	0301	1720		4		
101A	03	20,0	010102	3629	4	02	0104	0202	0301	0401	0501	1501	1713	
102A	03	20,0	010202	135	2	02	0101	0401	0502			3		
104A	02	20,0	020103	2672	1	02	0102	0402	0901			3		
104A	02	20,0	020103	2826	5	02	0102	0402	0801	0901		4		
104A	02	20,0	020103	2940	2	02	0102	0402	1602			3		
104B	01	5,0	020103	5164	4	03	0101	0201	1407	1602	1702	5		
104B	01	5,0	020103	10463	3	03	0103	0301	0402	1407	1602	5		
104B	01	5,0	020103	13149	1	03	0101	0301	0402	0902	1401	1602		
105A	02	20,0	020203	4306	1	02	0102	0402	1403	1501	1601	5		
105A	02	20,0	020203	5580	3	02	0102	0301	0402	1401	1602	5		
105A	02	20,0	020203	5690	4	02	0102	0402	0603	1401	1601	5		
108A	02	20,0	010204	4273	3	01	0101	0402	0701	0902	1401	1501	1601	
108A	02	20,0	010204	3796	4	02	0102	1403	1601			4		
108A	02	20,0	010204	4003	2	01	0101	0402	1501	1601		4		
112A	02	20,0	010104	5005	1	02	0102	0402	1602			3		
112A	02	20,0	010104	5005	2	02	0102	0402	1602			3		
112A	02	20,0	010104	5213	5	02	0102	0902	1501	1602		4		
113A	01	5,0	010104	4998	1	02	0101	0402	1101	1602		4		
113A	01	5,0	010104	4998	2	02	0101	0402	1101	1602		4		
113A	01	5,0	010104	4998	3	02	0101	0402	1101	1602		4		
113A	01	5,0	010104	4998	4	02	0101	0402	1602			3		
113A	01	5,0	010104	4998	5	02	0101	0402	1602			3		
114A	01	5,0	020104	6059	3	02	0101	0402	1601	1602		4		
114A	01	5,0	020104	6059	5	02	0101	0402	1401	1602		4		
114A	01	5,0	020104	6273	2	02	0101	0402	1407	1502	1602	5		
115A	03	20,0	020102	2107	3	02	0103	0203	0502	1727		4		
115A	03	20,0	020102	2203	2	02	0104	0401	0502	1501		4		
115I	03	20,0	020102	2241	4	02	0104	0401	0502	1502		4		
116A	03	20,0	020202	8274	3	0101	0401	1401	1602		4			
118A	02	20,0	030103	1747	2	02	0102	0402	0901			3		
118A	02	20,0	030103	1963	4	02	0102	0402	0901			3		
118A	02	20,0	030103	2937	5	02	0102	0402	0802			3		
118B	03	5,0	020103	4863	2	02	0101	0201	0602	1103	1401	1601	1702	
118B	03	5,0	020103	7755	4	02	0104	0603	1102	1401	1601	5		
118B	03	5,0	020103	8108	5	02	0104	0301	0603	1102	1401	1601	6	
119A	02	20,0	030203	222	5	02	0102					1		
119A	02	20,0	030203	1793	2	02	0103	0402	1401	1501		4		
119A	02	20,0	030203	1793	3	02	0103	0402	1401	1501		4		
120A	03	5,0	010103	9310	2	02	0104	1401	1602			3		
121A	03	5,0	020102	6694	1	02	0102	1401	1601			3		
121A	03	5,0	020102	10603	4	02	0101	0301	0801	1201		4		
122A	02	20,0	020204	801	2	02	0102	0402	1401	1501	1601	5		
122A	02	20,0	020204	801	3	02	0102	0402	1401	1501	1601	5		
122A	02	20,0	020204	983	5	02	0102	0402	1401	1501		4		
124A	01	12,0	020102	25786	5	0104	0403	1401	1602		2			
124A	01	12,0	020102	13218	3	02	0103	0203	0301	0401	1403	1501	1601	1708
126A	02	20,0	020104	1509	4	02	0102	0402	0901	1501	1601	5		
126A	02	20,0	020104	1569	5	02	0102	0402	0901			3		
126A	02	20,0	020104	1273	3	02	0102	0402	0901			3		
127A	03	5,0	010104	7218	2	02	0104	0902	1401	1602		4		
127A	03	5,0	010104	7649	1	02	0101	0603	1301	1602		4		
127A	03	5,0	010104	10638	4	02	0103	0301	0402	1301	1401	1602	6	
128A	03	5,0	020104	2422	3	02	0101	0602	1301	1401	1602	5		
128A	03	5,0	020104	5688	2	02	0101	0301	1301	1602		4		

***END OF FILE ON UNIT 0002