

PULL C to D

COMPUTED RAB DATE 8-24-85

CHECKED JRB DATE 8-27-85

$$T_{36} \quad \text{Horizontal Straight} \quad T = KLW_c = .42 \times 2.67 \times .73$$

$$= 0.82 \#$$

$$T_{35} \quad \text{Vertical Bend (90°)} \quad T = T_{36} e^{K\theta} = 0.82 e^{.42 \times \pi/2} = .82 \times 1.93$$

$$= 1.58 \#$$

$$T_{34} \quad \text{Down Ramp (78°)} \quad T = W_c L (K \cos \alpha - \sin \alpha) + T_{35}$$

$$= .73 \times \frac{13}{12} (.42 \cos 78^\circ - \sin 78^\circ) + 1.58$$

$$= 0.88 \#$$

$$T_{33} \quad \text{Vertical Bend (12°)} \quad T = T_{34} e^{K\theta} = 0.88 e^{.42 \times .21} = 0.88 \times 1.09$$

$$= 0.96 \#$$

$$T_{32} \quad \text{Vertical Straight (Down)} \quad T = T_{33} - W_c L = 0.96 - .73 \left( 31 + \frac{5.75}{12} \right)$$

$$= -22.02 \#$$

$$T_{31} \quad \text{Vertical Bend (90°)} \quad T = T_{32} e^{K\theta} = -22.02 e^{.42 \times \pi/2} = -42.60 \#$$

Since a negative pulling force is built up, the cable reel will be braked to counteract it. Thus restart calculations @ T<sub>30</sub>.

$$T_{30} \quad \text{Horiz. Straight} \quad T = KLW_c + \cancel{P_1}^0 = .42 \times \left( 10 + \frac{4}{12} \right) \times .73 + 0$$

$$= 3.35 \#$$

$$T_{29} \quad \text{Horizontal Bend (10°)} \quad T = T_{30} e^{K\theta} = 3.35 e^{.42 \times .17} = 3.35 \times 1.08$$

$$= 3.60 \#$$

T<sub>28</sub> Horiz. Straight

$$T = K L W_c + T_{29}$$

$$= .42 \times .5 \times .73 + 3.6$$

$$= 3.75 \#$$

T<sub>27</sub> Horiz. Bend (10°)

$$T = T_{28} e^{Kb} = 3.75 e^{.42 \times .17} = 3.75 \times 1.08$$

$$= 4.04 \#$$

T<sub>26</sub> Horiz. Straight

$$T = K L W_c + T_{27} = .42 \times .6 \times .73 + 4.04$$

$$= 5.88 \#$$

T<sub>25</sub> Vertical Bend (30°)

$$T = T_{26} e^{Kb} = 5.88 e^{.42 \times .52} = 5.88 \times 1.25$$

$$= 7.33 \#$$

T<sub>24</sub> Up Ramp (30°)

$$T = W_c L (\sin \alpha + K \cos \alpha) + T_{25}$$

$$= .73 \times \frac{1}{12} (\sin 30^\circ + .42 \cos 30^\circ) + 7.33$$

$$= 7.90 \#$$

T<sub>23</sub> Vertical Bend (30°)

$$T = T_{24} e^{Kb} = 7.9 e^{.42 \times .52} = 7.9 \times 1.25$$

$$= 9.85$$


T<sub>22</sub> Horiz. Straight

$$T = K L W_c + T_{23} = .42 \times \frac{11.5}{12} \times .73 + 9.85$$

$$= 10.14 \#$$

$$SWP_{c.o} = W_c T / 2R = \frac{1.4 \times 9.85}{2 \times .62}$$

$$SWP_{c.e} = 11.12 \# / \text{ft}$$



KEY PLAN  
 REACTOR BLDG. UNIT 2  
 EL. 716'-0"  
 208°-2-PENT-293-44-A  
 234°-2-JB-293-3204-A

- NOTES:
1. ALL BENDS HAVE RADII AS OF 8" UNLESS OTHERWISE NOTED (1 1/2" I.C. CONDUIT)
  2. TOLERANCES AT SPEC. BY EP-22.29
  3. ALL BENDS NOT SPEC. ARE 90°
  4. CABLE UNITS MANUFACTURE:  
 2V9943A LATEX  
 2V9953A LATEX
  5. REF. DWG. 45WB72-4, 17, 13, B
  6. ALL DIMENSIONS ARE E.T.O. EARLIER 4-1/2" #14 WPA NY3A (ULV CONTROL) OD = .269, .048 O/I

REACTOR BUILDING UNIT-2	
RACEWAY ISOMETRIC DRAWING EL. 716'-0" CONDUIT NO. 2VC-2577	
WATTS BAR NUCLEAR PLANT TVA-DC	
ENGINEER S. J. Jackson	
VERIFICATION M. J. Jones	
APPROVED S. J. Jackson	
DATE 8-22-66	DRAWING NO. NRC-EP-22-29 SAMPLE PROGRAM
OE	QA

BY THE SIGNATURES STAMP  
 IN ACCORDANCE TO "MORSE CASE"  
 CRITERIA.

$K = .3, W_c = 8 \times .048 = .384, W_p = 1.4$   
 $K = W_c K = 1.4 \times .3 = .42$

COMPUTED RHO DATE 8-27-85  
 CHECKED JRB DATE 8-29-85

PULL A to B (0°)

$T_1$  Vertical Straight (Up)  $T = W_c L = .384 \times (15 + \frac{8}{12})$   
 $= 6.02 \#$

There is no Side Wall Pressure calculation need here since there are no bends.

PULL B to C (26°)

$T_2$  Horiz. Straight  
 (Assumed; Actually a flex w/ slight offset)  
 $T = K L W_c = .42 \times 3.0 \times .384$   
 $= .48 \#$

$T_3$  Horiz. Bend (4°)  
 $T = T_2 e^{Kb} = .48 e^{.42 \times .07} = .48 \times 1.03$   
 $= .50 \#$

$T_4$  Horiz. Straight  
 $T = K L W_c + T_3 = .42 \times \frac{16}{12} \times .384 + .50$   
 $= .71 \#$

$T_5$  Horiz. Bend (4°)  
 $T = T_4 e^{Kb} = .71 e^{.42 \times .07} = .71 \times 1.03$   
 $= .73 \#$

$T_6$  Horiz. Straight  
 $T = K L W_c + T_5 = .42 \times (3 + \frac{1}{12}) \times .384 + .73$   
 $= 1.23 \#$

$T_7$  Horiz. Bend (9°)  
 $T = T_6 e^{Kb} = 1.23 e^{.42 \times .16} = 1.23 \times 1.07$   
 $= 1.32 \#$

$T_8$  Horiz. Straight  
 $T = K L W_c + T_7 = .42 \times \frac{16}{12} \times .384 + 1.32$   
 $= 1.53 \#$

$T_9$  Horiz. Bend (9°)  
 $T = T_8 e^{Kb} = 1.53 e^{.42 \times .16} = 1.53 \times 1.07$   
 $= 1.64 \#$



COMPUTED RHD DATE 8-27-85CHECKED JRB DATE 8-29-85

$T_{10}$  Horiz. Straight  
(Flex)

$$T = KLW_e + T_g = .42 \times \left(2 + \frac{4}{12}\right) \times .384 + 1.64$$

$$= 2.01 \#$$

$$SWP_{BC} = X \frac{T_g}{R} = .51 \times \frac{1.64}{.62}$$

$$SWP_{BC} = 1.35 \#/\text{ft}$$

where  $X = .51$  from  
interpolating table of  
values in G-38 (Section 2.1.6)

### PULL C + D (180° → saddle)

$T_{11}$  Horiz. Straight

(Actually, a curved section;  
but radius is so large, it is  
negligible.)

$$T = KLW_e = .42 \times \left(6 + \frac{5}{14}\right) \times .384$$

$$= 1.03 \#$$

$T_{12}$  Horiz. Round (180° saddle)

$$T = T_{11} e^{Kb} = 1.03 e^{.42 \times \pi} = 1.03 \times 3.74$$

$$= 3.87 \#$$

$T_{13}$  Horiz. Straight

$$T = KLW_e + T_{12} = .42 \times \left(2 + \frac{9}{12}\right) \times .384 + 3.87$$

$$= 4.32 \#$$

$$SWP_{CD} = X \frac{T_{12}}{R} = .51 \times \frac{3.87}{.62}$$

$$SWP_{CD} = 3.18 \#/\text{ft}$$

PULL D to E (0°)

Negligible pull, due to short run w/ no bends.

PULL E to F (6°)

Negligible pull, due to short (vertical rise) w/ two 3° bends.

PULL F to G [195° (includes 180° saddle)]

$$T_{20} \quad \text{Horiz. Straight} \quad T = K L W_e = .42 \times 1.25 \times .384 = .20 \#$$

$$T_{21} \quad \text{Horiz. Bend (180° Saddle)} \quad T = T_{20} e^{Kb} = .2 e^{.42\pi} = .2 \times 3.74 = .75 \#$$

$$T_{22} \quad \text{Horiz. Straight} \quad T = K L W_e + T_{21} = .42 \times 9.25 \times .384 + .75 = 2.25 \#$$

$$T_{23} \quad \text{Vertical Bend (15°)} \quad T = T_{22} e^{Kb} = 2.25 e^{.42 \times .26} = 2.25 \times 1.12 = 2.51 \#$$

$$T_{24} \quad \text{Up Ramp (15°)} \quad T = L W_e (\sin \alpha + K \cos \alpha) + T_{23} = 1 \times .384 (\sin 15^\circ + .42 \cos 15^\circ) + 2.51 = 2.76 \#$$

$$SWP_{FG} = X \frac{T_{23}}{R} = .51 \times \frac{2.51}{.62}$$

$$SWP_{FG} = 2.06 \quad \#/\text{ft}$$

PULL G to H (0°)

COMPUTED RHB DATE 8-27-85

CHECKED JRB DATE 8-29-85

Negligible, due to short, straight run.

PULL I to H (332°)

$$T_{40} \text{ Vertical Straight (up)} \quad T = LW_e = 3 \times .384 \\ = 1.15 \#$$

$$T_{39} \text{ Vertical Bend (90°)} \quad T = T_{40} e^{kb} = 1.15 e^{.21\pi} = 1.15 \times 1.93 \\ = 2.23 \#$$

$$T_{38} \text{ Horiz. Straight} \quad T = \frac{K}{L} LW_e + T_{37} = .42 \times (2 + \frac{8}{12}) \times .384 + 2.23 \\ = 2.66 \#$$

$$T_{37} \text{ Vertical Bend (30°)} \quad T = T_{38} e^{kb} = 2.66 e^{.42 \times \frac{\pi}{6}} = 2.66 \times 1.25 \\ = 3.31 \#$$

$$T_{36} \text{ Up Ramp (30°)} \quad T = LW_e (\sin \alpha + K \cos \alpha) + T_{37} \\ = (1 + \frac{10}{12}) \times .384 (\sin 30^\circ + .42 \cos 30^\circ) + 3.31 \\ = 3.92 \#$$

$$T_{35} \text{ Vertical Bend (30°)} \quad T = T_{36} e^{kb} = 3.92 e^{.07\pi} = 3.92 \times 1.25 \\ = 4.88 \#$$

$$T_{34} \text{ Horiz. Straight} \quad T = \frac{K}{L} LW_e + T_{35} = .42 \times 3.75 \times .384 + 4.88 \\ = 5.49 \#$$

$$T_{33} \text{ Vertical Bend (30°)} \quad T = T_{34} e^{kb} = 5.49 e^{.07\pi} = 5.49 \times 1.25 \\ = 6.84 \#$$

$$T_{32} \text{ Down Ramp (30°)} \quad T = LW_e (K \cos \alpha - \sin \alpha) + T_{33} \\ = 3 \times .384 (.42 \cos 30^\circ - \sin 30^\circ) + 6.84 \\ = 6.68 \#$$

$$T_{31} \text{ Vertical Bend (30°)} \quad T = T_{32} e^{kb} = 6.68 e^{.07\pi} = 6.68 \times 1.25 \\ = 8.33 \#$$

$T_{30}$  Horiz. Straight  $T = \frac{K}{L} W_e + T_{31} = .42 \times \frac{17.5}{12} \times .384 + 8.33$   
 $= 8.56 \#$

$T_{29}$  Horiz. Bend (90°)  $T = T_{30} e^{Kb} = 8.56 e^{.42 \times 17.5} = 8.56 \times 1.93$   
 $= 16.56 \#$

$T_{28}$  Horiz. Straight  $T = \frac{K}{L} W_e + T_{29} = .42 \times 4.25 \times .384 + 16.56$   
 $= 17.25 \#$

$T_{27}$  Vertical Bend (32°)  $T = T_{28} e^{Kb} = 17.25 e^{.42 \times 5.6} = 17.25 \times 1.26$   
 $= 21.80 \#$

$T_{26}$  Up Ramp (32°)  $T = L W_e (\sin \alpha + K \cos \alpha) + T_{27}$   
 $= \frac{13}{12} \times .384 (\sin 32^\circ + .42 \cos 32^\circ) + 21.8$   
 $= 22.17 \#$

$$SWP_{IH} = X \frac{T_{27}}{R} = .51 \times \frac{21.8}{.62}$$

$$SWP_{IH} = 17.93 \#/\text{ft}$$

Worst Case!

PULL 2-PENT-293-44-A to I

Negligible due to short vertical run of flex conduit.

PULL'S H to I, G to F, D to C, C to B, B to A

These are insignificant compared to the runs already calculated, due to more downward lengths.

# ATTACHMENT 7.3

WATTS BAR NUCLEAR PLANT  
ELECTRICAL CABLE DATA

7/30/84

The following data on cable size and weight was compiled as a guide for design consideration in determining conduit and cable tray loading. Exact size and weight should be obtained from manufacturer's test data. Size and weight will vary even from the same manufacturer.

\*Do not use unless specifically instructed to do so by the supervising engineer.

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WBM	#14 S/C 600V THHN BLACK	.125	.0123	NC	75	
WBN	#12 S/C 600V THHN WHITE	.12	.0145	NC	75	24
WBN-1	#12 S/C 600V THHN BLACK	.12	.0145	NC	75	24
WBN-2	#12 S/C 600V THHN	.12	.0145	NC	75	24
WBN-3	#12 S/C 600V THHN		.0145			24
	#10 S/C 600V THHN WHITE	.10	.0200	NC		
	#10 S/C 600V THHN BLACK	.10	.0200			
	#10 S/C 600V THHN BLUE	.10	.0200	NC	75	
			.0200			
			.0200			96
			.0200			154
			.0200			236
	#10 S/C 600V THHN BLACK					24
	#12 S/C 600V THHN WHITE					24
	#12 S/C 600V THHN BLACK					24

\*Cable availability from J.V. Perry...

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WBW-2	#12 S/C 600V XHHW RED	.12	.0145	NC	75	24
WBW-3	#12 S/C 600V XHHW BLUE	.12	.0145	NC	75	24
WBW-4	#10 S/C 600V XHHW WHITE	.15	.0227	NC	75	37
WBW-5	#10 S/C 600V XHHW BLACK	.15	.0227	NC	75	37
WBW-6	#10 S/C 600V XHHW RED	.15	.0227	NC	75	37
WBW-7	#10 S/C 600V XHHW BLUE	.15	.0227	NC	75	37
WDA	#10 S/C 600V CPJ WHITE	.214	.036	NC	90	54
WDA-1	#10 S/C 600V PXJ WHITE	.214	.036	IE	90	54
WDB	#10 S/C 600V CPJ BLACK	.223	.039	NC	90	54
WDB-1	#10 S/C 600V PXJ BLACK	.223	.039	IE	90	54
WDC	#10 S/C 600V CPJ RED	.217	.0366	NC	90	54
WDC-1	#10 S/C 600V PXJ RED	.217	.0366	IE	90	54
WDC-2	#10 S/C 600V PXJ BLUE	.217	.0366	IE	90	54
WDC-3	#10 S/C 600V PXJ BLUE	.217	.0366	IE	90	54
WDD-1	#8 S/C 600V PXJ	.173	.028	IE	90	83
WDE-1	#6 S/C 600V PXJ	.137	.018	IE	90	115
WDE-2	#4 S/C 600V PXJ	.101	.008	IE	90	170
WDF-1	#2 S/C 600V CPJ	.072	.004	IE	90	180
WDF-2	#2 S/C 600V PXJ	.072	.004	IE	90	256
WDH	#1/0 S/C 600V	.60	.37	IE	90	256
						401





<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WFA-3	#6 AWG 3/C 600V PXMJ	1.000	.786	IE	90	500
WFA-4	#8 AWG 3/C 600V PXMJ	.868	.592	IE	90	419
WFA-15	#6 AWG 3/C 600V PXMJ LOCA	1.000	.786	IE	90	500
WFB	#10 AWG 2/C 600V PJJ	.397	.124	IE	75	156
WFB-1	#10 AWG 2/C 600V PXMJ	.397	.124	IE	90	156
WFC	#10 AWG 3/C 600V PJJ	.487	.186	IE	75	236
WFC-1	#10 AWG 3/C 600V PXMJ	.487	.186	IE	90	236
WFD	#10 AWG 4/C 600V PJJ	.562	.248	IE	75	265
WFD-1	#10 AWG 4/C 600V PXMJ	.610	.292	IE	90	265
WFE	#10 AWG 5/C 600V PJJ	.620	.302	IE	75	312
WFE-1	#10 AWG 5/C 600V PXMJ	.675	.356		90	312
WFG	#10 AWG 7/C 600V PJJ	.670			75	420
WFG-1	#10 AWG 7/C 600V PXMJ	.670	.356	IE	90	420
WPH	#10 AWG 9/C 600V PJJ	.820	.538	IE	75	526
WPH-1	#10 AWG 9/C 600V PXMJ	.820	.538	IE	90	526
WPL	#10 AWG 12/C 600V PJJ	.916	.654	IE	75	691
WPL-1	#10 AWG 12/C 600V PXMJ	.916	.654	IE	90	691
WPP	#12 AWG 2/C 600V PJJ	.397	.124	IE	75	100
WPP-1	#12 AWG 2/C 600V PXMJ	.397	.124	IE	90	100
WPC	#12 AWG 3/C 600V PJJ	.475	.147	IE	75	140
WPC-1	#12 AWG 3/C 600V PXMJ	.475	.147	IE	90	140
WPD	#12 AWG 4/C 600V PJJ	.475	.147	IE	75	180
WPD-1	#12 AWG 4/C 600V PXMJ	.475	.147	IE	90	180
WPE	#12 AWG 5/C 600V PJJ	.562	.177	IE	75	240
WPE-1	#12 AWG 5/C 600V PXMJ	.562	.177	IE	90	240

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WGE-1	#12 AWG 5/C 600V FXMJ	.610	.292	IE	90	240
*WGG	#12 AWG 7/C 600V PJJ	.598	.281	IE	75	295
WGG-1	#12 AWG 7/C 600V FXMJ	.598	.281	IE	90	295
*WGH	#12 AWG 9/C 600V PJJ	.694	.378	IE	75	374
WGH-1	#12 AWG 9/C 600V FXMJ	.762	.456	IE	90	374
*WGX	#12 AWG 12/C 600V PJJ	.779	.476	IE	75	450
WGX-1	#12 AWG 12/C 600V FXMJ	.830	.541	IE	90	450
*WGM	#12 AWG 16/C 600V PJJ	.912	.653	IE	75	640
WGM-1	#12 AWG 16/C 600V FXMJ	.980	.528	IE	90	640
*WGN	#12 AWG 19/C 600V PJJ	.956	.718	IE	75	715
WGN-1	#12 AWG 19/C 600V FXMJ	1.03	.833	IE	90	715
WHA-1	#14 AWG 3/C 600V PJJ	.309	.152	IE	90	70
WHA-2	#14 AWG 3/C 600V FXMJ	.401	.170	IE	90	110
WHD-1	#14 AWG 4/C 600V FXMJ	.431	.181	IE	90	132
WHD-2	#14 AWG 4/C 600V PJJ	.471	.192	IE	75	165
WHE-1	#14 AWG 5/C 600V PJJ	.501	.199	IE	90	165
WHE-2	#14 AWG 5/C 600V FXMJ	.501	.199	IE	90	165
WHG	#14 AWG 7/C 600V PJJ	.510	.201	IE	75	195
WHG-1	#14 AWG 7/C 600V FXMJ	.510	.201	IE	90	195
WHG-2	#14 AWG 7/C 600V PJJ	.510	.201	IE	75	195
WHI	#14 AWG 9/C 600V PJJ	.610	.301	IE	75	253

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WHD-1	#14 AWG 9/C 600V PXMJ	.624	.306	IE	90	253
*WHL	#14 AWG 12/C 600V PJJ	.694	.378	IE	75	336
WHJ-1	#14 AWG 12/C 600V PXMJ	.795	.496	IE	90	336
WHJ-2	#14 AWG 12/C 600V PXMJ LOCA	.694	.378	IE	90	336
*WHL	#14 AWG 16/C 600V PJJ	.720	.407	IE	75	425
WHL-1	#14 AWG 16/C 600V PXMJ	1.125	1.000	IE	90	500
*WHM	#14 AWG 19/C 600V PJJ	.820	.528	IE	75	507
WHM-1	#14 AWG 19/C 600V PXMJ	.930	.679	IE	90	507
*WHS	#16 AWG 3/C 600V PJJ	.360	.102	IE	75	80
WHS-1	#16 AWG 3/C 600V PXMJ	.425	.142	IE	90	60
WHD	#18 AWG 1/C 600V SIS	.210	.010	IE	90	11
WHL	#18 AWG 1/C 600V SIS	.220	.011	IE	90	15
WHJ	#16 AWG 1/C 600V SIS	.180	.013	IE	150	16
WHK	#14 AWG 1/C 600V SIS	.140	.016	IE	90	20
WHL	#12 AWG 1/C 600V SIS	.100	.018	IE	150	25
WHM	#12 AWG 1/C 600V SIS	.160	.020	IE	90	28
WHN	#10 AWG 1/C 600V SIS	.120	.022	IE	150	30
WHJ	#10 AWG 1/C 600V SIS	.180	.024	IE	90	42
WHI-1	#10 AWG 1/C 600V TEFZEL	.200	.024	IE	150	50
WHK	#8 AWG 1/C 600V SIS	.260	.052	IE	90	70
WHK-1	#8 AWG 1/C 600V TEFZEL	.270	.0572	IE	150	80
WHN	#16 AWG 1/C 600V TEFLON	.127	.013	IE	200	11
WHN-1	#16 AWG 1/C 600V TEFLON GREEN	.127	.013	IE	200	11
WJP	#20 AWG 1/C 600V TEFLON	.058	.003	IE	200	6

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WJQ	#2 AWG 1/C 600V SIS	.51	.204	IE	90	240
WLB	#12 AWG 2/C 600V CPJJ	.454	.162	IE	90	150
WLC	#12 AWG 3/C 600V CPJJ	.557	.244	IE	90	205
WLC	#12 AWG 7/C 600V CPJJ	.765	.460	IE	90	405
WLH	#12 AWG 9/C 600V CPJJ	.892	.625	IE	90	595
WLJ	#12 AWG 12/C 600V CPJJ	1.05	.866	IE	90	660
WLK	#12 AWG 19/C 600V CPJJ	1.22	1.169	IE	90	1010
WLN	#10 AWG 2/C 600V CPJJ	.492	.190	IE	90	200
WLO	#10 AWG 3/C 600V CPJJ	.647	.327	IE	90	265
WLP	#10 AWG 4/C 600V CPJJ	.71	.396	IE	90	350
WLS	#10 AWG 7/C 600V CPJJ	.81	.502	IE	90	532
W	#10 AWG 2/C 600V CPJJ	.492	.190	IE	90	200
W	#10 AWG 3/C 600V CPJJ	.647	.327	IE	90	265
W	#10 AWG 4/C 600V CPJJ	.71	.396	IE	90	350
W	#10 AWG 7/C 600V CPJJ	.81	.502	IE	90	532
W	#2/0 AWG 1/C 8KV EPSJ	1.11	.980	IE	90	710
W	#2/0 AWG 1/C 8KV EPSJ	1.11	.980	IE	90	710
W	#4/0 AWG 1/C 8KV CPSJ	1.21	1.155	IE	90	1070
W	#4/0 AWG 1/C 8KV EPSJ	1.21	1.155	IE	90	1070
W	#300 NCM 1/C 8KV CPSJ	1.29	1.310	IE	90	1325
W	#300 NCM 1/C 8KV EPSJ	1.29	1.310	IE	90	1325
W	#400 NCM 1/C 8KV CPSJ	1.33	1.400	IE	90	1685

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C - TEMP</u>	<u>LBS PER 1000 FT</u>
WNE-1	#400 MCM 1/C 8KV EPSJ	1.335	1.400	IE	90	1685
WNF	#500 MCM 1/C 8KV CPSJ	1.439	1.626	IE	90	2030
WNF-1	#500 MCM 1/C 8KV EPSJ	1.439	1.626	IE	90	2030
WNG	#750 MCM 1/C 8KV CPSJ	1.534	1.848	IE	90	2920
WNG-1	#750 MCM 1/C 8KV EPSJ	1.534	1.848	IE	90	2920
WNL	#6 AWG 3/C 8KV EPSJ	1.95	2.985	IE	90	1000
WPA	#14 AWG 1/C 600V SROAJ LOCA	.269	.0572	IE	90	48
WBP	#12 AWG 1/C 600V SROAJ LOCA	.290	.0663	IE	125	60
WPC	#10 AWG 1/C 600V SROAJ LOCA	.313	.077	IE	125	80
WPD	#8 AWG 1/C 600V SROAJ LOCA	.391	.120	IE	125	120
WPE	#6 AWG 1/C 600V SROAJ LOCA	.431	.146	IE	125	170
WPF	#4 AWG 1/C 600V SROAJ LOCA	.480	.185	IE	200	170
WPG	#2 AWG 1/C 600V SROAJ LOCA	.500	.215	IE	200	250
WPH	#1 AWG 1/C 600V SROAJ LOCA	.500	.215	IE	200	350
WPI	#270 AWG 1/C 600V SROAJ LOCA	.700	.337	IE	125	550
WPK	#270 AWG 1/C 600V SROAJ LOCA	.700	.337	IE	125	700
WPL	#140 MCM 1/C 600V SROAJ LOCA	.932	.902	IE	125	1360
WPM	#12 AWG 3/C 600V SROJJ LOCA	.525	.216	IE	125	171
WPN	#12 AWG 7/C 600V SROJJ LOCA	.691	.375	IE	125	400
WPO	#10 AWG 3/C 600V SROJJ LOCA	.580	.264	IE	125	233
WPP	#8 AWG 4/C 600V SROJJ LOCA	.858	.578	IE	125	350
WPR	(2)#8 AWG (4) AWG 600V SROJJH	.800	.503	IE	200	400
WPS	#4 AWG 2/C 600V SROJJ LOCA	.915	.658	IE	125	460

LCPE



<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WST	#6 AWG 4/C TYPE SO	1.000	.785	NC	75	500
WTA	#19 AWG 50PR W/SHIELD	1.140	1.020	NC	90	660
WTB	#19 AWG 25PR W/SHIELD	.881	.610	NC	90	364
WTC	#19 AWG 18PR W/SHIELD	.759	.452	NC	90	284
WTD	#19 AWG 12PR W/SHIELD	.638	.320	NC	90	212
WTE	#19 AWG 6PR W/SHIELD	.540	.229	NC	90	135
WTF	#22 AWG 50PR W/SHIELD	.950	.441	NC	90	365
WTF-1	#22 AWG 2PR W/SHIELD	.404	.128	NC	90	
WTF-2	#22 AWG 3PR W/SHIELD	.400	.126	NC	90	
WTF-3	#22 AWG 6PR W/SHIELD	.520	.217	NC	90	95
WTF-4	#22 AWG 12PR W/SHIELD	.555	.245	NC	90	
WTF-5	#22 AWG 25PR W/SHIELD	.638	.320	NC	90	212
WTF-6	#22 AWG 50PR W/SHIELD	.950	.441	NC	90	365
WTF-7	#22 AWG 100PR W/SHIELD	1.140	1.020	NC	90	660
WTF-8	#22 AWG 150PR W/SHIELD	1.340	1.200	NC	90	750
WTF-9	#22 AWG 200PR W/SHIELD	1.540	1.380	NC	90	840
WTF-10	#22 AWG 250PR W/SHIELD	1.740	1.560	NC	90	930
WTF-11	#22 AWG 300PR W/SHIELD	1.940	1.740	NC	90	1020
WTF-12	#22 AWG 350PR W/SHIELD	2.140	1.920	NC	90	1110
WTF-13	#22 AWG 400PR W/SHIELD	2.340	2.100	NC	90	1200
WTF-14	#22 AWG 450PR W/SHIELD	2.540	2.280	NC	90	1290
WTF-15	#22 AWG 500PR W/SHIELD	2.740	2.460	NC	90	1380
WTF-16	#22 AWG 550PR W/SHIELD	2.940	2.640	NC	90	1470
WTF-17	#22 AWG 600PR W/SHIELD	3.140	2.820	NC	90	1560
WTF-18	#22 AWG 650PR W/SHIELD	3.340	3.000	NC	90	1650
WTF-19	#22 AWG 700PR W/SHIELD	3.540	3.180	NC	90	1740
WTF-20	#22 AWG 750PR W/SHIELD	3.740	3.360	NC	90	1830
WTF-21	#22 AWG 800PR W/SHIELD	3.940	3.540	NC	90	1920
WTF-22	#22 AWG 850PR W/SHIELD	4.140	3.720	NC	90	2010
WTF-23	#22 AWG 900PR W/SHIELD	4.340	3.900	NC	90	2100
WTF-24	#22 AWG 950PR W/SHIELD	4.540	4.080	NC	90	2190
WTF-25	#22 AWG 1000PR W/SHIELD	4.740	4.260	NC	90	2280
WTF-26	#22 AWG 1050PR W/SHIELD	4.940	4.440	NC	90	2370
WTF-27	#22 AWG 1100PR W/SHIELD	5.140	4.620	NC	90	2460
WTF-28	#22 AWG 1150PR W/SHIELD	5.340	4.800	NC	90	2550
WTF-29	#22 AWG 1200PR W/SHIELD	5.540	4.980	NC	90	2640
WTF-30	#22 AWG 1250PR W/SHIELD	5.740	5.160	NC	90	2730
WTF-31	#22 AWG 1300PR W/SHIELD	5.940	5.340	NC	90	2820
WTF-32	#22 AWG 1350PR W/SHIELD	6.140	5.520	NC	90	2910
WTF-33	#22 AWG 1400PR W/SHIELD	6.340	5.700	NC	90	3000
WTF-34	#22 AWG 1450PR W/SHIELD	6.540	5.880	NC	90	3090
WTF-35	#22 AWG 1500PR W/SHIELD	6.740	6.060	NC	90	3180
WTF-36	#22 AWG 1550PR W/SHIELD	6.940	6.240	NC	90	3270
WTF-37	#22 AWG 1600PR W/SHIELD	7.140	6.420	NC	90	3360
WTF-38	#22 AWG 1650PR W/SHIELD	7.340	6.600	NC	90	3450
WTF-39	#22 AWG 1700PR W/SHIELD	7.540	6.780	NC	90	3540
WTF-40	#22 AWG 1750PR W/SHIELD	7.740	6.960	NC	90	3630
WTF-41	#22 AWG 1800PR W/SHIELD	7.940	7.140	NC	90	3720
WTF-42	#22 AWG 1850PR W/SHIELD	8.140	7.320	NC	90	3810
WTF-43	#22 AWG 1900PR W/SHIELD	8.340	7.500	NC	90	3900
WTF-44	#22 AWG 1950PR W/SHIELD	8.540	7.680	NC	90	3990
WTF-45	#22 AWG 2000PR W/SHIELD	8.740	7.860	NC	90	4080
WTF-46	#22 AWG 2050PR W/SHIELD	8.940	8.040	NC	90	4170
WTF-47	#22 AWG 2100PR W/SHIELD	9.140	8.220	NC	90	4260
WTF-48	#22 AWG 2150PR W/SHIELD	9.340	8.400	NC	90	4350
WTF-49	#22 AWG 2200PR W/SHIELD	9.540	8.580	NC	90	4440
WTF-50	#22 AWG 2250PR W/SHIELD	9.740	8.760	NC	90	4530
WTF-51	#22 AWG 2300PR W/SHIELD	9.940	8.940	NC	90	4620
WTF-52	#22 AWG 2350PR W/SHIELD	10.140	9.120	NC	90	4710
WTF-53	#22 AWG 2400PR W/SHIELD	10.340	9.300	NC	90	4800
WTF-54	#22 AWG 2450PR W/SHIELD	10.540	9.480	NC	90	4890
WTF-55	#22 AWG 2500PR W/SHIELD	10.740	9.660	NC	90	4980
WTF-56	#22 AWG 2550PR W/SHIELD	10.940	9.840	NC	90	5070
WTF-57	#22 AWG 2600PR W/SHIELD	11.140	10.020	NC	90	5160
WTF-58	#22 AWG 2650PR W/SHIELD	11.340	10.200	NC	90	5250
WTF-59	#22 AWG 2700PR W/SHIELD	11.540	10.380	NC	90	5340
WTF-60	#22 AWG 2750PR W/SHIELD	11.740	10.560	NC	90	5430
WTF-61	#22 AWG 2800PR W/SHIELD	11.940	10.740	NC	90	5520
WTF-62	#22 AWG 2850PR W/SHIELD	12.140	10.920	NC	90	5610
WTF-63	#22 AWG 2900PR W/SHIELD	12.340	11.100	NC	90	5700
WTF-64	#22 AWG 2950PR W/SHIELD	12.540	11.280	NC	90	5790
WTF-65	#22 AWG 3000PR W/SHIELD	12.740	11.460	NC	90	5880
WTF-66	#22 AWG 3050PR W/SHIELD	12.940	11.640	NC	90	5970
WTF-67	#22 AWG 3100PR W/SHIELD	13.140	11.820	NC	90	6060
WTF-68	#22 AWG 3150PR W/SHIELD	13.340	12.000	NC	90	6150
WTF-69	#22 AWG 3200PR W/SHIELD	13.540	12.180	NC	90	6240
WTF-70	#22 AWG 3250PR W/SHIELD	13.740	12.360	NC	90	6330
WTF-71	#22 AWG 3300PR W/SHIELD	13.940	12.540	NC	90	6420
WTF-72	#22 AWG 3350PR W/SHIELD	14.140	12.720	NC	90	6510
WTF-73	#22 AWG 3400PR W/SHIELD	14.340	12.900	NC	90	6600
WTF-74	#22 AWG 3450PR W/SHIELD	14.540	13.080	NC	90	6690
WTF-75	#22 AWG 3500PR W/SHIELD	14.740	13.260	NC	90	6780
WTF-76	#22 AWG 3550PR W/SHIELD	14.940	13.440	NC	90	6870
WTF-77	#22 AWG 3600PR W/SHIELD	15.140	13.620	NC	90	6960
WTF-78	#22 AWG 3650PR W/SHIELD	15.340	13.800	NC	90	7050
WTF-79	#22 AWG 3700PR W/SHIELD	15.540	13.980	NC	90	7140
WTF-80	#22 AWG 3750PR W/SHIELD	15.740	14.160	NC	90	7230
WTF-81	#22 AWG 3800PR W/SHIELD	15.940	14.340	NC	90	7320
WTF-82	#22 AWG 3850PR W/SHIELD	16.140	14.520	NC	90	7410
WTF-83	#22 AWG 3900PR W/SHIELD	16.340	14.700	NC	90	7500
WTF-84	#22 AWG 3950PR W/SHIELD	16.540	14.880	NC	90	7590
WTF-85	#22 AWG 4000PR W/SHIELD	16.740	15.060	NC	90	7680
WTF-86	#22 AWG 4050PR W/SHIELD	16.940	15.240	NC	90	7770
WTF-87	#22 AWG 4100PR W/SHIELD	17.140	15.420	NC	90	7860
WTF-88	#22 AWG 4150PR W/SHIELD	17.340	15.600	NC	90	7950
WTF-89	#22 AWG 4200PR W/SHIELD	17.540	15.780	NC	90	8040
WTF-90	#22 AWG 4250PR W/SHIELD	17.740	15.960	NC	90	8130
WTF-91	#22 AWG 4300PR W/SHIELD	17.940	16.140	NC	90	8220
WTF-92	#22 AWG 4350PR W/SHIELD	18.140	16.320	NC	90	8310
WTF-93	#22 AWG 4400PR W/SHIELD	18.340	16.500	NC	90	8400
WTF-94	#22 AWG 4450PR W/SHIELD	18.540	16.680	NC	90	8490
WTF-95	#22 AWG 4500PR W/SHIELD	18.740	16.860	NC	90	8580
WTF-96	#22 AWG 4550PR W/SHIELD	18.940	17.040	NC	90	8670
WTF-97	#22 AWG 4600PR W/SHIELD	19.140	17.220	NC	90	8760
WTF-98	#22 AWG 4650PR W/SHIELD	19.340	17.400	NC	90	8850
WTF-99	#22 AWG 4700PR W/SHIELD	19.540	17.580	NC	90	8940
WTF-100	#22 AWG 4750PR W/SHIELD	19.740	17.760	NC	90	9030

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WTI-3	Ø22 AWG 2PR	.210	.0346	NC	75	
WTJ-2	Ø5 1/2" HELIAX 50 OHMS	.560	.246	NC	80	160
WTJ-3	Ø7 1/2" HELIAX SUPERFLEXIBLE 50 OHMS	.500	.497	NC	80	140
WTJ-4	Ø5 7/8" HELIAX 50 OHMS	.875	.601	NC	80	
WTJ-6	Ø14 1/4" HELIAX 50 OHMS	.250	.049	NC	80	
WTJ-7	Ø18 COAX RG 6/U	.272		NC		
WTK	Ø22 COAX RG59B/U	.246	.048	IE	80	50
WTK-3	Ø22 COAX RG59/U	.178	.025	NC	80	32
WTK-6	Ø22 COAX RG59B/U	.246	.048	NC	80	50
WTL-1	Ø18 COAX RG-11A/U	.405	.129	NC	80	96
WTL-2	Ø18 COAX RG-11/U	.405	.129	NC	80	96
WTL-4	Ø22 COAX RG58/U	.125	.0123	IE	80	96
WTM-1	Ø12 COAX RG 6/U	.412	.133	NC	80	
WTM-5	Ø18 AWG TWISTED PR	.210	.077		90	65
WTC	Ø18 AWG TWISTED PR W/SHIELD	.29	.060	NC	90	70
WTG	Ø16 AWG TWISTED PR	.25	.040	NC	90	72
WTG-6	Ø16 AWG TWISTED PR W/SHIELD	.23	.0434	NC	90	75
WTO-6	Ø16 AWG 2/C	.210	.0240	NC	90	
WTO-7	Ø18 AWG 2/C W/SHIELD	.195	.0299	NC	90	
WTQ	Ø24 AWG 100PR	1.024	.817	NC	75	440
WT	Ø14 AWG COAX RG34A/U	.638	.32	NC	80	274
TU	Ø20 AWG TRIAX RG11/U	.476	.178	IE	110	165
MTX	Ø12 AWG COAX RG6/U	.419	.138	NC	80	110
TY	Ø22 AWG COAX RG62/U	.250	.049	NC	80	40
TY-1	Ø21 AWG COAX RG58C/U	.195	.030	IE	90	

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS. PER 1000 FT</u>
WTY-3	#18 AWG COAX RG141/U TEFLON	.195	.030	NC	200	
WTY-4	#20 AWG COAX RG58/U	.200	.031	NC	80	27
WUB-1	T-C COPPER CONST #16 W/SHIELD	.339	.090 .909	NC	90	80
WUB-2	T-C COPPER CONST #16 W/SHIELD TEFLON	.223	.039	NC	200	75
WUP-1	T-C IRON CONST #16 W/SHIELD TEFZEL	.223	.039	NC	150	
WUP-3	T-C COPPER - CONST #16 W/SHIELD TEFZEL-180		.025	IE	90	80
WUY	T-C CHROMEL ALUMEL #20 W/SHIELD	.151	.018	NC	150 90	60
WVA	#16 AWG 2/C, SHIELD SIGNAL LOCA	.387	.118	IE	90	75
WVA-1	#18 AWG 2/C, SHIELD SIGNAL LOCA	.339	.090	IE	90	58
WVA-3	#18 AWG 2/C, SHIELD TEFLON LOCA	.199	.030	IE	90	60
	#16 AWG 3/C, SHIELD LOCA	.350	.110	IE	90	80
	#18 AWG 4/C, SHIELD LOCA	.300	.120	IE	90	100
	#20 AWG 4/C, SHIELD LOCA	.320	.080	IE	90	
	#16 AWG 7/C, SHIELD LOCA	.440	.130	IE	90	120
WVB	#16 AWG 7/C, SHIELD LOCA	.530	.220	IE	90	170
WVT	#16 AWG 9/C, SHIELD LOCA	.560	.240	IE	90	220
WVJ	#16 AWG 12/C, SHIELD LOCA	.630	.320	IE	90	270
WVK	#16 AWG 19/C, SHIELD LOCA	.750	.440	IE	90	430
WVL	#16 AWG 27/C, SHIELD LOCA	.920	.660	IE	90	580
WVJ	#16 AWG 37/C, SHIELD LOCA	1.000	.780	IE	90	740
WVK	#16 AWG 2/C LOCA	.350	.090	IE	90	60
WVL	#12 AWG 2/C, SHIELD LOCA	.400	.120	IE	90	95

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
WWK	(1 PR) #22 (1 PR) #20 (2) #27 COAX	.501	.197	IE	150	170
WWL	#16 AWG 3PR, SHIELD	.600	.283	NC	80	186
WWM	#16 AWG 9PR, SHIELD	.901	.637	NC	80	430
WWN-1	#22 AWG 6PR, SHIELD (823265)	.67	.353	NC	90	190
WWN-1	#22 AWG 6PR, SHIELD	.43	.145	NC	90	95
WWN-2	#22 AWG 6PR (823265)	.65	.332	NC	90	190
WWN-2	#22 AWG 6PR	.42	.138	NC	90	93
WWN-3	#22 AWG 12 SHLD PR	1.10	.950	NC	90	
WWN-4	#16 3 SHLD PR 600V, S/C 1000V TEFZEL	.470	.173	IE	150	
WWN-5	#16 3 SHLD PR 600V, S/C 1000V TEFLON	.470	.173	NC	200	
WZZ-4	#16 AWG SHLD PR	.870	.595	IE	90	
WZZ-1	#16 AWG 3 SHLD PR LOCAL	.430	.149	IE	90	
WZZ	#16 AWG SHLD PR	.500	.197	IE	90	
WAZ	#10 AWG TR GREEN, 1/0	.167	.077	NC	60	26
WXR	#8 AWG TR GREEN, 1/0	.228	.041	NC	60	42
XFB	1000 MCM BARE COPPER	1.152	1.042	NC	N/A	3088
XFC	500 MCM BARE COPPER	.831	.542	NC	N/A	1544
XFD	4/0 AWG BARE COPPER	.528	.219	NC	N/A	653
XFE	2/0 AWG BARE COPPER	.419	.138	NC	N/A	411
XFF	1/0 AWG BARE COPPER	.373	.109	NC	N/A	326
XFG	#2 AWG BARE COPPER	.292	.067	NC	N/A	205

<u>Mark No.</u>	<u>Description</u>	<u>OD</u>	<u>CSA</u>	<u>CLASS</u>	<u>C TEMP</u>	<u>LBS PER 1000 FT</u>
XFH	#4 AWG BARE COPPER	.232	.042	NC	N/A	129
XFJ	#6 AWG BARE COPPER	.184	.027	NC	N/A	81
XFK	#8 AWG BARE COPPER	.146	.017	NC	N/A	51

ALL BARE COPPER CLASS "B" STRANDING

Guenter Wadewitz, Project Manager, Watts Bar Nuclear Plant, OC (3)

J. W. Coan, Project Manager, Watts Bar Engineering Project, P-104 SB-K

August 29, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NSRS AUDIT FINDING  
I-85-06-WBN-02

An inquiry of cable manufacturers has been initiated in order to support OE's response to NSRS audit finding I-85-06-WBN-02. Letters dated July 26, 1985 (sample attached) were sent to 30 cable manufacturers requesting information related to cable furnished to TVA on each contract by each manufacturer. A total of six responses have been received as of this date. Some responses declined to provide any information. Each manufacturer's response is applicable only to his cable.

The following directives must be followed for each respective manufacturer.

Brand-Rex

Contracts: 70C7-54179-1, 71C7-54617, 71X7-54761-2, 72X7-74885-1, 72C7-75328-1, 67C3-91618-2, 68C7-61737-2, 77K5-822000, 79K5-824279-1, 80K5-824853, 80K6-825419, 81K5-828072, 82PN7-829867, 84K6-835633, 85PN2-837101, 85P7-837104, 81K9-828797, 83KN2-832166, 83K5-832289, 84K06-835633, and 84KN2-835806

1. The maximum side wall pressure allowed for each type of cable is as follows:

Unshielded Cables	500 lbs/ft.
Shielded Cables	250 lbs/ft.
Coax/Triax/Communications Cables	100 lbs/ft.

2. The nominal values of diameters have been submitted with each routine test report. Weights were not given.

Collyer Insulated Wire

Contracts: 77K5-8221733 for 2/0, 400, and 500 MCM Type EPSJ rated 8 kV; 78K5-824822 for 750 MCM Type EPSJ rated 8 kV

1. Sidewall pressure is 300 pounds per foot of radius of bend.
2. The nominal value of outside diameter, cross-sectional area, and weight are:

	<u>2/0</u>	<u>400</u>	<u>500</u>	<u>750</u>
OD (in.)	.985	1.300	1.385	1.685
Area (in <sup>2</sup> )	.762	1.327	1.507	2.230
Weight (lb/ft.)	.85	1.87	2.23	3.31



Guenter Wadewitz  
August 29, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NSRS AUDIT FINDING  
I-85-06<sup>WBN</sup>-02

General Electric

Contracts: 68C7-61985, 72C7-75025, 72C7-83426, 78K5-824443-2, and  
80XN4-827518

1. The maximum sidewall pressure on new cable is estimated to be 300 times the bend radius in feet.
2. Nominal values of outside diameter, cross-sectional area, and weight:

<u>No. Cond.</u>	<u>Size</u>	<u>Mark</u>	<u>No. OD</u>	<u>CMA* Cir Mills</u>	<u>Weight Lb/Ft</u>	<u>Sidewall<sup>++</sup> Pressure</u>
2	14	WHB	.370	4100	.0916	300
3	14	WHC	.390	4100	.1133	300
9	14	WHH	.628	4100	.2840	300
2	12	WGB	.409	6530	.1183	500
1	12	WDU	.185	6530	.0308	300
1	12	WDV	.185	6530	.0308	300
1	12	WDW	.185	6530	.0308	300
1	12	WDX	.185	6530	.0308	300
1	10	WDA	.210	10380	.0458	300
1	10	WDB	.210	10380	.0458	300
1	10	WDC	.210	10380	.0458	300
1	10	WDC-1	.210	10380	.0458	300
1	8	WDD	.305	16510	.0741	300
1	6	WDE	.310	26240	.1058	300
1	2	WDG	.424	66360	.2416	300

\*The circular mill area applies to single metallic conductor of the size specified. For multi-conductor cables the total area is obtained by multiply the CMA by number of conductors.

<sup>++</sup>Multiply by radius of the bend in feet.

Guenter Wadewitz  
August 29, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NSRS AUDIT FINDING  
I-85-06-WBN-02

The Okonite Company

Contracts: 68C7-61986-2, 68C7-61988-2, 72C7-74910-2, 74C7-85527-2,  
78K5-823412-2, 78K5-824443-1, 78K13-824701, 78K5-824749, 79K5-824754,  
80K5-824920, 79K5-824930, 79K5-825342-1, 80K6-827320-2, 81K5-827750,  
81K5-827928, 81K6-828538-1, 82K5-830040-1, 82K8-830135, 83PN1-832963,  
84K8-835699, and 85KN8-837102

1. Maximum Sidewall Pressure

Power Cables Low and High Voltage Shielded and Nonshielded

Sizes 1/0 AWG and Larger

One 1/C Cable = 500 lbs. per ft.  
Two or Three 1/C Cables = 1000 lbs. per ft.

Sizes 1 AWG and Smaller

One 1/C Cable = 300 lbs. per ft.  
Two or three 1/C Cables = 500 lbs. per ft.

Multiconductor Control Cables

One Cable = 300 lbs. per ft.  
Two or More = 500 lbs. per ft.

Multiconductor Instrumentation Cables

One Cable = 300 lbs. per ft.  
Two or More = 500 lbs. per ft.

2. Maximum Allowable Tension

n = Number of conductors per cable  
CMA = Circular mil area of each conductor  
N = Number of cables

Single Conductor Cables

1 or 2 cables =  $.008 \times N \times CMA$   
Single Conductors Twisted (e.g., Triplex) =  $.008 \times N \times CMA$   
3 Conductors Parallel =  $.008 \times (n-1) \times CMA$   
4 or more Conductors Parallel =  $.008 \times N \times CMA \times 0.6$

Guenter Wadewitz  
August 29, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NSRS AUDIT FINDING  
I-85-06-WBN-02

Multiconductor Cables (2 or more conductors under a common jacket)

1 or 2 Cables Parallel =  $.008 \times N \times n \times CMA$

3 or more Cables Parallel =  $.008 \times N \times n \times CMA \times 0.6$

These formulae assume all cables have the same number of conductors.

3. Nominal values of weight were not given. Nominal values of diameter are given in routine test reports.

Other data will be transmitted to your Floyd Smith as it becomes available. Questions may be directed to OE's F. B. Rosenzweig at extension 2624.

---

J. W. Coan

*one* ✓  
FWC:AWT:BB  
Attachments

cc: RIMS, SL26 C-K  
F. W. Chandler, W8C126 C-K  
R. R. Reeves, P-110 SB-K

Principally Prepared By: A. W. Thomas, Extension 4795.

035238.05

*ED*  
*1/2*  
*FOR*

# ATTACHMENT 7A

B43 851011 915

Quenter Vedevits, Project Manager, Watts Bar Nuclear Plant, OC (3)

J. V. Coan, Project Manager, Watts Bar Engineering Project, P-104 SB-E

October 7, 1985

85102380011 (7)

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NRRS AUDIT FINDING I-85-06-MNH-02

This supplements my memorandum to you dated August 29, 1985 (B43 850829 912), with additional vendor responses. Of the 30 vendors contacted, to date 13 have provided written responses (3 of whom declined to provide any pertinent information) and 2 have responded orally.

The following directives apply only to those cables furnished by the respective manufacturer.

### American Insulated Wire Corporation

CONTRACTS: 75K5-865001, 77K5-821609-1, 77K5-822173-2, 77K5-822401, 77K5-822502, 77K13-822556, 78K5-822803-1, 78K5-823128, 78K5-823412-1, 78K5-824164, 78K13-824482, 79K5-824717, 79K5-824597, 79K5-824965, 79K7-825180, 79K7-825247, 79K5-825342-2, 79K8-825668-2, 78K5-825687, 79K7-825714, 79K8-825848, 80K7-827727, 80K8-827292, 80K7-827594, 81K5-827749, 81K6-828714, 81K8-828824, 81K5-828920-3, and 81K6-828538-2

Based on a telecon between OE's Rob Brooks and AIM's Bill Firth on September 10, 1985, the following maximum sidewall pressures apply to the cables provided on the above contracts:

Cross-Linked Polyethylene (XLPE) Cables	300 lbf/ft
Ethylene-Propylene Rubber (EPR) Cables	500 lbf/ft

### Anaconda-Ericsson (now Ericsson-Continental Wire and Cable)

CONTRACTS: 68C7-61737-3, 68C7-61986-1, 72C7-74910-1, 72C7-83944, 73C7-83999, 74C7-85112, 74C7-85527-1, 75C7-85438, 75C7-85861, 76K5-87232, 79K5-824279-2, 78K5-824447, 79K5-825018, 79K6-825722-2, 80K6-825997, 80K5-827297, and 80K8-827380

Based on the vendor's letter to F. W. Chandier dated August 13, 1985 (B43 850923 007), and confirmed in a followup telecon between Rob Brooks and A-E's Tom Gardner on September 17, 1985, the following maximum sidewall pressures are allowed for the cables provided on the above contracts:

Power Cables (No. 8 AWG and larger)	500 lbf/ft
Control Cables (smaller than No. 8 AWG)	300 lbf/ft
Instrument and Signal Cables	100 lbf/ft

A copy of the vendor's cable installation manual which accompanied their letter is attached.

Guenther Wodewitz  
October 7, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NRSR AUDIT FINDING  
1-85-06-WBB-02

Boston Insulated Wire and Cable

CONTRACTS: 71C7-54335, 72C7-83849, and 77K5-820991

This vendor was non-responsive, but in his letter to F. W. Chandler of September 20, 1985 (BA3 850923 016), offered to provide the requested information for a fee of \$450 per 8-hour day. This will be pursued.

Eaton Corporation - Samuel Moore Operations

CONTRACTS: 77K5-821722, 79K5-824860, 79K7-825651, 79K13-825696, 79K6-825772, 79K5-825852, 79K5-825874, 80K8-826598, 84K6-834607, and 85PH1-837090

Based on a telecon between Rob Brooks and Eaton's Al Clements, the following maximum sidewall pressure applies:

All Cables (above contracts) 500 lbs/ft

The Okonite Company

CONTRACTS: 68C7-61986-2, 68C7-61988-2, 72C7-74910-2, 74C7-85527-2, 78K5-823412-2, 78K5-824443-1, 78K13-824701, 78K5-824749, 79K5-824754, 80K5-824920, 79K5-824930, 79K5-825342-1, 80K6-827320-2, 81K5-827750, 81K5-827928, 81K6-828538-1, 82K5-830040-1, 82K8-830135, 83PH1-832963, 84K8-835699, and 85KFB-837102

NOTE: THE PREVIOUSLY RELEASED SIDEWALL PRESSURE LIMITATIONS FOR OKONITE CABLES PROVIDED ON THE ABOVE CONTRACTS HAVE BEEN REVISED AND ARE NOW AS FOLLOWS [based on a second vendor letter to F. W. Chandler dated September 5, 1985 (BA3 850909 029)]:

1. Sidewall Pressures

Low Voltage (600V-2000V) Cables

One I/C Cable, No. 14 to No. 8 AWG	300 lbs/ft
One I/C Cable, No. 6 AWG and Larger	500 lbs/ft
Multiple I/C Cables, No. 14 to No. 8 AWG	500 lbs/ft
Multiple I/C Cables, No. 6 AWG and Larger	1000 lbs/ft
Multi-Conductor Cables, No. 14 to No. 8 AWG	500 lbs/ft
Multi-Conductor Cables, No. 6 AWG and Larger	1000 lbs/ft

Medium Voltage (5-15 kV) Shielded Cables

Sidewall pressures are same as those listed above for low voltage cables.



Quenter Wedowitz  
October 7, 1985

**HATTIS BAR NUCLEAR PLANT UNITS 1 AND 2 - ENCLASSED CONTRACTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1B - AECAS AUDIT FINDING  
1-85-06-928-02**

Eastern Insulated Wire and Cable

CONTRACTS: 71C7-54335, 72C7-83849, and 77K5-870991

This vendor was non-responsive, but in his letter to F. W. Chandler of September 20, 1985 (BA3 850923 JIG), offered to provide the requested information for a fee of \$450 per 8-hour day. This will be pursued.

Raton Corporation - Some of the Contractors

CONTRACTS: 77K5-821722, 78K5-82443-1, 79K7-825651, 79K13-825686, 79K6-825772, 79K5-825852, 79K4-82747, 80K8-826598, 80K6-827407, and 85PH1-837090

Based on a telephone interview between Rob Brooks and Raton's Al Clements, the following maximum sidewall pressure applies:

All Cables (above contracts) 500 lbs/ft

The Granite Company

CONTRACTS: 68C7-61986-2, 68C7-61988-2, 72C7-74910-2, 74C7-85527-2, 78K5-823412-2, 79K5-824443-1, 79K13-824701, 78K5-824749, 79K5-824754, 80K5-824920, 79K5-824730, 79K5-825342-1, 80K6-827320-2, 81K5-827750, 81K5-827929, 81K6-828538-1, 82K5-830046-1, 82K8-830135, 83PH1-832963, 84K8-835699, and 85K88-837102

NOTE: THE PREVIOUSLY RELEASED SIDEWALL PRESSURE LIMITATIONS FOR GRANITE CABLES PROVIDED ON THE ABOVE CONTRACTS HAVE BEEN REVISED AND ARE NOW AS FOLLOWS [based on a second vendor letter to F. W. Chandler dated October 5, 1985 (BA3 850909 029)]:

1. Sidewall Pressures

Low Voltage (600V-2000V) Cables

One 1/C Cable, No. 14 to No. 8 AWG	300 lbs/ft
One 1/C Cable, No. 6 AWG and Larger	500 lbs/ft
Multiple 1/C Cables, No. 14 to No. 8 AWG	300 lbs/ft
Multiple 1/C Cables, No. 6 AWG and Larger	1000 lbs/ft
Multi-Conductor Cables, No. 14 to No. 8 AWG	500 lbs/ft
Multi-Conductor Cables, No. 6 AWG and Larger	1000 lbs/ft

Medium Voltage (5-15 kV) Shielded Cables

Sidewall pressures are same as those listed above for low voltage cables.



2  
Gunter Wadovits  
October 7, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - MORS AUDIT FINDING  
1-85-06-02B-02

Boston Insulated Wire and Cable

CONTRACTS: 71C7-54335, 72C7-83849, and 77K5-820991

This vendor was non-responsive, but in his letter to F. W. Chandler of September 20, 1985 (B43 850923 016), offered to provide the requested information for a fee of \$450 per 8-hour day. This will be pursued.

Eaton Corporation - Samuel Moore Operations

CONTRACTS: 77K5-821722, 79K5-824860, 79K7-825651, 79K8-825686, 79K6-825772, 79K5-825852, 79K5-825874, 80K8-826598, 84K6-834007, and 85PH1-837090

Based on a telecon between Rob Brooks and Eaton's Al Clements, the following maximum sidewall pressure applies:

All Cables (above contracts) 500 lbs/ft

The Granite Company

CONTRACTS: 68C7-61986-2, 68C7-61988-2, 72C7-74910-2, 74C7-85527-2, 79K5-823412-2, 79K5-824443-1, 79K15-824701, 79K5-824749, 79K5-824754, 80K5-824920, 79K5-824930, 79K5-825342-1, 80K6-827370-2, 81K5-827750, 81K5-827928, 81K6-828538-1, 82K5-830040-1, 82K8-830135, 83PH1-832963, 84K8-835699, and 85K8B-837102

NOTE: THE PREVIOUSLY RELEASED SIDEWALL PRESSURE LIMITATIONS FOR GRANITE CABLES PROVIDED ON THE ABOVE CONTRACTS HAVE BEEN REVISED AND ARE NOW AS FOLLOWS [based on a second vendor letter to F. W. Chandler dated September 9, 1985 (B43 850909 029)]:

1. Sidewall Pressures

Low Voltage (600V-2000V) Cables

One 1/C Cable, No. 14 to No. 8 AWG	300 lbs/ft
One 1/C Cable, No. 6 AWG and Larger	500 lbs/ft
Multiple 1/C Cables, No. 14 to No. 8 AWG	300 lbs/ft
Multiple 1/C Cables, No. 6 AWG and Larger	1000 lbs/ft
Multi-Conductor Cables, No. 14 to No. 8 AWG	500 lbs/ft
Multi-Conductor Cables, No. 6 AWG and Larger	1000 lbs/ft

Medium Voltage (3-15 kV) Shielded Cables

Sidewall pressures are same as those listed above for low voltage cables.

Geosier Wadewits  
October 7, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NERS AUDIT FINDING  
I-85-06-WBK-02

The Ohonite Company (Continued)

Instrumentation Cables

(includes shielded and non-shielded  
pairs, Triads, and Quads No. 16 AMC  
and smaller)

300 lbs/ft

NOTE: THESE VALUES REVISE THE LOWER VALUES CURRENTLY PUBLISHED IN  
OHONITE'S "INSTALLATION PRACTICES MANUAL"

2. Testing

Where the sidewall pressure limits, listed under item 1 above, have  
been exceeded, Ohonite recommends the following:

- A. Visual examination of the pulling end of the installed cable. Any  
obvious damage (split jacket, deformation or flattening of the  
cable) could have been a result of excessive sidewall pressure.
- B. A dc dielectric withstand test at 80 percent factory test voltage  
should be performed on all cables which were subjected to excessive  
sidewall pressure. The test voltage should be applied between  
adjacent conductors and ground in nonshielded cables.

Philadelphia Insulated Wire Company

CONTRACT: 79R13-825319

This vendor was non-responsive [based on vendor letter to F.V. Chandler  
dated July 31, 1985 (B43 850806 012)].

Pirelli Cable Corporation

CONTRACT: 78K5-823741

The following data for outside diameter, cross-sectional area, weight, and  
maximum sidewall pressure for the cables under this contract was furnished  
by Pirelli in a letter to F. V. Chandler dated September 3, 1985  
(B43 850909 028):

<u>Cable</u>	<u>Type</u>	<u>U.D.</u>	<u>C.S.A.</u>	<u>Wt.</u> <u>(lbs/100FT)</u>	<u>Maximum</u> <u>Sidewall</u> <u>Pressure</u>
1/C 16 AMC 19/.0113 Bare-Copper Tefzel 280 Switchboard Wire	TE16-1929(BC)-018 Mark WJB-1	.092	.2890	10.48	209

4  
Gunter Wadovits  
October 7, 1985

**MATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NERS AUDIT FINDING  
I-85-06-WBN-02**

Pirelli Cable Corporation (Continued)

Cable	Type	O.D.	C.S.A.	Wt. (lbs/1000 FT)	Maximum Sidewall Pressure
1/C 14 AWG 19/.0142 Bare-Copper Tefzel 280 Switchboard Wire	TE14-1927(BC)-020 Mark WJC-1	.110	.34	16.06	278
1/C 12 AWG .9/.0179 Bare-Copper Tefzel 280 Switchboard Wire	TE12-1925(BC)-020 Mark WJB-1	.129	.4053	23.84	378
1/C 10 AWG 37/.0159 Bare-Copper Tefzel 280 Switchboard Wire	TE10-3726(BC)-026 Mark WJJ-1	.162	.5089	37.18	464
1/C 8 AWG 37/.0211 Bare-Copper Tefzel 280 Switchboard Wire	TE8-3724(BC)-026 Mark WJK-1	.216	.6786	61.47	610

The surveillance program for monitoring of reduction in qualified life of Class 1E cables if the maximum sidewall pressures are exceeded is recommended by Pirelli as follows:

1. Dynamic cut through test
2. Crush test
3. Conductor resistance test

If after exceeding the maximum sidewall pressure in installation the parameters above are within specification limits there is no reason to believe that there has been an effect on qualified life.

Raychem Corporation

CONTRACTS: 76K13-820363, 76K5-820642, 77K5-821043, 77K72-821104,  
77K13-822100

In his letter to F. W. Chandler dated September 9, 1985 (DAG 850916 005), the vendor provided an installation guide (attached) which details maximum pulling tensions depending upon type of pull mechanism (section 2.4). While not addressing sidewall pressure limitations per se, he does provide a figure for maximum tension at a bend which can be interpreted as a sidewall pressure limit of 500 lbs/ft (see section 2.4.2.3) for cables furnished on the above contracts.

Gunter Wadovitz  
October 7, 1985

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NERS AUDIT FINDING  
1-85-04-WBN-02

The Rockbestos Company

CONTRACTS: 69C3-64863-1, 69C7-64923, 69C7-64924, 76K5-87235, 77K5-821042,  
77K5-821729, 77K5-822173-1, 77K5-823265, 78K5-823428, 78K5-823577, 78K5-  
824171, 78K5-824308, 80K5-825730, 79K13-826045, 81K5-830078, 82K5-831192,  
83K5-832816, and 85P7-837104-1

1. Based on their letter to F. W. Chandler dated August 14, 1985 (B43 850819 001), Rockbestos recommends the following maximum allowable sidewall pressure in pounds-per-foot of bend radius based on generic type cables furnished on the above contracts:
 

A. Power, Control, Instrumentation Cables Without Shields - EPR & XLPE Insulated-Neoprene, Hypalon, PVC, XL Jacketed	1000
B. Control, Instrumentation Cables With Foil/Polyester Shields - EPR & XLPE Insulated - Neoprene, Hypalon, PVC, XL Jacketed	1000
C. All Cables with Copper Tape or Copper Braid Shields	500
D. Silicone Insulated Cables	300
E. Coaxial and Triaxial Cables	
Solid Dielectric	200
Foam Dielectric	150
F. Corrugated Aluminum Sheath or Interlocked Armor Cables	400
G. Steel Interlocked Armor Cables	500
  
2. Rockbestos knows of no practical test that can be made on installed cable which could establish that degradation of qualified life of Class 1E cables had occurred if recommended sidewall pressures were exceeded. Possibly some analysis such as an Arrhenius study on insulation samples could be made, but even these results would be subjected to interpretation. However, some tests could be made--such as: conductor resistance, dc voltage withstand, and insulation resistance--and based on a comparison of these results with the actual operating parameters of the cable, an engineering judgment could be made as to the present condition of the stressed cable. Once cable is in service, a repeat of these tests could be made after 1 year and results compared.

For coaxial cables, Rockbestos suggests that a check be made of other electrical parameters required for proper cable operation.

Guenter Wadewitz  
October 7, 1985

MATT'S BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 1E - NRS AUDIT FINDING  
1-85-06-WBN-02

Home Cable Corporation (formerly CYRUS)

CONTRACTS: 71C7-54762-1, 72C7-75328-3, 72C7-83874-2, 74C7-85069-1, 75K7-86150-1, 75K5-86506-3, 77K5-821609-3, and 80P5-827235

In Home's letter to Allen Thomas dated July 29, 1985 (BA3 850925 0077), the following maximum cable sidewall pressure was recommended:

All Cable Types (on above contracts) 300 lbs/ft

Immanus Cable Products Corporation

CONTRACT: 72C7-75328-2

The vendor was non-responsive in his letter to F. W. Chandler, dated August 21, 1985 (BA3 850827 010).

Triangle-Plastic Wire and Cable

CONTRACTS: 67C3-91618-1, 70C7-54179-2, 71C7-54517, 71C7-54762-2, 71C7-75128, 72C7-75228-1, 72C7-83483, 72C7-83874-1, 73C7-84528-1, 74C7-85069-1, 74C7-85528, 75C7-85744, and 75K7-86150-2

Based on a telecon between Rob Brooks and Triangle's George Strapiere on September 25, 1985, and confirmed in the vendor's letter received on September 27, 1985 (BA3 850927 015), the following sidewall pressure limitation applies:

All Cables (above contracts) 100 lbs/ft

An exception to this limit is allowed for those cables installed in accordance with conditions and cable types and sizes specified in EPH1 Report No. EL 3333, Volume I, Project 1519-1, entitled "Maximum Safe Pulling Length for Solid Dielectric Insulated Cable" (600V-138 kV insulation), which includes the upgraded limitations.

United Technologies, Essex Group

CONTRACTS: 72C7-75533-1, 70C7-92430, 76K5-820013, 79K8-825668-1, 79K5-825722-1, 80K6-827320-1, 81K5-828920-1, 74C7-85333, 77K5-821609-2, 79K5-825342-3, AND 84K2-835113

Based on the vendor's letter dated September 27, 1985 (BA3 850930 005), the following maximum sidewall pressure limitation applies:

All Cables (above contracts) 300 lbs/ft

Geometer Nadowitz  
October 7, 1965

**WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - INSULATED CONDUCTOR VENDOR DATA  
RELATED TO SIDEWALL PRESSURE ISSUE - CLASS 12 - NERS AUDIT FINDING  
E-85-66-933-02**

Dated Test Procedures, Kasek Group (Continued)

Cables exceeding this sidewall pressure limit can be tested by applying 80 percent factory test voltage, i.e., 8.4 kV dc, for a duration not to exceed 15 minutes. Each conductor should be energized at this level, with all others in the conduit being grounded (also ground the conduit). The results should then be compared by testing similar cables which did not exceed the above limit.

We will provide you with further updates as appropriate.

*aut/c*  
*RWC*

*J. W. Coan*  
J. W. Coan

FPC:RMB:RB

Attachment:

cc: EIME, EL 26 C-2

F. W. Chandler, WS C126 C-2

R. E. Reeves, F-110 22-X

*rr*

*if*

Principally Prepared By: E. H. Drooks, Jr., Extension 3344.

*W*  
*ODD*

- 9-623
- 9-633
- 9-245
- 9-246
- 9-488
- 9-731
- 9-864
- 9-894

ITEM 16

Describe the manner in which the techniques used to resolve Watts Bar cable pulling and bend radii concerns have been or will be applied to the Sequoyah cable system.

RESPONSE

SON specific cable pulling questions will be addressed in detail in TVA's response to NRC letter, B. J. Youngblood to S. A. White, dated August 29, 1986.

ENCLOSURE 2



## G-38 TRAINING REQUIREMENTS FOR ELECTRICAL CRAFT AT WBNP

Training requirements for construction craft personnel at WBNP are outlined in WBN-QCI 1.11-1. As stated in QCI 1.11-1, the construction craft organization is responsible for implementing and conducting or arranging by others, on a continuing basis, training sessions on applicable QCIs, QCPs, QCTs and project and general construction specifications. In addition, the construction craft organization may choose to incorporate information from applicable quality-related documents in craft training modules for specific work. A craft training module is defined as: an accumulation of applicable information derived from QCIs, QCPs, QCTs, process specifications, general construction specifications and other design documents that contain necessary information for a craftsman to make an acceptable installation.

Organization supervisors are required to develop training matrices for individuals within their units for minimum requirements and maintain unit records of training activities. Training is always given for updating to QCI, QCP or QCT revisions after a review by the construction craft organization and the quality managers organization determine there is no change in the acceptance criteria detailed in the training module. This determination is documented in attachment C of QCI 1.11-1.

ENCLOSURE 3

## ENCLOSURE 3

WBN EMPLOYEES CONCERNS  
 RELATED TO NRC QUESTIONS  
 ON CABLE PULLING

<u>Concern Number</u>	<u>Category</u>	<u>Subcategory</u>
EX-85-076-003	CO	10900
EX-85-092-003	CO	10900
HI-85-084-N03	QA	80203
HI-85-105-001	IH/QA	00000/ 80203
HI-85-113-N02	CO	10900
IN-85-018-004	CO	11300
IN-85-046-N09	CO	10900
IN-85-046-001	QA	80203
IN-85-046-001	CO	10900
IN-85-055-001	MP	70602
IN-85-097-018	NU	00000
IN-85-112-001	OP	30401
IN-85-138-X07	IH	00000
	QA	80203
IN-85-138-001	CO	19200
IN-85-138-002	NP	70200
	QA	80203
IN-85-201-001	CO	19200
IN-85-201-002	CO	10900
IN-85-201-003	CO	19200
IN-85-207-001	EN	23800
IN-85-207-002	OP	30402
IN-85-213-001	CO	10900
IN-85-241-N11	CO	10900
IN-85-241-007	CO	10900
	IH	00000
IN-85-255-001	CO	10900
IN-85-295-003	CO	10900
IN-85-300-002	CO	10900
IN-85-314-001	CO	10900
IN-85-318-001	CO	10900
IN-85-318-002	CO	10900
IN-85-318-003	CO	10900
IN-85-323-002	CO	10900
IN-85-325-005	CO	10900
IN-85-367-001	EN	23800
IN-85-425-004	CO	10900
IN-85-433-002	CO	10900
IN-85-506-001	EN	23800
IN-85-527-001	CO	10900
	MP	71600
IN-85-533-001	CO	10900
IN-85-581-001	CO	10900
IN-85-652-001	QA	80000
IN-85-743-006	EN	23900
IN-85-743-008	EN	23800
IN-85-774-006	CO	10900
IN-85-878-X01	CO	10900

IN-85-856-004	CO	19200
IN-85-856-005	CO	10900
IN-85-862-002	OP	30402
IN-85-919-001	EN	23800
IN-85-935-001	CO	10900
	CO	15100
IN-85-978-001	CO	10900
IN-85-993-001	CO	10900
	QA	80202
IN-85-978-013	CO	10100
	CO	10200
	CO	10900
	MC	40400
	MP	70605
	QA	80000
IN-85-978-012	QA	80000
	QA	80104
IN-86-028-001	CO	10900
IN-86-034-001	EN	23800
IN-86-036-001	EN	23800
IN-86-036-002	CO	10900
IN-86-119-001	CO	19200
IN-86-199-001	CO	10900
IN-86-201-001	CO	10900
IN-86-206-001	EN	23800
IN-86-212-001	CO	10900
IN-86-212-002	QA	80203
IN-86-254-001	CO	10900
IN-86-254-002	CO	10900
IN-86-254-006	CO	10900
	QA	80000
	QA	80203
	QA	80502
IN-86-259-002	CO	10900
IN-86-259-004	CO	10900
	MP	71600
IN-86-259-014	CO	10900
IN-86-262-003	CO	10900
IN-86-266-X09	QA	80203
IN-86-266-001	CO	10900
IN-86-266-006	CO	10900
IN-86-310-001	EN	23800
IN-86-314-001	CO	10900
IN-86-314-002	CO	10900
OO-85-005-003	QA	80203
OW-85-007-012	CO	10900
WI-85-046-016	QA	80104
WI-85-100-012	CO	10900

ENCLOSURE 4

B43 '86 0903 904

QA Record

TO : Those listed

FROM : W. S. Raughley, Chief Electrical Engineer, W8 C126 C-K

DATE : September 2, 1986

SUBJECT: ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - CLASS 1E CABLE BEND RADIUS

The purpose of this memorandum is to provide advance direction concerning the project specific actions which are necessary to resolve the outstanding concerns on the bend radius of Class 1E cables. Resolution of these concerns has been tied to plant restart/fuel load and should be scheduled for implementation accordingly.

The Electrical Engineering Branch has evaluated the adequacy of the bend radius to which Class 1E cables were installed. The basis for the evaluation was the comprehensive investigation conducted by the Nuclear Safety Review Staff on the same subject during February to April 1985. The measures specified herein are expected to comprise the majority of any project specific corrective actions resulting from this investigation. EEB's final report documenting the evaluation and providing conclusions and recommendations based upon an independent review of our evaluation will be issued in September 1986.

Each project should proceed immediately to perform the following inspections, as applicable, and to forward the results to the respective engineering projects.

1. The Watts Bar and Bellefonte projects shall inspect the installed bend radius of all Class 1E medium voltage power cable furnished by The Okonite Company. The cable shall be verified to be installed to a radius equal to 8 times its outside diameter. This inspection need not address the bend radius in standard conduit bends as this has been addressed generically in PIRGENEEB8605. The inspection of the bend radius in condulets is covered in item 2 below. Therefore, provided the project establishes that all cable tray fittings were procured with a radius equal to or greater than 8 times the outside diameter of the largest cable in question and that all conduit bends meet the minimum requirements of DS-E13.1.7, this inspection may be limited to cables in free air (transitions from raceway to raceway or raceway to equipment) and to the points of termination.

All installations which do not conform to the specified 8 times factor shall be documented as a nonconformance and forwarded to the respective engineering project for disposition. The documentation shall include the cable and, if applicable, the raceway number, the location of the violation, the actual installed bend radius and the results of a visual inspection noting any discernible stress on the cable jacket in the area of the bend or any cuts or ripples in the cable jacket which could indicate shield deformation.

Those listed  
September 2, 1986

ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - CLASS 1E CABLE BEND RADIUS

Effective immediately, the Watts Bar and Bellefonte projects shall take the steps necessary to ensure that all medium voltage power cable furnished by The Okonite Company is installed to a bend radius of 8 times its outside diameter as opposed to the previous direction of DS-E12.1.5. This design standard is being revised accordingly.

2. All projects shall perform a field inspection of all conduits containing Class 1E medium voltage power cables for the existence of any straight-thru pull box or conduit type (C, ELL, TEE, etc.) raceway fitting or any conduit raceway fitting other than a standard conduit bend around which a cable is bent. The existence of any such fittings, including the raceway number and size, the fitting description, manufacturer (if available) and size, and the location shall be documented as a nonconformance and forwarded to the respective engineering project for disposition.
3. All projects shall determine the minimum size conduit that the following coaxial, triaxial, and twinaxial cables, if utilized in Class 1E applications and routed in conduit, are installed in. If any of these cables are installed in Class 1E applications and in a conduit smaller than indicated below, the project shall perform a field inspection for the existence of condulets of any type (ELL, TEE, etc) in which the cable is bent. The existence of any such fittings, including the raceway number and size, the fitting description, manufacturer (if available) and size and the location shall be documented as a nonconformance and forwarded to the respective engineering project for disposition. In addition, each project shall verify that the following list includes all coaxial, triaxial, and twinaxial cables installed in Class 1E applications. A positive statement to this effect or a list of additional cable mark numbers shall be addressed to my attention.

<u>Cable Mark No.</u>	<u>Description</u>	<u>Minimum Condulet Size (Inches)</u>
WTJ	Coax RG6A/U	2
WTJ-5	1/c #21 Coax Solid Cu Clad Steel	2
WTK	#22 Coax RG59B/U	1-1/2
WTK-1	Coax RG59B/U XLP	1-1/2
WTL	Coax RG216/U Except 3 Shlds	3
WTL-4	Coax 55 ohm #22 AWG	1-1/2
WTM	Coax RG114A/U Except 3 Shlds & ST	3
WTM-6	1/c Coax #26, 7 Strands, LOCA	3
WTY-1	#21 AWG, Coax, RG58C/U	1-1/2
WTU	#20 Triax RG 11/U	3
WTN	Triax RG-59U #22, 2 Shlds LOCA	2
WTN-1	Triax Similar to RG11/U LOCA	3
WTN-2	Twinax RG22B/U	3
WWK	TP #22 W/SH TP #20 2/c #22 2-Coax	3



Those listed  
September 2, 1986

ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - CLASS 1E CABLE BEND RADIUS

4. The Watts Bar project shall perform a field inspection of all Class 1E coaxial, twinaxial, and triaxial cables which were installed or modified during the period of May 25, 1979 to May 18, 1981, under the guidance of Design Information Request (DIR) No. E-9. In addition, all projects shall inspect all Class 1E coaxial and twinaxial cables which were installed or modified during the period of September 20, 1983 to April 23, 1986, under the direction of DS-E12.1.5 Rev 0. The cable shall be verified to be installed to a bend radius equal to 8 times its outside diameter. This inspection need not address the bend radius in standard conduit bends as this has been addressed generically in PIRGENEEB8605. The inspection of the bend radius in condulets is covered in item 3 above. Therefore, provide the project establishes that all cable tray fittings were procured with a radius equal to or greater than 8 times the outside diameter of the largest cable in question or that the cable was restricted to use in conduit and that all conduit bends meet the minimum requirements of DS-E13.1.7, this inspection may be limited to cables in free air (transitions from raceway to raceway or raceway to equipment) and to the points of termination.

All installations which do not conform to the specified 8 times factor shall be documented as a nonconformance and forwarded to the respective engineering project for disposition. The documentation shall include the cable and, if applicable, the raceway number, the location of the violation, the actual installed bend radius and the results of a visual inspection noting any discernible stress on the cable jacket in the area of the bend or any ripples in the cable jacket which could indicate shield deformation.

Each Lead Engineer should prepare a fragnet reflecting the individual project's approach and schedule for resolving these issues. Please submit a copy of this fragnet to me for my use and information.

  
W. S. Raughley

J. D. Collins, P-205 SB-K  
G. T. Hull, DNE, DSC-A, Sequoyah  
D. F. Faulkner, A7-BFN  
J. L. Springer, 9-111 SB-K

JMS:TMS:TLT

cc: RIMS, SL 26 C-K  
R. R. Hoesly, 9-113 SB-K  
J. A. Kirkebo, W12 A8 C-K  
M. L. Rayfield, P-104 SB-K  
J. P. Stapleton, DNE, A10 Browns Ferry  
D. W. Wilson, DNE, DSC-A, Sequoyah  
Principally Prepared By: T. M. Shea, Extension 2672

UNITED STATES GOVERNMENT

## Memorandum

TENNESSEE VALLEY AUTHORITY

B43 '86 0717 905

TO : Those listed

FROM : W. S. Raughley, Chief Electrical Engineer, WB C126 C-K

QA Record

DATE : July 16, 1986

SUBJECT: ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - SUPPORT OF CABLES IN VERTICAL CONDUITS

PLEASE RESPOND BY AUGUST 1, 1986

Refer to my subject memorandum to Those listed dated May 21, 1986 (B43 860522 914).

The purpose of this memorandum is to provide additional direction on the evaluation process to be implemented as part of the corrective action inspection for this issue as well as to provide detailed technical guidance for the assessment of any conduits found to be deviating from the specified requirements. This memorandum supersedes the corrective action stipulated in the May 21, 1986 memorandum.

All previously installed vertical conduit runs containing Class 1E cables shall be identified and evaluated against the latest requirements of General Construction Specification G-38 for support of cables in vertical conduits. It is recommended that this effort be accomplished by a group walkdown with representatives from NUC CON, including a Quality Control (QC) inspector and the DNE Engineering Project. In determining the cable support requirements for conduits which are composed of other than straight vertical sections, the effective vertical length is equal to the nonhorizontal (vertical and inclined) sections length minus the length of the horizontal sections located directly above it. A support shall be installed whenever this effective length, as measured upward from the bottom of any nonhorizontal section, exceeds 25 percent of the spacing specified in Table 300-19(a) of the NEC. This support shall be installed at a point before the sum exceeds the spacing specified in the above table. This method recognizes the inherent support provided by a horizontal conduit run located above a nonhorizontal conduit. However no credit may be assumed for this horizontal section providing support to vertical sections located above it.

All deviations to the above shall be properly documented as nonconformances and forwarded to the DNE Engineering Project for disposition. This documentation shall include the conduit number as well as an approximate isometric diagram indicating the length of the conduit sections and the location of ELL or TEE conduit bodies if at the top of a cable run as well as the location and degree of conduit bends. For the purpose of the isometric diagram the estimated lengths for horizontal sections, when in doubt, should be conservatively shortened while nonhorizontal lengths should be conservatively lengthened. When specifying the degree of bends the conservative approach is to specify the bend in a manner which indicates a greater degree of vertical run. If an ELL or TEE conduit body exists at the top of a vertical cable run which exceeds the NEC limitations and is accessible, the cover of the conduit body shall be removed and the

Those Listed  
July 16, 1986

ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - SUPPORT OF CABLES IN VERTICAL CONDUITS

cable(s) inspected for adherence to the minimum bend radius requirements of G-38(DS-Z12.1.5). The documentation shall clearly state whether the conduit body was inspected and identify any nonconforming conditions.

Upon receipt of the documented nonconformances, the DNE Engineering Project shall evaluate each conduit to ensure the following:

- A. That the vertical cable weight does not, at any point in the run, exceed the maximum working load of the conductor. This is determined by the following equation which is applicable to cables with copper and thermocouple conductors of equal cross-sectional area:

$$\text{Maximum Effective Vertical Length Between Supports (ft)} = \frac{(24000)n (A \times \frac{\pi}{4,000,000})}{7 W}$$

where n = number of conductors in cable  
A = circular mil area of each conductor  
W = weight of cable (lb/ft) (use Max. value per mark letter)

This limitation shall be determined for each cable in the conduit.

For other conductor materials or for cables with various size conductors, contact the cable specialist.

- B. That the vertical cable weight does not result in excessive cable bearing pressure being exerted on the cable(s) as it passes around a raceway bend. This is determined by the following equation:

$$\text{Maximum Effective Vertical Length Between Supports (ft)} = \frac{25 \times R \times OD}{IW \times C}$$

where R = radius of bend of conduit or support surface in inches  
OD = outside diameter (use Avg. value per mark letter) of smallest cable in the conduit in inches  
IW = sum of cable weights in lbs/ft (use Max. value per mark letter)  
C = 1.0 for one cable in the conduit  
.5 for more than one cable in the conduit

NOTE: The quantity (IW x C) shall not be less than the weight of the heaviest cable in the conduit.

This limitation shall be determined once for each conduit based on the smallest bend in the vertical run and on the smallest cable OD.

Those Listed  
July 16, 1986

ALL NUCLEAR PLANTS - ELECTRICAL ISSUES - SUPPORT OF CABLES IN VERTICAL CONDUITS

- C. That the vertical cable weight does not contribute any tension, beyond that inherent in the NEC (Article 300-19) limitations, to the termination point(s) of the cable(s).
- D. That the bend radius of cables in vertical conduit runs which have an ELL or TEE conduit body at the top has not been exceeded. The DNE Engineering Project shall mandate in the disposition of the nonconformance the inspection of those conduit bodies identified but not inspected during the initial walkdown as well as specifying the fix of those identified originally as nonconforming.

Conduit sections which meet the above criteria are acceptable as is. For sections that do not, engineering shall specify the location of the new supports to be added to ensure compliance with the above criteria.

In determining the Effective Vertical Length Between Supports, the DNE Engineering Project shall utilize slight modifications of the equations provided in G-38 for expected Pulling Force. This will account for the reduction in tension afforded by bends, inclines and horizontal sections located above vertical cable drops. Each project should consult with the cable specialist to review the equation modifications prior to beginning the evaluation.

Attached are sample calculations demonstrating proper application of the above principles. The technical guidelines addressed herein will be incorporated into General Construction Specification G-38.

Each Lead Engineer should revise the fragnet provided in the previous memorandum to reflect the individual project's approach and schedule for resolving this issue. Please submit a copy of this fragnet to me for my use and information by August 1, 1986.

  
W. S. Raughley

J. D. Collins, P-205 SB-K  
G. T. Hall, DNE, DSC-A, Sequoyan  
D. F. Faulkner, A7-BFN ENG  
J. L. Springer, 9-111 SB-K

TMS:BB

Attachment

cc (Attachment):

RMS, SL 26 C-K

R. R. Hoesly, 9-113 SB-K

M. L. Rayfield, P-104 SB-K

J. P. Stapleton, A10-BFN ENG

D. W. Wilson, DNE, DSC-A, Sequoyan

Principally Prepared By: T. M. Shea, Extension 2672.

036192.04

ATTACHMENT 1

A. Calculate the effective vertical length (Vg)

$$\begin{aligned} VE1 &= 0 + 10 = 10 \\ VE2 &= 10 - 20 = 0 \text{ Note 1} \\ VE3 &= 0 + 20 = 20 \text{ Note 2} \\ VE4 &= 20 + 20 = 40 \\ VE5 &= 40 - 15 = 25 \\ VE6 &= 25 + 20 = 45 \\ VE7 &= 45 + 25 = 70 \text{ Note 3} \\ VE8 &= 70 + 10 = 80 \text{ Note 4} \\ VE9 &= 80 + 20 = 100 \\ VE10 &= 100 - 50 = 50 \\ VE11 &= 50 + 25 = 75 \end{aligned}$$

- NOTES:
1. Since horizontal sections cannot provide support to vertical sections located above them, the effective vertical length cannot be less than 0.
  2. This value exceeds 25 percent of the NEC spacing. This conduit therefore does not conform to the requirements and should be documented for further engineering evaluation.
  3. The inclined section (nonhorizontal) is added as a vertical section when initially determining the effective vertical length.
  4. This value equals the NEC specified spacing and, in lieu of further engineering evaluation, a support would have to be installed at some point between VE3 and VE8. A new effective vertical length would then be determined from the point of support upward.

At this point this conduit would be documented as a nonconformance and forwarded to the DNE Engineering Project for disposition.

B. Upon receipt of the documented nonconformance, the DNE Engineering Project shall evaluate the conduit as follows:

1. Calculate the Maximum Effective Vertical Length Between Supports based on the working load of the conductor.

$$\begin{aligned} &= \frac{1 \times (133,100 \text{ cm} \times \frac{97}{4,000,000}) (24,000)}{7 (.535)} \\ &= 670 \text{ ft} \end{aligned}$$

This is applicable to all three cables in the conduit since they are of equal cross-sectional area and weight. Since the effective vertical length does not at any point exceed this value, the installation is acceptable as is for this criterion.

2. Calculate the Maximum Effective Vertical Length Between Supports based on the bearing pressure limits of the cable.

$$= \frac{25 \times 8.465 \times .625}{(3 \times .535) .5}$$

$$= 165 \text{ ft}$$

Since the effective vertical length at any bend does not exceed this value, the installation is acceptable as is for this criterion.

3. Calculate the effective tension on the termination point.

NEC allows a maximum of 25 percent of 80 feet or 20 feet.  $V_{E11}$  is 75 feet.

Therefore, a cable support is required at the top of the last conduit section.

4. If EUL or TEE condulets exist at the top of any of the nonhorizontal sections, they shall be inspected to verify proper cable bend radius.

#### SUMMARY

This conduit when inspected in the field would be identified as a nonconformance. It would be appropriately documented and an isometric similar to that shown would be submitted to engineering. Following the above analytical steps, engineering would specify the installation of a single cable support located at the  $V_{E11}$  node. Note that this analysis did not take credit for the additional frictional support afforded by the bends and inclines in the conduit run. This would further reduce the effective vertical length however it would not alter the outcome as the vertical drop from node  $V_{E11}$  to  $V_{E10}$  (25') alone exceeds the maximum 25 percent value (20') allowed by the NEC.



SUBJECT SUPPORT OF CABLES IN VERTICAL CONDUITS PROJECT ALL NUCLEAR PLANTS

COMPUTED BY

DATE


CHECKED BY

DATE

ATTACHMENT #1

3 - 1/2 2/0 Cables WDJ-4  
2" Conduit

Maximum Spacing Per NEC  
80 Feet



From Design Standard DS-E12.1.13

For WDJ-4

Avg OD = .625 inches

Max Wt = .535 lbs/ft

From Design Standard DS-E13.1.7

For 2" Conduit

R = 8.465 inches

2/0 Cable = 133,100 cm