

REVISIONS				
LTR	CALC	DATE	APPV	DATE
A	SR	1/15/82	JG-y	1/15/82

POSI-SEAL INTERNATIONAL, INC.

North Stonington, CT 06359

LOCA & SEISMIC ANALYSIS

Stone & Webster Engineering	
I.O. No. 12177	P304D
Spec. No.	
RELEASED FOR:	FOR CONSTRUCTION
RETURN TO SUPPLIER	ACT FOR CONSTRUCTION
ENG & DESIGN	
FABRICATE	
<input checked="" type="checkbox"/> APP	Approved for Use
<input type="checkbox"/> AAR	As Released
<input type="checkbox"/> UVA	
<input type="checkbox"/> SLI	
<input type="checkbox"/> FIO	
Date:	2/12/86
By:	<i>[Signature]</i>

EdA 3/11/86

CUSTOMER: Niagara Mohawk Power Corp.

UNIT: Nine Mile Point Nuclear Station - Unit 2

P.O. NO.: NMP2-P304D Ch. 14

SPEC. NO.: NMP2-P304D

REPORT NO.: 33375SL-001

CALCULATED BY: *[Signature]*

DATE: 7/17/84

APPROVED BY: *[Signature]*

DATE: July 18, 1984

8606200048 860613
BDR ADDCK 05000410
PDR



REVISION A - Revised Pages 1,2,5,6,7,8,10,24 and
27 thru 36
Added Page 37

Revised Appendices A,B,C,D,E and F

Deleted Appendices G and H

The revision was made to take
into effect having elbows upstream
of Valves AOV107 and 109, and to
decrease the disc pin allowable
stress to 21120 psi.

The revision also addressed the fact
that all the valves are to be
installed in the preferred direction.



TABLE OF CONTENTS

	<u>Page</u>
<u>ENCLOSURES</u>	i
<u>REFERENCES</u>	i
<u>SUMMARY</u>	1
<u>INTRODUCTION</u>	3
Valves to be Qualified by this Analysis.	4
<u>RESULTS</u>	5
<u>RECOMMENDATIONS AND CONCLUSIONS</u>	8
<u>LOCA ANALYSIS</u>	10
Modeling the Piping System	10
Determination of Flow Conditions	11
Simulation of the Actuator Stroking the Valve Close	15
Derivation of Torque Equation	16
Aerodynamic Torque	16
Pneumatic Torque	19
Spring Torque	21
<u>SEISMIC ANALYSIS</u>	22
<u>DETAILED ANALYSIS</u>	23
Determination of LOCA Torques	23
Determination of Aerodynamic Torques	27
Resulting from Bends	
Seismic Analysis	36
Determination of Closing Times	37
<u>APPENDIX A</u> - Schematics of the Piping System	
<u>APPENDIX B</u> - Determination of Flow Conditions	
<u>APPENDIX C</u> - Seismic and LOCA Stress Analysis	
<u>APPENDIX D</u> - Determination of Closing Times	
<u>APPENDIX E</u> - Comparison of Actual to Calculated Closing Times	
<u>APPENDIX F</u> - Miscellaneous Calculations	



- ENCLOSURE
- (1) Valve Assembly Dwgs 19157-3 Rev. B
19157-4 Rev. A
19157-5 Rev. D
 - (2) Posi-Seal Technical Bulletin No. 2,
dated June 1982
 - (3) Derivation of Hydrodynamic Torque Curves
 - (4) Posi-Seal Technical Bulletin No. 1A,
dated June 1982

- REFERENCES
- (a) DuPont Tefzel Catalog, A-95151, dated 1973
 - (b) "Flow of Fluids through Valves, Fittings
and Pipe", Technical Paper No. 410, Crane
 - (c) Nuclear Seismic Analysis 19157SQ-01, Rev. A
dated July 18, 1983
 - (d) Stone & Webster Letter No. 9M2-15,128
dated December 13, 1983
 - (e) Stone & Webster Dwg 12177-EB-15AJ-9
 - (f) Stone & Webster Dwg 12177-EB-15N-10
 - (g) Stone & Webster Dwg 12177-EB-15P-9
 - (h) Stone & Webster Dwg 12177-EB-15F-9
 - (i) Stone & Webster Dwg 12177-EB-15G-8.
 - (j) Stone & Webster Sketch EB-15F
 - (k) Stone & Webster Sketch EB-15G
 - (l) Stone & Webster Telex, dated 11/19/85



B. If the recommendations made in this report are incorporated -

Upon receiving the closing signal all the valves will full close providing a proper shut off.




Figure 1



INTRODUCTION

The objective of this analysis is to show that the subject containment isolation valves can withstand a Loss of Coolant Accident (LOCA) as well as a seismic event of magnitude as given in customer's specification and still maintain operability.

The escape of containment atmosphere during a LOCA will result in aerodynamic torques acting on the valve assembly if it is in the open position. These torques are a result of the disc acting like an airfoil wanting to rotate about the axis of the stem. This analysis will determine the magnitude of the aerodynamic torque and its effect on the operation of the valve assembly.

The seismic aspect of the analysis will consist of determining the natural frequencies and stresses of the valve assembly, assuming the basic valve body to be rigid and the actuator to act as a lumped mass concentrated at its C.G. and rigidly connected to the valve bracket through the bracket bolting.

Those critical sections of the valve assembly such as the bolting, neck, stem and pin are analyzed assuming a g static load (magnitude per customer specification) applied at either actuator or disc C.G., in each of the orthogonal directions simultaneously. Seismic stresses are combined with operating stresses as well as the stresses due to the LOCA aerodynamic torque.

Section modulus of the valve body and deflection of the actuator relative to the valve due to seismic loading are also analyzed.



The valves to be qualified by this analysis are as follows:

<u>PSI Item No.</u>	<u>Description</u>	<u>Tag No.</u>
19157-3	14"-150 C1 with Bettis N721C-SR80-M3HW	AOV104 AOV106 AOV108 AOV110
-4	12"-150 C1 with Bettis N721C-SR80-M3HW	AOV107 AOV109
-5	12"-150 C1 with Bettis N721C-SR80-M3HW	AOV105 AOV111

The assembly drawings of these valves are shown in Enclosure ,
(1).



RESULTS

33375SL-001

Maximum Torques Resulting from a LOCA
and Closing Times

Page - 5

Tag No.	AOV106	AOV104	AOV108	AOV110
Design Item No.	3	3	3	3
Case No.	1A	1B	2A	2B
Valve Size	14"	14"	14"	14"
Actuator Model	N721C-SR80	N721C-SR80	N721C-SR80	N721C-SR80
Actuator Max Allow Torque	22,500	22,500	22,500	22,500
Max Torque Resulting from a LOCA (in.lbs) Preferred Direction	6170	6519	5848	9584
80° Max Opening	-	-	-	7496
Calculated Closing Times (Sec.)				
No Flow	1.5	1.5	1.5	1.5
Preferred Direction				
Valve Opened to 90°	.8	1.00	.8	-
Valve Opened to 70°	-	-	-	.65
Required Closing Time	5.0	5.0	5.0	5.0

A



RESULTS

33375SL-001

Maximum Torques Resulting from a LOCA
and Closing Times

Page - 6

Item No.	AOV102	AOV105	AOV109	AOV111
Item No.	4	5	4	5
Case No.	3A	3B	4A	4B
Valve Size	12"	12"	12"	12"
Actuator Model	N721C-SR80	N721C-SR80	N721C-SR80	N721C-SR80
Actuator Max Allow Torque	22,500	22,500	22,500	22,500
Maximum Torque Resulting from a LOCA (in.lbs)				
Preferred Direction				
30°	3991	4100	4319	6776
70° Max Opening	3321	2542 (Seating Torque)	3590	-
60° Max Opening	-	-	-	2611
Calculated Closing Times (Sec.)				
to Flow	1.5	1.5	1.5	1.5
Preferred Direction				
Valve Opened to 70°	.65	1.05	.60	-
Valve Opened to 60°	-	-	-	.75
Required Closing Time	5.0	5.0	5.0	5.0



LOCA AN. SEISMIC STRESSES (PSI)

375SI-001

Page - 7

Tag No.	Size	Max Valve Opening	Opening of Max Torque	Flow Direction	Actuator Bolt		Bracket Bolt		Bracket		Valve Neck		Stem		Disc Pin	
					Calc	Allow	Calc	Allow	Calc	Allow	Calc	Allow	Calc	Allow	Calc	Allow
AOV106	14"	90°	80°	Preferrad	15019	37500	20400	37500	3765	18900	1722	23400	14522	52800	14808	21120
AOV104	14"	90°	80°		16457		21209		3819		1761		15175		15646	
AOV108	14"	90°	80°		14788		20255		3701		1705		13902		14035	
AOV110	14"	90°	80°		18168		24240		5105		2166		21138		23002	
		70°	70°		16649		23319		4689		2049		17048		17990	
AOV107	12"	90°	80°		14791		21158		3312		9639		12987		22937	
		70°	70°		14371		20812		3178		9550		11274		19086	
AOV105	12"	90°	80°		14860		25347		3366		3146		13267		23563	
		70°	0°		13897		24782		3054		3023		9313		14609	
AOV109	12"	90°	80°		15000		21332		3378		9684		13830		24822	
		70°	70°		14538		20950		3231		9585		11960		20632	
AOV111	12"	90°	80°		16632		26431		3903		3376		20203		38943	
		60°	60°		13938		24806		3068		3029		9484		15005	

NOTE: The allowable stresses are based on 1.5 times the allowable given in



RECOMMENDATIONS AND CONCLUSIONS

Based on the results of this analysis, Posi-Seal recommends that all the subject valves be installed in the preferred direction and that the amount of valve opening of valves AOV105, 107, 109 and 110 be restricted to 70 degrees and 60 degrees for valve AOV111. For valves inside containment the retaining ring will be on the side of the valve closest to the containment wall. For the valves outside containment the retaining ring will be on the side the farthest from the containment wall. Valves AOV107, 109, 110 and 111 should be orientated as shown in Figures 8, 10 and 13 on Pages 27, 29 and 33.

If, for some reason, a valve cannot be installed in the preferred direction, then the amount of valve opening should be restricted to 70 degrees.

Posi-Seal recommends that one of the two methods shown on the following page be used to restrict the amount of valve opening.

It is concluded that if the above recommendations are incorporated the subject valves will properly operate within the required time during a combined LOCA and seismic event. Whether the amount of pressure drop across the valves under normal flow conditions is acceptable with the amount of valve opening restricted to 60 and 70 degrees remains for Stone & Webster to determine. See Page F-1 and F-2 in Appendix F.

The ability of the Tefzel seals to provide a proper shut off is based on the following:

1. Posi-Seal's experience with Tefzel seals in applications where the velocities are comparable to those the subject valves will experience during a LOCA.
2. Radiation testing performed by DuPont as reported in Reference (a). For Posi-Seal's application we have rated the Tefzel seals to 3×10^8 rads.
3. The ability of Tefzel to withstand 340 degrees F. temperatures for a short period of time as also reported in Reference (a).



BETTIS ACTUATOR

Mechanical Stops for
Restricting Valve Opening to 70°




Figure 1



LOCA ANALYSIS

The purpose of this analysis is to determine what effects the aerodynamic torque resulting from a LOCA will have on a valve assembly. Since aerodynamic torque is dependent upon the flow conditions and the valve angle, computer programs are developed which:

1. Models the piping system
2. Determines the flow at various valve angles
3. Simulates the actuator as it strokes the valve from fully open to fully close.

MODELING THE PIPING SYSTEM

For the subject order there are four piping systems which are to be investigated. They are:

<u>Case 1</u>	A	14" Valve AOV106	Cycles Close
	B	14" Valve AOV104	Cycles Close
<u>Case 2</u>	A	14" Valve AOV108	Cycles Close
	B	14" Valve AOV110	Cycles Close
<u>Case 3</u>	A	12" Valve AOV107	Cycles Close
	B	12" Valve AOV105	Cycles Close
	C	12" Valve AOV105	Cycles Close with piping upstream of Valve AOV107 broken off
<u>Case 4</u>	A	12" Valve AOV109	Cycles Close
	B	12" Valve AOV111	Cycles Close
	C	12" Valve AOV111	Cycles Close with piping upstream of Valve AOV109 broken off

Shown in Appendix A are schematics of the piping systems with each system broken down into the individual components with its corresponding resistance factor. These factors are inputted into the computer program either as a K value, as a length of pipe, a change in pipe diameter, or as a valve C. The K values are obtained from Reference (b), the C values from Posi-Seal Technical Bulletin No. 2, Enclosure (2).



Thus, with the piping system modeled, and with the upstream and downstream conditions known, the flow conditions can be determined.

Determination of Flow Conditions

Derivation of equations

Bernoulli's Equation

$$Z_1 + \frac{144 P_1}{\rho_1} + \frac{V_1^2}{2g} = Z_2 + \frac{144 P_2}{\rho_2} + \frac{V_2^2}{2g} + h_L$$

Since the flow investigated will either be steam or air the height terms (Z_1, Z_2) can be ignored. The head loss due to other restrictions, h_L , can also be ignored since the equation will be used across one resistance at a time.

$$\frac{144 P_1}{\rho_1} + \frac{V_1^2}{2g} = \frac{144 P_2}{\rho_2} + \frac{V_2^2}{2g}$$

where P = Pressure PSIG

ρ = Density lb/ft³

V = Velocity ft/sec

g = Gravitational constant = 32.2 ft/sec²

h_L = Head Loss

Since the piping systems are relatively short the flow is assumed to be adiabatic.

$$\rho_2 = \rho_1 \left(\frac{P_2'}{P_1'} \right)^{1/K_1} \quad \text{per Ref. (b)}$$

$$T_2 = T_1 \left(\frac{P_2'}{P_1'} \right)^{\frac{K_1-1}{K_1}}$$



where K_1 = Ratio of specific heats
 P' = Pressure PSIA
 T = Absolute temperature °R

Flow equations

In pipe

$$Q = \frac{694.3 P' v D^2}{T}$$

where Q = Flow SCFH
 D = Diameter in²

In valve

$$Q = 1360 C_V P_1' Y \sqrt{\frac{X}{GTZ}} \quad \text{per Encl. (2)}$$

where C_V = Valve coefficient
 $X = \Delta P / P_1'$
 ΔP = Pressure drop across valve PSI
 $Y = 1 - \frac{X}{3F_K X_T}$

F_K = Ratio of specific heat factors
 X_T = Rated pressure drop ratio factor
 G = Specific gravity
 Z = Compressibility factor

For choke flow in valve

$$Q = 907.1 C_V P_1' \sqrt{\frac{F_K X_T}{G T Z}} \quad \text{per Encl. (2)}$$

$$\Delta P \text{ choked} = F_K X_T P_1'$$



Sonic Velocity Equation

$$V_S = \sqrt{\frac{4637 K_1 P_1}{\rho}} \quad \text{per Ref. (b)}$$

Determination of the flow conditions will be performed as follows:

1. Calculate density at the end condition

$$\rho_{N+1} = \left(\frac{P'_{N+1}}{P'_N} \right)^{1/K_1} \rho_1$$

2. Calculate an estimated initial velocity based on beginning and end conditions.

$$V(1) = \sqrt{\frac{\left(\frac{P'_{N+1}}{\rho_{N+1}} - \frac{P'_1}{\rho_1} \right) 286g}{\left(1 - \left(\frac{D_1}{D_{N+1}} \right)^4 - K \right)}} \quad \text{Derived from equations 1.3, 2.2 and 2.5 of Ref. (b)}$$

where $K = K(1) + K(2) + \dots + K(N+1) = \text{Total resistance of the system}$

3. Using the initial velocity $V(1)$, calculate ΔP for all the stations as shown below

For $I = 1$ to N

$$\rho = \rho(I)$$

$$\rho(I+1) = \rho$$

$$V(I+1) = D(I)^2 V(I) \rho(I) / D(I+1)^2 / \rho(I+1)$$

$$P(I) = P(I) - 14.7$$

$$P(I+1) = \rho(I+1) \left(\frac{P(I)}{\rho(I)} + \frac{V(I)^2 (1 - K(I))}{9274} \right) - \frac{V(I+1)^2}{9274}$$

$$P(I) = P(I) + 14.7 \quad P(I+1) = P(I+1) + 14.7$$

$$\rho(I+1) = \rho(I) \left(\frac{P(I+1)}{P(I)} \right)^{1/K_1}$$

$$\text{If } |\rho(I+1) - \rho| > .0005 \text{ then } \rho = \rho - .0005$$

and recalculate $P(I+1)$

Note: This is done since $\rho(I+1)$ is a function of $P(I+1)$ and vice versa.

$$T(I+1) = T(I) \left(\frac{P(I+1)}{P(I)} \right)^{(K_1-1)/K_1}$$



For determining the ΔP across the valves, the equation for Q given on the preceding page is used. Solving for ΔP from this equation results in a cubic equation with the smallest root being equal to the actual drop across the valve.

4. With the final pressure $P(N+1)$ calculated, this pressure is compared to the final pressure given. For this particular study the final pressure is atmospheric.

If the calculate pressure is less than the given final pressure, then the initial velocity is decreased and Step 3 is repeated. The initial velocity is increased if the calculated final pressure is greater than the given final pressure.

5. Steps 3 and 4 are repeated until the calculated final pressure approximately equals the given final pressure.
6. If sonic velocity is encountered at any of the stations the initial velocity is decreased until Step 5 is achieved or until the calculated sonic velocity approximately equals the actual sonic velocity.
If the latter is the case then the given final pressure is assumed and the pressures at the stations between the outlet and the station at which sonic flow occurs are determined by using the equation given in Step 3 in reverse order and using the flow, Q , based on the sonic velocity.
7. If choke flow is encountered in any of the valves then the same approach is taken as given in Step 6.
8. To determine the flow conditions for the various valve angles, the C_v of the valve closing is determined for the angle of interest and Steps 1 thru 7 are repeated.

The above is formulated into the computer program "FLOW-GAS."



Simulation of the Actuator Stroking the Valve Close

In order to simulate the closing of the valve, an equation which describes the torques acting on the valve stem has to be defined. This equation is given below:

$$T_{TTO} = T_{flow} + T_{air} + T_{spring} + T_{packing \text{ and seal}} + T_{bearing}$$

Where T_{TTO} = The net torque tending to open the valve (equals zero when the valve starts to close).

T_{flow} = The torque due to aerodynamic flow caused by the LOCA.

T_{air} = The torque exert by the actuator as a result of the air acting on the actuator piston tending to open the valve.

T_{spring} = The torque exerted by the actuator spring tending to close the valve.

$T_{packing \ \& \ seal}$ = Torque of the packing and the seal resisting the closing motion of the valve. The seal torque does not take affect until the disc begins to seal which occurs at approximately 3° from fully closed. The running torque of the packing is approximately .6 times the break away torque.

$T_{bearing}$ = Torque due to the ΔP acting across the valve which forces the stem/disc assembly into the bearings.



Derivation of Torque EquationsAerodynamic Torque (T_{flow})

Since Posi-Seal has only determined hydrodynamic torques for water based on testing, see Encl. (3), a way to determining aerodynamic torques for air and steam from those for water has to be derived.

The resultant drag and lift forces acting on the disc are as follows:

$$F_D = C_D \rho \frac{V^2 A}{2} \quad \text{Resultant Drag Force}$$

$$F_L = C_L \rho \frac{V^2 A}{2} \quad \text{Resultant Lift Force}$$

The resultant torque is the resultant force times the length from ξ of stem to the location of the resultant force.

$$\therefore T_D = C_D L_D \rho \frac{V^2 A}{2} \quad \text{Resultant Drag Torque}$$

$$T_L = C_L L_L \rho \frac{V^2 A}{2} \quad \text{Resultant Lift Torque}$$

$$T_{D,L} = C_{D,L} L_{D,L} \rho \frac{V^2 A}{2}$$

Where V = Velocity

A = Surface Area

ρ = Density of Fluid

C_D, C_L = Drag and Lift Coefficients (Dependent upon shape and orientation of disc)

L_D, L_L = Length ξ stem to resultant lift and drag forces

D,L = Combined Subscript



NOTE: $C_{D,L}$ and $L_{D,L}$ are the same for the same size and class valve, assuming the same angular position, regardless of fluid, flow, media or temperature.

$$\therefore \frac{T_{\text{fluid}}}{T_{\text{water}}} \approx \frac{\rho_{\text{fluid}} V_{\text{fluid}}^2}{\rho_{\text{water}} V_{\text{water}}^2}$$

$$T_{4F} = \rho_F \frac{T_{4W} V_F^2}{62.4 V_W^2}$$

Where W = Water

F = Fluid

$$\rho_{\text{water}} = 62.4 \text{ lbs./ft}^3$$

V_F = Calculated in the determination of the flow conditions

$$V_W = .00223 \frac{Q}{A} = .00223 \frac{C_V}{A} \sqrt{\Delta P}$$

T_{4W} = Disc Hydrodynamic Torque per PSI ΔP (function of valve angle)

T_{4F} = Disc Aerodynamic Torque per PSI ΔP

The total aerodynamic torque equals

$$T_F = \int_F \frac{T_{4W} V_F^2}{62.4 V_W^2} \Delta P$$



$$\text{Since } \rho_F = \frac{144 P_1}{R T_1} \quad R_{\text{Air}} = 53.34$$

$$V_F = \frac{Q T_1}{127300 P_1 A} \quad R_{\text{Steam}} = 85.76$$

$$V_W = \frac{.00223 C_v \sqrt{\Delta P}}{A}$$

$$\text{Then } T_F = \frac{144 P_1}{R T_1} \left(\frac{T_{LW}}{62.4} \right) \left(\frac{Q T_1}{127300 P_1 A} \right)^2 \quad \Delta P$$

$$\qquad \qquad \qquad \frac{.00223 C_v \sqrt{\Delta P}}{A}$$

$$T_{\text{Air}} = .04326 T_{LW} \frac{P_1}{P_1} \left(\frac{Q}{253.5 C_v} \right)^2$$

$$T_{\text{Steam}} = .0269 T_{LW} \frac{P_1}{P_1} \left(\frac{Q}{283.0 C_v} \right)^2$$

Values for C_v and T_{LW} can be found in Enclosures (2) and (4) respectively for various valve angles.

For critical flow the equations can be simplified to:

$$T_{\text{Air}} = .441 T_{LW} \frac{F_K X_T P_1}{G Z}$$

$$T_{\text{Steam}} = .274 T_{LW} \frac{F_K X_T P_1}{G Z}$$

The above aerodynamic torque equations have also been incorporated into "FLOW-GAS" computer program such that the torque resulting from a LOCA can be determined for every 10° of valve closure.

In performing the LOCA analysis it is assumed that the valves close individually. This assumption is made for two reasons. The first is for ease of analysis. The second reason being, this is considered to be more conservative since if both valves close simultaneously the resistance in the system will be greater; consequently, the flow will be less and the aerodynamic torque will be less.



Pneumatic Torque (T_{air})

$$T_{air} = \frac{A R P_1}{C_2}$$

- Where
- A = Area of piston
 - $A = \frac{D_c}{2R}$
 - $A = \frac{1728 V}{2R} \left(\frac{14.7}{P+14.7} \right)$
 - R = Radius of Scotch Yoke (See Figure 4)
 - $P_1 = \text{Pressure of the air in the piston cylinder}$
 - $= \frac{P_1 (V - \Delta V)}{V}$
 - $\Delta V = \text{Change in Volume}$
 - $= \frac{dt * Q}{3600}$
 - Q = Flow thru solenoid valve or quick exhaust
 - $= \frac{963 C_{vs} F_{LS} P_1 \sqrt{1 - .25 (F_L)^2}}{\sqrt{GT}}$
 - $C_{vs} = C_v \text{ of solenoid valve or quick exhaust}$
 - $F_{LS} = \text{Rated liquid pressure recovery factor of a solenoid valve or quick exhaust} = .9$
 - G = Specific Gravity of Air = 1
 - T = Temperature ° Rankine = Assume equals 530°
 - Q = 33.62 $C_v P_1$
 - C2 = Equation describing the advantage of the Scotch yoke as a function of angle.

NOTE: In order to take the effect of the building atmospheric pressure into consideration the initial pressure for P_1 is equal to the working pressure of the actuator minus the building atmospheric pressure.






Figure 4

Forces acting on Scotch Yoke Pin




Figure 5

Summing forces in the horizontal direction

$$F_H - \cos \theta F_R - \mu \sin \theta F_R = 0$$

$$F_R = F_H / (\cos \theta + \mu \sin \theta)$$

F_R = Resultant Force

F_H = Horizontal Force

$$T_R = F_R R' = \frac{F_R R}{\cos \theta} = \text{Resultant Torque}$$

$$T_R = \frac{T}{\cos \theta (\cos \theta + \mu \sin \theta)}$$


$$C2 = \cos \theta (\cos \theta + \mu \sin \theta)$$



Spring Torque (T_{spring})

$$T_{\text{spring}} = \frac{K X^2 R}{C}$$

Figure 6



$K = \text{Springrate}$

$$= \frac{\Delta F}{\Delta X} = \frac{T_{\text{spring beginning}} - T_{\text{spring ending}}}{1.414 (1.414)R \quad \Delta X}$$

$$K = \frac{T_{\text{spring beginning}} - T_{\text{spring ending}}}{4R^2}$$

$$X_2 = X_1 + R (1 + \tan \theta)$$

$$X_1 = \frac{T_{\text{spring ending}} C^2 @ \theta = 45}{KR}$$

$$X_1 = \frac{.571 T_{\text{spring ending}}}{KR}$$

$$X_2 = \frac{.571 T_{\text{spring ending}}}{KR} + R (1 + \tan \theta)$$

Bearing Torque (T_{bearing})

$$T_{\text{bearing}} = \frac{\pi \mu P D^2 d}{8}$$

where μ = Coefficient of friction
= .059 for bronze bearings

D = Disc gage diameter

d = Stem diameter



The torque equations are formulated into the computer program "FLOW-CL". This program calculates the various torques acting on the valve and the amount of valve closure as time is incremented until which time the valve is fully closed. In order to determine the aerodynamic torque for angles other than the ten degree increments calculated by "FLOW-GAS" the values for the densities, pressure drops and velocities are taken from "FLOW-GAS", interpolated to correspond to the angle of interest and then the aerodynamic torques are calculated based on those values. The reason for calculating aerodynamic torque in this manner is that density, pressure drop and velocity are more linear between the ten degree increments than is the aerodynamic torque. However, for those cases where there is a bend upstream of the valve the torque is inputted directly. The program used for this is "FLOW-CL1".

SEISMIC ANALYSIS

The equations used for the seismic analysis are those given in Reference (c). The only difference between the seismic analyses performed in this report and those performed in Reference (c) is the analyses in this report use the torque resulting from a LOCA for input rather than operational torques.



DETAILED ANALYSISDetermination of LOCA Torques

Per Reference (d) when a Loss of Coolant Accident (LOCA) occurs the pressure inside containment will increase to 45 psig and 3.1 psig outside containment. The temperature inside of containment during an accident can range from 135 degrees F. to 340 degrees F., for outside containment the range is from 104 degrees F. to 275 degrees F.

To perform the LOCA analysis it is assumed for conservatism that the pressure drop across each piping system investigated is the full 45 psig. However, the actuators outside containment are subjected to the 3.1 psig.

Since the make up of the media is not known, three different conditions are analyzed using the first case to determine which condition results in the largest aerodynamic torques. This condition is then used in the analysis of the other piping systems. The three conditions investigated are as follows:

<u>Condition</u>	<u>Media</u>	<u>Temperature (Degrees F)</u>
1	Air	135
2	Air	340
3	Steam	292 (Saturated)

As can be seen in Appendix B, Condition 2 resulted in the largest torques.



The torques resulting from a LOCA based on Condition 2 are determined using the program "FLOW-GAS". The computer results can be seen in Appendix B on the pages as described below:

<u>Case</u>	<u>Page</u>
1A	B-5
1B	B-17
2A	B-25
2B	B-30
3A	B-35
3B	B-40
3C	B-45
4A	B-49
4B	B-54
4C	B-59

As can be seen in Appendix A just upstream from valves AOV107, 109, 110 and 111 are bends. Therefore, the effects of these bends on the aerodynamic torques during a LOCA have to be determined.


Posi-Seal has performed an investigation to determine what effect a pipe bend will have. To date this investigation has not revealed anything Posi-Seal can use with confidence. Consequently, Posi-Seal has taken the following approach:

1. Assume the flow results in a resultant load acting at the midpoint between the edge of the disc and the stem centerline.
2. Determine the load based on the principles of impulse and momentum.
3. Calculate the resulting torque choosing the angle of attack which results in the worst case when added to the aerodynamic torque of the normal flow thru the valve.



The assumption that the flow resultant acts at the midpoint between the edge of the disc and the stem center line with a bend upstream is based on the following:

1. For flow through a straight pipe the largest aerodynamic torque will occur at 80 degrees open for flow in the preferred direction and 90 degrees for flow in the nonpreferred direction. This torque is predominately due to the lift and drag forces acting on the disc. Only a small amount of torque is due to the flow impacting on the disc since the moment arm is relatively small.
2. It is assumed that the resultant of the flow impacts the disc at the midpoint between the disc edge and the stem center line throughout the closure from 90 degrees open to fully closed. Although this may not be conservative at the smaller angles, it will result in very conservative results at 80 and 90 degrees where the maximum torques due to the lift and drag forces occur. See the diagram below.



Velocity profile with resultant acting at midpoint between disc edge and stem ξ

Valve at 80 degrees

Velocity profile acting on the disc at 80 degrees and the corresponding resultant.

Figure 7

Posi-Seal uses the full value of F_R throughout the valve closure.



The magnitude of the force impacting the disc is determined by using the principles of impulse and momentum as follows:

$$\Delta M V_1 + F \Delta t = \Delta M V_2$$

$$V_2 = 0$$

$$\Delta M V_1 = F \Delta t$$

where ΔM = Change in mass - lbm

V = Velocity - ft/sec

F = Force - lbs

Δt = Change in time

$$\Delta M = \frac{A \rho V \Delta t}{g}$$

where A = Area - ft²

ρ = Density - lbm/ft³

g = Gravitational Constant

$W = A \rho V =$ Flow - lbs/sec

$$\frac{W \cdot V_1}{g} \Delta t = F \Delta t$$

$$F = \frac{W V_1}{g}$$

$$W = \frac{.0764 Q G}{3600}$$

where Q = Flow - SCFH

$$F = \frac{.0764 Q V G}{32.2 (3600)} = \frac{Q V G}{1.517 \times 10^6}$$

G = Specific Gravity



The magnitude of the force impacting the disc is determined by using the principles of impulse and momentum as follows:

$$\Delta M V_1 + F \Delta t = \Delta M V_2$$

$$V_2 = 0$$

$$\Delta M V_1 = F \Delta t$$

where ΔM = Change in mass - lbm

V = Velocity - ft/sec

F = Force - lbs

Δt = Change in time

$$\Delta M = \frac{A \rho V \Delta t}{g}$$

where A = Area - ft²

ρ = Density - lbm/ft³

g = Gravitational Constant

$W = A \rho V$ = Flow - lbs/sec

$$\frac{W V_1}{g} \Delta t = F \Delta t$$

$$F = \frac{W V_1}{g}$$

$$W = \frac{.0764 Q G}{3600}$$

where Q = Flow - SCFH

$$F = \frac{.0764 Q V}{32.2 (3600)} = \frac{Q V G}{1.517 \times 10^6}$$



DETERMINATION OF AERODYNAMIC TORQUES RESULTING FROM THE BENDSValve AOV110 (Case 2B)

With this valve installed in the preferred direction it is recommended that the valve be orientated as shown below such that flow assists closing of the valve. With this orientation the direction of the flow resultant is assumed to be in line with the tangent to the inside diameter of the bend and the arc of the midpoint as the valve closes. See Figure 9 on Page 28.




Figure 8

This resultant direction is chosen since it results in the largest impingement torques when added to the normal flow induced torques. This represents the worst case, stress wise, in terms of the torque the valve assembly will be subject to. These torques are:

<u>Degree</u>	<u>Q</u> (Per Appendix B)	<u>V</u>	<u>F</u>
90	4,646,000	633.8	1941
80	4,470,000	642.2	1892
70	3,982,000	647.2	1699
60	3,068,000	619.7	1253
50	2,289,000	526.8	795
40	1,552,000	388.3	397
30	958,000	250.3	158
20	483,000	128.4	41
10	244,000	65.2	10






Figure 9

NINE MILE PT. NUCLEAR STA. - UNIT 2
VENTILATION REACTOR BLDG.
AIR COOL & PURGE SECTIONS

SCALE 1/8" = 1'



$$R = D/4 \cos (20-\theta)$$

<u>Degree</u>	<u>R</u>	<u>T_R</u>	<u>T_{LOCA}</u> (Per Appendix B)	<u>T_{Total}</u>
90	1.11	-2153	-5433	-7586
80	1.62	-3068	-6516	-9584
70	2.08	-3542	-3954	-7496
60	2.48	-3113	- 730	-3113
50	2.81	-2233	741	-1492
40	3.05	-1210	1217	7
30	3.19	- 504	1393	888
20	3.24	- 133	1436	1303
10	3.19	- 32	1445	1413

A positive torque indicates that the valve will tend to remain open.

AOV107 (Case 3A)

As with Valve AOV110, this valve should be oriented as shown below such that the flow assists in closing the valve.





Figure 10

The total torque is calculated in the same manner as for AOV110 with the flow resultant being as shown on Page 30.





NINE MILE PT. NUCLEAR STA.-UNIT 2
 VENTILATION REACTOR BLDG.
 AIR COOL & PURGE SECTIONS

SCALE: 1/8" = 1"

Figure 11



<u>Degree</u>	<u>Q</u> (Per Appendix B)	<u>V</u>	<u>E</u>
90	3,395,000	508	1137
80	3,302,000	549	1195
70	3,080,000	554	1125
60	2,443,000	557	897
50	1,811,000	508	606
40	1,221,000	394	317
30	747,600	260	128
20	378,500	136	34
10	191,400	69.5	9

$$R = \frac{D}{4} \cos (10 - \theta)$$


<u>Degree</u>	<u>R</u>	<u>T_R</u>	<u>T_{LOCA}</u> (Per Appendix B)	<u>T_{Total}</u>
90	.51	- 580	-2295	-2875
80	1.00	-1195	-2796	-3991
70	1.46	-1643	-1678	-3321
60	1.88	-1686	- 80	-1766
50	2.24	-1357	759	- 598
40	2.53	- 802	1056	254
30	2.75	- 352	1172	820
20	2.88	- 98	1202	1104
10	2.93	- 26	1209	1183

Valve AOV109 (Case 4A)

This valve should be orientated in the same manner as valve AOV107.

The determination of the total torque is based on the flow resultant as shown on Page 32.





- 32 -

12" CLASS 150 POSI-SEAL VALVE # AOV-109

Figure 12

NINE MILE PT. NUCLEAR STA.-UNIT 2

VENTILATION REACTOR BLDG.
AIR COOL & PURGE SECTIONS

SCALE: 1/8" = 1"



<u>Degree</u>	<u>Q</u> (Per Appendix B)	<u>V</u>	<u>E</u>
90	3,332,000	532	1169
80	3,247,000	535	1145
70	3,039,000	536	1074
60	2,438,000	485	779
50	1,811,000	494	590
40	1,219,000	389	313
30	752,600	260	129
20	378,800	136	34
10	191,500	69.5	9

$$R = \frac{D}{4} \cos (20 - \theta)$$

<u>Degree</u>	<u>R</u>	<u>T_R</u>	<u>T_{LOCA}</u> (Per Appendix B)	<u>T_{Total}</u>
90	1.00	-1169	-2127	-3296
80	1.46	-1672	-2647	-4319
70	1.88	-2019	-1571	-3590
60	2.24	-1745	15	-1730
50	2.53	-1492	760	-732
40	2.75	-860	1055	195
30	2.88	-372	117	799
20	2.93	-100	1202	1102
10	2.88	-26	1209	1183

Valve AOV111 (Case 4C)

It is recommended with this valve in the preferred direction it be orientated as shown below:




Figure 13



The calculated torques for valve AOV111 are as follows with the resultant flow as shown on Page 35.

<u>Degree</u>	<u>Q</u> (Per Appendix B)	<u>Y</u>	<u>E</u>
90	3,444,000	631.5	1434
80	3,444,000	720.1	1635
70	3,049,000	642.5	1291
60	2,376,000	632.0	990
50	1,785,000	548.3	645
40	1,212,000	409.2	327
30	749,000	265.4	131
20	377,000	136.6	34
10	191,000	69.4	9


$$R = \frac{D}{4} \cos (20 - \theta)$$

<u>Degree</u>	<u>R</u>	<u>T_R</u>	<u>T_{LOCA}</u> (Per Appendix B)	<u>T_{Total}</u>
90	1.00	-1592	-2813	-4404
80	1.46	-2649	-4127	-6776
70	1.88	-2685	-2044	-4729
60	2.24	-2455	-156	-2611
50	2.53	-1812	751	-1061
40	2.74	-997	1058	61
30	2.88	-418	1174	756
20	2.93	-110	1203	1093
10	2.88	-29	1209	1180



90° LONG RADIUS
WELDELL

12" CLASS 150 FULL-SEAL
VALVE #2CPS-AOVIII



- 35 -

Figure 14

NINE MILE PT. NUCLEAR STA.-UNIT:

VENTILATION REACTOR BLDG.
AIR COOL & PURGE SECTIONS

SCALE $\frac{1}{8}'' = 1'$



Seismic Analysis

For the seismic analysis each valve is analyzed based on the maximum torque resulting from a LOCA. The valve angle which results in the largest torque is 80 degrees. If this torque results in overstressing of the valve then the amount of valve angle is restricted to 70 degrees and the stress determined based on the LOCA torque at that angle. If that results in overstressing then the valve angle is restricted to 60 degrees.

The various seismic analyses are given in Appendix C on the pages listed below.

<u>Case</u>	<u>Angle of Max Torque</u>	<u>Page</u>
1A	80°	C-1
1B	80°	C-4
2A	80°	C-7
2B	80°	C-10
	70°	C-13
3A	80°	C-15
	70°	C-18
3C	80°	C-20
	0°	C-23
4A	80°	C-25
	70°	C-28
4C	80°	C-30
	70°	C-33
	60°	C-35



DETERMINATION OF CLOSING TIMES

Shown in Appendix D are the calculated closing times. These closing times are based on the aerodynamic torques determined in Appendix B and the section pertaining to the influence of bends. They are calculated using the computer programs "FLOW-CL" and "FLOW-CL1".

The closing times are determined for all the valves being fully opened. They are also determined for those valves where it is recommended that the amount of valve opening be restricted.

Shown in Appendix E is a comparison of actual closing times to those calculated.



APPENDIX A

SCHEMATIC OF THE PIPING SYSTEM

NOTE: The orientation of the valves is based on the normal flow directions given on Posi-Seal assembly drawings, Enclosure (1)..




CASE 1

14" - 150 Class Valves 2CPS*AOV 104 & 106

Worse Condition

Piping outboard of valve 2CPS*AOV104 breaks off.

The resulting system is as shown below.

Per References
(e) & (f)Station No.Type of Resistance (No.)

1	Entrance (1)	$K = .5$ $D_{in} = 14"$
2	Valve (7) Flow in the Preferred Direction	$C_v = 6317$
3	Straight Pipe (4)	$L = 11'$
4	Valve (7) Flow in the Preferred Direction	$C_v = 6317$
5	Exit (8)	$K = 1.0$ $D_{out} = 14"$

Case 1A - Valve AOV106 Cycles.
1B - Valve AOV104 Cycles




CASE 2

14" - 150 Class Valves 2CPS*AOV 108 & 110

Worse Condition

Piping outboard of valve 2CPS*AOV110 breaks off.

The resulting system is as shown below.

Per References
(e) & (g)

<u>Station No.</u>	<u>Type of Resistance (No.)</u>	
1	Entrance (1)	$K = .5 \quad D_{in} = 14"$
2	Valve (7) Flow in the Preferred Direction	$C_v = 6317$
3	Straight Pipe (4)	$L = 9'$
4	Bend 90 Degrees (5)	$K = 12 \quad f_c = .16$
5	Straight Pipe (4)	$L = 3'$
6	Valve (7) Flow in the Preferred Direction	$C_v = 6317$
7	Exit (8)	$K = 1 \quad D_{out} = 14"$

Case 2A - Valve AOV108 Cycles
 2B - Valve AOV110 Cycles




CASE 3

12" - 150 Class Valves 2CPS*AOV 105 & 107

Worse Condition

Piping outboard of valve 2CPS*AOV105 breaks off.

The resulting system is as shown below.



<u>Station No.</u>	<u>Type of Resistance (No.)</u>	
1	Entrance (1)	$K = .5 \quad D_{in} = 12''$
2	Straight Pipe (4)	$L = 6.77'$
3	Bend 90 Degrees (5)	$K = 12 \quad f_t = .16$
4	Straight Pipe (4)	$L = 4.76$
5	Valve (7) Flow in the Nonpreferred Direction	$C_V = 4942$
6	Straight Pipe (4)	$L = 11'$
7	Valve (7) Flow in the Nonpreferred Direction	$C_V = 4942$
8	Exit (8)	$K = 1 \quad D_{out} = 12''$

- Case 3A - Valve AOV107 Cycles
 3B - Valve AOV105 Cycles
 3C - Valve AOV105 Cycles with piping upstream of
 Valve AOV107 broken off




CASE 4

12" - 150 Class Valves 2CPS*AOV 109 & 111

Worse Condition

Piping outboard of valve 2CPS*AOV111 breaks off.

The resulting system is as shown below.



<u>Station No.</u>	<u>Type of Resistance (No.)</u>	
1	Entrance (1)	$K = .5 \quad D_{in} = 12''$
2	Straight Pipe (4)	$L = 9'$
3	Bend 90 Degrees (5)	$K = 12 \quad f_t = .16$
4	Straight Pipe (4)	$L = 3.77'$
5	Valve (7) Flow in the Preferred Direction	$C_v = 4942$
6	Straight Pipe (4)	$L = 9'$
7	Bend 90 Degrees (5)	$K = 12 \quad f_t = .16$
8	Straight Pipe (4)	$L = 4'$
9	Valve (7) Flow in the Nonpreferred Direction	$C_v = 4942$
10	Exit (8)	$K = 1 \quad D_{out} = 12''$

- Case 4A - Valve AOV109 Cycles
 4B - Valve AOV111 Cycles
 4C - Valve AOV111 Cycles with piping upstream of
 Valve AOV107 broken off



APPENDIX B

Determination of Flow Conditions



CASE 1A

CONDITION 1

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"

VALVE CLASS: 150

ACTUATOR: Bettis N721C-SR90-M3H4

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 135 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY 2.71 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1.0

HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN. LBS
PSI

STEM DIA. 1.375 IN.

PACKING TORQUE 832 IN. LBS.

DIRECTION Preferred

GAGE DIA. 12.974 IN

SEAL TORQUE 1454 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

UPSTREAM PRESSURE	INITIAL TEMPERATURE	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	27.1	135	14.7	59.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	290 DEG

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.375	2.774	832	1434

STATION NO.	TYPE OF RESISTANCE	DIAMETER (D)	LENGTH (L)	RESISTANCE (K)	CORRECTED RESISTANCE (K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.171	0.17142
4	VALVE	14.0	0.0	0.860	0.86066
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW = 5,447,632 SCFH

STATION	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	398.9
2	53.5	0.2506	130.8	430.7
3	48.0	0.2320	126.3	485.2
4	46.0	0.2252	125.3	478.5
5	39.1	0.2003	119.6	539.6
6	14.7	0.0773	70.4	1085.5

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT
VALVE TORQUE = 3,101 IN. LBS
DELTA P = 45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	5,447,632	9.66	6,115	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	398.9
2	53.5	0.2506	130.9	430.7
3	48.0	0.2320	126.8	465.1
4	48.0	0.2292	125.3	472.5
5	39.1	0.2003	119.6	539.6
6	14.7	0.0995	90.4	1085.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	5,447,632	9.66	6,115	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	398.9
2	53.5	0.2506	130.9	430.7
3	43.8	0.2173	123.6	496.6
4	41.6	0.2095	121.7	514.4
5	32.8	0.1767	113.7	611.8
6	14.7	0.0995	90.4	1085.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	4,828,829	14.98	3,415	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	353.6
2	55.1	0.2561	131.9	373.6
3	40.2	0.2042	120.5	468.5
4	38.5	0.1983	119.1	481.5
5	31.6	0.1722	112.6	554.4
6	14.7	0.1012	91.0	938.5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	3,708,674	29.57	613	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	271.6
2	57.2	0.2631	133.4	279.3
3	27.7	0.1566	108.4	469.7
4	26.6	0.1523	107.2	483.0
5	22.6	0.1357	102.3	542.1
6	14.7	0.0995	90.4	739.1

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,711,930	37.75	752	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	198.3
2	58.5	0.2671	134.2	201.2
3	20.7	0.1274	99.8	422.3



12.3 0.113 90.4 400.2
 14.7 0.0995 90.4 500.4

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,812,259	42.07	1,215	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	132.7
2	59.2	0.2709	134.9	132.2
3	17.2	0.1114	94.6	322.8
4	16.9	0.1104	94.2	325.6
5	16.1	0.1087	92.9	335.9
6	14.7	0.0995	90.4	361.1

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	1,109,994	43.97	1,391	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	81.2
2	59.6	0.2706	134.9	81.2
3	15.0	0.1040	92.0	211.7
4	15.5	0.1037	91.9	212.4
5	15.2	0.1021	91.3	215.6
6	14.7	0.0995	90.4	221.2

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	561,987	44.26	1,435	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	41.1
2	59.6	0.2709	134.9	41.1
3	15.0	0.1010	90.9	110.3
4	14.7	0.1009	90.7	110.4
5	14.8	0.1002	90.6	111.2
6	14.7	0.0995	90.4	112.0

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	284,134	44.91	1,444	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	20.8
2	59.6	0.2709	134.9	20.8
3	14.7	0.0999	90.5	56.4
4	14.7	0.0999	90.5	56.4
5	14.7	0.0997	90.5	56.5
6	14.7	0.0995	90.4	56.6

NOTE: THERE IS CHOKED FLOW AT STATION 2

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN

1781



CASE 1A

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"
VALVE CLASS: 150
ACTUATOR: Bettis N721C - SR80 - M3HW

UPSTREAM PRESSURE 59.7 PSIA
INITIAL TEMPERATURE 340 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.4
COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Air
SPECIFIC GRAVITY 1
HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN.LBS
PSI

STEM DIA. 1.375 IN.
PACKING TORQUE 832 IN.LBS.
DIRECTION Preferred

GAGE DIA. 12.974 IN
SEAL TORQUE 1454 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



~~CONTROL SYSTEM ANALYSIS~~

VALVE SIZE=14

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE 59.7	INITIAL DENSITY-110°C 0.2010	INITIAL TEMPERATURE 340	FINAL PRESSURE 14.7	SHUT-OFF PRESSURE 59.7
MEDIA AIR	RATIO OF SP. HEAT 1.4	SPECIFIC GRAVITY 1	COMPRESSIBILITY 1	HYDRODYNAMIC FACTOR 890-060 1182
STEM DIA. 1.375	GAGE DIA. 12.974	PACKING TORQUE 832	SEAL TORQUE 1454	

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGHT-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.141	0.14142
4	VALVE	14.0	0.0	0.360	0.36033
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN

FLOW= 4,727,176 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	483.4
2	53.5	0.1860	329.6	501.6
3	48.0	0.1722	319.6	541.9
4	48.1	0.1672	313.7	556.4
5	39.2	0.1489	301.5	628.1
6	14.7	0.0738	227.8	1266.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT

VALVE TORQUE= 3,101 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	4,727,176	9.74	- 6,170	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	465.4
2	53.5	0.1860	329.6	501.6
3	48.0	0.1722	319.6	541.9
4	43.8	0.1611	311.2	579.0
5	39.2	0.1489	301.5	628.1
6	14.7	0.0738	227.8	1266.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	4,727,176	9.74	- 6,170	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	465.4
2	53.5	0.1860	329.6	501.6
3	43.8	0.1611	311.2	579.0
4	41.7	0.1557	306.9	597.5
5	33.1	0.1321	287.3	706.0
6	14.7	0.0738	227.8	1266.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	4,185,884	15.15	- 3,450	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	412.1
2	55.2	0.1900	332.4	454.9
3	40.0	0.1511	303.3	548.7
4	38.4	0.1467	299.8	561.8
5	31.6	0.1277	283.6	645.4
6	14.7	0.0738	227.8	1162.7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	3,202,679	29.86	- 622	

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	315.3
2	57.3	0.1951	336.0	324.2
3	27.4	0.1153	272.2	549.5
4	26.4	0.1123	269.4	563.9
5	22.6	0.1006	257.8	629.7
6	14.7	0.0738	227.8	858.1

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,339,992	37.94	752	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	230.4
2	58.5	0.1982	338.1	233.3
3	20.5	0.0939	250.8	492.8



7	15.3	0.0738	227.8	324.0
8	14.7	0.0738	227.8	327.0

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,565,243	42.12	1,217	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	154.1
2	59.3	0.2001	339.3	154.2
3	17.2	0.0826	238.2	374.8
4	16.9	0.0819	237.4	378.1
5	16.1	0.0791	234.2	371.3
6	14.7	0.0738	227.8	419.4

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	957,243	44.00	1,392	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	94.2
2	59.6	0.2007	339.8	94.2
3	15.8	0.0770	231.7	245.8
4	15.5	0.0768	231.4	246.6
5	15.2	0.0757	230.1	250.0
6	14.7	0.0738	227.8	258.5

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	483,747	44.87	1,435	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	47.6
2	59.6	0.2009	339.9	47.6
3	14.9	0.0749	229.1	127.7
4	14.9	0.0748	229.0	127.7
5	14.8	0.0743	228.4	128.7
6	14.7	0.0738	227.8	129.6

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	244,569	44.91	1,444	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	24.0
2	59.6	0.2009	339.9	24.0
3	14.7	0.0741	228.1	65.2
4	14.7	0.0741	228.1	65.3
5	14.7	0.0739	227.9	65.4
6	14.7	0.0738	227.8	65.5

NOTE: THERE IS CHOKED FLOW AT STATION 2

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 1A

CONDITION 3

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"
VALVE CLASS: 150
ACTUATOR: Butts 11721C-SR80-M3HW

UPSTREAM PRESSURE 59.7 PSIA
INITIAL TEMPERATURE 292 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.212
COMPRESSIBILITY 1

INITIAL DENSITY .138 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Sat. Steam
SPECIFIC GRAVITY .62
HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN. LBS
PSI

STEM DIA. 1.375 IN.
PACKING TORQUE 932 IN. LBS.
DIRECTION Ported

GAGE DIA. 12.974 IN
SEAL TORQUE 1454 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



VALVE SIZE=14

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY-X10+2	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	13.8	292	24.7	29.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
SAT. STEAM	1.312	.62	1	1182

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.375	12.974	832	1454

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.141	0.14142
4	VALVE	14.0	0.0	0.260	0.26066
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN

FLOW= 5,375,146 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	545.8
2	53.3	0.1266	284.2	592.9
3	48.3	0.1175	277.7	638.9
4	46.5	0.1141	275.1	655.8
5	40.3	0.1024	266.0	735.2
6	14.7	0.0474	209.2	1587.9

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT

VALVE TORQUE= 3,101 IN. LBS
 DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	5,895,146	8.77	- 5,789	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	545.6
2	53.3	0.1266	284.2	592.9
3	48.3	0.1175	277.7	638.9
4	46.5	0.1141	273.1	655.6
5	40.3	0.1024	266.0	735.2
6	14.7	0.0474	209.2	1587.9

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	5,895,146	8.77	- 5,789	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	545.6
2	53.3	0.1266	284.2	592.9
3	44.5	0.1104	272.3	679.9
4	42.5	0.1065	269.3	702.2
5	35.2	0.0922	257.3	816.6
6	14.7	0.0474	209.2	1587.9

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	5,279,451	14.10	- 3,317	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	488.6
2	54.9	0.1296	286.3	518.7
3	40.8	0.1034	268.8	650.2
4	39.3	0.1004	264.4	666.3
5	33.3	0.0884	254.1	757.0
6	14.7	0.0487	211.3	1354.1

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	4,057,308	29.47	- 630	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	375.5
2	57.2	0.1336	289.1	386.7
3	27.7	0.0770	243.4	672.9
4	26.7	0.0747	241.1	693.2
5	23.3	0.0674	233.5	768.8
6	14.7	0.0474	209.2	1092.9

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,966,301	37.94	- 739	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	274.5
2	58.6	0.1361	290.7	277.5
3	20.6	0.0615	226.9	615.7



15.2 1.1380 292.0 553.2
 14.7 0.0474 209.2 490.0

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,004,824	42.23	1,210	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	184.6
2	59.6	0.1375	291.7	184.6
3	17.2	0.0534	217.2	476.5
4	17.0	0.0530	216.6	480.5
5	16.2	0.0512	214.3	497.0
6	14.7	0.0474	209.2	537.3

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	1,217,400	43.98	1,390	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	112.6
2	59.6	0.1378	291.8	112.6
3	15.8	0.0496	212.2	313.1
4	15.5	0.0494	212.0	314.2
5	15.2	0.0487	211.1	318.6
6	14.7	0.0474	209.2	327.7

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	815,184	44.67	1,435	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	56.9
2	59.6	0.1379	291.9	56.9
3	14.9	0.0481	210.2	163.1
4	14.9	0.0481	210.1	163.3
5	14.8	0.0477	209.7	164.5
6	14.7	0.0474	209.2	165.7

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	311,010	44.91	1,444	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	28.7
2	59.6	0.1377	291.7	28.7
3	14.7	0.0476	209.5	83.4
4	14.7	0.0475	209.4	83.4
5	14.7	0.0475	209.3	83.6
6	14.7	0.0474	209.2	83.7

NOTE: THERE IS CHOKED FLOW AT STATION 2

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN

1700



CASE 1B

CONDITION 1

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"
VALVE CLASS: 150
ACTUATOR: B-44; N721G-SR80-M3HW

UPSTREAM PRESSURE 59.7 PSIA
INITIAL TEMPERATURE 135 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.4
COMPRESSIBILITY 1

INITIAL DENSITY .271 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Air
SPECIFIC GRAVITY 1.0
HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN.LBS
PSI

STEM DIA. 1.375 IN.
PACKING TORQUE 832 IN.LBS.
DIRECTION Preferred

GAGE DIA. 12.974 IN
SEAL TORQUE 1754 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

VALVE SIZE=14

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY-X10+2	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	27.1	135	14.7	59.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	890 DEG 1182

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.375	12.974	832	1454

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.141	0.14142
4	VALVE	14.0	0.0	0.860	0.86066
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 5.447.632 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	398.9
2	53.5	0.2506	130.8	430.7
3	48.0	0.2320	126.8	465.1
4	44.0	0.2252	125.3	478.5
5	39.1	0.2003	119.6	539.6
6	14.7	0.0998	90.4	1085.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT

VALVE TORQUE= 3,101 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	5,447,632	6.95	- 5,440	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	398.9
2	53.5	0.2506	130.8	430.7
3	46.0	0.2320	126.8	465.1
4	46.0	0.2252	125.3	478.5
5	32.1	0.2003	112.6	539.6
6	14.7	0.0995	90.4	1085.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	5,226,233	11.22	- 6,486	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	382.7
2	54.1	0.2526	131.2	409.9
3	49.2	0.2363	127.8	438.3
4	47.5	0.2304	126.5	448.7
5	36.3	0.1901	117.1	545.5
6	14.7	0.0995	90.4	1041.5

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	4,652,050	20.82	- 3,283	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	340.7
2	55.5	0.2575	132.2	357.1
3	52.0	0.2458	129.8	374.8
4	50.9	0.2412	129.0	380.2
5	30.0	0.1659	110.9	556.3
6	14.7	0.0995	90.4	927.1

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	3,567,082	33.10	- 740	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	261.2
2	57.4	0.2637	133.5	268.1
3	55.5	0.2574	132.2	274.6
4	55.0	0.2555	131.8	276.3
5	21.8	0.1323	101.3	534.7
6	14.7	0.0995	90.4	710.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,661,389	39.16	737	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	194.9
2	58.6	0.2675	134.3	197.0
3	57.6	0.2642	133.6	199.5



4	57.3	0.2634	133.4	199.9
5	18.2	0.1160	96.1	455.2
6	14.7	0.0995	90.4	530.3

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
40	1,602,844	42.57	1,216

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	132.0
2	59.2	0.2696	134.7	132.5
3	58.8	0.2681	134.4	133.2
4	58.7	0.2679	134.3	133.2
5	16.1	0.1066	92.9	335.4
6	14.7	0.0995	90.4	359.2

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
30	1,113,245	44.16	1,393

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	81.5
2	59.6	0.2704	134.9	81.5
3	59.4	0.2701	134.8	81.6
4	59.4	0.2700	134.8	81.6
5	15.2	0.1021	91.3	216.2
6	14.7	0.0995	90.4	221.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
20	560,464	44.79	1,436

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	41.0
2	59.6	0.2709	134.9	41.0
3	59.6	0.2707	134.9	41.0
4	59.6	0.2707	134.9	41.0
5	14.8	0.1002	90.6	110.9
6	14.7	0.0995	90.4	111.6

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
10	283,334	44.94	1,445

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2710	135.0	20.7
2	59.6	0.2709	134.9	20.7
3	59.6	0.2709	134.9	20.7
4	59.6	0.2709	134.9	20.7
5	14.7	0.0997	90.5	56.3
6	14.7	0.0995	90.4	56.4

NOTE: THERE IS CHOKED FLOW AT STATION 4

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 1B

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"

VALVE CLASS: 150

ACTUATOR: Bettis 11721C-SR80-11344

UPSTREAM PRESSURE, 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1.0

HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN.LBS
PSI

STEM DIA. 1.325 IN.

PACKING TORQUE 832 IN.LBS.

DIRECTION Preferred

GAGE DIA. 12.974 IN

SEAL TORQUE 1454 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

VALVE SIZE: 14

VALVE CLASS: 150

FLOW-GAS

INITIAL PRESSURE	INITIAL DENSITY	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
340	0.2010	340	14.0	37.7
MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	1192
STEM DIA.	GASKET DIA.	PACKING TORQUE	STEM TORQUE	
1.375	12.974	832	1454	

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.141	0.14142
4	VALVE	14.0	0.0	0.500	0.50000
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW = 4,727,176 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	485.4
2	53.5	0.1860	329.6	501.6
3	48.0	0.1722	319.6	541.9
4	42.1	0.1572	309.9	583.4
5	39.2	0.1489	301.5	628.1
6	14.7	0.0738	227.8	1266.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT
VALVE TORQUE = 3,101 IN. LBS
DELTA P = 45.00 PSI



CONDITIONS AS VALVE CLOSING

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
			PRESSURE	VELOCITY
1	59.7	0.2010	340.0	446.1
2	53.5	0.1860	320.6	501.6
3	48.0	0.1722	319.3	541.9
4	44.1	0.1672	319.0	558.4
5	39.2	0.1489	301.5	629.1
6	14.7	0.0738	227.8	1266.0

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	4,530,955	11.10	-	6,519
			PRESSURE	VELOCITY
1	59.7	0.2010	340.0	446.1
2	54.1	0.1876	324.7	477.0
3	49.3	0.1754	321.9	510.1
4	47.6	0.1710	319.7	522.0
5	36.5	0.1415	296.4	635.0
6	14.7	0.0738	227.8	1214.1

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	4,030,437	20.69	-	3,998
			PRESSURE	VELOCITY
1	59.7	0.2010	340.0	396.8
2	55.6	0.1910	333.1	416.3
3	52.0	0.1822	326.9	436.7
4	50.9	0.1793	324.8	442.8
5	30.2	0.1235	279.8	645.5
6	14.7	0.0738	227.8	1077.7

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	3,080,012	33.24	-	748
			PRESSURE	VELOCITY
1	59.7	0.2010	340.0	303.7
2	57.5	0.1956	336.3	311.6
3	55.5	0.1910	333.1	319.3
4	52.0	0.1877	326.2	320.7
5	21.9	0.0982	255.3	621.7
6	14.7	0.0738	227.8	827.0

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,302,002	39.28	-	737
			PRESSURE	VELOCITY
1	59.7	0.2010	340.0	226.6
2	50.1	0.1886	320.8	228.8



57.7	0.2010	340.0	152.9
59.3	0.2001	339.4	153.2
59.8	0.1989	338.5	154.0
16.1	0.0790	234.1	388.4
14.7	0.0738	227.8	415.8

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
40	1,551,983	42.64	1,219

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	152.9
2	59.3	0.2001	339.4	153.2
3	59.8	0.1989	338.5	154.0
4	16.1	0.0790	234.1	388.4
5	14.7	0.0738	227.8	415.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
30	960,302	44.10	1,373

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	94.5
2	59.6	0.2007	339.8	94.5
3	59.4	0.2003	339.5	94.7
4	15.2	0.0757	230.1	250.7
6	14.7	0.0738	227.8	257.3

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
20	483,477	44.79	1,436

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	47.6
2	59.6	0.2009	339.9	47.6
3	59.6	0.2008	339.8	47.6
4	59.6	0.2008	339.8	47.6
5	14.8	0.0743	229.4	128.7
6	14.7	0.0738	227.8	129.5

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
10	244,414	44.94	1,445

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	24.0
2	59.6	0.2009	339.9	24.0
3	59.6	0.2009	339.9	24.0
4	59.6	0.2009	339.9	24.0
5	14.7	0.0739	227.9	65.3
6	14.7	0.0738	227.8	65.4

NOTE: THERE IS CHOKED FLOW AT STATION 4

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 1B

CONDITION 3

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"

VALVE CLASS: 150

ACTUATOR: Bettis N721 C-SR80-M3HW

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 292 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.312

COMPRESSIBILITY 1

INITIAL DENSITY 138 LB/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Sat. Steam

SPECIFIC GRAVITY .62

HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN. LBS
PSI

STEM DIA. 1.375 IN.

PACKING TORQUE 832 IN. LBS.

DIRECTION Perforated

GAGE DIA. 12.974 IN

SEAL TORQUE 1454 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

VALVE SIZE=14

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY-X10+2	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	13.8	292	14.7	59.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
STEAM	1.312	.62	1	890 DEG 1182

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.375	12.974	832	1454

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	11.0	0.141	0.14142
4	VALVE	14.0	0.0	0.860	0.86066
5	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 5,825,146 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	545.6
2	53.3	0.1266	284.2	592.9
3	48.3	0.1175	277.7	638.9
4	46.5	0.1141	275.1	655.6
5	40.3	0.1024	266.0	735.2
6	14.7	0.0474	209.2	1587.9

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 3,101 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE 90 FLOW 5,895,146 DP ACROSS VALVE 6.14 Tclosing 5,125

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	545.6
2	53.3	0.1260	284.2	592.9
3	48.3	0.1175	277.7	638.9
4	46.5	0.1141	275.1	655.6
5	40.3	0.1024	266.0	735.2
6	14.7	0.0474	209.2	1587.9

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE 80 FLOW 5,693,308 DP ACROSS VALVE 10.05 Tclosing 6,205

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	526.9
2	53.9	0.1276	284.9	568.1
3	49.4	0.1194	279.1	607.2
4	47.8	0.1165	276.9	620.1
5	37.7	0.0973	261.8	747.2
6	14.7	0.0474	209.2	1533.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE 70 FLOW 5,113,537 DP ACROSS VALVE 18.79 Tclosing 3,817

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	473.3
2	55.4	0.1305	296.9	490.6
3	52.1	0.1244	282.7	522.9
4	51.0	0.1225	281.7	529.3
5	32.2	0.0863	252.2	756.3
6	14.7	0.0474	209.2	1377.4

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE 60 FLOW 3,923,324 DP ACROSS VALVE 32.66 Tclosing 763

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	363.1
2	57.5	0.1341	289.4	372.6
3	55.7	0.1308	287.2	381.7
4	55.2	0.1300	286.6	383.2
5	22.5	0.0657	231.7	741.9
6	14.7	0.0474	209.2	1056.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE 50 FLOW 2,912,227 DP ACROSS VALVE 39.14 Tclosing 722

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.1380	292.0	269.5
2	58.6	0.1361	290.7	272.5
3	57.7	0.1344	289.6	275.9



4	57.5	0.1341	289.4	375.9
5	18.4	0.0562	220.7	660.8
6	14.7	0.0474	209.2	784.4

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing		
40	1,975,299	42.70	1,211		
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY	
1	59.7	0.1380	292.0	182.8	
2	59.4	0.1375	291.7	182.8	
3	59.0	0.1368	291.2	183.8	
4	58.9	0.1366	291.1	183.8	
5	16.2	0.0511	214.3	492.8	
6	14.7	0.0474	209.2	532.0	

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing		
30	1,216,772	44.16	1,391		
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY	
1	59.7	0.1380	292.0	112.6	
2	59.6	0.1378	291.8	112.6	
3	59.4	0.1375	291.7	112.8	
4	59.4	0.1375	291.6	112.8	
5	15.2	0.0487	211.1	318.5	
6	14.7	0.0474	209.2	327.7	

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing		
20	612,341	44.79	1,436		
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY	
1	59.7	0.1380	292.0	56.6	
2	59.6	0.1379	291.9	56.6	
3	59.6	0.1378	291.9	56.7	
4	59.6	0.1378	291.9	56.7	
5	14.8	0.0477	209.7	163.7	
6	14.7	0.0474	209.2	164.9	

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing		
10	309,559	44.94	1,445		
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY	
1	59.7	0.1380	292.0	28.6	
2	59.6	0.1379	291.9	28.6	
3	59.6	0.1379	291.9	28.6	
4	59.6	0.1379	291.9	28.6	
5	14.7	0.0475	209.3	83.2	
6	14.7	0.0474	209.2	83.3	

NOTE: THERE IS CHOKED FLOW AT STATION 4

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 2 A

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"

VALVE CLASS: 150

ACTUATOR: Butt. 11721C - SR80 - M3HW

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1

HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN. LBS
PSI

STEM DIA. 1.375 IN.

PACKING TORQUE 832 IN. LBS.

DIRECTION Proced

GAGE DIA. 12.974 IN

SEAL TORQUE 1454 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

VALVE SIZE=14

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY-X10+2	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	20.1	340	14.7	59.7
MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	270 CXC 1182
STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE	
1.375	12.974	832	1454	

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGHT-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.500	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	9.0	0.115	0.11571
4	PIPE END	14.0	0.0	0.130	0.13000
5	STRAIGHT PIPE	14.0	3.0	0.038	0.03857
6	VALVE	14.0	0.0	0.860	0.86066
7	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 4,645,997 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	457.5
2	55.7	0.1888	330.0	471.7
3	48.5	0.1734	320.5	528.9
4	47.2	0.1699	317.9	538.2
5	45.1	0.1645	315.8	554.3
6	44.7	0.1636	313.1	556.2
7	37.8	0.1450	298.4	633.8
8	14.7	0.0738	227.8	1244.7

NOTE: THERE IS CHOKED FLOW AT STATION 7

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 3,101 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSING

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	4,705,000	8.22	4,393	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	457.5
2	53.7	0.1866	330.0	491.7
3	48.5	0.1734	320.5	528.9
4	47.2	0.1697	317.7	539.2
5	45.1	0.1645	313.8	554.5
6	44.7	0.1636	313.1	556.2
7	37.8	0.1430	298.4	633.8
8	14.7	0.0738	227.8	1244.9

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	4,645,997	9.13	5,848	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	457.5
2	53.7	0.1866	330.0	491.7
3	44.8	0.1633	312.7	561.8
4	43.1	0.1593	309.8	573.9
5	40.8	0.1534	305.1	594.4
6	40.5	0.1524	304.4	596.4
7	31.8	0.1281	284.0	717.3
8	14.7	0.0738	227.8	1244.9

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	4,142,038	14.35	3,307	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	407.8
2	53.2	0.1901	332.3	430.3
3	40.9	0.1534	305.1	533.4
4	39.6	0.1501	302.5	544.1
5	37.8	0.1432	298.3	560.7
6	37.5	0.1444	297.8	562.8
7	30.7	0.1251	281.1	655.0
8	14.7	0.0738	227.8	1107.8

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	3,204,786	28.71	387	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	315.3
2	57.2	0.1951	336.0	324.4
3	38.5	0.1187	290.3	534.0
4	27.8	0.1106	273.4	543.7
5	26.7	0.1132	270.2	560.0
6	26.5	0.1128	269.8	562.2
7	22.8	0.1006	257.8	629.7
8	14.7	0.0738	227.8	858.7

NOTE: THERE IS CHOKED FLOW AT STATION 7



ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	2,339,508	37.40	756	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	230.2
2	58.5	0.1982	339.1	233.1
3	21.1	0.0737	252.7	483.3
4	20.7	0.0944	251.3	490.0
5	20.1	0.0925	249.3	499.9
6	20.0	0.0925	249.0	501.3
7	18.3	0.0865	242.7	534.6
8	14.7	0.0738	227.8	626.6

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,568,865	41.92	1,215	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	154.4
2	59.3	0.2001	337.3	154.3
3	17.4	0.0833	239.0	372.6
4	17.2	0.0828	238.4	374.9
5	17.0	0.0820	237.5	376.0
6	16.9	0.0818	237.3	379.4
7	16.2	0.0791	234.2	392.1
8	14.7	0.0738	227.8	420.3

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	958,472	43.88	1,370	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	74.3
2	59.6	0.2007	339.8	94.3
3	15.7	0.0774	232.1	244.8
4	15.6	0.0772	231.7	245.3
5	15.5	0.0769	231.6	246.4
6	15.5	0.0769	231.5	246.6
7	15.2	0.0757	230.1	250.3
8	14.7	0.0738	227.8	256.8

NOTE: THERE IS CHOKED FLOW AT STATION 2

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	485,258	44.65	1,435	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	47.7
2	59.6	0.2009	339.9	47.7
3	15.0	0.0750	229.2	128.0
4	15.0	0.0749	229.1	128.1
5	14.9	0.0748	229.0	128.2
6	14.9	0.0748	229.0	128.2
7	14.8	0.0743	228.4	129.1
8	14.7	0.0738	227.8	130.0

NOTE: THERE IS CHOKED FLOW AT STATION 2



ANGLE 10 FLOW 245.337 OF ACROSS VALVE 44.91 Closing 1.444

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.0210	340.0	24.1
2	59.7	0.0741	229.1	65.4
3	14.7	0.0741	229.1	65.4
4	14.7	0.0741	229.1	65.4
5	14.7	0.0741	229.1	65.4
6	14.7	0.0741	229.1	65.5
7	14.7	0.0739	227.9	65.6
8	14.7	0.0738	227.8	65.7

NOTE: THERE IS CHOKED FLOW AT STATION 2

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN

DATE AND REPORT ON SUBJECT ATTACHED HERE

1225



CASE 2B

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 14"
VALVE CLASS: 150
ACTUATOR: Buttis N721C-SR80-M3HW

UPSTREAM PRESSURE 59.7 PSIA
INITIAL TEMPERATURE 340 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.4
COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Air
SPECIFIC GRAVITY 1
HYDRODYNAMIC FACTOR
@ 90 DEG 1182 IN.LBS
PSI

STEM DIA. 1.325 IN.
PACKING TORQUE 832 IN.LBS.
DIRECTION Preferred

GAGE DIA. 12.974 IN
SEAL TORQUE 1754 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



~~CONTROL SYSTEM ANALYSIS~~

VALVE SIZE=14		VALVE CLASS=150		FLOW-GAS	
INITIAL PRESSURE	INITIAL DENSITY-10 ⁻²	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE	
59.7	0.2010	340	14.0	37.8	
MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR	
AIR	1.4	1	1	1182	
STEM DIA.	SALE DIA.	PACKING TORQUE	STEM TORQUE		
1.375	12.974	832	1454		

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	14.0	0.0	0.5000	0.50000
2	VALVE	14.0	0.0	0.860	0.86066
3	STRAIGHT PIPE	14.0	9.0	0.115	0.11571
4	PIPE BEND	14.0	0.0	0.120	0.12000
5	STRAIGHT PIPE	14.0	3.0	0.038	0.03857
6	VALVE	14.0	0.0	0.860	0.86066
7	EXIT	14.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 4,645,997 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	457.5
2	53.7	0.1866	330.0	471.7
3	48.5	0.1734	320.5	528.9
4	47.2	0.1699	317.9	536.2
5	45.2	0.1645	313.8	554.3
6	44.7	0.1636	313.1	556.2
7	37.8	0.1450	298.4	633.8
8	14.7	0.0733	227.3	1244.7

NOTE: THERE IS CHOKED FLOW AT STATION 7

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 3,101 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
			TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	440.1
2	53.7	0.1860	330.0	491.7
3	48.5	0.1734	320.5	528.9
4	47.7	0.1723	322.8	500.4
5	45.1	0.1645	313.9	554.5
6	44.7	0.1635	313.1	556.2
7	35.1	0.1377	292.1	642.2
8	14.7	0.0738	227.8	1244.9

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
			TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	440.1
2	54.3	0.1880	331.0	469.3
3	47.7	0.1723	322.8	500.4
4	48.5	0.1733	320.4	507.6
5	46.6	0.1685	316.8	521.2
6	48.4	0.1730	318.3	511.2
7	35.1	0.1377	292.1	642.2
8	14.7	0.0738	227.8	1197.7

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
			TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	392.1
2	55.2	0.1927	332.2	411.2
3	52.2	0.1827	327.2	430.7
4	51.4	0.1807	325.8	434.2
5	50.2	0.1777	323.3	440.3
6	50.1	0.1774	323.4	440.3
7	29.6	0.1217	278.2	647.2
8	14.7	0.0738	227.8	1067.2

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
			TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	302.1
2	57.6	0.1960	336.5	309.0
3	55.7	0.1914	333.4	316.3
4	55.4	0.1903	332.3	317.2
5	54.8	0.1992	331.8	318.9
6	54.7	0.1890	331.7	318.9
7	31.8	0.0977	285.0	327.7
8	14.7	0.0738	227.8	822.1



ANGLE	FLOW	DP ACROSS VALVE	Tclosing
40	1,551,568	42.55	1,217
1	59.7	0.2010	340.0
2	58.8	0.1990	338.6
3	57.5	0.1958	336.4
4	57.3	0.1953	336.1
5	57.3	0.1953	336.1
6	57.3	0.1953	336.1
7	18.1	0.0738	227.8
8	14.7	0.0738	227.8

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
30	958,471	44.13	1,323
1	59.7	0.2010	340.0
2	59.3	0.2001	339.4
3	58.8	0.1990	338.6
4	58.8	0.1989	338.5
5	58.7	0.1987	338.4
6	58.7	0.1986	338.4
7	16.1	0.0790	234.1
8	14.7	0.0738	227.8

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
20	482,546	44.78	1,436
1	59.7	0.2010	340.0
2	59.6	0.2009	339.9
3	59.6	0.2008	339.8
4	59.6	0.2008	339.8
5	59.6	0.2008	339.8
6	59.3	0.2003	339.5
7	14.8	0.0743	228.3
8	14.7	0.0738	227.8

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing
40	1,551,568	42.55	1,217
1	59.7	0.2010	340.0
2	58.8	0.1990	338.6
3	57.5	0.1958	336.4
4	57.3	0.1953	336.1
5	57.3	0.1953	336.1
6	57.3	0.1953	336.1
7	18.1	0.0738	227.8
8	14.7	0.0738	227.8

NOTE: THERE IS CHOKED FLOW AT STATION 6



STATION	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.0010	340.0	24.0
2	59.5	0.0010	339.9	24.0
3	59.5	0.0009	339.9	24.0
4	59.5	0.0009	339.9	24.0
5	14.7	0.0739	227.9	45.2
6	14.7	0.0739	227.9	45.2

NOTE. THERE IS CHOKED FLOW AT STATION 6

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 3A

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12"

VALVE CLASS: 150

ACTUATOR: Buttis N721C-SK80-M3H4

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY 1201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1

HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN.LBS
PSI

STEM DIA. 1.25 IN.

PACKING TORQUE 756 IN.LBS.

DIRECTION Perforated

GAGE DIA. 11.703 IN

SEAL TORQUE 1183 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

Case 72

	VALVE SIZE=12	VALVE CLASS=150	FLOW-GAS	
UPSTREAM PRESSURE	INITIAL DENSITY=10.10	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	20.1	340	19.7	59.7
MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	761
STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE	
1.25	11.703	756	1183	

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.500	0.50000
2	STRAIGHT PIPE	12.0	6.7	0.101	0.10155
3	PIPE BEND	12.0	0.0	0.160	0.16000
4	STRAIGHT PIPE	12.0	4.7	0.071	0.07140
5	VALVE	12.0	0.0	0.759	0.75903
6	STRAIGHT PIPE	12.0	11.0	0.165	0.16500
7	VALVE	12.0	0.0	0.759	0.75903
8	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 3,394.870 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	455.0
2	53.8	0.1866	330.0	489.0
3	52.6	0.1838	328.0	495.7
4	50.7	0.1790	324.6	508.1
5	50.0	0.1771	323.2	512.4
6	45.1	0.1646	313.9	551.2
7	42.9	0.1587	302.4	570.2
8	36.8	0.1423	296.0	642.4
9	14.7	0.0738	227.8	1238.1

NOTE: THERE IS CHOKED FLOW AT STATION 8

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 2,542 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE 50 FLOW 3,394,870 DP ACROSS VALVE 4.85 Tclosing 2,295

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	455.0
2	53.2	0.1866	330.0	489.0
3	52.6	0.1858	326.0	495.7
4	50.7	0.1790	324.6	508.1
5	50.0	0.1771	323.2	512.4
6	45.1	0.1646	313.9	551.2
7	42.9	0.1587	309.4	570.2
8	36.8	0.1423	296.0	642.4
9	14.7	0.0738	227.8	1238.1

NOTE: THERE IS CHOKED FLOW AT STATION 8

ANGLE 80 FLOW 3,301,609 DP ACROSS VALVE 7.53 Tclosing 2,796

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	442.5
2	54.3	0.1880	331.0	471.8
3	53.3	0.1855	329.3	476.9
4	51.6	0.1812	326.2	487.4
5	51.0	0.1797	325.1	490.1
6	43.5	0.1604	310.6	549.3
7	41.4	0.1549	306.3	567.0
8	35.4	0.1385	292.9	641.8
9	14.7	0.0738	227.8	1204.1

NOTE: THERE IS CHOKED FLOW AT STATION 8

ANGLE 70 FLOW 3,079,859 DP ACROSS VALVE 13.44 Tclosing 1,628

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	412.7
2	55.2	0.1900	332.4	435.5
3	54.4	0.1881	331.1	439.0
4	53.0	0.1847	328.7	446.1
5	52.5	0.1834	327.7	448.5
6	39.0	0.1485	301.2	554.0
7	37.2	0.1435	297.1	571.3
8	31.3	0.1267	282.7	646.8
9	14.7	0.0732	227.0	1111.7

ANGLE 60 FLOW 3,443,352 DP ACROSS VALVE 27.43 Tclosing 80

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	327.4
2	57.0	0.1946	335.6	337.5
3	56.7	0.1937	335.0	338.4
4	55.9	0.1919	333.8	341.0
5	55.8	0.1915	333.5	341.0
6	28.3	0.1181	274.9	557.1
7	27.0	0.1142	271.2	575.9
8	23.5	0.1032	260.5	637.2
9	14.7	0.0738	227.8	891.1



NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	1,811,021	36.84	759	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	242.7
2	58.4	0.1950	337.9	245.7
3	58.3	0.1977	337.7	245.7
4	58.1	0.1972	337.4	245.7
5	58.0	0.1970	337.2	245.7
6	21.2	0.0959	252.9	506.3
7	20.5	0.0937	250.5	520.4
8	18.8	0.0881	244.5	553.3
9	14.7	0.0738	227.8	660.5

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,220,686	41.65	1,056	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	163.6
2	59.2	0.2000	339.3	164.0
3	59.2	0.1992	339.2	164.0
4	59.1	0.1996	339.0	164.0
5	59.1	0.1995	339.0	164.0
6	17.4	0.0934	239.2	393.8
7	17.1	0.0825	238.1	398.3
8	16.3	0.0798	235.0	411.8
9	14.7	0.0738	227.8	445.2

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	747,551	43.81	1,172	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.1
2	59.5	0.2007	339.8	100.1
3	59.5	0.2006	339.7	100.1
4	59.5	0.2006	339.7	100.1
5	59.5	0.2005	339.7	100.1
6	15.7	0.0774	232.1	260.0
7	15.6	0.0771	231.7	261.1
8	15.3	0.0760	230.4	264.8
9	14.7	0.0738	227.8	272.6

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	378,486	44.63	1,202	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.7
2	59.6	0.2009	339.9	50.7
3	59.6	0.2009	339.9	50.7
4	59.6	0.2008	339.9	50.7
5	59.6	0.2008	339.9	50.7
6	15.0	0.0750	229.2	135.9
7	14.9	0.0749	229.1	136.0
8	14.8	0.0744	228.4	137.0



0 14.7 0.0738 227.8 138.0
 NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP. ACROSS VALVE	Tclosing	
10	191.3c-	44.90	1.209	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	25.6
2	59.6	0.2009	339.9	25.6
3	59.6	0.2009	339.9	25.6
4	59.6	0.2009	339.9	25.6
5	59.6	0.2009	339.9	25.6
6	14.7	0.0741	228.1	69.5
7	14.7	0.0741	228.1	69.5
8	14.7	0.0740	227.9	69.6
9	14.7	0.0738	227.8	69.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 3B

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12"
VALVE CLASS: 150
ACTUATOR: Betts N771C-SM80-M3HW

UPSTREAM PRESSURE 57.7 PSIA
INITIAL TEMPERATURE 340 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.4
COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Air
SPECIFIC GRAVITY 1
HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN.LBS
PSI

STEM DIA. 1.25 IN.
PACKING TORQUE 756 IN.LBS.
DIRECTION Perforated

GAGE DIA. 11.703 IN
SEAL TORQUE 1183 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

Case 38

VALVE SIZE=12 VALVE CLASS=150 FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY-x10+2	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	20.1	340	14.7	59.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	890 DEG 761

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.25	11.703	756	1183

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.500	0.50000
2	STRAIGHT PIPE	12.0	4.7	0.101	0.10155
3	PIPE BEND	12.0	0.0	0.160	0.16000
4	STRAIGHT PIPE	12.0	4.7	0.071	0.07140
5	VALVE	12.0	0.0	0.759	0.75903
6	STRAIGHT PIPE	12.0	11.0	0.165	0.16500
7	VALVE	12.0	0.0	0.759	0.75903
8	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 3,394,870 SCFH

STATION	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	455.0
2	53.8	0.1866	330.0	489.0
3	52.6	0.1838	328.0	495.7
4	50.7	0.1790	324.6	508.1
5	50.0	0.1771	323.2	512.4
6	45.1	0.1646	313.9	551.2
7	42.9	0.1587	309.4	570.2
8	36.8	0.1423	296.0	642.4
9	14.7	0.0738	227.8	1238.1

NOTE: THERE IS CHOKED FLOW AT STATION 8

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 2,542 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	3,394,870	6.09	- 2,823	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	455.0
2	53.8	0.1960	330.0	468.2
3	52.6	0.1838	328.0	495.7
4	50.7	0.1790	324.6	508.1
5	50.0	0.1771	323.2	512.4
6	45.1	0.1646	313.9	551.2
7	42.9	0.1587	309.4	570.2
8	36.8	0.1423	226.0	642.4
9	14.7	0.0738	227.8	1238.1

NOTE: THERE IS CHOKED FLOW AT STATION 8

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	3,285,444	9.64	- 3,408	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	440.3
2	54.3	0.1880	331.0	469.5
3	53.4	0.1856	329.3	474.6
4	51.6	0.1813	326.2	485.0
5	51.1	0.1798	325.2	487.7
6	46.7	0.1687	317.0	519.7
7	44.8	0.1638	313.3	534.0
8	35.1	0.1378	292.2	642.2
9	14.7	0.0738	227.8	1198.2

NOTE: THERE IS CHOKED FLOW AT STATION 8

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	3,001,555	17.31	- 2,004	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	402.3
2	55.4	0.1906	332.8	423.3
3	54.6	0.1887	331.5	426.7
4	53.3	0.1854	329.2	433.6
5	52.9	0.1845	328.5	434.7
6	49.5	0.1760	322.4	455.6
7	48.2	0.1725	319.8	463.5
8	30.9	0.1255	281.6	643.9
9	14.7	0.0738	227.8	1094.7

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	2,354,692	30.96	- 144	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	315.6
2	57.2	0.1951	336.0	324.4
3	56.9	0.1943	335.4	325.3
4	56.3	0.1929	334.4	326.9
5	56.2	0.1925	334.1	326.9
6	54.3	0.1880	331.0	334.8
7	53.6	0.1862	329.7	337.5
8	22.6	0.1006	257.8	630.0



9 14.7 0.0738 227.8 858.8

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	1,074,227	36.14	753	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	237.8
2	58.5	0.1981	338.0	240.8
3	58.3	0.1978	337.8	240.8
4	58.1	0.1973	337.5	240.8
5	58.0	0.1971	337.3	240.8
6	57.1	0.1947	335.2	243.7
7	56.7	0.1939	335.1	244.3
8	18.6	0.0875	243.8	546.0
9	14.7	0.0738	227.8	647.1

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,212,566	42.19	1,057	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	162.5
2	59.2	0.2000	339.3	162.9
3	59.2	0.1998	339.2	162.9
4	59.1	0.1996	339.1	162.9
5	59.1	0.1995	339.0	162.9
6	58.6	0.1984	338.3	163.8
7	58.5	0.1982	338.1	163.8
8	16.3	0.0797	234.9	409.4
9	14.7	0.0738	227.8	442.2

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	748,860	44.00	1,173	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.3
2	59.5	0.2007	339.8	100.3
3	59.5	0.2006	339.7	100.3
4	59.5	0.2006	339.7	100.3
5	59.5	0.2005	339.7	100.3
6	59.3	0.2001	339.4	100.5
7	59.3	0.2000	339.3	100.5
8	15.3	0.0240	230.4	265.3
9	14.7	0.0738	227.8	273.1

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	377,022	44.75	1,203	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.5
2	59.6	0.2009	339.9	50.5
3	59.6	0.2009	339.9	50.5
4	59.6	0.2008	339.9	50.5
5	59.6	0.2008	339.9	50.5
6	59.6	0.2007	339.8	50.5



7	59.6	0.2007	339.8	50.5
8	14.8	0.0744	228.4	136.5
9	14.7	0.0738	227.8	132.5

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	190.000	44.93	1.200	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	25.5
2	59.6	0.2009	339.9	25.5
3	59.6	0.2009	339.9	25.5
4	59.6	0.2009	339.9	25.5
5	59.6	0.2009	339.9	25.5
6	59.6	0.2009	339.9	25.5
7	59.6	0.2009	339.9	25.5
8	14.7	0.0740	227.9	69.3
9	14.7	0.0738	227.8	69.5

NOTE: THERE IS CHOKED FLOW AT STATION 7

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 3 C

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12"
VALVE CLASS: 150
ACTUATOR: Boltz N721C-SM80-M3HW

UPSTREAM PRESSURE 59.7 PSIA
INITIAL TEMPERATURE 340 °F
SHUT OFF PRESSURE 59.7 PSIA
RATIO OF SP. HEAT 1.4
COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³
FINAL PRESSURE 14.7 PSIA
MEDIA Air
SPECIFIC GRAVITY 1
HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN. LBS
PSI

STEM DIA. 1.25 IN.
PACKING TORQUE 756 IN. LBS.
DIRECTION Portered

GAGE DIA. 11.703 IN.
SEAL TORQUE 1183 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



~~CONTROL SYSTEM ANALYSIS~~

VALVE SIZE=12

VALVE CLASS=150

FLOW-GAS

DESIGN PRESSURE	INITIAL DENSITY	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
30.0	0.001	340	14.7	37.7

MEDIA	RATIO OF SPEC. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	761

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.25	11.703	756	1183

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.100	0.30000
2	VALVE	12.0	0.0	0.759	0.75903
3	STRAIGHT PIPE	12.0	11.0	0.165	0.16500
4	VALVE	12.0	0.0	0.759	0.75903
5	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN

FLOW= 3,317,147 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	471.4
2	53.3	0.1855	329.2	509.4
3	48.5	0.1732	320.4	545.4
4	46.1	0.1673	318.9	555.2
5	40.2	0.1516	303.6	624.9
6	14.7	0.0738	227.8	1292.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

CONDITIONS WITH VALVE SHUT

VALVE TORQUE= 2,542 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	3,517,149	11.89	4,100	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	471.4
2	55.0	0.1894	332.2	439.4
3	48.5	0.1732	320.4	545.4
4	46.1	0.1673	315.9	563.2
5	40.2	0.1516	303.0	624.9
6	14.7	0.0738	227.8	1282.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	3,517,149	11.89	4,100	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	471.4
2	55.0	0.1894	332.2	439.4
3	48.5	0.1732	320.4	545.4
4	46.1	0.1673	315.9	563.2
5	34.2	0.1352	270.0	700.5
6	14.7	0.0738	227.8	1282.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	3,099,067	18.46	2,135	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	415.3
2	55.0	0.1894	332.2	439.4
3	51.4	0.1822	328.2	460.0
4	50.0	0.1773	323.3	469.0
5	31.6	0.1276	283.4	653.9
6	14.7	0.0738	227.8	1282.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	2,393,102	31.58	107	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	322.1
2	57.2	0.1950	335.9	330.1
3	55.3	0.1904	332.7	338.1
4	34.2	0.1352	331.4	340.8
5	23.0	0.1018	259.0	633.9
6	14.7	0.0738	227.8	873.9

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	1,788,061	38.46	751	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	239.6



1	57.1	0.1932	335.2	246.3
2	57.1	0.1932	335.2	246.3
3	57.1	0.1932	335.2	246.3
4	14.7	0.0738	227.8	452.1

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,214,155	42.37	1,059	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	162.7
2	59.2	0.2000	339.3	163.1
3	58.8	0.1987	338.3	164.0
4	58.7	0.1987	338.4	164.0
5	18.3	0.0797	234.9	409.9
6	14.7	0.0738	227.8	442.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	750,788	44.87	1,274	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.8
2	59.5	0.2007	339.8	100.6
3	59.4	0.2003	339.5	100.8
4	59.3	0.2002	339.4	100.8
5	15.3	0.0760	230.4	265.9
6	14.7	0.0738	227.8	273.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	377,992	44.76	1,203	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.6
2	59.5	0.2007	339.7	50.5
3	59.6	0.2008	339.8	50.6
4	59.6	0.2008	339.8	50.6
5	14.8	0.0744	228.4	138.8
6	14.7	0.0738	227.8	137.8

NOTE: THERE IS CHOKED FLOW AT STATION 4

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	191,090	44.94	1,209	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	25.6
2	59.6	0.2009	339.9	25.6
3	59.6	0.2009	339.9	25.6
4	59.6	0.2009	339.9	25.6
5	14.7	0.0740	227.9	69.5
6	14.7	0.0738	227.8	69.5

NOTE: THERE IS CHOKED FLOW AT STATION 4

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 4A

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12⁴

VALVE CLASS: 150

ACTUATOR: Bottle N721C - SR80 - M3 H4

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.7

COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA As

SPECIFIC GRAVITY 1

HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN. LBS
PSI

STEM DIA. 1.25 IN.

PACKING TORQUE 756 IN. LBS.

DIRECTION Preferred

GAGE DIA. 1.1703 IN

SEAL TORQUE 1183 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

Case 47

VALVE SIZE=12

VALVE CLASS=150

FLOW-GAS

UPSTREAM PRESSURE 59.7	INITIAL DENSITY- ρ 20.1	INITIAL TEMPERATURE 340	FINAL PRESSURE 14.7	SHUT-OFF PRESSURE 59.7
------------------------------	------------------------------------	-------------------------------	---------------------------	------------------------------

MEDIA AIR	RATIO OF SP. HEAT 1.4	SPECIFIC GRAVITY 1	COMPRESSIBILITY 1	HYDRODYNAMIC FACTOR 890, DEG 761
--------------	-----------------------------	--------------------------	----------------------	--

STEM DIA. 1.25	GAGE DIA. 11.703	PACKING TORQUE 756	SEAL TORQUE 1183
----------------------	------------------------	--------------------------	------------------------

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.500	0.50000
2	STRAIGHT PIPE	12.0	9.0	0.135	0.13500
3	PIPE BEND	12.0	0.0	0.160	0.16000
4	STRAIGHT PIPE	12.0	3.7	0.056	0.05655
5	VALVE	12.0	0.0	0.759	0.75903
6	STRAIGHT PIPE	12.0	9.0	0.135	0.13500
7	PIPE BEND	12.0	0.0	0.160	0.16000
8	STRAIGHT PIPE	12.0	4.0	0.060	0.06000
9	VALVE	12.0	0.0	0.759	0.75903
10	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 3,331,783 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	446.5
2	54.1	0.1875	330.7	477.4
3	52.7	0.1841	328.2	485.2
4	51.0	0.1796	325.0	495.9
5	50.6	0.1786	324.3	497.3
6	46.0	0.1670	315.7	532.0
7	44.4	0.1626	312.4	545.1
8	42.3	0.1573	308.2	562.3
9	41.7	0.1558	307.0	565.9
10	35.7	0.1394	293.5	643.7
11	14.7	0.0738	227.8	1215.1

NOTE: THERE IS CHOKED FLOW AT STATION 10

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 2,542 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE 90 FLOW 3,331,763 DP ACROSS VALVE 4.56 Tclosing 2,127

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	446.5
2	54.1	0.1875	330.2	477.4
3	52.7	0.1841	328.2	485.2
4	51.0	0.1796	325.0	495.9
5	50.6	0.1786	324.3	497.3
6	46.0	0.1670	315.7	532.0
7	44.4	0.1626	312.4	545.1
8	42.3	0.1573	308.2	562.3
9	41.7	0.1558	307.0	565.9
10	35.7	0.1394	293.5	643.7
11	14.7	0.0738	227.8	1215.1

NOTE: THERE IS CHOKED FLOW AT STATION 10

ANGLE 80 FLOW 3,247,125 DP ACROSS VALVE 7.13 Tclosing 2,647

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	435.2
2	54.5	0.1885	331.3	462.8
3	53.2	0.1851	329.0	470.3
4	51.6	0.1812	326.1	479.3
5	51.2	0.1802	325.5	480.7
6	44.1	0.1619	311.8	535.0
7	42.6	0.1572	308.7	546.9
8	40.6	0.1526	304.5	564.7
9	40.0	0.1511	303.3	568.5
10	33.9	0.1343	289.3	651.1
11	14.7	0.0738	227.8	1184.2

NOTE: THERE IS CHOKED FLOW AT STATION 10

ANGLE 70 FLOW 3,039,219 DP ACROSS VALVE 12.58 Tclosing 1,571

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	407.3
2	55.3	0.1905	332.7	428.6
3	54.3	0.1880	331.0	433.2
4	53.0	0.1846	328.6	440.2
5	52.6	0.1838	328.0	441.4
6	40.0	0.1512	303.4	536.4
7	38.6	0.1473	300.3	549.1
8	36.8	0.1425	296.3	566.4
9	36.3	0.1410	295.1	570.4
10	30.4	0.1241	280.3	648.4
11	14.7	0.0741	228.1	1078.5

ANGLE 60 FLOW 2,438,258 DP ACROSS VALVE 21.77 Tclosing 15

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	326.8
2	57.0	0.1946	335.6	336.8
3	56.5	0.1933	334.7	338.5
4	55.7	0.1915	333.4	341.2



5	55.6	0.1911	333.2	341.2
6	53.8	0.1341	289.1	485.6
7	28.2	0.1150	257.1	558.5
8	27.0	0.1161	272.9	565.7
9	27.2	0.1146	271.7	572.0
10	23.4	0.1031	260.4	638.6
11	14.7	0.0736	227.8	888.2

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE 50 FLOW 1,811,625 DP ACROSS VALVE 35.91 Tclosing 760

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	242.8
2	56.4	0.1980	337.9	245.8
3	58.3	0.1976	337.7	245.8
4	58.0	0.1971	337.3	245.8
5	58.0	0.1969	337.2	245.8
6	22.1	0.0988	255.9	493.7
7	21.5	0.0971	254.1	502.5
8	20.8	0.0949	251.8	513.9
9	20.6	0.0942	251.1	517.9
10	18.8	0.0881	244.5	553.4
11	14.7	0.0738	227.8	660.7

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE 40 FLOW 1,219,632 DP ACROSS VALVE 41.37 Tclosing 1,055

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	163.4
2	59.2	0.2000	339.3	163.8
3	59.2	0.1998	339.2	163.8
4	59.1	0.1996	339.0	163.8
5	59.0	0.1995	339.0	163.8
6	17.7	0.0844	240.3	389.2
7	17.4	0.0836	239.4	392.7
8	17.2	0.0827	238.4	397.0
9	17.1	0.0824	238.0	398.4
10	16.3	0.0798	235.0	411.4
11	14.7	0.0738	227.8	444.8

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE 30 FLOW 752,648 DP ACROSS VALVE 43.67 Tclosing 1,171

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.8
2	59.5	0.2007	339.8	100.8
3	59.5	0.2006	339.7	100.8
4	59.5	0.2005	339.7	100.8
5	59.5	0.2005	339.6	100.8
6	15.8	0.0778	232.6	260.3
7	15.7	0.0776	232.3	261.2
8	15.6	0.0772	231.9	262.3
9	15.6	0.0771	231.8	262.7
10	15.3	0.0760	230.5	266.5
11	14.7	0.0738	227.8	274.5

NOTE: THERE IS CHOKED FLOW AT STATION 5



ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	378.946	44.60	1,202	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.7
2	59.6	0.2009	339.9	50.7
3	59.6	0.2009	339.9	50.7
4	59.6	0.2008	339.9	50.7
5	59.6	0.2008	339.9	50.7
6	15.0	0.0751	229.3	135.8
7	15.0	0.0750	229.2	136.0
8	15.0	0.0749	229.1	136.1
9	14.9	0.0749	229.1	136.2
10	14.8	0.0744	228.4	137.1
11	14.7	0.0738	227.8	138.1

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	191.512	44.89	1,209	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	25.6
2	59.6	0.2009	339.9	25.6
3	59.6	0.2009	339.9	25.6
4	59.6	0.2009	339.9	25.6
5	59.6	0.2009	339.9	25.6
6	14.7	0.0741	228.2	69.5
7	14.7	0.0741	228.1	69.5
8	14.7	0.0741	228.1	69.5
9	14.7	0.0741	228.1	69.5
10	14.7	0.0740	227.9	69.7
11	14.7	0.0738	227.8	69.8

NOTE: THERE IS CHOKED FLOW AT STATION 5

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 4B

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12"

VALVE CLASS: 150

ACTUATOR: Detlo 11721 C-SRVO - M3HW

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1

HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN.LBS
PSI

STEM DIA. 1.25 IN.

PACKING TORQUE 756 IN.LBS.

DIRECTION Preferred

GAGE DIA. 11.703 IN

SEAL TORQUE 1183 IN.LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



CONTROL SYSTEM ANALYSIS

Case 48

VALVE SIZE=12 VALVE CLASS=150 FLOW-GAS

UPSTREAM PRESSURE	INITIAL DENSITY- $\times 10^4$	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE
59.7	20.1	340	14.7	59.7

MEDIA	RATIO OF SP. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR
AIR	1.4	1	1	890 DEG Z61

STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE
1.25	11.703	756	1183

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.500	0.50000
2	STRAIGHT PIPE	12.0	9.0	0.135	0.13500
3	PIPE BEND	12.0	0.0	0.160	0.16000
4	STRAIGHT PIPE	12.0	3.7	0.056	0.05655
5	VALVE	12.0	0.0	0.759	0.75903
6	STRAIGHT PIPE	12.0	9.0	0.135	0.13500
7	PIPE BEND	12.0	0.0	0.160	0.16000
8	STRAIGHT PIPE	12.0	4.0	0.060	0.06000
9	VALVE	12.0	0.0	0.759	0.75903
10	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 3,331,783 SCFH

STATION	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	446.5
2	54.1	0.1875	330.7	477.4
3	52.7	0.1841	328.2	485.2
4	51.0	0.1796	325.0	495.9
5	50.6	0.1786	324.3	497.3
6	46.0	0.1670	315.7	532.0
7	44.4	0.1626	312.4	545.1
8	42.3	0.1573	308.2	562.3
9	41.7	0.1558	307.0	565.9
10	35.7	0.1394	293.5	643.7
11	14.7	0.0738	227.8	1215.1

NOTE: THERE IS CHOKED FLOW AT STATION 10

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 2,542 IN. LBS
DELTA P=45.00 PSI



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
90	3,331,763	6.01	- 2,763	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	446.5
2	54.1	0.1875	330.2	427.4
3	52.7	0.1841	328.2	485.2
4	51.0	0.1796	325.0	495.9
5	50.5	0.1786	324.3	497.3
6	46.0	0.1670	315.7	532.0
7	44.4	0.1626	312.4	545.1
8	42.3	0.1573	308.2	525.3
9	41.7	0.1558	307.0	565.9
10	35.7	0.1394	293.5	643.7
11	14.7	0.0738	227.8	1215.1

NOTE: THERE IS CHOKED FLOW AT STATION 10

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	3,216,287	9.25	- 3,367	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	431.0
2	54.6	0.1886	331.4	458.4
3	53.2	0.1853	329.1	465.8
4	51.7	0.1813	326.7	474.8
5	51.3	0.1804	325.6	476.1
6	47.2	0.1699	317.9	505.4
7	45.7	0.1661	315.0	516.0
8	43.8	0.1613	311.3	530.4
9	43.3	0.1599	310.3	533.7
10	33.5	0.1333	288.7	642.9
11	14.7	0.0738	227.8	1173.0

NOTE: THERE IS CHOKED FLOW AT STATION 10

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	2,938,239	17.40	- 1,955	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	393.8
2	55.6	0.1911	333.2	413.3
3	54.6	0.1887	331.5	417.7
4	53.4	0.1858	329.4	423.3
5	53.1	0.1850	328.9	424.4
6	49.9	0.1770	323.1	443.6
7	48.8	0.1741	321.0	450.0
8	47.5	0.1708	318.5	457.9
9	47.1	0.1699	317.9	459.2
10	29.7	0.1223	278.7	647.0
11	14.7	0.0738	227.8	1071.6

NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
60	2,334,619	30.62	- 133	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	312.9
2	57.4	0.1955	336.2	320.8



3	56.9	0.1942	335.3	322.5
4	56.3	0.1929	334.3	324.2
5	56.1	0.1925	334.1	324.2
6	54.3	0.1860	331.0	331.8
7	53.8	0.1867	330.1	335.6
8	53.2	0.1852	329.1	335.4
9	53.1	0.1849	328.8	335.4
10	22.5	0.1001	257.2	258.1
11	14.7	0.0738	227.8	251.4

NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
50	1,771,908	38.01	752	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	227.4
2	58.5	0.1981	338.0	240.4
3	58.3	0.1977	337.7	240.4
4	58.1	0.1972	337.4	240.4
5	58.0	0.1970	337.3	240.4
6	57.0	0.1946	335.6	243.4
7	56.9	0.1942	335.4	243.4
8	56.7	0.1937	335.0	243.4
9	56.6	0.1936	334.9	243.4
10	18.6	0.0875	243.7	545.5
11	14.7	0.0738	227.8	646.2

NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,210,253	42.08	1,057	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	162.2
2	59.3	0.2000	339.3	162.6
3	59.2	0.1998	339.2	162.6
4	59.1	0.1996	339.0	162.6
5	59.1	0.1995	339.0	162.6
6	58.6	0.1984	338.2	163.4
7	58.5	0.1982	338.1	163.4
8	58.4	0.1980	338.0	163.4
9	58.4	0.1979	337.9	163.4
10	16.3	0.0797	234.9	408.7
11	14.7	0.0738	227.8	441.4

NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	747,428	43.96	1,173	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.1
2	59.5	0.2007	339.8	100.1
3	59.5	0.2006	339.7	100.1
4	59.5	0.2005	339.7	100.1
5	59.5	0.2005	339.6	100.1
6	59.3	0.2001	339.4	100.3
7	59.3	0.2000	339.3	100.3
8	59.2	0.1999	339.2	100.3
9	59.2	0.1999	339.2	100.3
10	15.3	0.0760	230.4	264.8
11	14.7	0.0738	227.8	272.6



NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	376.307	44.24	1.203	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.4
2	59.6	0.2009	339.9	50.4
3	59.6	0.2009	339.9	50.4
4	59.6	0.2008	339.9	50.4
5	59.6	0.2008	339.9	50.4
6	59.6	0.2007	339.8	50.4
7	59.6	0.2007	339.8	50.4
8	59.5	0.2007	339.8	50.4
9	59.5	0.2007	339.8	50.4
10	14.8	0.0744	228.4	136.2
11	14.7	0.0738	227.8	137.2

NOTE: THERE IS CHOKED FLOW AT STATION 9

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
10	190,249	44.93	1,209	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	25.4
2	59.6	0.2009	339.9	25.4
3	59.6	0.2009	339.9	25.4
4	59.6	0.2009	339.9	25.4
5	59.6	0.2009	339.9	25.4
6	59.6	0.2009	339.9	25.5
7	59.6	0.2009	339.9	25.5
8	59.6	0.2009	339.9	25.5
9	59.6	0.2009	339.9	25.5
10	14.7	0.0740	227.9	69.2
11	14.7	0.0738	227.8	69.3

NOTE: THERE IS CHOKED FLOW AT STATION 9

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN



CASE 4C

CONDITION 2

NUCLEAR LOCA ANALYSIS

VALVE SIZE: 12"

VALVE CLASS: 150

ACTUATOR: Det. H. 11721 C - SR40 - M3HW

UPSTREAM PRESSURE 59.7 PSIA

INITIAL TEMPERATURE 340 °F

SHUT OFF PRESSURE 59.7 PSIA

RATIO OF SP. HEAT 1.4

COMPRESSIBILITY 1

INITIAL DENSITY .201 LBS/FT³

FINAL PRESSURE 14.7 PSIA

MEDIA Air

SPECIFIC GRAVITY 1

HYDRODYNAMIC FACTOR
@ 90 DEG 761 IN. LBS
PSI

STEM DIA. 1.25 IN.

PACKING TORQUE 756 IN. LBS.

DIRECTION Postward

GAGE DIA. 11.703 IN

SEAL TORQUE 1183 IN. LBS

INPUT STATION NO., K FACTORS, ETC.

(See Appendix A)



~~CONTROL SYSTEM ANALYSIS~~

VALVE SPECIFIC		VALVE CLASSIFIED		FLOW-GAS	
UPSTREAM PRESSURE	INITIAL DENSITY- $\times 10^{-3}$	INITIAL TEMPERATURE	FINAL PRESSURE	SHUT-OFF PRESSURE	
59.7	20.1	340	29.7	59.7	
MEDIA	RATIO OF SPEC. HEAT	SPECIFIC GRAVITY	COMPRESSIBILITY	HYDRODYNAMIC FACTOR	
AIR	1.4	1	1	670 DEG 761	
STEM DIA.	GAGE DIA.	PACKING TORQUE	SEAL TORQUE		
1.25	11.703	756	1183		

STATION NO.	TYPE OF RESISTANCE	DIAMETER-(D)	LENGTH-(L)	RESISTANCE-(K)	CORRECTED RESISTANCE-(K)
1	ENTRANCE	12.0	0.0	0.200	0.50000
2	VALVE	12.0	0.0	0.759	0.75903
3	STRAIGHT PIPE	12.0	9.0	0.135	0.13500
4	PIPE SEAL	12.0	0.0	0.110	0.11000
5	STRAIGHT PIPE	12.0	4.0	0.060	0.06000
6	VALVE	12.0	0.0	0.759	0.75903
7	EXIT	12.0	0.0	1.000	1.00000

FLOW IN PREFERRED DIRECTION

CONDITIONS WITH VALVE OPEN
FLOW= 3,443,764 SCFH

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	461.5
2	51.6	0.1981	329.7	477.4
3	49.0	0.1971	321.3	530.2
4	47.2	0.1902	318.1	542.7
5	45.1	0.1847	313.7	559.1
6	44.4	0.1828	312.5	564.2
7	38.4	0.1469	299.8	631.5
8	14.7	0.0738	227.2	1256.0

NOTE: THERE IS CHOKED FLOW AT STATION 7

CONDITIONS WITH VALVE SHUT
VALVE TORQUE= 2,542 IN. LBS
DENSITY = 0.0738



CONDITIONS AS VALVE CLOSES

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	3,443,764	12.44	4,127	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	461.5
2	53.6	0.1861	329.7	497.4
3	49.0	0.1746	321.3	530.2
4	47.2	0.1702	318.1	542.7
5	45.1	0.1647	313.9	559.1
6	44.4	0.1629	312.5	564.2
7	38.4	0.1489	299.5	631.5
8	14.7	0.0738	227.8	1256.0

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	3,443,764	12.44	4,127	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	461.5
2	53.6	0.1861	329.7	497.4
3	49.0	0.1746	321.3	530.2
4	47.2	0.1702	318.1	542.7
5	45.1	0.1647	313.9	559.1
6	44.4	0.1629	312.5	564.2
7	32.0	0.1298	284.5	720.1
8	14.7	0.0739	227.8	1256.0

NOTE: THERE IS CHOKED FLOW AT STATION 7

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
70	3,049,241	17.33	2,044	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	408.6
2	55.2	0.1906	332.8	421.2
3	51.9	0.1819	326.6	450.7
4	50.7	0.1790	324.6	457.0
5	49.3	0.1755	322.0	464.8
6	49.0	0.1746	321.3	466.1
7	31.6	0.1278	283.7	642.5
8	14.7	0.0738	227.8	1256.1

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
80	2,373,062	31.29	156	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	318.4
2	57.2	0.1951	335.9	327.4
3	55.4	0.1906	332.8	335.1
4	54.8	0.1893	331.9	336.8
5	54.2	0.1878	330.8	338.6
6	54.1	0.1874	330.6	338.6
7	32.8	0.1278	283.7	642.5
8	14.7	0.0738	227.8	866.6



ANGLE	FLOW	DP ACROSS VALVE	Tclosing
30	1,739,342	39.35	751
1	59.7	0.2010	340.0
2	59.7	0.1980	338.0
3	57.8	0.1955	335.3
4	57.3	0.1952	336.0
5	57.1	0.1947	335.7
6	18.6	0.0776	243.9
7	14.7	0.0738	227.8

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
40	1,211,947	42.27	1,058	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	162.4
2	59.7	0.2000	339.3	162.3
3	58.8	0.1989	338.6	163.7
4	58.7	0.1987	338.4	163.7
5	58.6	0.1985	338.3	163.7
6	18.6	0.1984	338.2	163.7
7	16.3	0.0797	234.9	409.2
8	14.7	0.0738	227.8	442.6

NOTE: THERE IS CHOKED FLOW AT STATION 6

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
30	747,433	44.03	1,174	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	100.4
2	59.5	0.2007	339.8	100.4
3	59.4	0.2003	339.5	100.6
4	59.3	0.2002	339.5	100.6
5	59.3	0.2001	339.4	100.6
6	59.3	0.2001	339.4	100.6
7	15.3	0.0760	230.4	285.4
8	14.7	0.0738	227.8	273.3

NOTE: THERE IS CHOKED FLOW AT STATION 5

ANGLE	FLOW	DP ACROSS VALVE	Tclosing	
20	377,317	44.75	1,203	
	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2010	340.0	50.5
2	59.6	0.2009	339.9	50.5
3	59.6	0.2008	339.8	50.5
4	59.6	0.2008	339.8	50.5
5	59.6	0.2007	339.8	50.5
6	59.6	0.2007	339.8	50.5
7	14.8	0.0744	228.4	136.6
8	14.7	0.0738	227.8	137.6

NOTE: THERE IS CHOKED FLOW AT STATION 6



NO. 1 100.000 10.000 1.000

	PRESSURE	DENSITY	TEMPERATURE	VELOCITY
1	59.7	0.2015	340.0	25.5
2	59.7	0.2015	336.0	25.5
3	59.7	0.2004	339.0	25.5
4	59.7	0.2009	339.0	25.5
5	59.7	0.2009	339.0	25.5
6	59.6	0.2009	339.9	25.5
7	14.7	0.0740	227.9	69.4
8	14.7	0.0740	227.9	69.4

NOTE: THERE IS CHOKED FLOW AT STATION 6

NOTE: A POSITIVE CLOSING TORQUE INDICATES THAT THE VALVE WILL TEND TO REMAIN OPEN

MANUFACTURED BY BAKER VALVE CO. ST. LOUIS, MO.

6175



APPENDIX C

Seismic and LOCA Stress Analysis



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 14"
 VALVE CLASS: 150
 ACTUATOR: N721C - SR80 - M3 HWI
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304 D / 12177
 SPEC. NO.: NMP2 - P304 D and Add #1, #2 #3
 REFERENCE NO.: 19157
 ITEM NO.: 3 AOV 106

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-3</u>	REV.	<u>B</u>
B.	BODY DWG. NO.	<u>1114-302</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2114-301</u>	REV.	<u>B</u>
D.	STEM DWG. NO.	<u>2510-015</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>2600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-197</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI
B.	STEM	<u>SA 564 GR 630 Cond H 1075</u>	<u>52800</u>	PSI
C.	PIN	<u>SA 564 GR 630 Cond H 1075</u>	<u>35200</u>	PSI IA
D.	BRACKET	<u>CS</u>	<u>18900</u>	PSI
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 6170 Case 1A IN-LBS
 MEDIA: Air
 FLOW DIRECTION: Per Tower

G-LOADINGS

TRANSVERSE: 4
 VERTICAL: 3
 LONGITUDINAL: 3



SIZE 14" CLASS 150

DIMENSIONAL DATA

ACTUATOR N721C-CR80-

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUT. NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	1.375	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	61	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	7	T3	T3
THICKNESS OF VALVE NECK	3	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	T0	T0
VALVE NECK O.D.	0	d3	D0
PACKING BORE I.D.	2.125	Di	B5
STEM DIA.	1.375	D1	D1
GAGE DIA. OF DISC	13.974	D	D
WIDTH SMALL DIA. BACK OF DISC	1.906	E1	E1
WIDTH LARGE DIA. OF DISC	.813	E2	E2
THRUST WASHER THICKNESS	.316	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.604	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	.1416	A1	A1
DEC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	.1416	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
$\frac{3}{8}$ TORQUE ON DISC PIN	.65	$\frac{3}{8}$	T7
DISC PIN DIA.	.498	d _p	D5
VALVE BODY O.D.	2.1	d1	D8
VALVE BODY WATERWAY DIA.	13.312	R7	R7
ADJACENT PIPING O.D.	14	R8	R8
ADJACENT PIPING I.D.	13.126	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DEC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS

Case 1A

14' CLASS 150 VALVE ASSEMBLY
WITH NUCLEAR SERVICE ACTUATOR

1. PROJECT NO. 10000000000000000000
 2. DRAWING NO. 10000000000000000000
 3. REV. NO. 10000000000000000000
 4. DATE 10.13

REFERENCE DWGS.
 A. NUC Y DWG. NO. 19157-3 REV. B
 B. NUC Z DWG. NO. 2114-201 REV. A
 C. NUC X DWG. NO. 2114-201 REV. B
 D. STEM DWG. NO. 12510-015 REV. A
 E. PIN DWG. NO. 12400-020 REV. A
 F. BRACKET DWG. NO. 10000-197 REV. -

ALLOWABLE STRESSES (PSI)
 A. BODY: 23400
 B. STEM: 52800
 C. PIN: 35200
 D. BRACKET: 18900
 E. BOLTING: 37500

DESIGN CONDITIONS
 PRESSURE (PSIG) = 45
 TEMPERATURE (°F) = 340

LOCAL TORQUE = 6170	G LOADINGS
MEDIA = AISI	TRANSVERSE = 4
FLOW DIRECTION = PREFERRED	VERTICAL = 3
	LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 1.375	W1 = 219	W2 = 27
W4 = 61	T1 = .275	T2 = 5	T3 = 7	T4 = 3	T9 = .75	T0 = .625
Z3 = 2	D1 = 2.125	D1 = 1.375	D7 = 12.974	F1 = 1.904	F2 = .817	
L2 = .316	Y2 = 1.604	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	RS = 0	R6 = 0	
Z = 65	dp = .498	d1 = 21	R7 = 13.712	R8 = 14	R9 = 13.126	
L = 0	Tn = 0	G = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALVE = 65 VS. 33HZ.
 VERTICAL (Y) ACT./VALVE = 576 VS. 33HZ.
 TRANSVERSE (X) ACT./VALVE = 130 VS. 33HZ.
 LATERAL DISC/STEM = 604 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 9901 PSI
 TENSILE = 8491 PSI
 COMBINED = 15010 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 8315 PSI
 TENSILE = 17010 PSI
 COMBINED = 20400 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 438 PSI
 TENSILE = 3657 PSI
 COMBINED = 3745 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 917 PSI
 TENSILE = 1234 PSI
 COMBINED = 1722 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 12087 PSI
 TENSILE = 4460 PSI
 COMBINED = 14522 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 14808 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 762.38 IN³
 PIPING = 61.22 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 3.63100000E-03 INCHES
 VERTICAL = 8.30000000E-05 INCHES
 TRANSVERSE = 2.10000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED..... *[Signature]* DATED..... 12/12/55.....



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 14"
 VALVE CLASS: 150
 ACTUATOR: N721C - SRKO - M3 HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304 D / 12177
 SPEC. NO.: NMP2 - P304 D and Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 3 ADV 104

REFERENCE DWGS.

A. ASS'Y DWG. NO.	<u>19157-3</u>	REV.	<u>B</u>
B. BODY DWG. NO.	<u>1114-302</u>	REV.	<u>A</u>
C. DISC DWG. NO.	<u>2114-301</u>	REV.	<u>B</u>
D. STEM DWG. NO.	<u>2510-015</u>	REV.	<u>A</u>
E. PIN DWG. NO.	<u>2600-060</u>	REV.	<u>A</u>
F. BRACKET DWG. NO.	<u>8000-197</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A. BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI	
B. STEM	<u>SA 564 GR 630 Cond H1075</u>	<u>52800</u>	PSI	
C. PIN	<u>SA 564 GR 630 Cond H1075</u>	<u>35200</u>	PSI	1A
D. BRACKET	<u>CS</u>	<u>18900</u>	PSI	
E. BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI	

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 6519 IN-LBS Case 1B.
 MEDIA: Air
 FLOW DIRECTION: Preferred |A

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 14" CLASS 150

ACTUATOR N721C-CR80-

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUT. NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	1.375	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	61	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	7	T3	T3
THICKNESS OF VALVE NECK	3	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	TO	TO
VALVE NECK O.D.	0	d3	Do
PACKING BORE I.D.	2.125	Di	B5
STEM DIA.	1.375	D1	D1
GAGE DIA. OF DISC	1.375	D	D
WIDTH SMALL DIA. BACK OF DISC	1.906	E1	E1
WIDTH LARGE DIA. OF DISC	.813	E2	E2
THRUST WASHER THICKNESS	.316	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.604	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	1.416	A1	A1
DBC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	1.416	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
% TORQUE ON DISC PIN	.65	g	T7
DISC PIN DIA.	.498	dp	D5
VALVE BODY O.D.	2.1	d1	D8
VALVE BODY WATERWAY DIA.	13.312	R7	R7
ADJACENT PIPING O.D.	14	R8	R8
ADJACENT PIPING I.D.	13.126	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	11	N3	N3
DBC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS, INC.

Case 16

14 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR50 ACTUATOR

QUALIFIED WAREHOUSE
P.O. BOX 1000
SPECIAL ORDER
SEP. 1965
ITEM NO. 13

REFERENCE DWG.	ALLOWABLE STRESSES (PSI)
A. ASB 1 DWG. NO. 119157-3 REV. G	A. BODY: 23400
B. DISC DWG. NO. 11114-302 REV. A	B. STEM: 52800
C. DISC DWG. NO. 11114-301 REV. B	C. FIN: 35200
D. STEM DWG. NO. 12810-015 REV. A	D. BRACKET: 18900
E. FIN DWG. NO. 12800-260 REV. A	E. ROLLING: 37500
F. BRACKET DWG. NO. 8000-197 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOCA TORQUE = 6519
MEDIUM AIR
FLOW DIRECTION = PREFERRED

G LOADINGS
TRANSVERSE = 3
VERTICAL = 4
LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.608	X4 = 6	X5 = 1.375	W1 = 219	W2 = 27
W4 = 61	T1 = .875	T2 = 5	T3 = 7	T4 = 3	T5 = .75	T0 = 1625
d3 = 0	D1 = 2.175	D1 = 1.375	D = 12.974	E1 = 1.006	E2 = .813	
L2 = .316	Y2 = 1.604	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 0	R6 = 0	
Z7 = .65	dp = .498	d1 = 21	R7 = 13.312	R9 = 14	R9 = 13.126	
L = 0	T = 0	G = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT. / VALVE = 85 VS. 33HZ.
VERTICAL (Y) ACT. / VALVE = 576 VS. 33HZ.
TRANSVERSE (X) ACT. / VALVE = 130 VS. 33HZ.
LATERAL DISC / STEM = 604 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 9735 PSI
TENSILE = 10697 PSI
COMBINED = 16457 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 7636 PSI
TENSILE = 18314 PSI
COMBINED = 21209 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 598 PSI
TENSILE = 3725 PSI
COMBINED = 3819 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 916 PSI
TENSILE = 1284 PSI
COMBINED = 1761 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 15771 PSI
TENSILE = 4427 PSI
COMBINED = 15175 PSI VS. ALLOW. = 52800

DISC FIN STRESS

SHEAR = 15646 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 762.38 IN³
PIPING = 61.22 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 3.83100000E-03 INCHES
VERTICAL = 1.11000000E-04 INCHES
TRANSVERSE = 1.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED... *John L. Kelly* ... DATED... 12/13/80...



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 14"
 VALVE CLASS: 150
 ACTUATOR: N721C - SR50 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304 N / 12177
 SPEC. NO.: NMP2 - P304 N and Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 3 AOV 108

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-3</u>	REV.	<u>B</u>
B.	BODY DWG. NO.	<u>1114-302</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2114-301</u>	REV.	<u>B</u>
D.	STEM DWG. NO.	<u>2510-015</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>2600-560</u>	REV.	<u>1</u>
F.	BRACKET DWG. NO.	<u>8000-197</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI
B.	STEM	<u>SA 524 GR C70 Cond H1075</u>	<u>52800</u>	PSI
C.	PIN	<u>SA 524 GR C70 Cond H1075</u>	<u>35200</u>	PSI 1A
D.	BRACKET	<u>CS</u>	<u>12900</u>	PSI
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 5848 Case 2A IN-LBS
 MEDIA: Air
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 4
 VERTICAL: 3
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 14" CLASS 150

ACTUATOR N721C-SK80-

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUT. NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	1.375	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	61	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	7	T3	T3
THICKNESS OF VALVE NECK	3	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	T0	T0
VALVE NECK O.D.	0	d3	Do
PACKING BORE I.D.	2.125	Di	B5
STEM DIA.	1.375	D1	D1
GAGE DIA. OF DISC	13.974	D	D
WIDTH SMALL DIA. BACK OF DISC	1.906	E1	E1
WIDTH LARGE DIA. OF DISC	.813	E2	E2
THRUST WASHER THICKNESS	.316	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.604	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	.1414	A1	A1
DBC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	.1414	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
% TORQUE ON DISC PIN	.65	g	T7
DISC PIN DIA.	.498	dp	D5
VALVE BODY O.D.	2.1	d1	D8
VALVE BODY WATERWAY DIA.	13.312	R7	R7
ADJACENT PIPING O.D.	14	R8	R8
ADJACENT PIPING I.D.	13.126	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DBC OF BODY BOLTS		X0	X0
ROOT AREA OF BODY BOLTS	V	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



POSI-SEAL INTERNATIONAL, INC.
NUCLEAR SEISMIC ANALYSIS

Case 26

14 CLASS 150 VALVE ASSEMBLY
WITH NUCLEAR SEISMIC ACTUATOR

QUOTA-EE NIAGARA POWER
P.O. BOX 1000
SHELDON, WYOMING 82400
REF. NO. 11157
ITEM NO. 13

REFERENCE DWGS.
A. BODY DWG. NO. 11114-302 REV. A
B. STEM DWG. NO. 11114-301 REV. A
C. DISC DWG. NO. 11114-301 REV. B
D. STEM DWG. NO. 2510-015 REV. A
E. PIN DWG. NO. 2500-060 REV. A
F. BRACKET DWG. NO. 0000-197 REV. -

ALLOWABLE STRESSES (PSI)
A. BODY: 23400
B. STEM: 52800
C. PIN: 35200
D. BRACKET: 18900
E. BOLTING: 37500

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°C) = 140

LOCA TORQUE = 5248
MEDIA = AIR
FLOW DIRECTION = PREFERRED

G LOADINGS
TRANSVERSE = 4
VERTICAL = 3
LONGITUDINAL = 3

DIMENSIONAL DATA						
X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 1.375	U1 = 219	U2 = 27
W4 = .61	T1 = .975	T2 = 5	T3 = 7	T4 = 3	T9 = .75	T0 = .625
d3 = 0	D1 = 2.125	D1 = 1.375	D = 12.974	E1 = 1.906	E2 = .813	
L2 = .316	Y2 = 1.604	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 0	R4 = 0	
Z = .65	dp = .498	d1 = 21	R7 = 13.312	R8 = 14	R9 = 13.126	
L = 0	T = 0	B = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)
LONGITUDINAL (Z) ACT./VALVE = 85 VS. 33HZ.
VERTICALLY (Y) ACT./VALVE = 574 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 130 VS. 33HZ.
LATERAL DISC/STEM = 604 VS. 33HZ.

ACTUATOR BOLT STRESSES
SHEAR = 9650 PSI
TENSILE = 8491 PSI
COMBINED = 14788 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES
SHEAR = 8107 PSI
TENSILE = 17010 PSI
COMBINED = 20255 PSI VS. ALLOW. = 37500

BRACKET STRESSES
SHEAR = 629 PSI
TENSILE = 3524 PSI
COMBINED = 3701 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES
SHEAR = 896 PSI
TENSILE = 1234 PSI
COMBINED = 1705 PSI VS. ALLOW. = 23400

STEM STRESSES
SHEAR = 11456 PSI
TENSILE = 4460 PSI
COMBINED = 13902 PSI VS. ALLOW. = 52900

DISC PIN STRESS
SHEAR = 14075 PSI VS. ALLOW. = 21120

SECTION MODULUS
VALVE = 762.38 IN⁴
PIPING = 61.22 IN⁴

ACTUATOR DEFLECTIONS
LONGITUDINAL = 3.83100000E-03 INCHES
VERTICAL = 8.30000000E-05 INCHES
TRANSVERSE = 2.10000000E-03 INCHES

BODY BOLTING
NOT APPLICABLE

SIGNED... *[Signature]* ... DATED... 12/12/85



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 14"
 VALVE CLASS: 150
 ACTUATOR: N721C - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304 D / 12127
 SPEC. NO.: NMP2 - P304 D and Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 3 ADV 110

REFERENCE DWGS.

A. ASS'Y DWG. NO.	<u>19157-3</u>	REV.	<u>B</u>
B. BODY DWG. NO.	<u>1114-302</u>	REV.	<u>A</u>
C. DISC DWG. NO.	<u>2114-301</u>	REV.	<u>B</u>
D. STEM DWG. NO.	<u>2510-015</u>	REV.	<u>A</u>
E. PIN DWG. NO.	<u>2600-060</u>	REV.	<u>A</u>
F. BRACKET DWG. NO.	<u>8000-197</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A. BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI
B. STEM	<u>SA 524 GR 670 Cond H1075</u>	<u>52800</u>	PSI
C. PIN	<u>SA 564 GR 630 Cond H1075</u>	<u>35200</u>	PSI
D. BRACKET	<u>CS</u>	<u>18900</u>	PSI
E. BOLTING	<u>A193 GR B7</u>	<u>32500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 9584 @ 90° Case 2B IN-LBS
 MEDIA: Air
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 3
 LONGITUDINAL: 4



DIMENSIONAL DATA

SIZE 14" CLASS 150

ACTUATOR N721C-6680-

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUTE NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	1.375	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	61	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	7	T3	T3
THICKNESS OF VALVE NECK	3	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	T0	T0
VALVE NECK O.D.	0	d3	D0
PACKING BORE I.D.	2.125	Di	B5
STEM DIA.	1.375	D1	D1
GAGE DIA. OF DISC	12.924	D	D
WIDTH SMALL DIA. BACK OF DISC	1.906	E1	E1
WIDTH LARGE DIA. OF DISC	.813	E2	E2
THRUST WASHER THICKNESS	.316	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.604	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	.1416	A1	A1
DBC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	.1416	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
% TORQUE ON DISC PIN	.65	&	T7
DISC PIN DIA.	.498	dp	D5
VALVE BODY O.D.	21	d1	D8
VALVE BODY WATERWAY DIA.	17.312	R7	R7
ADJACENT PIPING O.D.	.14	R8	R8
ADJACENT PIPING I.D.	13.126	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DBC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS

Case 2
80°

CLASS 150 VALVE ASSEMBLY
WITH N7210-SR20 ACTUATOR

SYSTEMS ANALYSIS
ELECTRO-MECHANICAL
DESIGN
BY: J. B. ...
DATE: 12/13/85

REFERENCE DESIG.
A. BODY DWG. NO. 1114-301 REV. B
B. STEM DWG. NO. 1114-301 REV. B
C. DISC DWG. NO. 12510-015 REV. A
D. BRACKET DWG. NO. 12510-040 REV. A
E. FIN DWG. NO. 12510-040 REV. A
F. BRACKET DWG. NO. 0200-177 REV. -

ALLOWABLE STRESSES (PSI)
A. BODY: 23400
B. STEM: 52800
C. FIN: 35200
D. BRACKET: 18900
E. BOLTING: 37500

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOC. TORQUE = 9584
C. LOADING
TRANSVERSE = 3
VERTICAL = 7
LONGITUDINAL = 4
FLOW DIRECTION = PREFERRED

DIMENSIONAL DATA

X1= 8.438	X2= 2.688	X3= 3.682	X4= 5	X5= 1.375	U1= 319	W2= 27
W4= 61	T1= .875	T2= 5	T3= 7	T4= 3	T9= .75	T0= .625
D3= 0	D1= 2.125	D17= 1.775	D= 12.574	E1= 1.006	E2= .913	
L2= .316	Y2= 1.504	N1= 4	A1= .1416	X6= 4.5	N2= 4	
A2= .1416	X7= 5	X8= 2	T5= 9.75	R5= 0	R6= 0	
M= .65	d2= .458	d1= .21	R7= 12.712	R8= 14	R9= 13.126	
L= 0	T= 0	B= 0	E= 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALUE = 85 VS. 33HZ.
VERTICAL (Y) ACT./VALUE = 576 VS. 33HZ.
TRANSVERSE (X) ACT./VALUE = 130 VS. 33HZ.
LATERAL DISC/STEM = 604 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 13259 PSI
TENSILE = 8491 PSI
COMBINED = 18166 PSI US. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 10333 PSI
TENSILE = 19836 PSI
COMBINED = 24240 PSI US. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 782 PSI
TENSILE = 4956 PSI
COMBINED = 5105 PSI US. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 1261 PSI
TENSILE = 1431 PSI
COMBINED = 2166 PSI US. ALLOW. = 23400

STEM STRESSES

SHEAR = 12776 PSI
TENSILE = 4460 PSI
COMBINED = 21138 PSI US. ALLOW. = 52800

DISC FIN STRESS

SHEAR = 23002 PSI US. ALLOW. = 21120

SECTION MODULUS

VALVE = 762.38 IN⁴
PIPING = 61.32 IN⁴

ACTUATOR DEFLECTIONS

LONGITUDINAL = 5.10800000E-03 INCHES
VERTICAL = 8.30000000E-05 INCHES
TRANSVERSE = 1.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED..... *J. B. ...* DATED... 12/13/85.....



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 14"
 VALVE CLASS: 150
 ACTUATOR: N721C - SR80 - M3HW1
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304D / 12177
 SPEC. NO.: NMP2 - P304D and Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 3 ADU 110

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-3</u>	REV.	<u>B</u>
B.	BODY DWG. NO.	<u>1114-302</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2114-301</u>	REV.	<u>B</u>
D.	STEM DWG. NO.	<u>2510-015</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>2600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-197</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI	
B.	STEM	<u>SA 564 GR 630 Cond H1025</u>	<u>52200</u>	PSI	
C.	PIN	<u>SA 564 GR 630 Cond H1025</u>	<u>35200</u>	PSI	A
D.	BRACKET	<u>CS</u>	<u>18900</u>	PSI	
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI	

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 7496 @ 70° Case 2B IN-LBS |A
 MEDIA: Air
 FLOW DIRECTION: Recirculated

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 3
 LONGITUDINAL: 4



NUCLEAR SEISMIC ANALYSIS

Case 2

70°

14 CLASS 150 VALVE ASSEMBLY
WITH N721C-5R60 ACTUATOR

DESIGNER: [REDACTED]
DATE: [REDACTED]
SPEC. NO.: [REDACTED]
REF. NO.: 191E
ITEM NO. 13

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. WGE 1 DWG. NO.: 9157-3 REV. B	A. BODY: 23400
B. 2301 DWG. NO.: 1111-1300 REV. A	C. STEM: 52900
C. DISC DWG. NO.: 2114-301 REV. B	C. PIN: 35200
D. STEM DWG. NO.: 2510-015 REV. A	D. BRACKET: 16900
E. PIN DWG. NO.: 12400-020 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO.: 8000-197 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOCAL TORQUE = 7496
MPCIA = 61F
FLOW DIRECTION = PREFERRED

G LOADINGS
TRANSVERSE = 3
VERTICAL = 3
LONGITUDINAL = 4

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.686	X4 = 6	X5 = 1.375	U1 = 219	U2 = 27
U4 = 61	T1 = .875	T2 = 5	T3 = 7	T4 = 3	T9 = .75	T0 = .625
d3 = 0	O1 = 2.125	O1 = 1.375	O = 12.974	E1 = 1.906	E2 = .813	
L2 = .316	Y2 = 1.604	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 0	R6 = 0	
Z = .65	d0 = .498	d1 = 21	R7 = 13.312	R8 = 14	R9 = 13.126	
L = 0	T = 0	R = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALVE = 85 VS. 33HZ.
VERTICAL (Y) ACT./VALVE = 574 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 170 VS. 33HZ.
LATERAL DISC/STEM = 604 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 11654 PSI
TENSILE = 8491 PSI
COMBINED = 16649 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 9013 PSI
TENSILE = 19836 PSI
COMBINED = 23319 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 724 PSI
TENSILE = 4574 PSI
COMBINED = 4687 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 1125 PSI
TENSILE = 1431 PSI
COMBINED = 2049 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 14685 PSI
TENSILE = 4460 PSI
COMBINED = 17084 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 17990 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 762.38 IN³
PIPING = 61.22 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 5.10800000E-03 INCHES
VERTICAL = 8.30000000E-05 INCHES
TRANSVERSE = 1.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED... [Signature] ... DATED... 12/17/85...



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12"
 VALVE CLASS: 150
 ACTUATOR: N7LIC - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 4 AOV 107

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-4</u>	REV.	<u>A</u>
B.	BODY DWG. NO.	<u>1113-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2113-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA351 GR CF8M</u>	<u>23400</u>	PSI	
B.	STEM	<u>SA514 GR 630 Cond H1025</u>	<u>52800</u>	PSI	
C.	PIN	<u>SA564 GR 670 Cond H1025</u>	<u>35200</u>	PSI	1A
D.	BRACKET	<u>CS</u>	<u>18900</u>	PSI	
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI	

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 3991 @ 80° Case 3A IN-LBS 1A
 MEDIA: Air
 FLOW DIRECTION: Pre turn 1A

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 12" CLASS 150

ACTUATOR U721C-3180-M3

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUTER NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	2.665	X5	X5
ACTUATOR WEIGHT	2.19	W1	W4
BRACKET WEIGHT	2.7	W2	W5
DISC WEIGHT	2.6	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	3.182	T3	T3
THICKNESS OF VALVE NECK	0	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.175	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	TO	TO
VALVE NECK O.D.	2.875	d3	Do
PACKING BORE I.D.	1.255	Di	B5
STEM DIA.	1.247	D1	D1
FACE DIA. OF DISC	11.203	D	D
WIDTH SMALL DIA. BACK OF DISC	1.625	E1	E1
WIDTH LARGE DIA. OF DISC	.938	E2	E2
RUST WASHER THICKNESS	.305	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.557	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	1.1716	A1	A1
DBC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	1.1716	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	3.182	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	3.182	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
% TORQUE ON DISC PIN	.65	%	T7
DISC PIN DIA.	.309	dp	D5
VALVE BODY O.D.	12.0	d1	D8
VALVE BODY WATERWAY DIA.	12.062	R7	R7
ADJACENT PIPING O.D.	12.75	R8	R8
ADJACENT PIPING I.D.	11.988	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DBC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
WIDTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	1	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



**FEDERAL INTERNATIONAL, INC.
NUCLEAR SEISMIC ANALYSIS**

Case 3A
80°

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR80 ACTUATOR

CUSTOMER: NIAGARA MOHAWK
P.O. NO. NMF2-F3040-12177
SPEC. NO.: NMF2-F3040
REF. NO.: 19157
ITEM NO.: 4

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. ASS'Y DWG. NO.: 19157-4 REV. A	A. BODY: 23400
B. BODY DWG. NO.: 1112-301 REV. A	B. STEM: 52800
C. DISC DWG. NO.: 2112-301 REV. A	C. PIN: 35200
D. STEM DWG. NO.: 2510-013 REV. A	D. BRACKET: 18900
E. PIN DWG. NO.: 2600-060 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO. 8000-199 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 300

VALVE TORQUE (IN-LBS)	G LOADINGS
LOCA TORQUE = 3991	TRANSVERSE = 3
MEDIA = AIR	VERTICAL = 4
FLOW DIRECTION = PREFERRED	LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
U4 = 26	T1 = .875	T2 = 5	T3 = 3.182	T4 = 0	T9 = .75	T0 = .625
U3 = 2.875	D1 = 1.755	D1 = 1.247	D = 11.703	E1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 3.182	X8 = 3.182	T5 = 9.75	R5 = 0	R6 = 0	
Z = .65	dp = .309	d1 = .15	R7 = 12.067	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 1	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALUE = 62 VS. 33HZ.
VERTICAL (Y) ACT./VALUE = 456 VS. 33HZ.
TRANSVERSE (X) ACT./VALUE = 70 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 7781 PSI
TENSILE = 10697 PSI
COMBINED = 14791 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 8363 PSI
TENSILE = 17852 PSI
COMBINED = 21158 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 529 PSI
TENSILE = 3227 PSI
COMBINED = 3312 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 2874 PSI
TENSILE = 8782 PSI
COMBINED = 9639 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 10482 PSI
TENSILE = 4526 PSI
COMBINED = 12987 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 22937 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 192.79 IN⁴
PIPING = 47.09 IN⁴

ACTUATOR DEFLECTIONS

LONGITUDINAL = 7.08200000E-03 INCHES
VERTICAL = 1.77000000E-04 INCHES
TRANSVERSE = 5.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED: *[Signature]* DATED: 1/8/50



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: .12 "
 VALVE CLASS: 150
 ACTUATOR: N2LIC - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 4 AOV 107

REFERENCE DWGS.

A. ASS'Y DWG. NO.	<u>19157-4</u>	REV.	<u>A</u>
B. BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C. DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D. STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E. PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F. BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A. BODY	<u>SA351 GR CF8M</u>	<u>23400</u>	PSI
B. STEM	<u>SA514 GR 630 Cond H1075</u>	<u>52800</u>	PSI
C. PIN	<u>SA564 GR 670 Cond H1075</u>	<u>35200</u>	PSI 14
D. BRACKET	<u>CS</u>	<u>18900</u>	PSI
E. BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 3321 @ 70° Case 3A IN-LBS 14
 MEDIA: Air
 FLOW DIRECTION: Pre Flood 1A

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



**FUSI-DEME INTERNATIONAL, INC.
NUCLEAR SEISMIC ANALYSIS**

Case 34
75

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR20 ACTUATOR

CUSTOMER: NIAGARA MOHAWK
P.O. NO. NMF2-F3040-12177
SPEC. NO.: NMF2-F3040
REF. NO.: 19157
ITEM NO.: 4

REFERENCE DWGS.
A. ASS'Y DWG. NO.: 19157-4 REV. A
B. BODY DWG. NO.: 1112-301 REV. A
C. DISC DWG. NO.: 2112-301 REV. A
D. STEM DWG. NO.: 2510-013 REV. A
E. PIN DWG. NO.: 2600-060 REV. A
F. BRACKET DWG. NO. 8000-199 REV. -

ALLOWABLE STRESSES (PSI)
A. BODY: 23400
B. STEM: 52800
C. PIN: 35200
D. BRACKET: 18900
E. BOLTING: 37500

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 300

VALVE TORQUE (IN-LBS) G LOADINGS
LOCA TORQUE = 3321 TRANSVERSE = 3
MEDIA = AIR VERTICAL = 4
FLOW DIRECTION = PREFERRED LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
W4 = 26	T1 = .875	T2 = 5	T3 = 3.182	T4 = 0	T9 = .75	T0 = .625
d3 = 2.875	Di = 1.755	Di = 1.247	D = 11.703	E1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 3.182	X8 = 3.182	T5 = 9.75	R5 = 0	R6 = 0	
Z = .65	dp = .309	d1 = 15	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 1	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT. / VALVE = 62 VS. 33HZ.
VERTICAL (Y) ACT. / VALVE = 456 VS. 33HZ.
TRANSVERSE (X) ACT. / VALVE = 70 VS. 33HZ.
LATERAL DISC / STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 7266 PSI
TENSILE = 10697 PSI
COMBINED = 14371 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 7848 PSI
TENSILE = 17852 PSI
COMBINED = 20812 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 511 PSI
TENSILE = 3095 PSI
COMBINED = 3178 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 2707 PSI
TENSILE = 8782 PSI
COMBINED = 9550 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 8722 PSI
TENSILE = 4526 PSI
COMBINED = 11274 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 19086 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 192.79 IN³
PIPING = 47.09 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 7.08900000E-03 INCHES
VERTICAL = 1.77000000E-04 INCHES
TRANSVERSE = 5.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED..... *[Signature]* DATED... 1/9/75.....



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12
 VALVE CLASS: 150
 ACTUATOR: N741C - SR80 - M3HW
 CUSTOMER: Ningbo Mahawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 5 AOV 105

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-5</u>	REV.	<u>C</u>
B.	BODY DWG. NO.	<u>1113-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2113-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SAS51 GR CFRM</u>	<u>23400</u>	PSI	
B.	STEM	<u>SAS14 GR 630 Cond H1025</u>	<u>52800</u>	PSI	
C.	PIN	<u>SAS64 GR 630 Cond H1025</u>	<u>35200</u>	PSI	1A
D.	BRACKET	<u>CS</u>	<u>18900</u>	PSI	
E.	BOLTING	<u>A193 GR B7</u>	<u>27500</u>	PSI	

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 4100 @ 80 Case 3E IN-LBS 1A
 MEDIA: Air
 FLOW DIRECTION: P-to-R 1A

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 12" CLASS 150

ACTUATOR U721C-2A80-M3H

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUTER NAME
TRANSVERSE DIST. ACTUATOR C.G. TO ϕ VALVE	3.438	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO ϕ VALVE	2.688	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	0	X4	X4
HEIGHT VALVE NECK	2.665	X5	X5
ACTUATOR WEIGHT	2.19	W1	W4
BRACKET WEIGHT	2.7	W2	W5
DISC WEIGHT	2.6	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	3.182	T3	T3
THICKNESS OF VALVE NECK	0	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	1.625	TO	TO
VALVE NECK O.D.	2.875	d3	Do
PACKING BORE I.D.	1.255	Di	B5
STEM DIA.	1.247	D1	D1
GAGE DIA. OF DISC	11.703	D	D
WIDTH SMALL DIA. BACK OF DISC	1.625	E1	E1
WIDTH LARGE DIA. OF DISC	.938	E2	E2
WASHER THICKNESS	.305	L2	L2
L. I. ϕ STEM TO FRONT OF DISC	1.557	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	1.1716	A1	A1
DBC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	1.1716	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	3.182	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	3.182	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	0	R5	R5
DIA. OF VALVE BODY BOLT HOLES	0	R6	R6
% TORQUE ON DISC PIN	65	%	T7
DISC PIN DIA.	.309	dp	D5
VALVE BODY O.D.	12.0	d1	D8
VALVE BODY WATERWAY DIA.	12.062	R7	R7
ADJACENT PIPING O.D.	12.75	R8	R8
ADJACENT PIPING I.D.	11.938	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DBC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	1	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS

Case 3C

12 CLASS 150 VALVE ASSEMBLY WITH N721C-SR50 ACTUATOR

80°

CUSTOMER DRAWING NUMBER
P.D. NO. 110-157-5
SPEC. NO. 110-157-5
REF. NO. 110-157-5
ITEM NO. 15

REFERENCE DWG. ALLWAGLE STRESSES (PSI)
A. ASSY Dwg. NO.: 110-157-5 REV. C A.GDY: 23400
B. BODY Dwg. NO.: 110-157-5 REV. A B. STEM: 52600
C. DISC Dwg. NO.: 110-157-5 REV. A C. PIN: 35200
D. STEM Dwg. NO.: 110-157-5 REV. A D. BRACKET: 18900
E. PIN Dwg. NO.: 110-157-5 REV. A E. BOLTING: 37500
F. BRACKET Dwg. NO.: 110-157-5 REV. -

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOCA TORQUE = 4100 G LOADINGS
MERIDIAN: TRANSVERSE = 3
FLOW DIRECTION = PREFERRED VERTICAL = 4
LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 2.282	X2 = 8.438	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
U4 = 26	T1 = .875	T2 = 5	T3 = 6.5	T4 = 2.938	T9 = .75	T0 = .625
d3 = 0	d4 = 1.755	d1 = 1.247	d = 11.703	F1 = 1.625	F2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 3.4	R6 = 1	
% = 65	dp = .309	d1 = 16	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	G = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALVE = 78 VS. 33HZ.
VERTICAL (Y) ACT./VALVE = 563 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 123 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 7865 PSI
TENSILE = 10697 PSI
COMBINED = 14860 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 8084 PSI
TENSILE = 22749 PSI
COMBINED = 25347 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 532 PSI
TENSILE = 3282 PSI
COMBINED = 3366 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 1736 PSI
TENSILE = 2578 PSI
COMBINED = 3146 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 10768 PSI
TENSILE = 4526 PSI
COMBINED = 13267 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 23543 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 272.23 IN⁴
PIPING = 47.09 IN⁴

ACTUATOR DEFLECTIONS

LONGITUDINAL = 4.45400000E-03 INCHES
VERTICAL = 1.16000000E-04 INCHES
TRANSVERSE = 1.80000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED.....*[Signature]*..... DATED... 12/13/85...



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12"
 VALVE CLASS: 150
 ACTUATOR: N7LIC - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2 - P304 D - 12177
 SPEC. NO.: NMP2 - P304 D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 5 AOV 105

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-5</u>	REV.	<u>C</u>
B.	BODY DWG. NO.	<u>1113-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2113-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA 351 GR CF8M</u>	<u>23400</u>	PSI
B.	STEM	<u>SA 514 GR 630 Cond H1075</u>	<u>52800</u>	PSI
C.	PIN	<u>SA 524 GR 670 Cond H1075</u>	<u>35200</u>	PSI
D.	BRACKET	<u>CS</u>	<u>18500</u>	PSI
E.	BOLTING	<u>A193 GR B7</u>	<u>27500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 2542 Unseal Case 3C IN-LBS
 MEDIA: Air
 FLOW DIRECTION: P-to-L-rod

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



POSI-SEAL INTERNATIONAL, INC.
NUCLEAR SEISMIC ANALYSIS

Case 3C

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-5880 ACTUATOR

Unseal Torque

CUSTOMER: NIAGARA MOHAWK
P.O. NO.: NMP2-F3040-12177
SPEC. NO.: NMP2-F3040
REF. NO.: 19157
ITEM NO.: 5

REFERENCE DWGS.
A. ASS'Y DWG. NO.: 19157-5 REV. C
B. BODY DWG. NO.: 1112-301 REV. A
C. DISC DWG. NO.: 2112-301 REV. A
D. STEM DWG. NO.: 2510-013 REV. A
E. PIN DWG. NO.: 2600-060 REV. A
F. BRACKET DWG. NO. 8000-199 REV.-

ALLOWABLE STRESSES (PSI)
A. BODY: 23400
B. STEM: 52800
C. PIN: 35200
D. BRACKET: 18900
E. BOLTING: 37500

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 300

VALVE TORQUE (IN-LBS)
LOCA TORQUE = 2542
MEDIA = AIR
FLOW DIRECTION = PREFERRED

G LOADINGS
TRANSVERSE = 3
VERTICAL = 4
LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 2.688	X2 = 8.438	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
W4 = .26	T1 = .875	T2 = 5	T3 = 6.5	T4 = 2.938	T9 = .75	T0 = .625
d3 = 0	D1 = 1.755	D1 = 1.247	D = 11.703	E1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 3.4	R6 = 1	
Z = 65	dp = .309	d1 = 16	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.)
LONGITUDINAL (Z) ACT./VALVE = 78 VS. 33HZ.
VERTICALLY ACT./VALVE = 563 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 123 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES
SHEAR = 6669 PSI
TENSILE = 10497 PSI
COMBINED = 13897 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES
SHEAR = 7063 PSI
TENSILE = 22249 PSI
COMBINED = 24782 PSI VS. ALLOW. = 37500

BRACKET STRESSES
SHEAR = 489 PSI
TENSILE = 2975 PSI
COMBINED = 3054 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES
SHEAR = 1160 PSI
TENSILE = 2578 PSI
COMBINED = 3023 PSI VS. ALLOW. = 23400

STEM STRESSES
SHEAR = 6676 PSI
TENSILE = 4526 PSI
COMBINED = 9313 PSI VS. ALLOW. = 52800

DISC PIN STRESS
SHEAR = 14609 PSI VS. ALLOW. = 21120

SECTION MODULUS
VALVE = 272.23 IN⁴
PIPING = 47.09 IN⁴

ACTUATOR DEFLECTIONS
LONGITUDINAL = 4.45400000E-03 INCHES
VERTICAL = 1.16000000E-04 INCHES
TRANSVERSE = 1.80000000E-03 INCHES

BODY BOLTING
NOT APPLICABLE

SIGNED... *[Signature]* ... DATED... 12/2/85



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12
 VALVE CLASS: 150
 ACTUATOR: N7LIC - SR80 - M3HW
 CUSTOMER: Ningora Mahawli
 P.O. NO.: NMP2 - P304 D - 12177
 SPEC. NO.: NMP2 - P304 D # Add #1, #2 f #3
 REFERENCE NO.: 19157
 ITEM NO.: 4 AOV 109

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-4</u>	REV.	<u>A</u>
B.	BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA351 GR CF8M</u>	<u>23400</u>	PSI
B.	STEM	<u>SA514 GR 630 Cond H1025</u>	<u>52800</u>	PSI
C.	PIN	<u>SA524 GR 630 Cond H1025</u>	<u>35200</u>	PSI 1A
D.	BRACKET	<u>CS</u>	<u>18900</u>	PSI
E.	BOLTING	<u>A193 GR B7</u>	<u>27500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA. TORQUE: 4319 @ 80° Case 4A IN-LBS 1A
 MEDIA: Air
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 12" CLASS 150
 ACTUATOR N721C-SK50-A

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUTE NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.688	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	2.665	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	26	W4	W3
THICKNESS OF BRACKET LOWER PLATE	1.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	6.5	T3	T3
THICKNESS OF VALVE NECK	2.938	T4	T4
THICKNESS OF BRACKET SIDE PLATES	1.25	T9	T9
THICKNESS OF BRACKET TOP PLATE	1.625	TO	TO
VALVE NECK O.D.	0	d3	Do
PACKING BORE I.D.	1.755	Di	B5
STEM DIA.	1.247	D1	D1
GAGE DIA. OF DISC	11.703	D	D
WIDTH SMALL DIA. BACK OF DISC	11.625	E1	E1
WIDTH LARGE DIA. OF DISC	19.38	E2	E2
THRUST WASHER THICKNESS	3.05	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.557	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	11416	A1	A1
DEC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	11416	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	3.4	R5	R5
DIA. OF VALVE BODY BOLT HOLES	1	R6	R6
% TORQUE ON DISC PIN	65	&	T7
DISC PIN DIA.	3.09	dp	D5
VALVE BODY O.D.	16.0	d1	D8
VALVE BODY WATERWAY DIA.	12.062	R7	R7
ADJACENT PIPING O.D.	12.75	R8	R8
ADJACENT PIPING I.D.	11.938	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DEC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	1	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS

Case 4E
90°

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR80 ACTUATOR

CUSTOMER: NIAGARA MOHAWK
P.O. NO. NMF2-F3040-12177
SPEC. NO.: NMF2-F3040
REF. NO.: 19157
ITEM NO.: 4

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. ASS'Y DWG. NO.: 19157-4 REV. A	A. BODY: 23400
B. BODY DWG. NO.: 1112-301 REV. A	B. STEM: 52800
C. DISC DWG. NO.: 2112-301 REV. A	C. PIN: 35200
D. STEM DWG. NO.: 2510-013 REV. A	D. BRACKET: 18900
E. PIN DWG. NO.: 12600-060 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO. 8000-199 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 300

VALVE TORQUE (IN-LBS) LOCA TORQUE = 4319 MEDIA = AIR FLOW DIRECTION = PREFERRED	G LOADINGS TRANSVERSE = 3 VERTICAL = 4 LONGITUDINAL = 3
--	--

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 2.665	U1 = 219	U2 = 27
W4 = 26	T1 = .875	T2 = 5	T3 = 3.182	T4 = 0	T9 = .75	T0 = .625
d3 = 2.875	D1 = 1.755	D1 = 1.247	O = 11.703	F1 = 1.625	F2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 3.182	X8 = 3.182	T5 = 9.75	R5 = 0	R6 = 0	
Z = .65	dp = .309	d1 = 15	R7 = 12.042	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 1	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT. / VALVE = 62 VS. 33HZ.
VERTICAL (Y) ACT. / VALVE = 456 VS. 33HZ.
TRANSVERSE (X) ACT. / VALVE = 70 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 8034 PSI
TENSILE = 10697 PSI
COMBINED = 15000 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 8615 PSI
TENSILE = 17652 PSI
COMBINED = 21332 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 538 PSI
TENSILE = 3292 PSI
COMBINED = 3378 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 2256 PSI
TENSILE = 8782 PSI
COMBINED = 9684 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 11343 PSI
TENSILE = 4526 PSI
COMBINED = 13830 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 24822 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 192.79 IN³
PIPING = 47.09 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 7.08200000E-03 INCHES
VERTICAL = 1.77000000E-04 INCHES
TRANSVERSE = 5.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED... *[Signature]* ... DATED... 1/9/82 ...



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12"
 VALVE CLASS: 150
 ACTUATOR: N711C - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 4 ADV 109

REFERENCE DWGS.

A. ASS'Y DWG. NO.	<u>19157-4</u>	REV.	<u>A</u>
B. BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C. DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D. STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E. PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F. BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A. BODY	<u>S1351 GR CF8M</u>	<u>23400</u>	PSI
B. STEM	<u>S1514 GR 630 Cond H1025</u>	<u>52800</u>	PSI
C. PIN	<u>S1524 GR 630 Cond H1025</u>	<u>35200</u>	PSI 1A
D. BRACKET	<u>CS</u>	<u>18500</u>	PSI
E. BOLTING	<u>A193 GR B7</u>	<u>27500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 3590 @ 70° Case 4A IN-LBS **1A**
 MEDIA: Air
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



FUGRO INTERNATIONAL, INC.
NUCLEAR SEISMIC ANALYSIS

Case 44

70

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR80 ACTUATOR

CUSTOMER: NIAGARA MOHAWK
P.O. NO. NMF2-F3040-12177
SPEC. NO.: NMF2-F3040
REF. NO.: 19157
ITEM NO.: 4

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. ASS'Y DWG. NO.: 19157-4 REV. A	A. BODY: 23400
B. BODY DWG. NO.: 1112-301 REV. A	B. STEM: 52900
C. DISC DWG. NO.: 2112-301 REV. A	C. PIN: 35200
D. STEM DWG. NO.: 2510-013 REV. A	D. BRACKET: 18900
E. PIN DWG. NO.: 2600-060 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO. 8000-199 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 300

VALVE TORQUE (IN-LBS) G LOADINGS
LOCA TORQUE = 3590 TRANSVERSE = 3
MEDIA = AIR VERTICAL = 4
FLOW DIRECTION = PREFERRED LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 8.438	X2 = 2.688	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
W4 = 26	T1 = .875	T2 = 5	T3 = 3.182	T4 = 0	T9 = .75	T0 = .625
d3 = 2.875	D1 = 1.755	D1 = 1.247	O = 11.703	F1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 3.182	X8 = 3.182	T5 = 9.75	R5 = 0	R6 = 0	
X = .65	dp = .309	d1 = 15	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 1	E = 30000000			

NATURAL FREQUENCIES (HZ.)

LONGITUDINAL (Z) ACT./VALVE = 62 VS. 33HZ.
VERTICAL (Y) ACT./VALVE = 456 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 70 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 7472 PSI
TENSILE = 10697 PSI
COMBINED = 14538 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 8055 PSI
TENSILE = 17852 PSI
COMBINED = 20950 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 518 PSI
TENSILE = 3148 PSI
COMBINED = 3231 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 2774 PSI
TENSILE = 8782 PSI
COMBINED = 9585 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 9428 PSI
TENSILE = 4526 PSI
COMBINED = 11960 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 20632 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 192.79 IN⁴
PIPING = 47.09 IN⁴

ACTUATOR DEFLECTIONS

LONGITUDINAL = 7.08900000E-03 INCHES
VERTICAL = 1.77000000E-04 INCHES
TRANSVERSE = 5.60000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED..... *J. H. S. [Signature]* DATED..... 1/18/86.....



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12
 VALVE CLASS: 150
 ACTUATOR: N71C - SR&D - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D # Add #1, #2, #3
 REFERENCE NO.: 19157
 ITEM NO.: 5 ADV111

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-5</u>	REV.	<u>C</u>
B.	BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7600-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>4000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SA351 GR CERM</u>	<u>23400</u>	PSI
B.	STEM	<u>SA514 GR 630 Cond H1075</u>	<u>52800</u>	PSI
C.	PIN	<u>SA514 GR 630 Cond H1075</u>	<u>35200</u>	PSI A
D.	BRACKET	<u>CS</u>	<u>18500</u>	PSI
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 6776 @ 90° Case 4C IN-LBS |A
 MEDIA: A1
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 7
 LONGITUDINAL: 3



DIMENSIONAL DATA

SIZE 12" CLASS 170

ACTUATOR N721C-5850-A

DESCRIPTION OF VARIABLE		INPUT NAME	COMPUTE NAME
TRANSVERSE DIST. ACTUATOR C.G. TO \perp VALVE	2.688	X1	X1
LONGITUDINAL DIST. ACTUATOR C.G. TO \perp VALVE	8.438	X2	X2
VERTICAL DIST. ACTUATOR C.G. TO BRACKET	3.685	X3	X3
HEIGHT BRACKET	6	X4	X4
HEIGHT VALVE NECK	2.665	X5	X5
ACTUATOR WEIGHT	219	W1	W4
BRACKET WEIGHT	27	W2	W5
DISC WEIGHT	20	W4	W3
THICKNESS OF BRACKET LOWER PLATE	.875	T1	T1
WIDTH OF BRACKET	5	T2	T2
WIDTH OF VALVE NECK	6.5	T3	T3
THICKNESS OF VALVE NECK	2.938	T4	T4
THICKNESS OF BRACKET SIDE PLATES	.75	T9	T9
THICKNESS OF BRACKET TOP PLATE	.625	T0	T0
VALVE NECK O.D.	0	d3	Do
PACKING BORE I.D.	1.755	Di	B5
STEM DIA.	1.247	D1	D1
GAGE DIA. OF DISC	11.703	D	D
WIDTH SMALL DIA. BACK OF DISC	1.625	E1	E1
WIDTH LARGE DIA. OF DISC	1.938	E2	E2
THRUST WASHER THICKNESS	30.5	L2	L2
DIST. \perp STEM TO FRONT OF DISC	1.557	Y2	Y2
NO. OF ACTUATOR BOLTS	4	N1	N1
TENSILE STRESS AREA OF ACTUATOR BOLTS	1416	A1	A1
DEC OF ACTUATOR BOLTS	4.5	X6	X6
NO. OF BRACKET/VALVE BOLTS	4	N2	N2
TENSILE STRESS AREA OF BRACKET/VALVE BOLTS	1416	A2	A2
TRANSVERSE DIST. BETWEEN BRACKET BOLTS	5	X7	X7
LONGITUDINAL DIST. BETWEEN BRACKET BOLTS	2	X8	X8
LENGTH OF BRACKET	9.75	T5	T5
DISTANCE BETWEEN VALVE BODY BOLT HOLES	3.4	R5	R5
DIA. OF VALVE BODY BOLT HOLES	1	R6	R6
% TORQUE ON DISC PIN	65	%	T7
DISC PIN DIA.	1.309	dp	D5
VALVE BODY O.D.	16.0	d1	D8
VALVE BODY WATERWAY DIA.	12.062	R7	R7
ADJACENT PIPING O.D.	12.75	R8	R8
ADJACENT PIPING I.D.	11.938	R9	R9
MAXIMUM PIPING BENDING MOMENT	N/A	M4	M4
NO. OF BODY BOLTS	1	N3	N3
DEC OF BODY BOLTS	1	X0	X0
ROOT AREA OF BODY BOLTS	4	A4	A4
LENGTH ACROSS GUSSETS	0	L	L
THICKNESS OF GUSSETS	0	T	T
DIA. OF FLANGE BOSSES	0	B	B
MODULUS OF ELASTICITY	30,000,000	E	E



NUCLEAR SEISMIC ANALYSIS

Case 4C
90°

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SK30 ACTUATOR

CUSTOMER: CATAPAWA POWER
P.O. NO. N721C-SK30, 12177
SPEC. NO. N721C-SK30
REF. NO. 12157
ITEM NO. 15

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. ASSY DWG. NO.: 12157-5 REV. C	A. BODY: 23400
B. BODY DWG. NO.: 12112-301 REV. A	B. STEM: 52800
C. DISC DWG. NO.: 12112-301 REV. A	C. PIN: 35200
D. STEM DWG. NO.: 12510-013 REV. A	D. BRACKET: 18900
E. PIN DWG. NO.: 12600-060 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO.: 8006-196 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOC. TORQUE = 6776	G LOADINGS
MEDIA = AIR	TRANSVERSE = 3
FLOW DIRECTION = PREFERRED	VERTICAL = 4
	LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 2.028	X2 = 8.438	X3 = 3.688	X4 = 6	X5 = 2.665	U1 = 219	U2 = 27
W4 = 26	T1 = .875	T2 = 5	T3 = 6.5	T4 = 2.938	T9 = .75	T0 = .625
d3 = C	D1 = 1.755	D1 = 1.247	D = 11.703	E1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 3.4	R6 = 1	
X = 65	dn = .309	d1 = 16	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	G = 0	E = 30000000			

NATURAL FREQUENCIES (HZ)

LONGITUDINAL (Z) ACT./VALVE = 78 VS. 33HZ.
VERTICAL (Y) ACT./VALVE = 563 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 123 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 9935 PSI
TENSILE = 10697 PSI
COMBINED = 14632 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 9836 PSI
TENSILE = 22769 PSI
COMBINED = 26431 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 605 PSI
TENSILE = 3609 PSI
COMBINED = 3903 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 1640 PSI
TENSILE = 3579 PSI
COMBINED = 3376 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 17794 PSI
TENSILE = 4526 PSI
COMBINED = 20203 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 38943 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 272.23 IN³
PIPING = 47.09 IN³

ACTUATOR DEFLECTIONS

LONGITUDINAL = 4.45400000E-03 INCHES
VERTICAL = 1.16000000E-04 INCHES
TRANSVERSE = 1.80000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED..... *[Signature]* DATED... 12/13/82.....



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12"
 VALVE CLASS: 150
 ACTUATOR: N711C - SR80 - M3HW
 CUSTOMER: Niagara Mohawk
 P.O. NO.: NMP2-P304D-12177
 SPEC. NO.: NMP2-P304D & Add #1, #2 & #3
 REFERENCE NO.: 19157
 ITEM NO.: 5 ADV111

REFERENCE DWGS.

A.	ASS'Y DWG. NO.	<u>19157-5</u>	REV.	<u>C</u>
B.	BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C.	DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D.	STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E.	PIN DWG. NO.	<u>7620-060</u>	REV.	<u>A</u>
F.	BRACKET DWG. NO.	<u>8000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A.	BODY	<u>SASS1 GR CF8M</u>	<u>23400</u>	PSI	
B.	STEM	<u>SASS1 GR 630 cond H1025</u>	<u>52800</u>	PSI	
C.	PIN	<u>SASS4 GR 670 cond H1025</u>	<u>35200</u>	PSI	<u>1A</u>
D.	BRACKET	<u>CS</u>	<u>18500</u>	PSI	
E.	BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI	

DESIGN CONDITIONS

PRESSURE: 45 PSI
 TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 4729 @ 70° Casi 4C IN-LBS 1A
 MEDIA: Air
 FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
 VERTICAL: 4
 LONGITUDINAL: 3



NUCLEAR SEISMIC ANALYSIS

Case 4
70°

15 CLASS 150 VALVE ASSEMBLY
WITH NUC-3850 ACTUATOR

CUSTOMER: NIAGARA MOHAWK
F.O. NO. N-2-30-0 121
SPEC. NO. NPS-57
REF. NO. 10157
ITEM NO. 15

REFERENCE DWGS.	ALLOWABLE STRESSES (PSI)
A. BODY DWG. NO.: 19157-S REV. C	A. BODY: 23400
B. BODY DWG. NO.: 1112-301 REV. A	B. STEM: 52800
C. DISC DWG. NO.: 1112-301 REV. A	C. PIN: 35200
D. STEM DWG. NO.: 2510-013 REV. A	D. BRACKET: 18900
E. PIN DWG. NO.: 2600-060 REV. A	E. BOLTING: 37500
F. BRACKET DWG. NO.: 9000-199 REV. -	

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOCAL TORQUE = 4729	G LOADINGS
MECH. EFF.	TRANSVERSE = 3
FLOW DIRECTION = PREFERRED	VERTICAL = 4
	LONGITUDINAL = 3

DIMENSIONAL DATA						
X1 = 2.682	X2 = 8.438	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
U4 = 26	T1 = .875	T2 = 5	T3 = 6.5	T4 = 2.938	T9 = .75	T0 = .635
D3 = .0	D1 = 1.755	D1 = 1.247	D = 11.703	E1 = 1.625	E2 = .938	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	R5 = 3.4	R6 = 1	
Z = 45	d = .309	d1 = 16	R7 = 12.062	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	B = 0	E = 30000000			

NATURAL FREQUENCIES (HZ.) LONGITUDINAL (Z) ACT./VALVE = 76 VS. 33HZ. VERTICAL (Y) ACT./VALVE = 563 VS. 33HZ. TRANSVERSE (X) ACT./VALVE = 123 VS. 33HZ. LATERAL DISC/STEM = 906 VS. 33HZ.	ACTUATOR BOLT STRESSES SHEAR = 8350 PSI TENSILE = 10697 PSI COMBINED = 15265 PSI VS. ALLOW. = 37500
---	---

BRACKET BOLT STRESSES SHEAR = 6497 PSI TENSILE = 22769 PSI COMBINED = 25590 PSI VS. ALLOW. = 37500	BRACKET STRESSES SHEAR = 549 PSI TENSILE = 3406 PSI COMBINED = 3492 PSI VS. ALLOW. = 18900
--	--

VALVE NECK STRESSES SHEAR = 1408 PSI TENSILE = 2578 PSI COMBINED = 3198 PSI VS. ALLOW. = 23400	STEM STRESSES SHEAR = 12420 PSI TENSILE = 4526 PSI COMBINED = 14888 PSI VS. ALLOW. = 52800
--	--

DISC PIN STRESS SHEAR = 27178 PSI VS. ALLOW. = 21120	SECTION MODULUS VALVE = 272.23 IN ⁴ PIPING = 47.09 IN ⁴
--	--

ACTUATOR DEFLECTIONS LONGITUDINAL = 4.45400000E-03 INCHES VERTICAL = 1.16000000E-04 INCHES TRANSVERSE = 1.80000000E-03 INCHES	BODY BOLTING NOT APPLICABLE
---	---------------------------------------

SIGNED... *[Signature]* ... DATED... 12/13/85...



NUCLEAR LOCA & SEISMIC ANALYSIS

VALVE SIZE: 12
VALVE CLASS: 150
ACTUATOR: N7110 - CR20 - M3HW
CUSTOMER: Niagara Mohawk
P.O. NO.: NMP2-P304D-12177
SPEC. NO.: NMP2-P304D # Add #1, #2, #3
REFERENCE NO.: 19157
ITEM NO.: 5 A0V111

REFERENCE DWGS.

A. ASS'Y DWG. NO.	<u>19157-5</u>	REV.	<u>C</u>
B. BODY DWG. NO.	<u>1112-301</u>	REV.	<u>A</u>
C. DISC DWG. NO.	<u>2112-301</u>	REV.	<u>A</u>
D. STEM DWG. NO.	<u>2510-013</u>	REV.	<u>A</u>
E. PIN DWG. NO.	<u>2600-060</u>	REV.	<u>A</u>
F. BRACKET DWG. NO.	<u>4000-199</u>	REV.	<u>-</u>

ALLOWABLE STRESSES

A. BODY	<u>SA351 GR CF8M</u>	<u>23400</u>	PSI
B. STEM	<u>SA514 GR 630 Cond H1025</u>	<u>52800</u>	PSI
C. PIN	<u>SA564 GR 670 Cond H1025</u>	<u>35200</u>	PSI
D. BRACKET	<u>CS</u>	<u>18500</u>	PSI
E. BOLTING	<u>A193 GR B7</u>	<u>37500</u>	PSI

DESIGN CONDITIONS

PRESSURE: 45 PSI
TEMPERATURE: 340 DEG. F.

VALVE TORQUES

LOCA TORQUE: 2611 @ 60° CASI YC IN-LBS 1A
MEDIA: Air
FLOW DIRECTION: Preferred

G-LOADINGS

TRANSVERSE: 3
VERTICAL: 7
LONGITUDINAL: 3



NUCLEAR SEISMIC ANALYSIS

Case 4:
60°

12 CLASS 150 VALVE ASSEMBLY
WITH N721C-SR60 ACTUATOR

CUSTOMER: INDIANAPOLIS
P.O. NO. 4480-270 C 12177
REF. NO. 119157
ITEM NO. 15

REFERENCE DWGS.
A. ASSY DWG. NO. 119157-5 REV. C
B. BODY DWG. NO. 1112-301 REV. A
C. DISC DWG. NO. 1112-301 REV. A
C. STEM DWG. NO. 12510-013 REV. A
E. PIN DWG. NO. 12000-060 REV. A
F. BRACKET DWG. NO. 8003-199 REV. -

ALLOWABLE STRESSES (PSI)
A. BODY: 23400
B. STEM: 52800
C. PIN: 35200
D. BRACKET: 18900
E. BOLTING: 37500

DESIGN CONDITIONS
PRESSURE (PSIG) = 45
TEMPERATURE (°F) = 340

LOCAL TORQUE = 2611
MEDIA = AIR
FLOW DIRECTION = PREFERRED
G LOADINGS
TRANSVERSE = 3
VERTICAL = 4
LONGITUDINAL = 3

DIMENSIONAL DATA

X1 = 2.698	X2 = 8.438	X3 = 3.688	X4 = 6	X5 = 2.665	W1 = 219	W2 = 27
U4 = 26	T1 = .875	T2 = 5	T3 = 6.5	T4 = 2.938	T9 = .75	T0 = .625
d3 = 0	D1 = 1.255	D1 = 1.247	D = 11.203	E1 = 1.625	E2 = .038	
L2 = .305	Y2 = 1.557	N1 = 4	A1 = .1416	X6 = 4.5	N2 = 4	
A2 = .1416	X7 = 5	X8 = 2	T5 = 9.75	RS = 3.4	RS = 1	
Z = .65	dp = .309	d1 = 14	R7 = 12.067	R8 = 12.75	R9 = 11.938	
L = 0	T = 0	G = 0	E = 30000000			

NATURAL FREQUENCIES (HZ)

LONGITUDINAL (Z) ACT./VALVE = 78 VS. 33HZ.
VERTICAL (Y) ACT./VALVE = 563 VS. 33HZ.
TRANSVERSE (X) ACT./VALVE = 123 VS. 33HZ.
LATERAL DISC/STEM = 906 VS. 33HZ.

ACTUATOR BOLT STRESSES

SHEAR = 6721 PSI
TENSILE = 10697 PSI
COMBINED = 13938 PSI VS. ALLOW. = 37500

BRACKET BOLT STRESSES

SHEAR = 7109 PSI
TENSILE = 22769 PSI
COMBINED = 24806 PSI VS. ALLOW. = 37500

BRACKET STRESSES

SHEAR = 491 PSI
TENSILE = 2989 PSI
COMBINED = 3068 PSI VS. ALLOW. = 18900

VALVE NECK STRESSES

SHEAR = 1147 PSI
TENSILE = 2578 PSI
COMBINED = 3029 PSI VS. ALLOW. = 23400

STEM STRESSES

SHEAR = 6857 PSI
TENSILE = 4526 PSI
COMBINED = 9484 PSI VS. ALLOW. = 52800

DISC PIN STRESS

SHEAR = 15005 PSI VS. ALLOW. = 21120

SECTION MODULUS

VALVE = 272.23 IN⁴
PIPING = 47.09 IN⁴

ACTUATOR DEFLECTIONS

LONGITUDINAL = 4.45400000E-03 INCHES
VERTICAL = 1.16000000E-04 INCHES
TRANSVERSE = 1.80000000E-03 INCHES

BODY BOLTING

NOT APPLICABLE

SIGNED... *[Signature]* ... DATED... 12/13/85...



APPENDIX D

Determination of Closing Times

NOTE: Positive torques are tending to open the valve, negative torques are tending to close the valve.



DETERMINATION OF CLOSING TIME

VALVE SIZE 14" VALVE CLASS 150

ACTUATOR Bettis N721C-5R80-M3HV

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 7770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26

MEDIA Air VALVE C_v 6317

HYDRODYNAMIC TORQUE @ 90 1182 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 832 IN. LBS. SEAL TORQUE 1457 IN. LBS.

STEM DIA. 1.375 IN. GAGE DIA. 12.977 IN.

BUILDING PRESSURE 45 PSIG dt .05 SEC.

DEG.	DENSITY (LBS/FT ³)	VELOCITY (FT/SEC)	PRESSURE DROP (PSI)
10	<u>.0741</u>	<u>657.2</u>	<u>44.9</u>
20	<u>.0749</u>	<u>127.7</u>	<u>44.7</u>
30	<u>.0770</u>	<u>245.8</u>	<u>44.0</u>
40	<u>.0826</u>	<u>374.8</u>	<u>42.1</u>
50	<u>.0939</u>	<u>492.8</u>	<u>37.9</u>
60	<u>.115</u>	<u>549.5</u>	<u>29.9</u>
70	<u>.151</u>	<u>546.9</u>	<u>15.2</u>
80	<u>.161</u>	<u>579.0</u>	<u>9.74</u>
90	<u>.172</u>	<u>541.9</u>	<u>5.78</u>



14 - 150 CLASS VALVE WITH A N210-SK50 ACTUATOR

Case 1E

THE VALVE IS IN THE PREFERRED DIRECTION

TYPICAL PRESSURE = 45
 ACT. PRESS = 50
 MED. AIR
 BUILDING PRESSURE = 45
 TYPICAL TORQUE = 3770
 ACT. TORQUE RADIUS = 2.3
 VALVE O.T. 9317
 ACT. TORQUE = -6
 SOLE VALVE CO. 2.2
 SHUT-OFF PRES. DROP = 45
 Gage = 12.97

SEC.	10	20	30	40	50	60	70	80	90
DENSITY	.0741	.0743	.0770	.0823	.0939	.1150	.1510	.1610	.1720
VELOCITY	35.3	107.7	246.9	374.3	492.3	546.8	546.9	570.0	541.0
PRES DROP	44.90	44.70	44.00	42.10	37.90	29.90	15.20	9.74	5.48

LOCAL CLOSURE THE VALVE TO 62 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM AERODYNAMIC TORQUE AS VALVE CLOSING IS -6514 IN. LBS. @ 90 DEGREES

TIME SEC.	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	0	4634	-3006	-2312	499	368	62.00	26.96
0.05	0	2532	-2825	-708	499	504	51.17	36.05
0.10	0	2059	-2764	-342	499	547	44.70	40.12
0.15	0	1799	-2697	-177	499	576	39.44	42.20
0.20	0	1493	-2675	-95	499	588	34.91	43.06
0.25	0	1633	-2663	-47	499	598	30.82	43.84
0.30	0	1637	-2713	-26	499	603	27.06	44.20
0.35	0	1470	-2741	-14	499	606	23.55	44.45
0.40	0	1724	-2826	-7	499	610	20.24	44.68
0.45	0	1800	-2906	-4	499	611	17.13	44.75
0.50	0	1890	-2990	-2	499	611	14.19	44.81
0.55	0	1994	-3105	-1	499	612	11.42	44.87
0.60	0	2107	-3221	-0	499	613	8.81	44.91
0.65	0	2275	-3348	-0	499	613	6.36	44.93
0.70	0	2369	-3483	-0	499	613	4.06	44.95
0.75	0	1640	-3625	-0	1370	614	1.92	44.96
0.80	0	1304	-3721	-0	1800	614	0.59	44.90



DETERMINATION OF CLOSING TIME

VALVE SIZE 14" VALVE CLASS 150
 ACTUATOR Bettis N721C-5P80-M3HW
 AMOUNT OF VALVE OPENING 90°
 DIRECTION OF FLOW Preferred
 ACTUATOR TORQUES (IN. LBS)
 SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.
 ACTUATOR PRESSURE 40 PSIG SOLENOID VALVE C_v 2.26
 MEDIA Air VALVE C_v 6317
 HYDRODYNAMIC TORQUE @ 90 1182 SHUT OFF PRESSURE DROP 45 PSI
 PACKING TORQUE 832 IN. LBS. SEAL TORQUE 1454 IN. LBS.
 STEM DIA. 1.375 IN. GAGE DIA. 12.974 IN.
 BUILDING PRESSURE 3.1 PSIG dt .25 SEC.

<u>DEG.</u>	<u>DENSITY (LBS/FT³)</u>	<u>VELOCITY (FT/SEC)</u>	<u>PRESSURE DROP (PSI)</u>
10	<u>.0739</u>	<u>65.3</u>	<u>44.9</u>
20	<u>.0743</u>	<u>128.7</u>	<u>44.8</u>
30	<u>.0757</u>	<u>250.7</u>	<u>44.2</u>
40	<u>.0790</u>	<u>388.4</u>	<u>42.6</u>
50	<u>.0861</u>	<u>529.0</u>	<u>39.3</u>
60	<u>.0982</u>	<u>641.7</u>	<u>33.1</u>
70	<u>.124</u>	<u>645.5</u>	<u>20.7</u>
80	<u>.142</u>	<u>633.6</u>	<u>11.1</u>
90	<u>.149</u>	<u>628.1</u>	<u>6.92</u>



DETERMINATION OF CLOSING TIME

14 - 150 CLASS VALVE WITH A N2310-5850 ACTUATOR

Case 1B

THE VALVE IS IN THE PREFERRED DIRECTION

Tipping Point = 5.75	Tipping Point = 5.75	ACT. PRESS = 60	SOL. VALVE Cv = 2.24
ACT. VALVE RADIIUS = 2.5	ACT. VALVE RADIIUS = 2.5	HYDRA. TORQUE @ 1100	SHUT-OFF PRES. DROP = 45
VALVE Cv = 3.1	VALVE Cv = 3.1	Dist = 1.375	Dqage = 12.974
PACKING TORQUE = 532	SEAL TORQUE = 1454		
BUILDING PRESSURE = 3.1			

DEC.	10	20	30	40	50	60	70	80	90
DEPTH	.0739	.0743	.0757	.0790	.0821	.0882	.1020	.1420	.1490
VELOCITY	69.3	125.7	250.7	388.4	529.0	621.7	648.5	633.6	628.1
PRES. DROP	44.30	44.80	44.20	42.60	39.30	33.10	20.70	11.10	6.92

TIME sec	TORQUE total to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	1563	12993	-5924	-6431	832	94	90.00	6.92
0.05	0	11528	-5924	-6431	832	94	90.00	6.92
0.10	0	10175	-5924	-6431	832	94	90.00	6.92
0.15	0	11254	-4492	-7404	499	144	81.32	10.54
0.20	0	5770	-3246	-3588	499	358	65.55	26.21
0.25	0	2704	-2843	-877	499	517	52.31	37.86
0.30	0	2103	-2771	-388	499	557	45.42	40.81
0.35	0	1818	-2702	-196	499	581	40.04	42.58
0.40	0	1692	-2676	-106	499	591	35.44	43.32
0.45	0	1634	-2681	-53	499	600	31.31	43.98
0.50	0	1632	-2708	-20	499	605	27.52	44.34
0.55	0	1663	-2754	-15	499	608	23.98	44.56
0.60	0	1715	-2817	-7	499	611	20.66	44.76
0.65	0	1788	-2895	-4	499	612	17.52	44.82
0.70	0	1877	-2966	-2	499	612	14.56	44.85
0.75	0	1980	-3090	-1	499	612	11.77	44.88
0.80	0	2094	-3204	-0	499	613	9.14	44.90
0.85	0	2218	-3331	-0	499	613	6.67	44.93
0.90	0	2352	-3465	-0	499	613	4.35	44.95
0.95	0	1778	-3406	-0	1253	614	2.19	44.97
1.00	0	1340	-3708	-0	1753	614	0.76	44.99



DETERMINATION OF CLOSING TIME

VALVE SIZE 14" VALVE CLASS 150

ACTUATOR Bell, H721C-SR80

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW Recirculated

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26

MEDIA Air VALVE C_v 6317

HYDRODYNAMIC TORQUE @ 90 1182 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 832 IN. LBS. SEAL TORQUE 1454 IN. LBS.

STEM DIA. 1.375 IN. GAGE DIA. 12.974 IN.

BUILDING PRESSURE 45 PSIG dt .05 SEC.

DEG.	DENSITY (LBS/FT ³)	VELOCITY (FT/SEC)	PRESSURE DROP (PSI)
10	<u>.0741</u>	<u>65.7</u>	<u>47.9</u>
20	<u>.0750</u>	<u>128.0</u>	<u>44.7</u>
30	<u>.0774</u>	<u>247.8</u>	<u>43.9</u>
40	<u>.0833</u>	<u>372.8</u>	<u>41.9</u>
50	<u>.0957</u>	<u>483.3</u>	<u>37.7</u>
60	<u>.119</u>	<u>534.0</u>	<u>28.7</u>
70	<u>.153</u>	<u>533.4</u>	<u>14.4</u>
80	<u>.163</u>	<u>526.6</u>	<u>9.13</u>
90	<u>.173</u>	<u>528.9</u>	<u>5.22</u>



DETERMINATION OF CLOSING TIME
 14 - 150 CLASS VALVE WITH A WDMC-5500 ACTUATOR

Case 2A

THE VALVE IS IN THE PREFERRED DIRECTION

Tapping Speed 3770	Tapping Endirc= 3770	ACT. PRESS= 80	SOL. VALVE Cv= 2.25
ACT. VOLUME= 1.70	ACT. VOLUME RADIUS= 0.5	WYCCO. TORQUE @ 60= 1100	SHUT-OFF PRES. PRESS= .45
WATER RATE	VALVE C.L.R. 1317	Order= 1.375	Dgage= 12.97
FACING TORQUE= 832	SEAL TORQUE= 1454		
BUILDING PRESSURE= 45			

DEC.	10	20	30	40	50	60	70	80	90
DENSITY	.074	.0750	.0774	.0823	.0957	.1190	.1530	.1630	.1730
VELOCITY	55.0	129.0	244.8	372.8	483.3	534.0	535.4	561.6	528.9
PRES DROP	44.90	44.70	43.90	41.90	37.40	28.70	14.40	9.13	5.22

LCCA CLOSES THE VALVE TO 60 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM AERODYNAMIC TORQUE AS VALVE CLOSES IS -6183 IN.LBS. @ 80 DEGREES

TIME	TORQUE	TORQUE	TORQUE	TORQUE	TORQUE	TORQUE	ANGLE	DELTA P
sec	tend to open	air	spring	flow	packing & seal	bearing	degrees	psi
0.00	0	4634	-3098	-2251	499	352	62.00	25.84
0.05	0	2524	-2825	-694	499	496	51.17	36.37
0.10	0	2061	-2764	-339	499	543	44.72	39.77
0.15	0	1802	-2697	-177	499	573	39.46	42.00
0.20	0	1685	-2675	-95	499	586	34.91	42.91
0.25	0	1634	-2683	-47	499	597	30.82	43.73
0.30	0	1637	-2717	-26	499	602	27.06	44.13
0.35	0	1670	-2761	-14	499	606	23.54	44.41
0.40	0	1724	-2827	-7	499	610	20.24	44.68
0.45	0	1800	-2906	-4	499	611	17.12	44.75
0.50	0	1890	-2999	-2	499	611	14.18	44.81
0.55	0	1994	-3105	-1	499	612	11.41	44.87
0.60	0	2100	-3221	-0	499	612	8.80	44.91
0.65	0	2235	-3348	-0	499	613	6.36	44.93
0.70	0	2370	-3483	-0	499	613	4.06	44.95
0.75	0	2539	-3625	-0	1371	614	1.91	44.98
0.80	0	2700	-3721	-0	1800	614	0.59	44.99



DETERMINATION OF CLOSING TIME

VALVE SIZE 14"

VALVE CLASS 150

ACTUATOR B-Hic N721C-SR90-M3HV

AMOUNT OF VALVE OPENING 90

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF

ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG

SOLENOID VALVE C_v 2.20

MEDIA Air

VALVE C_v 6.317

HYDRODYNAMIC TORQUE @ 90 1182

SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 832 IN. LBS.

SEAL TORQUE 1454 IN. LBS.

STEM DIA. 1.375 IN.

GAGE DIA. 12.974 IN.

BUILDING PRESSURE 3.1 PSIG

dt .05 SEC.

DEG.	LOCAL TORQUE (IN. LBS)	PRESSURE DROP (PSI)
10	<u>1413</u>	<u>44.94</u>
20	<u>1303</u>	<u>44.78</u>
30	<u>888</u>	<u>44.13</u>
40	<u>7</u>	<u>42.55</u>
50	<u>-1492</u>	<u>39.15</u>
60	<u>-5113</u>	<u>32.73</u>
70	<u>-7496</u>	<u>20.51</u>
80	<u>-9584</u>	<u>11.29</u>
90	<u>-7586</u>	<u>6.95</u>



DETERMINATION OF CLOSING TIME
 14 - 150 CLASS VALVE WITH A N721C-SR60 ACTUATOR

Case 2B

 THE VALVE IS IN THE PREFERRED DIRECTION

Tspring begin= 5930	Tspring ending= 3720	ACT. FRESS= 60	SOL. VALVE Cv= 2.26
ACT. VOL.= .72	ACT. YOKE RADIUS= 2.5	HYDRO. TORQUE @ 90= 1182	SHUT-OFF PRES. DROP= 45
MEDIA= AIR	VALVE Cv= 6317	Delta= 1.375	Dgage= 12.974
PACKING TORQUE= 832	SEAL TORQUE= 1454		
BUILDING PRESSURE= 3.1			

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1413	1303	886	7	-1492	-3113	-7496	-9584	-7586
PRES DROP	44.94	44.78	44.13	42.55	39.15	32.93	20.51	11.29	6.95

LOCA CLOSES THE VALVE TO 69 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -9584 IN.LBS. @ 80 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	10309	-3428	-8186	832	297	69.00	21.752
0.05	0	4171	-2781	-2437	499	548	47.10	40.135
0.10	0	2693	-2679	-1101	499	588	36.45	43.109
0.15	0	2128	-2688	-541	499	602	29.87	44.138
0.20	0	1979	-2738	-347	499	606	25.08	44.449
0.25	0	1882	-2802	-182	499	610	21.03	44.712
0.30	0	1897	-2894	-114	499	612	17.56	44.816
0.35	0	1960	-2991	-80	499	612	14.42	44.869
0.40	0	2037	-3100	-49	499	613	11.53	44.915
0.45	0	2135	-3219	-28	499	613	8.85	44.946
0.50	0	2255	-3347	-20	499	613	6.37	44.961
0.55	0	2381	-3483	-13	499	614	4.06	44.975
0.60	0	1307	-3626	-6	1711	614	1.90	44.988
0.65	0	1026	-3702	-2	2064	614	0.84	44.994
0.70	0	876	-3761	-0	2270	614	0.06	44.999



DETERMINATION OF CLOSING TIME

VALVE SIZE 14" VALVE CLASS 150

ACTUATOR B-Hic N721C-SR90-M3HV

AMOUNT OF VALVE OPENING 70°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 5770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26

MEDIA Air VALVE C_v 6.317

HYDRODYNAMIC TORQUE @ 90 1182 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 832 IN. LBS. SEAL TORQUE 1454 IN. LBS.

STEM DIA. 1.375 IN. GAGE DIA. 12.974 IN.

BUILDING PRESSURE 3.1 PSIG dt .05 SEC.

DEG.	LOCA TORQUE (IN. LBS)	PRESSURE DROP (PSI)
10	<u>1413</u>	<u>44.94</u>
20	<u>1303</u>	<u>44.78</u>
30	<u>888</u>	<u>44.13</u>
40	<u>7</u>	<u>42.55</u>
50	<u>-1492</u>	<u>39.15</u>
60	<u>-3113</u>	<u>32.73</u>
70	<u>-7496</u>	<u>20.51</u>
80	<u>-9584</u>	<u>11.29</u>
90	<u>-7586</u>	<u>6.95</u>



DETERMINATION OF CLOSING TIME

14 - 150 CLASS VALVE WITH A N721C-SR60 ACTUATOR

Case 22

THE VALVE OPENING IS RESTRICTED TO 70 DEGS.

THE VALVE IS IN THE PREFERRED DIRECTION.

Tapping begins= 5950 Tapping ending= 3770
 ACT. VOL.= .72 ACT. YOKE RADIUS= 2.5 ACT. PRESS.= 20 SOL. VALVE Cv= 2.26
 MEDIA=AIR VALVE Cv= 6317 HYDRO. TORQUE @ 90= 1162 SHUT-OFF PRES. DROP= 45
 PACKING TORQUE= 832 SEAL TORQUE= 1454 Dstem= 1.375 Dgage= 12.974
 BUILDING PRESSURE= 3.1

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1413	1303	888	7	-1492	-3113	-7496	-9584	-7586
PRES DROP	44.94	44.78	44.13	42.55	39.15	32.93	20.51	11.29	6.95

LOCA CLOSING THE VALVE TO 64 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -7496 IN LBS. @ 70 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	8258	-3178	-6080	832	381	64.00	27.962
0.05	0	3830	-2767	-2120	499	558	44.91	40.878
0.10	0	2580	-2676	-994	499	591	35.21	43.306
0.15	0	2097	-2695	-505	499	603	28.98	44.196
0.20	0	1959	-2749	-316	499	607	24.33	44.498
0.25	0	1869	-2823	-156	499	611	20.39	44.754
0.30	0	1906	-2909	-108	499	612	17.01	44.827
0.35	0	1972	-3009	-74	499	612	13.91	44.877
0.40	0	2051	-3120	-44	499	613	11.06	44.923
0.45	0	2155	-3240	-27	499	613	8.42	44.949
0.50	0	2276	-3370	-19	499	614	5.96	44.964
0.55	0	2406	-3507	-12	499	614	3.68	44.977
0.60	0	1199	-3651	-5	1842	614	1.55	44.990
0.65	0	975	-3721	-1	2132	614	0.59	44.996



DETERMINATION OF CLOSING TIME

VALVE SIZE 12 VALVE CLASS 150

ACTUATOR Bett's N721C-SK80-M3HW

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26

MEDIA Air VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN.LBS. SEAL TORQUE 1183 IN.LBS.

STEM DIA. 1.25 IN. GAGE DIA. 11.703 IN.

BUILDING PRESSURE 45 PSIG dt .05 SEC.

DEG.	LOCA TORQUE (IN.LBS)	PRESSURE DROP (PSI)
10	<u>1183</u>	<u>44.90</u>
20	<u>1104</u>	<u>44.63</u>
30	<u>820</u>	<u>43.81</u>
40	<u>254</u>	<u>41.65</u>
50	<u>-598</u>	<u>36.84</u>
60	<u>-1766</u>	<u>27.43</u>
70	<u>-3321</u>	<u>13.44</u>
80	<u>-3991</u>	<u>7.53</u>
90	<u>-2875</u>	<u>4.85</u>



DETERMINATION OF CLOSING TIME
12 - 150 CLASS VALVE WITH A N721C-SF80 ACTUATOR

Case 3A

THE VALVE IS IN THE PREFERRED DIRECTION

Testing begin# 5930 Spring ending# 3720
 ACT. VOL.# 1.72 ACT. YONE RADIUS# 2.5 ACT. PRES# 80 SOL. VALVE Cv# 2.25
 MEDIA#AIR VALVE Cv# 4942 HYDRO. TORQUE @ 90# 761 SHUT-OFF PRES. DROP# 45
 PACKING TORQUE# 756 SEAL TORQUE# 1183 Design# 1.25 Dgage# 11.703
 BUILDING PRESSURE# 45

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1183	1604	820	254	-596	-1766	-3321	-3991	-2875
PRES DROP	44.90	44.63	43.81	41.65	36.84	27.43	13.44	7.53	4.85

LOCA CLOSES THE VALVE TO 59 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -3991 IN.LBS. @ 80 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	4654	-2997	-2691	756	286	59.00	28.371
0.05	0	3488	-2785	-1539	453	383	47.67	37.957
0.10	0	2669	-2692	-854	453	423	38.74	41.921
0.15	0	2278	-2678	-492	453	437	32.08	43.358
0.20	0	1946	-2716	-129	453	445	26.78	44.073
0.25	0	1683	-2777	191	453	448	22.65	44.412
0.30	0	1570	-2846	371	453	450	19.39	44.646
0.35	0	1761	-2921	254	453	451	16.62	44.721
0.40	0	1973	-3013	134	453	452	13.79	44.797
0.45	0	2204	-3124	13	453	453	10.95	44.874
0.50	0	2369	-3255	-21	453	453	8.13	44.918
0.55	0	2504	-3397	-14	453	453	5.48	44.945
0.60	0	2647	-3549	-8	453	454	3.03	44.969
0.65	0	1482	-3707	-2	1772	454	0.78	44.992



DETERMINATION OF CLOSING TIMEVALVE SIZE 12VALVE CLASS 150ACTUATOR Bell's N721C-SR80-M3HWAMOUNT OF VALVE OPENING 70°DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26MEDIA Air VALVE C_v 4942HYDRODYNAMIC TORQUE @ 90 761 SHUT OFF PRESSURE DROP 45 PSIPACKING TORQUE 756 IN.LBS. SEAL TORQUE 1183 IN.LBS.STEM DIA. 1.25 IN. GAGE DIA. 11.703 IN.BUILDING PRESSURE 45 PSIG dt .05 SEC.

DEG.	LOCA TORQUE (IN.LBS)	PRESSURE DROP (PSI)
10	<u>1183</u>	<u>44.90</u>
20	<u>1104</u>	<u>44.63</u>
30	<u>820</u>	<u>43.81</u>
40	<u>254</u>	<u>41.65</u>
50	<u>-598</u>	<u>30.84</u>
60	<u>-1766</u>	<u>27.43</u>
70	<u>-3321</u>	<u>13.44</u>
80	<u>-3991</u>	<u>7.53</u>
90	<u>-2875</u>	<u>4.85</u>



DETERMINATION OF CLOSING TIME
 12 - 150 CLASS VALVE WITH A N721C-SR80 ACTUATOR

Case 3f

THE VALVE OPENING IS RESTRICTED TO 70 DEGS.

THE VALVE IS IN THE PREFERRED DIRECTION

Tspring begin= 5930 Tspring ending= 3770
 ACT. VOL.= .72 ACT. YOKE RAD:US= 2.5 ACT. PRESS= 80 SOL. VALVE Cv= 2.20
 MEDIA=AIR VALVE Cv= 4942 HYDRO. TORQUE @ 90= 761 SHUT-OFF PRES. DROP= 45
 FACING TORQUE= 750 SEAL TORQUE= 1183 Ostem= 1.25 Dgage= 11.703
 BUILDING PRESSURE= 45

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1183	1604	820	254	-598	-1766	-3321	-3991	-2875
PRES DROP	44.90	44.63	43.81	41.65	36.84	27.43	13.44	7.53	4.85

LOCA CLOSES THE VALVE TO 53 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -3321 IN LBS @ 70 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	3799	-2855	-2047	755	343	53.00	34.017
0.05	0	3074	-2742	-1190	453	404	43.33	40.047
0.10	0	2472	-2676	-679	453	430	35.52	42.615
0.15	0	2136	-2621	-342	453	442	29.53	43.848
0.20	0	1814	-2743	28	453	446	24.75	44.240
0.25	0	1590	-2809	314	453	449	21.06	44.542
0.30	0	1457	-2872	317	453	451	18.11	44.680
0.35	0	1857	-2962	198	453	452	15.31	44.756
0.40	0	2078	-3063	78	453	452	12.47	44.833
0.45	0	2301	-3183	-25	453	453	9.63	44.903
0.50	0	2431	-3320	-18	453	453	6.86	44.931
0.55	0	2571	-3467	-11	453	454	4.31	44.956
0.60	0	1720	-3622	-5	1452	454	1.96	44.980
0.65	0	1449	-3723	-1	1820	454	0.56	44.994



DETERMINATION OF CLOSING TIME

VALVE SIZE 12" VALVE CLASS 150

ACTUATOR B.F.L. N721C-SR80-MJHW

AMOUNT OF VALVE OPENING 20°

DIRECTION OF FLOW P. to L.

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 2770

ACTUATOR VOLUME .72 SCF ACTUATOR YORE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.26

MEDIA A1- VALVE C_v 4972

HYDRODYNAMIC TORQUE @ 90 761 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN. LBS. SEAL TORQUE 1183 IN. LBS.

STEM DIA. 1.25 IN. GAGE DIA. 16.703 IN.

BUILDING PRESSURE 3.1 PSIG dt .25 SEC.

<u>DEG.</u>	<u>DENSITY (LBS/FT³)</u>	<u>VELOCITY (FT/SEC)</u>	<u>PRESSURE DROP (PSI)</u>
10	<u>.0740</u>	<u>69.5</u>	<u>44.9</u>
20	<u>.0744</u>	<u>136.8</u>	<u>44.8</u>
30	<u>.0760</u>	<u>205.9</u>	<u>44.1</u>
40	<u>.0797</u>	<u>209.9</u>	<u>42.4</u>
50	<u>.0877</u>	<u>549.0</u>	<u>38.5</u>
60	<u>.102</u>	<u>633.8</u>	<u>31.6</u>
70	<u>.128</u>	<u>653.9</u>	<u>18.5</u>
80	<u>.135</u>	<u>700.5</u>	<u>11.9</u>
90	<u>.152</u>	<u>624.9</u>	<u>5.95</u>



12 - 150 CLASS VALVE WITH A N7210-SR50 ACTUATOR

Case 38

THE VALVE IS IN THE PREFERRED DIRECTION

TEST NO. 5930 CYLINDER CAPACITY 3.770
 ACT. TORQUE 14000 ACT. PRESS. 60 SGL. VALVE CV = 1.25
 VALVE 1.74 HYDRO. TORQUE @ 90° 731 SHUT-OFF PRES. 1500 = 45
 SEP. 25 1954 1:00 OIL TEMP 1.25 DESIGN 11.707
 BUILDING PRESSURE 3.1

SEC.	10	20	30	40	50	60	70	80	90
DENSITY	.0740	.0744	.0760	.0767	.0877	.1020	.1280	.1350	.1520
VELOCITY	17.8	136.3	285.7	400.9	540.0	633.3	652.7	700.5	624.9
FRES SECP	44.70	44.30	44.10	42.40	38.50	31.60	18.50	11.90	5.95

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	4197	12993	-5924	-3687	756	60	90.00	5.95
0.05	2732	11528	-5924	-3687	756	60	90.00	5.95
0.10	1579	10375	-5924	-3687	756	60	90.00	5.95
0.15	645	9442	-5924	-3687	756	60	90.00	5.95
0.20	0	8668	-5924	-3687	756	60	90.00	5.95
0.25	0	8778	-4497	-4599	457	102	82.91	10.16
0.30	0	6416	-3618	-3425	453	172	71.97	17.19
0.35	0	3478	-3023	-1228	453	320	59.83	31.71
0.40	0	2488	-2570	-489	457	378	51.51	37.45
0.45	0	2145	-2749	-237	453	407	45.16	40.38
0.50	0	1937	-2699	-120	453	428	39.68	42.45
0.55	0	1844	-2475	-61	457	437	34.80	43.28
0.60	0	1816	-2626	-28	453	444	30.32	44.04
0.65	0	1836	-2723	-15	453	448	26.19	44.36
0.70	0	1886	-2787	-7	453	450	22.33	44.63
0.75	0	1960	-2863	-3	453	452	18.72	44.81
0.80	0	2055	-2960	-1	453	452	15.36	44.84
0.85	0	2114	-3072	-0	453	452	12.22	44.87
0.90	0	2291	-3198	-0	453	453	9.29	44.90
0.95	0	2428	-3335	-0	453	453	6.58	44.93
1.00	0	2575	-3482	-0	453	454	4.07	44.95
1.05	0	1964	-3637	-0	1216	454	1.74	44.98
1.10	0	1498	-3752	-0	1600	454	0.18	44.99



DETERMINATION OF CLOSING TIME

VALVE SIZE 12" VALVE CLASS 150

ACTUATOR B.L.L. N721C-5A82-M34W

AMOUNT OF VALVE OPENING 70°

DIRECTION OF FLOW P. to A. 5

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 7770

ACTUATOR VOLUME .72 SCF

ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG

SOLENOID VALVE C_v 2.26

MEDIA Air

VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761

SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN. LBS.

SEAL TORQUE 1183 IN. LBS.

STEM DIA. 1.25 IN.

GAGE DIA. 1.623 IN.

BUILDING PRESSURE 3.1 PSIG

dt .25 SEC.

DEG.	DENSITY (LBS/FT ³)	VELOCITY (FT/SEC)	PRESSURE DROP (PSI)
10	<u>.0740</u>	<u>69.5</u>	<u>44.9</u>
20	<u>.0744</u>	<u>136.8</u>	<u>44.8</u>
30	<u>.0760</u>	<u>205.9</u>	<u>44.1</u>
40	<u>.0797</u>	<u>409.9</u>	<u>42.4</u>
50	<u>.0877</u>	<u>549.0</u>	<u>38.5</u>
60	<u>.102</u>	<u>633.8</u>	<u>31.6</u>
70	<u>.128</u>	<u>653.9</u>	<u>18.5</u>
80	<u>.135</u>	<u>700.5</u>	<u>11.9</u>
90	<u>.152</u>	<u>624.9</u>	<u>5.95</u>



DETERMINATION OF CLOSING TIME

Case 38

THE VALVE OPENING IS RESTRICTED TO 70 DEGS.

THE VALVE IS IN THE CLOSED POSITION

ACT. PRESS= 80 SOL. VALVE CV= 2.26
 HYDRG. TORQUE @ 90°= 761 SHUT-OFF PRES. DROP= .5
 DELTA= 1.25
 ACT. TORQ. RADING= 2.0 VALVE CV= 4042
 SEAL TORQUE= 1103

DEL.	1	20	30	40	50	60	70	80	90
DENSITY	.0740	.0744	.0740	.0737	.0077	.1020	.1280	.1350	.1520
VELOCITY	69.8	136.8	265.7	406.9	549.3	633.8	653.4	700.5	624.9
PRES. DROP	44.20	44.20	44.10	42.40	30.50	31.00	18.50	11.20	5.75

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	2634	8475	-3422	-3074	750	186	70.00	18.50
0.05	1870	7521	-3402	-3094	750	186	70.00	18.50
0.10	1127	6577	-3402	-3094	750	186	70.00	18.50
0.15	518	6159	-3488	-3094	750	186	70.00	18.50
0.20	14	5254	-3488	-3094	756	186	70.00	18.50
0.25	0	5228	-3488	-3094	754	186	70.00	18.50
0.30	0	3453	-3010	-1200	453	321	59.66	31.82
0.35	0	2477	-2829	-481	453	379	51.39	37.53
0.40	0	2147	-2779	-274	457	408	45.96	40.42
0.45	0	1935	-2698	-118	453	428	39.59	42.46
0.50	0	1845	-2675	-60	453	437	34.72	43.29
0.55	0	1816	-2684	-28	453	445	30.25	44.05
0.60	0	1837	-2724	-14	453	446	26.12	44.37
0.65	0	1887	-2784	-7	453	450	22.27	44.64
0.70	0	1942	-2864	-3	453	452	18.67	44.81
0.75	0	2057	-2962	-1	453	452	15.30	44.84
0.80	0	2168	-3074	-0	453	453	12.17	44.87
0.85	0	2204	-3200	-0	453	453	9.25	44.90
0.90	0	2431	-3338	-0	453	453	6.54	44.93
0.95	0	2577	-3485	-0	453	454	4.03	44.95
1.00	0	1955	-3640	-0	1230	454	1.70	44.98
1.05	0	1694	-3754	-0	1605	454	0.15	44.99



DETERMINATION OF CLOSING TIME

VALVE SIZE 12 VALVE CLASS 150

ACTUATOR B&H: N721C-5R80-M3HW

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW Portugal

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME 72 SCF ACTUATOR YOKE RADIUS 25 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.20

MEDIA Air VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN. LBS. SEAL TORQUE 1183 IN. LBS.

STEM DIA. 1.25 IN. GAGE DIA. 11.703 IN.

BUILDING PRESSURE 45 PSIG dt .05 SEC.

DEG.	LOCA TORQUE (IN. LBS)	PRESSURE DROP (PSI)
10	<u>1183</u>	<u>44.89</u>
20	<u>1102</u>	<u>44.60</u>
30	<u>799</u>	<u>43.67</u>
40	<u>195</u>	<u>41.37</u>
50	<u>-732</u>	<u>35.91</u>
60	<u>-1730</u>	<u>21.77</u>
70	<u>-3590</u>	<u>12.58</u>
80	<u>-4319</u>	<u>7.13</u>
90	<u>-3296</u>	<u>4.56</u>



DETERMINATION OF CLOSING TIME
 12 - 150 CLASS VALVE WITH A N721C-SR60 ACTUATOR

THE VALVE IS IN THE PREFERRED DIRECTION

Case 4 A

Ispring begin= 5930	Ispring ending= 3270	ACT. PRESS= 80	SOL. VALVE Cv= 2.26
ACT. VOL.= .72	ACT. YOKE RADIUS= 3.5	HYDRG. TORQUE @ 90= 761	SHUT-OFF PRES. DROP= 45
MEDIA= AIR	VALVE Cv= 49.2	Osten= 1.25	Dgate= 11.703
PACKING TORQUE= 750	SEAL TORQUE= 1183		
BUILDING PRESSURE= 45			

DEG.	10	20	30	40	50	60	70	80	90
ACTO TORQUE	1183	1102	799	195	-732	-1730	-3590	-4319	-3296
PRES DROP	44.89	44.60	43.67	41.37	35.91	21.77	12.58	7.13	4.56

LOCA CLOSES THE VALVE TO 59 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -4319 IN. LBS. @ 80 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	4654	-3997	-2620	756	234	59.00	23.184
0.05	0	3604	-2785	-1648	453	375	47.67	37.178
0.10	0	2703	-2689	-886	453	421	38.44	41.727
0.15	0	2287	-2679	-498	453	437	31.72	43.273
0.20	0	2115	-2720	-293	453	444	26.43	44.001
0.25	0	2050	-2790	-162	453	448	21.98	44.415
0.30	0	2064	-2879	-89	453	451	18.11	44.654
0.35	0	2141	-2984	-62	453	452	14.64	44.755
0.40	0	2234	-3103	-37	453	452	11.46	44.847
0.45	0	2350	-3234	-22	453	453	8.54	44.906
0.50	0	2484	-3376	-15	453	453	5.86	44.935
0.55	0	2627	-3526	-8	453	454	3.38	44.962
0.60	0	1535	-3683	-2	1596	454	1.10	44.987



DETERMINATION OF CLOSING TIME

VALVE SIZE 12

VALVE CLASS 150

ACTUATOR Bell N721C-SR80-M3HV

AMOUNT OF VALVE OPENING 70°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930

SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF

ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG

SOLENOID VALVE C_v 2.20

MEDIA Air

VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761

SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN.LBS.

SEAL TORQUE 1183 IN.LBS.

STEM DIA. 1.25 IN.

GAGE DIA. 11.703 IN.

BUILDING PRESSURE 45 PSIG

dt .05 SEC.

DEG.	LOCA TORQUE (IN.LBS)	PRESSURE DROP (PSI)
10	<u>1183</u>	<u>44.89</u>
20	<u>1102</u>	<u>44.60</u>
30	<u>799</u>	<u>43.67</u>
40	<u>195</u>	<u>41.57</u>
50	<u>-732</u>	<u>35.91</u>
60	<u>-1730</u>	<u>21.77</u>
70	<u>-3590</u>	<u>12.58</u>
80	<u>-4319</u>	<u>7.13</u>
90	<u>-3296</u>	<u>4.56</u>



DETERMINATION OF CLOSING TIME
 12 - 150 CLASS VALVE WITH A N721C-SR80 ACTUATOR

Case 18

THE VALVE OPENING IS RESTRICTED TO 70 DEGS.

THE VALVE IS IN THE PREFERRED DIRECTION

Tspring begin= 5030	Tspring ending= 3770	ACT. PRESS= 80	SOL. VALUE Cv= 2.26
ACT. VOL.= .72	ACT. YOKE SAZIUC= 2.5	HYDRO. TORQUE @ 90= 761	SHUT-OFF PRES. DROP= 45
MEDIA= AIR	VALVE Cv= 4942	Dstem= 1.25	Dgage= 11.703
FACING TORQUE= 756	SEAL TORQUE= 1183		
BUILDING PRESSURE= 45			

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1183	1102	799	195	-732	-1730	-3590	-4319	-3296
PRES DROP	44.89	44.60	43.67	41.37	35.91	21.77	12.58	7.13	4.56

LOCA CLOSES THE VALVE TO 52 DEGREES WITH THE ACTUATOR STILL ACTUATED

MAXIMUM LOCA TORQUE AS VALVE CLOSES IS -3590 IN. LBS. @ 70 DEGREES

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	0	3817	-2838	-2021	756	334	52.00	33.062
0.05	0	3043	-2727	-1175	453	405	42.25	40.141
0.10	0	2453	-2675	-662	453	430	34.54	42.624
0.15	0	2160	-2657	-358	453	442	28.65	43.794
0.20	0	2074	-2756	-219	453	446	23.90	44.236
0.25	0	2036	-2837	-102	453	450	19.78	44.606
0.30	0	2104	-2934	-74	453	451	16.18	44.710
0.35	0	2190	-3047	-48	453	452	12.87	44.806
0.40	0	2292	-3173	-26	453	453	9.83	44.891
0.45	0	2421	-3310	-18	453	453	7.05	44.922
0.50	0	2561	-3457	-11	453	454	4.48	44.950
0.55	0	1766	-3611	-5	1396	454	2.12	44.976
0.60	0	1466	-3715	-1	1796	454	0.67	44.992



DETERMINATION OF CLOSING TIME

VALVE SIZE 12" VALVE CLASS 150

ACTUATOR Betts 11721 C-SR80-M3HW

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.25

MEDIA Air VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761 SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN.LBS. SEAL TORQUE 1183 IN.LBS.

STEM DIA. 1.25 IN. GAGE DIA. 11.703 IN.

BUILDING PRESSURE 3.1 PSIG dt .05 SEC.

DEG.	LOCA TORQUE (IN.LBS)	PRESSURE DROP (PSI)
10	<u>1180</u>	<u>44.93</u>
20	<u>1093</u>	<u>44.75</u>
30	<u>756</u>	<u>44.03</u>
40	<u>61</u>	<u>42.27</u>
50	<u>-1061</u>	<u>38.36</u>
60	<u>-2611</u>	<u>31.28</u>
70	<u>-4729</u>	<u>17.32</u>
80	<u>-6776</u>	<u>12.44</u>
90	<u>-4404</u>	<u>5.97</u>



DETERMINATION OF CLOSING TIME
 12 - 150 CLASS VALVE WITH A N721C-SR80 ACTUATOR

Case 48

 THE VALVE IS IN THE PREFERRED DIRECTION

Tspring begin= 5930	Tspring ending= 3770		
ACT. VOL. = .70	ACT. YOKE RADIUS= 2.5	ACT. PRESS= 80	SOL. VALVE Cv= 2.26
MEDIA= AIR	VALVE Cv= 4942	HYDRJ. TORQUE @ 90= 761	SHUT-OFF PRES. DROP= 45
PACKING TORQUE= 75c	SEAL TORQUE= 1183	Ortem= 1.25	Dgage= 11.703
BUILDING PRESSURE= 3.1			

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1180	1093	756	61	-1061	-2611	-4729	-6776	-4404
PRES DROP	44.93	44.75	44.03	42.27	38.36	31.28	17.33	12.44	5.97

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	2664	12993	-5924	-5220	756	60	90.00	5.970
0.05	1200	11529	-5924	-5220	756	60	90.00	5.970
0.10	47	10376	-5924	-5220	756	60	90.00	5.970
0.15	0	9442	-5924	-5220	756	60	90.00	5.970
0.20	0	11159	-4603	-7120	453	111	82.20	11.014
0.25	0	7777	-3331	-5113	453	214	67.23	21.187
0.30	0	4234	-2014	-2258	453	384	50.36	38.059
0.35	0	2906	-2698	-1089	453	427	39.52	42.354
0.40	0	2380	-2677	-597	453	440	32.25	43.633
0.45	0	2152	-2717	-334	453	447	26.70	44.267
0.50	0	2069	-2787	-186	453	450	22.15	44.594
0.55	0	2070	-2676	-99	453	452	18.22	44.781
0.60	0	2144	-2981	-70	453	452	14.73	44.844
0.65	0	2236	-3100	-42	453	453	11.54	44.902
0.70	0	2349	-3231	-25	453	453	8.61	44.939
0.75	0	2482	-3322	-17	453	454	5.92	44.958
0.80	0	2625	-3522	-10	453	454	3.44	44.975
0.85	0	1545	-3679	-3	1683	454	1.15	44.991



DETERMINATION OF CLOSING TIME

VALVE SIZE 12"

VALVE CLASS 150

ACTUATOR Beths 11721 C-SR80-M3HW

AMOUNT OF VALVE OPENING 70°

DIRECTION OF FLOW Preferred

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930

SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF

ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG

SOLENOID VALVE C_v 2.25

MEDIA Air

VALVE C_v 4942

HYDRODYNAMIC TORQUE @ 90 761

SHUT OFF PRESSURE DROP 45 PSI

PACKING TORQUE 756 IN.LBS.

SEAL TORQUE 1183 IN.LBS.

STEM DIA. 1.25 IN.

GAGE DIA. 11.703 IN.

BUILDING PRESSURE 3.1 PSIG

dt .05 SEC.

DEC.	LOCA TORQUE (IN.LBS)	PRESSURE DROP (PSI)
10	<u>1180</u>	<u>44.93</u>
20	<u>1093</u>	<u>44.75</u>
30	<u>756</u>	<u>44.03</u>
40	<u>61</u>	<u>42.27</u>
50	<u>-1061</u>	<u>38.36</u>
60	<u>-2611</u>	<u>31.28</u>
70	<u>-4729</u>	<u>17.33</u>
80	<u>-6776</u>	<u>12.44</u>
90	<u>-4404</u>	<u>5.97</u>



DETERMINATION OF CLOSING TIME
 12 - 150 CLASS VALVE WITH A N721C-SR60 ACTUATOR

Case # 40

THE VALVE OPENING IS RESTRICTED TO 50 DEGS.

THE VALVE IS IN THE PREFERRED DIRECTION

Testing begin 5930
 ACT. VOL. = 1.72
 MEDIA = AIR
 PACKING TORQUE = 756
 BUILDING PRESSURE = 3.1

Testing ending = 3770
 ACT. YOKE RADIUS = 2.5
 VALVE Cv = 4942
 SEAL TORQUE = 1183

ACT. PRESS. 80
 HYDRO. TORQUE @ 90 = 761
 Dstem = 1.25

SOL. VALVE Cv = 2.26
 SHUT-OFF PRES. DROP = 45
 Dgage = 11.703

DEG.	10	20	30	40	50	60	70	80	90
AERO TORQUE	1180	1093	756	61	-1061	-2611	-4729	-6776	-4404
PRES DROP	44.93	44.75	44.03	42.27	38.36	31.28	17.33	12.44	5.97

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P sec
0.00	2024	7665	-3029	-3682	756	315	60.00	31.280
0.05	1161	6801	-3029	-3682	756	315	60.00	31.280
0.10	481	6121	-3029	-3682	756	315	60.00	31.280
0.15	0	5570	-3029	-3682	756	315	60.00	31.280
0.20	0	3753	-2777	-1871	453	401	46.55	32.708
0.25	0	2712	-2681	-917	453	432	36.97	42.802
0.30	0	2254	-2686	-465	453	444	30.31	43.975
0.35	0	2121	-2736	-286	453	448	25.21	44.374
0.40	0	2051	-2813	-143	453	451	20.86	44.687
0.45	0	2091	-2907	-90	453	452	17.11	44.801
0.50	0	2171	-3016	-61	453	453	13.71	44.863
0.55	0	2267	-3139	-35	453	453	10.60	44.919
0.60	0	2389	-3274	-23	453	453	7.75	44.945
0.65	0	2525	-3418	-15	453	454	5.13	44.964
0.70	0	2003	-3570	-8	1121	457	2.71	44.981
0.75	0	1522	-3689	-3	1715	454	1.02	44.992



APPENDIX E

A

Comparison of Actual to Calculated
Closing Times



DETERMINATION OF CLOSING TIME

VALVE SIZE 14" VALVE CLASS 150

ACTUATOR Betts N721 C-SR90-M3HW

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW —

ACTUATOR TORQUES (IN.LBS)

SPRING BEGINNING 5930 SPRING ENDING 7770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.76

MEDIA _____ VALVE C_v _____

HYDRODYNAMIC TORQUE @ 90 _____ SHUT OFF PRESSURE DROP _____ PSI

PACKING TORQUE 832 IN.LBS. SEAL TORQUE 1754 IN.LBS.

STEM DIA. 1.375 IN. GAGE DIA. 12.974 IN.

BUILDING PRESSURE 0 PSIG dt 0.1 SEC.

<u>DEG.</u>	<u>DENSITY (LBS/FT³)</u>	<u>VELOCITY (FT/SEC)</u>	<u>PRESSURE DROP (PSI)</u>
10.	_____	_____	_____
20	_____	_____	_____
30	_____	_____	_____
40	_____	_____	_____
50	_____	_____	_____
60	_____	_____	_____
70	_____	_____	_____
80	_____	_____	_____
90	_____	_____	_____



DETERMINATION OF CLOSING TIME

THERE IS NO FLOW

Testing engine S930
ACT. VOL. = .77
FACT. TORQUE = 832
BUILDING PRESSURE = 0

Testing engine J770
ACT. YONE RADIUS = 2.5
ACT. TORQUE = 1454

ACT. PRESS = 90
System = 10376

SOL. VALVE Cv = 2.24
Dgaga = 12.774

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	8424	13517	-5924	0	832	0	90.00	0.00
0.10	5254	10347	-5924	0	832	0	90.00	0.00
0.20	3378	8487	-5924	0	832	0	90.00	0.00
0.30	2146	7239	-5924	0	832	0	90.00	0.00
0.40	1237	6330	-5924	0	832	0	90.00	0.00
0.50	542	5534	-5924	0	832	0	90.00	0.00
0.60	0	5084	-5924	0	832	0	90.00	0.00
0.70	0	4017	-4517	0	499	0	81.52	0.00
0.80	0	3043	-3542	0	499	0	70.34	0.00
0.90	0	2498	-2997	0	499	0	58.98	0.00
1.00	0	2279	-2779	0	499	0	46.80	0.00
1.10	0	2176	-2576	0	499	0	35.17	0.00
1.20	0	2241	-2741	0	499	0	24.89	0.00
1.30	0	2437	-2937	0	499	0	16.10	0.00
1.40	0	2723	-3223	0	499	0	6.77	0.00
1.50	0	2689	-3565	0	876	0	2.79	0.00



POST-SEAL INTERNATIONAL, INC.

VALVE ASSEMBLY CYCLE TEST REPORT

PSI VALVE SERIAL NO. 19157-03A		TRAVELER NO. 83-19157-03-0100	
CUSTOMER Stone + Webster	PURCHASE ORDER NO. Nmp2-P.304D	ITEM	TAG NO. 2CPS*ADV104
OPERATOR TYPE N721C-SR80-M3HW	MANUFACTURER Bettis	SERIAL NO. 83-9021-3	

ACCESSORIES: As listed per spec. sheet.

CYCLE TEST REQUIREMENTS PER SPECIFICATION: 19157 T-5, REV. B

TEST CONDITIONS

- Each valve shall be cycle tested with the specific actuator which will be shipped with that particular valve.
- This test shall be performed after hydrostatic testing is completed and without further adjustment to packing.
- Each valve shall be cycled, open and closed two (2) times with its actuator. The valve shall also be cycled once with the maximum working ~~differentia~~ ^{differs} pressure applied (= 150 PSIG). The time to open and close the valve shall not exceed three (3) minutes for valves with manual gear actuators.
- During the cycle test, there shall be no binding or malfunctions.

TEST RESULTS

- Failure Mode: F/C
- | | |
|--|--|
| <u>Closed to Open:</u> | <u>Open to Closed:</u> |
| First time: <u>1.9</u> sec. (w/actuator) | First time: <u>1.7</u> sec. (w/actuator) |
| Second time: <u>1.8</u> sec. (w/actuator) | Second time: <u>1.7</u> sec. (w/actuator) |
| Third time: <u>1.7</u> sec. (w/ <u>150</u> PSIG) | Third time: <u>1.7</u> sec. (w/ <u>N/A</u> PS) |
| Fourth time: <u>60</u> sec. (Man. override) | Fourth time: <u>60</u> sec. (Man. overr) |
- During the cycle test, there shall be no binding or malfunctions.
- The cycle test was performed and completed satisfactorily in accordance with all requirements per PSI Specification No. 19157-T5, Rev. B



NIAGARA MOHAWK POWER CORP
NINE MILE POINT NUC STA UNIT 2
P.O. NO. NMP2-P3040 JO NC 12177
BUTTERFLY VALVES - CATEGORY I
PAGE 56 TAG 2CPS*ADV104.....

GAGE #1091

TESTED BY <u>F. ROSE</u>	DATE <u>7/8/83</u>	INSPECTED BY <u>Stephen Fusano</u>	DATE <u>7/8/83</u>
WITNESSED BY <u>J. E. DONOVAN SVEC P&A</u>	DATE <u>7-8-83</u>	AUTHORIZED INSPECTOR	DATE



DETERMINATION OF CLOSING TIME

VALVE SIZE 12" VALVE CLASS 150

ACTUATOR Betts N721C-SR80-M3HW

AMOUNT OF VALVE OPENING 90°

DIRECTION OF FLOW -

ACTUATOR TORQUES (IN. LBS)

SPRING BEGINNING 5930 SPRING ENDING 3770

ACTUATOR VOLUME .72 SCF ACTUATOR YOKE RADIUS 2.5 IN.

ACTUATOR PRESSURE 80 PSIG SOLENOID VALVE C_v 2.2

MEDIA _____ VALVE C_v _____

HYDRODYNAMIC TORQUE @ 90 _____ SHUT OFF PRESSURE DROP _____ PSI

PACKING TORQUE 756 IN. LBS. SEAL TORQUE 1183 IN. LBS.

STEM DIA. 1.25 IN. GAGE DIA. 1.703 IN.

BUILDING PRESSURE 0 PSIG dt 0.1 SEC.

<u>DEG.</u>	<u>DENSITY (LBS/FT³)</u>	<u>VELOCITY (FT/SEC)</u>	<u>PRESSURE DROP (PSI)</u>
10	_____	_____	_____
20	_____	_____	_____
30	_____	_____	_____
40	_____	_____	_____
50	_____	_____	_____
60	_____	_____	_____
70	_____	_____	_____
80	_____	_____	_____
90	_____	_____	_____



DETERMINATION OF CLOSING TIME

IS 100 CLASS OF 2 1/2 IN. A. R. P. VALVE ACTUATOR

THERE IS NO FLOW

TORQUE BEARING 4930
ACT. VALVE 1.72
PACKING TORQUE 1750
BUILDING PRESSURE 0

TORQUE SPRING 3770
ACT. VALVE RADIUS 2.6
SEAL TORQUE 1100

ACT. PRESS 30
ORIGIN 11.00

SOL. VALVE CV 2.26
ORIGIN 11.00

TIME sec	TORQUE tend to open	TORQUE air	TORQUE spring	TORQUE flow	TORQUE packing & seal	TORQUE bearing	ANGLE degrees	DELTA P psi
0.00	8348	13517	-5924	0	756	0	90.00	0.00
0.10	5178	10347	-5924	0	756	0	90.00	0.00
0.20	3220	8487	-5924	0	756	0	90.00	0.00
0.30	2070	7239	-5924	0	756	0	90.00	0.00
0.40	1161	6330	-5924	0	756	0	90.00	0.00
0.50	465	5634	-5924	0	756	0	90.00	0.00
0.60	0	5094	-5924	0	756	0	90.00	0.00
0.70	0	4063	-4517	0	453	0	81.52	0.00
0.80	0	3020	-3333	0	453	0	70.70	0.00
0.90	0	2533	-2987	0	453	0	58.64	0.00
1.00	0	2321	-2775	0	453	0	46.24	0.00
1.10	0	2221	-2675	0	453	0	34.45	0.00
1.20	0	2300	-2753	0	453	0	24.04	0.00
1.30	0	2510	-2964	0	453	0	15.23	0.00
1.40	0	2820	-3243	0	453	0	7.96	0.00
1.50	0	2489	-3618	0	1128	0	2.02	0.00



POSTI-SEAL INTERNATIONAL, INC.

VALVE ASSEMBLY CYCLE TEST REPORT

PSI VALVE SERIAL NO. 19157-4A		TRAVELER NO. 83-19157-04	
CUSTOMER Stone + Webster	PURCHASE ORDER NO. Nmp2-P304D	ITEM	TAG NO. 2CPS A0V107
OPERATOR TYPE N721C-SR80-M3HW	MANUFACTURER BETTIS	SERIAL NO. 83-9021-8	

ACCESSORIES: As listed per spec. sheet.

CYCLE TEST REQUIREMENTS PER SPECIFICATION: 19157 T-5, REV. B

TEST CONDITIONS

- Each valve shall be cycle tested with the specific actuator which will be shipped with that particular valve.
- This test shall be performed after hydrostatic testing is completed and without further adjustment to packing.
- Each valve shall be cycled, open and closed two (2) times with its actuator. The valve shall also be cycled once with the maximum working ~~difference~~ ^{at 150} pressure applied (= 150 PSIG). The time to open and close the valve shall not exceed three (3) minutes for valves with manual gear actuators.
- During the cycle test, there shall be no binding or malfunctions.

TEST RESULTS



- Failure Mode: FAIL CLOSED
- | | |
|--|--|
| <u>Closed to Open:</u> | <u>Open to Closed:</u> |
| First time: <u>2.1</u> sec. (w/actuator) | First time: <u>1.7</u> sec. (w/actuator) |
| Second time: <u>2.0</u> sec. (w/actuator) | Second time: <u>1.7</u> sec. (w/actuator) |
| Third time: <u>2.2</u> sec. (w/ <u>150</u> PSIG) | Third time: <u>2.0</u> sec. (w/ <u>N/A</u> PSIG) |
| Fourth time: <u>2.4</u> sec. (man. override) | Fourth time: <u>2.1</u> sec. (man. override) |
- During the cycle test, there shall be no binding or malfunctions.
- The cycle test was performed and completed satisfactorily in accordance with all requirements per PSI Specification No. 19157-T5, Rev. B

NIAGARA MOHAWK POWER CORP
 NINE MILE POINT NUC STA UNIT 2
 P.O. NO. NMP2-P304D JO NO 12177
 BUTTERFLY VALVES - CATEGORY I
 PAGE 41 TAG 2CPS A0V107.....

Post-Seal International, Inc.
 Rts. 49 & U.S. 95
 North Stonington, Conn. 06359

I-1091

TESTED BY John Robbins	DATE 7-11-83	INSPECTED BY Jude Burdiak	DATE 7-11-83
WITNESSED BY J. E. Donovan S.E.W. P&A	DATE 7-11-83	AUTHORIZED INSPECTOR	DATE



APPENDIX F

Miscellaneous Calculations



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title Determination of Flow APs with Valve Angle = 70° ^{160°} Page F-1

Calc. By J. [Signature] 7/16/84 Checked By _____

12" Valves @ 70°

$P_1 = 15.7 \text{ psia}$

$Q = 1300 \text{ SCFM} = 78000 \text{ SCFH}$

$G = 1 \quad Z = 1 \quad T = 150^\circ\text{F}$

$C_v @ 70^\circ = 3113 \quad X_T @ 70^\circ = .42 \quad F_k = 1$

VALUE SIZE = 12 IN. CLASS = 150

Q = 78000	Cv = 3113	P1 = 15.7	Fp = 1
Fk = 1	Xt = .42	G = 1	F = 150
			Z = 1

~~DELTA P = 0.0132 PSI~~

@ 90°

$C_v @ 90^\circ = 4942 \quad X_T @ 90^\circ = .33$

VALUE SIZE = 12 IN. CLASS = 150

Q = 78000	Cv = 4942	P1 = 15.7	Fp = 1
Fk = 1	Xt = .33	G = 1	F = 150
			Z = 1

~~DELTA P = 0.0052 PSI~~

@ 60°

$C_v @ 60^\circ = 2224 \quad X_T @ 60^\circ = .46$

VALUE SIZE = 12 IN. CLASS = 150

Q = 78000	Cv = 2224	P1 = 15.7	Fp = 1
Fk = 1	Xt = .46	G = 1	F = 150
			Z = 1

~~DELTA P = 0.0259 PSI~~



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title _____ Page F-2
Calc. By [Signature] 7/16/84 Checked By _____

14" Valves @ 70°

P₁ = 15.7 psia

Q = 2200 SCFM = 132000 SCFH

G = 1 Z = 1 T = 150 °F

C_v @ 70° = 3979 X_T @ 70 = .42 F_k = 1

VALUE SIZE = 14 IN. CLASS = 150

Q = 132000	C _v = 3979	P ₁ = 15.7	F _p = 1
F _k = 1	X _t = .42	G = .1	'F = 150 Z = 1

DELTA P = 0.0232 PSI

@ 90°

C_v @ 90° = 6317 X_T @ 90° = .33

VALUE SIZE = 14 IN. CLASS = 150

Q = 132000	C _v = 6317	P ₁ = 15.7	F _p = 1
F _k = 1	X _t = .33	G = 1	'F = 150 Z = 1

DELTA P = 0.0091 PSI

@ 60°

C_v @ 60° = 2842 X_T @ 60° = .46

VALUE SIZE = 14 IN. CLASS = 150

Q = 132000	C _v = 2842	P ₁ = 15.7	F _p = 1
F _k = 1	X _t = .46	G = 1	'F = 150 Z = 1

DELTA P = 0.0455 PSI






ACTUATOR INFORMATION
 5800-M3HV WITH CORE 14V-80 KEYWAY
 VALVE SOL VALVE NPKC03M3A,120VAC


CHES NAMCO EA-760 20100 (110P/N POS (11) CLOSE POS.
 100 EL-010-E3333 LEVER
 ACTUATOR-WATTS 211-056, SET AT 80 PSIG
 3/4" TRIDE-1E DIA. HANDWHEEL
 5 SEC TO OPEN 5 SEC TO CLOSE
 CERTIFY THAT SOL VALVE LIMIT SWITCHES MEET IEEE
 1171 REQUIREMENTS
 ELEMENTS OF IOCRZ11 IOCRFSO APPENDIX B APPLY TO CLASS I.E EQUIP
 G. N° 59333

GEN NOTES (CONT'D)
 10. MAKE EXSC FROM 212-301-CA REV'D NOTE D10115
 17. MAKE BODY FROM 112-301-CA REV'A NOTE D10115
 20. MAKE MOUNTING BRKT FROM 1000-NT BL REV'

POST-SEAL
 1" CLASS 150
 VALVE DESCRIPTION N°
 NVC03-R-12Q
 VALVE RATING 175 PSI
 12-1 SERIAL N° 1951-9
 DESIGN PRESS. 150 PSIG
 DESIGN TEMP. 185°F
 YEAR OF MFR. 1953
 VALVE TAG N° 12PS140V
 NATIONAL BOARD N°
 CUST IDENT TAG LAYOUT



11 SERIAL N° 57-4
 12 VALVE TAG N° 12PS140V
 13 QUANTOR TAG LAYOUT



SHALL TEST PER 1957-71 REV. A
 CLEAN PER 1957-71 REV. A
 SEAT TEST PER 1957-71 REV. A
 PART PER 212-1-231 REV. A

- GENERAL NOTES
1. ALL FINISHING OF BODY AND BRKT SHALL BE DONE IN ACCORDANCE WITH POST SEAL DRAWING NO 7500-000 REV. A.
 2. SPECIFIC PERFORMANCE REQUIREMENTS
 3. NUCLEAR PLATE PER POST SEAL PROCEDURE 51-100 REV. A
 4. MEASUREMENTS PER POST SEAL PROCEDURE 10 OF 97 REV. A
 5. PURCHASED CODE MATERIALS ACCEPTED WILL TEST PER POST SEAL IN ACCORDANCE WITH ASME B & PV CODE, SECTION IX PARAGRAPH 5300.4.19.11 FOR MATERIAL INCLUDING THE 212-1-231 ADDENDUM
 6. ACTUAL NUMBER OF TESTS SHALL BE AS SHOWN IN DRAWING AND IN ACCORDANCE WITH POST SEAL STANDARD INSTRUCTION NO. 3-117
 7. A CERTIFICATE OF COMPLIANCE TO THE MATERIAL SPECIFICATION IS REQUIRED
 8. RADIOGRAPHIC TEST PER ASME B & PV CODE SECTION IX PARAGRAPH 5300.3.12
 9. 100% PERMEABILITY TEST PER ASME B & PV CODE SECTION IX PARAGRAPH 5300.3.12.1
 10. 100% PERMEABILITY TEST PER ASME B & PV CODE SECTION IX PARAGRAPH 5300.3.12.2
 11. VALVE ASSEMBLY TO BE DESIGN AND CONSTRUCTION IN ACCORDANCE WITH ASME B & PV CODE SECTION IX SUBSECTION 5300.3.12.1 INCLUDING THE 212-1-231 ADDENDUM, SECTION 2

- CUSTOMER INFORMATION
 CUSTOMER NIAGARA MOHAWK POWER CORPORATION
 CUSTOMER ORDER NO. NMP2-P504D/12177
- 14 TOTAL ASSEMBLY WEIGHT: 401 LBS ACT/BRKT WT: 246 LBS VALVE WT: 155 LBS
 VALVE CV 4942 (90° OPEN)
- 15 CENTER OF GRAVITY: Ø TOTAL ASSEMBLY Ø ACTUATOR
- 16 TAG EACH VALVE USING BACK SIDE OF STANDARD TAG NO 7500-000 WITH THE FOLLOWING NOS. 12PS140V101
 (NOTE: ALL TAGS TO BE ATTACHED TO VALVE WITH Ø DRIVE SCAS # 2201-001 12PS140V101)
13. AUSTENITIC STAINLESS STEEL CASTINGS TO CONTAIN 5% MIN FERRITE AS DETERMINED BY ANALYSIS
 14. REMOVE PACKING AFTER ALL TESTING IS COMPLETED AND REPLACE PACKING GLAND FOLLOWER AND HAND TIGHTEN NUTS SECOND SET OF PACKING TO BE ATTACHED TO VALVE IN PLASTIC BAG
 15. TORQUE NUTS TO 45.10 IN LBS (WHEN 2ND SET OF PACKING IS INSTALLED BY CUSTOMER)
 16. FINISHED TEFTEL SEALS SHALL BE BOILED IN DEMINERALIZED WATER FOR A MINIMUM OF 24 HOURS PRIOR TO ASSEMBLY.

LINE MILE POINT 11K STATION UNIT 2
 NIAGARA MOHAWK POWER CORPORATION
 P.O. N° 12177, P.O. N° NMP2-P504D

QTY	DESCRIPTION	UNIT	REV	DATE	BY	CHKD	DATE
1	3010-001	A	1	11-1-53			
1	3010-002	A	1	11-1-53			
1	3010-003	A	1	11-1-53			
1	3010-004	A	1	11-1-53			
1	3010-005	A	1	11-1-53			
1	3010-006	A	1	11-1-53			
1	3010-007	A	1	11-1-53			
1	3010-008	A	1	11-1-53			
1	3010-009	A	1	11-1-53			
1	3010-010	A	1	11-1-53			
1	3010-011	A	1	11-1-53			
1	3010-012	A	1	11-1-53			
1	3010-013	A	1	11-1-53			
1	3010-014	A	1	11-1-53			
1	3010-015	A	1	11-1-53			
1	3010-016	A	1	11-1-53			
1	3010-017	A	1	11-1-53			
1	3010-018	A	1	11-1-53			
1	3010-019	A	1	11-1-53			
1	3010-020	A	1	11-1-53			
1	3010-021	A	1	11-1-53			
1	3010-022	A	1	11-1-53			
1	3010-023	A	1	11-1-53			
1	3010-024	A	1	11-1-53			
1	3010-025	A	1	11-1-53			
1	3010-026	A	1	11-1-53			
1	3010-027	A	1	11-1-53			
1	3010-028	A	1	11-1-53			
1	3010-029	A	1	11-1-53			
1	3010-030	A	1	11-1-53			
1	3010-031	A	1	11-1-53			
1	3010-032	A	1	11-1-53			
1	3010-033	A	1	11-1-53			
1	3010-034	A	1	11-1-53			
1	3010-035	A	1	11-1-53			
1	3010-036	A	1	11-1-53			
1	3010-037	A	1	11-1-53			
1	3010-038	A	1	11-1-53			
1	3010-039	A	1	11-1-53			
1	3010-040	A	1	11-1-53			
1	3010-041	A	1	11-1-53			
1	3010-042	A	1	11-1-53			
1	3010-043	A	1	11-1-53			
1	3010-044	A	1	11-1-53			
1	3010-045	A	1	11-1-53			
1	3010-046	A	1	11-1-53			
1	3010-047	A	1	11-1-53			
1	3010-048	A	1	11-1-53			
1	3010-049	A	1	11-1-53			
1	3010-050	A	1	11-1-53			


LIST OF MATERIALS FOR ONE ASSY.

DESIGNED BY: 11/53
 DATE: 11-53
 CHECKED BY: GJ
 DATE: 11-53

POST SEAL INTERNATIONAL INC
 NORTH STONINGTON, CT. 06359

1" CLASS 150 SINGLE FLG. VV ASSY I
 BETTIS NTRIC 5800-M3HV
 VALVE TAG N° 12PS140V

REVISIONS: 11/53



VALVE SHOWN IN SHUT POSITION
 112-301-CA REV'D NOTE D10115







JUNE 82

I. INTRODUCTION

This technical bulletin is intended to assist in the selection of Posi-Seal trunnion valves to control a given set of flow conditions.

II. FLOW COEFFICIENT - C_v

The flow coefficient or C_v of a valve is used to describe its inherent flow capacity. This value is defined as the number of U.S. gallons of water per minute at standard conditions (60° F and 14.7PSIA) that will flow thru a valve at a constant 1.0PSI pressure drop. Accordingly, a C_v value based on extensive flow testing of valves at these conditions has been assigned to each Posi-Seal trunnion valve. Using this C_v value, the capacity of each valve with regard to other fluids under various conditions can be related to this basic C_v value.

III. VALVE SIZING AND SELECTION

Proper valve sizing and selection of Posi-Seal trunnion valves are to be based on the following criteria.

1. Throttling control valves should be sized between the 15° and 80° disc open position.

2. To prevent actuator/valve instability resulting from a hydrodynamic torque reversal when flowing liquids for throttling service, valves should be installed with the retaining ring side of the valve downstream. Complete information on this torque reversal phenomenon can be found in Posi-Seal Technical Bulletin No. 1A.
3. The maximum recommended operating differential pressures and pipeline velocities noted in Posi-Seal Technical Bulletin No. 6 are to be used in valve selection.
4. Valve materials of construction are governed by media and operating conditions.
5. Liquid, gas and steam gas flow limitations are governed by the parameters noted in this technical bulletin.



IV. SIZING FOR LIQUID FLOW

A. Line size valves with a fluid viscosity (μ) less than 90 centipoise.

$$C_v = \frac{\text{GPM}}{\sqrt{\frac{\Delta P}{G_F}}}$$

C_v = Valve Coefficient
See Tables 7-10

GPM = Flow, U.S. Gallons Per Minute

$$\text{GPM} = C_v \sqrt{\frac{\Delta P}{G_F}}$$

G_F = Specific Gravity of Liquid at Flowing Conditions

$$\Delta P = \left(\frac{\text{GPM}}{C_v} \right)^2 G_F$$

= $\frac{\text{Density of Liquid at Flowing Conditions}}{\text{Density of Water at Standard Conditions}}$

ΔP = Differential Pressure Across Valve, PSI

B. Valves installed between reducers with a fluid viscosity (μ) greater or less than 90 centipoise.

$$C_v = \frac{\text{GPM}}{F_P F_Y F_R \sqrt{\frac{\Delta P}{G_F}}}$$

F_P = Piping Geometry Factor (for valves installed in line size pipe $F_P = 1.0$) See Figure 2

$$\text{GPM} = F_P F_Y F_R C_v \sqrt{\frac{\Delta P}{G_F}}$$


F_R = Reynolds Number Factor, when viscosity (μ) is less than 90 centipoise $F_R = 1.0$, See Figure 3

$$\Delta P = \left(\frac{\text{GPM}}{F_P F_Y F_R C_v} \right)^2 G_F$$

F_Y = Liquid Choke Flow Factor, See Fig. 1



FIGURE 1



PIPING EFFECTS

For valves that are installed in piping where the connecting pipe diameter is greater or less than the nominal valve diameter, the factor F_p is utilized in the sizing equations to account for additional friction losses due to piping reducers or expanders directly adjacent to the valve.

$$F_p = \sqrt{\frac{C_{vp}^2}{C_v^2 - C_{vp}^2}}$$

$$C_{vp} = \frac{29.8D^2}{\sqrt{\left(1 - \frac{D^2}{D_2^2}\right)^2 + 0.5\left(1 - \frac{D^2}{D_1^2}\right)}}$$

WHERE:

C_{vp} = flow coefficient of pipe enlargement and contraction combined.

C_v = valve flow coefficient

D = ID of pipe equal valve size, inches

D_1 = ID of upstream pipe, inches

D_2 = ID of downstream pipe, inches

FOR INSTALLATIONS WHERE D_1 EQUALS D_2 :


WHERE:

$$C_{vp} = KD^2$$

D = ID of pipe equal to valve size, inches

K = Refer to Fig. 2

FIGURE 2





CAVITATION

When flowing liquids, cavitation can occur at certain differential pressures across the valve. Generally, cavitation may not damage the valve but can cause damage to downstream piping in addition to creating objectionable vibration and noise. When the differential pressure across the valve is greater than calculated by the following formula, cavitation will occur:

LINE SIZE VALVES

$$\Delta P_T = .8 F_L^2 (P_1 - F_F P_V)$$

VALVES INSTALLED BETWEEN REDUCERS

$$\Delta P_T = .8 \left(\frac{F_L P}{F_P} \right)^2 (P_1 - F_F P_V)$$

WHERE:

ΔP_T = Terminal Pressure Drop (PSI) maximum allowable for sizing purposes, above which cavitation will occur.

F_F = Liquid critical pressure ratio, Fig. 5

F_L = Liquid pressure recovery factor, Fig. 4

P_1 = Upstream pressure, PSIA.

P_V = Vapor pressure, PSIA.

An increase in the differential pressure across the valve will increase the amount of cavitation and begin to choke the flow. At the differential pressure approximated by the following formula, the flow will be choked.


$$\Delta P \text{ choked} = F_L^2 (P_1 - F_F P_V)$$

$$\text{GPM CHOKED} = C_v \sqrt{\frac{F_L^2 (P_1 - F_F P_V)}{G_F}}$$

WHERE:

$\Delta P \text{ choked}$ = maximum differential pressure above which no further increase in flow will occur.

FIGURE 3



$$Re = 123.9 \frac{dvp}{\mu}$$

WHERE:

d = Internal pipe dia., inches.

v = Mean velocity of flow, FPS.

ρ = Weight density of fluid, pounds per cubic foot.

μ = Absolute (Dynamic) viscosity centipoise.



8

FIGURE 4





FIGURE 5





VALVE SIZING FOR GAS FLOW

CRITICAL FLOW

$$Q = 1360 F_p C_v P_1 Y \sqrt{\frac{X}{G T_1 Z}}$$

OR

$$C_v = \frac{Q}{1360 F_p P_1 Y \sqrt{\frac{X}{G T_1 Z}}}$$

$$Q = Q_f \left(\frac{P_1}{14.7} \right) \left(\frac{520}{T_1} \right)$$

STEAM FLOW

$$W = 63.3 F_p C_v Y \sqrt{\frac{X P_1}{V_1}}$$

OR

$$C_v = \frac{W}{63.3 F_p Y \sqrt{\frac{X P_1}{V_1}}}$$

$$.0764 G$$

WHERE

- Q = Flow in SCFH
- Q_f = Flow at flow conditions CFH
- F_p = Piping geometry factor (See Pg 3 of 16)
- C_v = Valve coefficient (Tables 7-10)
- P₁ = Upstream pressure in PSIA
- T₁ = Upstream temperature in °R = 460 + °F
- Z = Compressibility factor (See Table 3 or Fig. 10 & 11—most application, Z may assumed to be 1.0)
- G = Specific Gravity = $\frac{\text{Density of Gas at Standard Conditions}}{\text{Density of Air at Standard Conditions}}$ (See Table 1)
- X = Pressure drop ratio = ΔP/P₁
- ΔP = Differential pressure across valve in PSI
- Y = Expansion factor = $Y = 1 - \frac{X}{3 F_K X_T}$

WHERE:

- X_T = Rated pressure drop ratio factor (See Fig. 6)
- F_K = Ratio of specific heats factor (see table 2) = K/1.4 = Where K = ratio of specific heats.

WHERE.

- W = Flow in Lbs/hr
- V₁ = Specific volume of steam upstream in Ft³/Lb (See Tables 5 & 6)

Note: For values of K for steam (See Fig. 9)



CRITICAL FLOW

$$Q_{MAX} = 907.12 F_P C_V P_1 \sqrt{\frac{F_K X_T}{G T_1 Z}}$$

Q_{MAX} = Max Flow that can pass through valve at the stated conditions.

$C_V MIN$ = Minimum Required C_V in order to pass flow at the stated conditions


ΔP_c = Max usable differential pressure drop above which no increase in flow will occur.

F_L = Rated Liquid Pressure Recovery Factor (See Figure 4)

$$C_V MIN = \frac{Q}{907.12 F_P P_1 \sqrt{\frac{F_K X_T}{G T_1 Z}}}$$

$$\Delta P_c = F_K X_T P_1$$

FIGURE 6
 X_T VS. % FLOW





VI. TECHNICAL DATA

FIGURE 7

Viscosity of Water and Liquid Petroleum Products





FIGURE 8

Viscosity of Various Liquids



- 1 Ethane (C₂H₆)
- 2 Propane (C₃H₈)
- 3 Butane (C₄H₁₀)
- 4 Natural Gasoline
- 5 Gasoline
- 6 Water
- 7 Kerosene
- 8 Distillate
- 9 48 Deg API Crude
- 10 40 Deg API Crude
- 11 35.6 Deg API Crude
- 12 32.6 Deg API Crude
- 13 Salt Creek Crude
- 14 Fuel 3 (Max.)
- 15 Fuel 5 (Min)
- 16 SAE 10 Lube (100 V.I)
- 17 SAE 30 Lube (100 V.I)
- 18 Fuel 5 (Max) or Fuel 6 (Min)
- 19 SAE 70 Lube (100 V.I)
- 20 Bunker C Fuel (Max) and M.C. Residuum
- 21 Asphalt

- 1 Carbon DioxideCO₂
- 2 AmmoniaNH₃
- 3 Methyl ChlorideCH₃Cl
- 4 Sulphur DioxideSO₂
- 5 Freon 12F-12
- 6 Freon 114F-114
- 7 Freon 11F-11
- 8 Freon 113F-113
- 9 Ethyl Alcohol
- 10 Isopropyl Alcohol
- 11 20% Sulphuric Acid20% H₂SO₄
- 12 Dowtherm E
- 13 Dowtherm A
- 14 20% Sodium Hydroxide 20% NaOH
- 15 Mercury
- 16 10% Sodium Chloride Brine10% NaCl
- 17 20% Sodium Chloride Brine 20% NaCl
- 18 10% Calcium Chloride Brine10% CaCl₂
- 19 20% Calcium Chloride Brine20% CaCl₂

Example: The viscosity of ammonia at 40°F is 0.14 centipoise

Example: The viscosity of water at 125°F is 0.52 centipoise (Curve No. 6).



TABLE 1

NAME	FORMULA OF SOLUTION	MOLECULAR WEIGHT	MELTING POINT °F.	VAPOR PRESSURE PSIA	SATURATE TEMPERATURE °F.	SATURATE PRESSURE PSIA	SPECIFIC GRAVITY	
							AT 494.8°F.	AT 356.4°F.
Acetic Acid	$HC_2H_3O_2$	60.05	16		61.2	811	1.05	
Acetic Anhydride	$(C_2H_3O_2)_2$	102.09	255			876		1.28
Acetone	C_3H_6O	58.08	175		155	691	0.79	2.01
Acetylene	C_2H_2		-119		97	911	0.62	0.91
Air	N_2O_2	28.97	-317		-221	517	0.56	1.0
Alcohol, Ethyl	C_2H_5OH	46.07	172	2.57	179	125	0.791	1.17
Alcohol, Methyl	CH_3OH	32.04	148	2.05 ¹	165	1174	0.796	1.11
Ammonia	NH_3	17.03	-28	11.4	270	1656	0.62	0.59
Aniline	$C_6H_5NH_2$	93.12	365		798	770	1.02	
Argon	Ar	39.94	-302		-188	731	1.38	1.38
Benzene	C_6H_6	78.11	176	3.22 ²	552	719	0.88	2.69
Bromine	Br_2	159.84	188		575	1483	2.75	5.52
Butadiene	$CH_2=CH=CH=CH_2$	54.09	24			627		0.63
n-Butane	C_4H_{10}	58.12	51	51.6 ¹	395	350	0.58	2.0
butyl Alcohol	C_4H_9OH	74.12	212			711		1.81
Carbon Dioxide	CO_2	44.01	-7	5.1	88	1072	1.5	1.5
Carbon Monoxide	CO	28.01	-213		-229	507	0.80	0.97
Carbon tetrachloride	CCl_4	153.84	27		312	961	1.59	5.51
Chlorine	Cl_2	70.91	-35	8.5	291	1118	1.32	2.15
Chloroform	$CHCl_3$	119.38	6			711	1.48	
Cyclohexane	C_6H_{12}	98.15	6		90	585	1.12	
Ethane	C_2H_6	30.07	-127		90	709	0.58	1.01
Ethyl Chloride	C_2H_5Cl	64.52	35			2750	0.9	2.22
Ethylene	C_2H_4	28.05	-169		48	712		1.0
Ethyl Ether	$C_2H_5OC_2H_5$	74.12	-112		55.5	522		0.71
Fluorine	F_2	38.0	-188		-188	892	1.71	1.71
Helium	He	4.003	-452		-452	55	0.18	1.13
hydrochloric Acid	HCl	36.47	-115				1.01	
Hydrogen	H_2	2.016	-422		-400	188	0.07	0.07
Hydrogen Chloride	HCl	36.47	-115		125	1198	0.86	1.26
Hydrogen Sulfide	H_2S	34.08	-70	25.2	213	1508	0.75	1.17
Isobutane	C_4H_{10}	58.12	11	72.2	274	529	0.56	2.31
Isopropyl Alcohol	C_3H_7OH	60.09	180		155	779	0.78	2.08
Methane	CH_4	16.04	-258		-116	675	0.52	0.55
Methyl Chloride	CH_3Cl	50.49	-15	5.1	290	267	0.91	1.74
Naphthalene	$C_{10}H_8$	128.16	123				1.14	1.45
Nitric Acid	HNO_3	63.02	187				1.5	
Nitrogen	N_2	28.02	-320		-255	492	0.81	0.97
n-Octane	C_8H_{18}	114.23	258	0.34 ¹	364	362	0.71	3.94
Oxygen	O_2	32.00	-297		-181	730	1.14	1.105
n-Pentane	C_5H_{12}	72.15	26	15	386	485	0.63	2.49
Phenol	C_6H_5OH	94.11	358		786	889	1.07	
Phosphoric Acid	H_3PO_4	98.00	415				1.83	
Propane	C_3H_8	44.10	-45	190 ¹	206	617	0.51	1.52
Propylene	$CH_2=CH=CH_2$	42.08	-54		198	661		0.61
Propyl Alcohol	$CH_3CH_2CH_2OH$	60.09	208			735		0.80
Propyl Chloride	$CH_3CH_2CH_2Cl$	78.54	115			664		0.89
Refrigerant 11	$C_2Cl_2F_2$	157.38	75		388	635		5.04
Refrigerant 12	C_2ClF_3	120.93	-22	70.2	234	597		4.2
Refrigerant 21	$CHCl_2F$	102.93	48	8.4	353	750		5.92
Refrigerant 22	$CHClF_2$	86.48	-41	122.5	205	713		
Styrene	C_8H_8	104.15	295	0.24 ¹	706	580	0.91	3.59
Sulfur Dioxide	SO_2	64.06	14	54.4	316	1142	1.39	2.21
Toluene	C_7H_8	92.14	231	1.03 ¹	605	611	0.87	3.18
Water	H_2O	18.016	212	0.95	706	3206.2	1.00	0.62

1. Vapor Pressure in PSIA @ 100°F
 2. Specific Gravity @ 494.8°F.
 3. Specific Gravity @ 356.4°F.



FIGURE 9
 STEAM — VALUES OF K
 Ratio of Specific Heat at Constant Pressure
 to Specific Heat at Constant Volume
 $K = C_p / C_v$




TABLE 2
 VALUES OF K FOR VARIOUS GASES

Name of Gas	Chemical Formula or Symbol	K, equal to C_p / C_v
Acetylene	C_2H_2	1.23
Air	—	1.40
Ammonia	NH_3	1.29
Argon	A	1.67
Carbon Dioxide	CO_2	1.28
Carbon Monoxide	CO	1.41
Ethane	C_2H_6	1.168
Ethylene	C_2H_4	1.22
Freon [®]	CCl_2F_2	1.136
Helium	He	1.66
Hydrochloric Acid	HCl	1.40
Hydrogen	H_2	1.40
Methane	CH_4	1.26
Methyl Chloride	CH_3Cl	1.20
Neon	Ne	1.667
Nitrogen	N_2	1.40
Nitric Oxide	NO	1.40
Nitrous Oxide	N_2O	1.26
Octane	C_8H_{18}	1.046
Oxygen	O_2	1.40
Propane	C_3H_8	1.128
Sulphur Dioxide	SO_2	1.25
Water Vapor	H_2O	1.329



TABLE 3
COMPRESSIBILITY FACTORS FOR GAS

Gas	Pressure		-100 F	0 F	200 F	1000 F	2000 F
	atm	psia					
Argon	1	14.7	0.997	0.999	1.000	1.000	1.000
	10	147	0.970	0.987	0.999	1.003	1.002
	40	588	0.877	0.952	0.995	1.011	1.009
	100	1470	0.690	0.887	0.995	1.029	1.022
Carbon monoxide	1	14.7	0.997	0.999	1.000	1.000	1.000
	10	147	0.973	0.991	1.001	1.004	1.003
	40	588		0.967	1.007	1.017	1.012
	100	1470			1.027	1.044	1.031
Carbon dioxide	1	14.7		0.991	0.997	1.000	1.000
	10	147		0.910	0.974	1.001	1.003
	40	588			0.894	1.006	1.010
	100	1470			0.721	1.018	1.026
Hydrogen	1	14.7	1.001	1.001	1.001		
	10	147	1.007	1.006	1.005		
	40	588	1.028	1.026	1.021		
	100	1470	1.076	1.067	1.052		





FIGURE 10
COMPRESSIBILITY FACTORS
FOR SUPERHEATED STEAM

FIGURE 11
COMPRESSIBILITY FACTORS
FOR NITROGEN





PROPERTIES OF WATER AT VARIOUS TEMPERATURES

(Referred to Water at 68 F Weighing 62.318 Lb Cu Ft)

TABLE 4

Temp °F	Specific Volume cu ft/lb	Specific Gravity	Vapor Pressure PSIA	Temp °F	Specific Volume cu ft/lb	Specific Gravity	Vapor Pressure PSIA
32	0.01602	1.0016	0.0835	210	0.01670	0.9609	14.123
33	0.01603	1.0017	0.0922	220	0.01677	0.9569	17.186
34	0.01602	1.0017	0.0960	230	0.01684	0.9529	20.780
35	0.01602	1.0017	0.1000	240	0.01692	0.9484	24.969
36	0.01602	1.0017	0.1040	250	0.01700	0.9439	29.825
37	0.01602	1.0018	0.1082	260	0.01709	0.9392	35.429
38	0.01602	1.0018	0.1126	270	0.01717	0.9346	41.853
39	0.01602	1.0018	0.1171	280	0.01726	0.9297	49.203
40	0.01602	1.0018	0.1217	290	0.01735	0.9249	57.556
41	0.01602	1.0018	0.1265	300	0.01745	0.9196	67.013
42	0.01602	1.0018	0.1315	310	0.01755	0.9143	77.68
43	0.01602	1.0017	0.1367	320	0.01765	0.9092	89.60
44	0.01602	1.0017	0.1420	330	0.01776	0.9036	103.04
45	0.01602	1.0017	0.1475	340	0.01787	0.8976	118.01
46	0.01602	1.0017	0.1532	350	0.01799	0.8920	134.63
47	0.01603	1.0016	0.1591	360	0.01811	0.8861	153.04
48	0.01603	1.0016	0.1653	370	0.01823	0.8802	173.37
49	0.01603	1.0016	0.1716	380	0.01836	0.8741	195.77
50	0.01603	1.0015	0.1781	390	0.01850	0.8673	220.37
51	0.01603	1.0014	0.1849	400	0.01864	0.8609	247.31
52	0.01603	1.0014	0.1918	410	0.01878	0.8545	276.75
53	0.01603	1.0013	0.1990	420	0.01894	0.8473	308.83
54	0.01603	1.0013	0.2064	430	0.01910	0.8402	343.72
55	0.01603	1.0012	0.2141	440	0.01926	0.8332	381.59
56	0.01603	1.0011	0.2220	450	0.0194	0.826	422.6
57	0.01603	1.0010	0.2302	460	0.0196	0.818	466.9
58	0.01604	1.0010	0.2386	470	0.0195	0.810	514.7
59	0.01604	1.0009	0.2473	480	0.0200	0.802	566.1
60	0.01604	1.0008	0.2563	490	0.0202	0.794	621.4
62	0.01604	1.0006	0.2751	500	0.0204	0.786	680.3
64	0.01605	1.0004	0.2951	510	0.0207	0.775	744.3
66	0.01605	1.0002	0.3164	520	0.0209	0.767	812.4
68	0.01605	1.0000	0.3390	530	0.0212	0.757	885.0
70	0.01606	0.9998	0.3631	540	0.0215	0.746	962.5
75	0.01607	0.9991	0.4298	550	0.0218	0.737	1045.2
80	0.01608	0.9984	0.5069	560	0.0221	0.725	1133.1
85	0.01609	0.9975	0.5959	570	0.0224	0.716	1226.5
90	0.01610	0.9968	0.6982	580	0.0228	0.704	1325.8
95	0.01612	0.9958	0.8153	590	0.0232	0.692	1431.2
100	0.01613	0.9949	0.9492	600	0.0236	0.680	1542.9
110	0.01617	0.9927	1.275	610	0.0241	0.666	1661.2
120	0.01620	0.9903	1.692	620	0.0247	0.650	1786.6
130	0.01625	0.9878	2.223	630	0.0253	0.634	1919.3
140	0.01629	0.9850	2.889	640	0.0260	0.618	2059.7
150	0.01634	0.9821	3.713	650	0.0268	0.599	2203.2
160	0.01639	0.9790	4.741	660	0.0278	0.578	2354.4
170	0.01645	0.9755	5.992	670	0.0290	0.554	2531.8
180	0.01651	0.9720	7.510	680	0.0305	0.526	2703.1
190	0.01657	0.9684	9.337	690	0.0328	0.489	2895.1
200	0.01663	0.9649	11.526	705.4	0.0503	0.319	3205.2

TABLE 5

PROPERTIES OF SATURATED STEAM					
Absolute Pressure PSIA	Temperature °F	Specific Volume Δ Ft ³ /lbs.	Absolute Pressure PSIA	Temperature °F	Specific Volume Δ Ft ³ /lbs.
14.7	212	26.799	120	341	3.7275
20	228	20.087	130	347	3.4544
25	240	16.301	140	353	3.2190
30	250	13.7436	150	358	3.0139
35	259	11.8959	160	363	2.8336
40	267	10.4965	170	368	2.6738
45	274	9.3988	180	373	2.5312
50	281	8.5140	190	377	2.4030
55	287	7.7850	200	382	2.28728
60	293	7.1736	210	386	2.18217
65	298	6.6533	220	390	2.08629
70	303	6.2050	230	394	1.99846
75	308	5.8144	240	397	1.91769
80	312	5.4711	250	401	1.84317
85	316	5.1669	260	404	1.77418
90	320	4.8953	270	408	1.71013
95	324	4.6514	280	411	1.65049
100	328	4.4310	290	414	1.59482
110	335	4.0484	300	417	1.54274



TABLE 6
SUPERHEATED VAPOR

Pressure (psia)	Temperature (°F)																
	200	260	300	360	400	460	500	600	700	800	900	1000	1100	1200			
10	v	38.85	42.56	45.00	48.63	51.04	54.05	57.05	63.04	69.01	74.96	80.95	86.92	92.88	98.84		
	h	1146.6	1175.1	1193.9	1221.9	1240.6	1268.7	1287.5	1335.1	1383.4	1432.5	1482.4	1533.2	1585.0	1637.6		
	v	17927	18341	18595	18950	19172	19488	19689	20160	20596	21002	21383	21744	22086	22413		
20	v		21.11	22.36	24.21	25.43	27.25	28.46	31.47	34.47	37.46	40.45	43.44	46.42	49.41		
	h		1172.2	1191.6	1220.3	1239.2	1267.5	1286.6	1334.4	1382.9	1432.1	1482.1	1533.0	1584.7	1637.4		
	v		17545	17808	18170	18396	18716	18918	19392	19829	20235	20618	20978	21321	21648		
50	v			8.773	9.557	10.065	10.815	11.309	12.532	13.744	14.950	16.152	17.352	18.550	19.747		
	h			1184.3	1215.2	1235.1	1264.5	1283.9	1332.5	1381.4	1430.9	1481.1	1532.1	1584.0	1636.8		
	v			16721	17112	17349	17680	17867	18366	18809	19219	19602	19964	20308	20636		
100	v				4.663	4.937	5.333	5.589	6.218	6.835	7.446	8.052	8.656	9.259	9.860		
	h				1205.7	1227.6	1258.8	1279.1	1329.1	1378.9	1426.9	1479.5	1530.8	1582.9	1635.7		
	v				16258	16518	16869	17085	17581	18029	18443	18829	19193	19538	19867		
150	v				3.023	3.223	3.502	3.781	4.113	4.532	4.944	5.352	5.758	6.162	6.564		
	h				1195.1	1219.4	1252.9	1274.1	1325.7	1376.3	1426.9	1477.8	1529.4	1581.7	1634.7		
	v				15706	15895	16372	16599	17109	17566	17984	18374	18740	19086	19416		
200	v					2.361	2.585	2.725	3.060	3.380	3.693	4.002	4.309	4.613	4.917		
	h					1210.3	1246.5	1268.9	1322.1	1373.6	1424.8	1476.2	1528.0	1580.5	1633.7		
	v					15594	16001	16240	16767	17232	17655	18048	18415	18763	19094		
300	v						1.6638	1.7675	2.005	2.227	2.442	2.652	2.859	3.065	3.269		
	h						1232.5	1257.6	1314.7	1368.3	1420.6	1472.8	1525.2	1578.1	1631.7		
	v						15434	15701	16268	16751	17184	17582	17954	18305	18638		
500	v							0.9927	1.1591	1.3044	1.4405	1.5715	1.6996	1.8256	1.9504		
	h							1231.3	1298.6	1357.0	1412.1	1466.0	1519.6	1573.4	1627.6		
	v							14919	15588	16115	16571	16982	17363	17719	18056		
700	v								0.7934	0.9077	1.0108	1.1082	1.2024		1.3853		
	h								1280.6	1345.0	1403.2	1459.0	1513.9		1623.5		
	v								15084	15665	16147	16573	16963		17666		
1000	v									0.5140	0.6084	0.6878	0.7604	0.8294	0.8962	0.9615	
	h									1248.8	1325.3	1389.2	1448.2	1505.1	1561.3	1617.3	
	v									14450	15141	15670	16121	16525	16897	17245	
2000	v										0.2489	0.3074	0.3532	0.3935	0.4311	0.4668	
	h										1240.0	1335.5	1409.2	1474.5	1536.2	1596.1	
	v										13783	14576	15139	15603	16012	16384	
3000	v											0.0984	0.1760	0.2159	0.2476	0.2757	0.3018
	h											1060.7	1267.2	1365.0	1441.8	1510.0	1574.3
	v											11966	13690	14439	14984	15437	15837



VII. VALVE INHERENT FLOW COEFFICIENTS - C_v

TABLE 7
VALVE FLOW COEFFICIENTS C_v
CLASS 150 STD. RATING

Valve Size	DEGREES OF DISC OPENING								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
2"	2	4	9	15	23	34	43	51	57
3"	6	14	29	50	77	111	143	167	188
4"	12	30	63	107	165	238	307	359	404
6"	32	81	167	285	441	635	818	957	1076
8"	34	113	248	429	677	1015	1421	1827	2256
10"	47	159	349	604	953	1430	2002	2573	3172
12"	74	247	543	939	1482	2224	3113	4003	4942
14"	95	316	695	1200	1895	2842	3979	5117	6317
16"	129	430	946	1635	2581	3872	5420	6969	8604
18"	166	553	1216	2100	3316	4974	6963	8953	11053
20"	208	692	1523	2631	4155	6232	8725	11218	13850
24"	322	1075	2365	4024	6449	9574	13544	17413	21498
30"	508	1693	3725	6434	10160	15240	21335	27431	33866
36"	757	2523	5550	9586	15136	22704	31785	40867	50453
42"	1091	3637	8001	13821	21822	32733	45827	58920	72741
48"	1389	4632	10190	17601	27791	41687	58362	75037	92638
54"	1977	6591	14501	25048	39549	59323	83053	106782	131830
60"	2639	8796	19352	33426	52778	79167	110834	142502	175928
66"	2951	9837	21642	37381	59023	88534	123948	159362	196743
72"	3867	12892	28362	48989	77351	116027	162438	208849	257838

TABLE 8
VALVE FLOW COEFFICIENTS, C_v
CLASS 150/150 PSI RATING

Valve Size	DEGREES OF DISC OPENING								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
24"	351	1171	2575	4448	7024	10535	14749	18964	23412
30"	607	2025	4455	7695	12150	18225	25515	32805	40500
36"	910	3032	6671	11523	18194	27292	38208	49125	60648
42"	1198	3992	8783	15170	23953	35930	50302	64674	79845
48"	1590	5299	11658	20137	31795	47693	66770	85847	105984
54"	1977	6591	14501	25048	39544	59323	83053	106782	131830
60"	2639	8796	19352	33426	52778	79168	110835	142502	175928
66"	2951	9837	21642	37381	59023	88534	123948	159362	196743
72"	3867	12892	28362	48989	77351	116027	162438	208849	257838



TABLE 9
VALVE FLOW COEFFICIENTS C_v
CLASS 300 STD. RATING

Valve Size	DEGREES OF DISC OPENING								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
1 1/2"	1	3	6	10	15	22	29	34	38
2"	2	4	9	15	23	34	43	51	57
3"	6	14	29	50	77	111	143	167	188
4"	12	30	63	107	165	238	307	359	404
6"	32	81	167	285	441	635	818	957	1076
8"	40	100	206	352	545	783	1010	1183	1329
10"	71	178	367	628	971	1398	1800	2108	2369
12"	110	276	570	975	1509	2172	2797	3276	3661
14"	136	341	704	1204	1863	2681	3454	4045	4545
16"	169	422	873	1492	2309	3323	4280	5012	5632
18"	247	617	1276	2181	3374	4856	6255	7325	8230
20"	286	714	1476	2524	3906	5620	7240	8478	9526
24"	375	938	1939	3315	5129	7381	9508	11135	12511
30"	715	1782	3696	6319	9776	14068	18121	21221	23844
36"	1104	2760	5704	9752	15087	21711	27967	32751	36799
42"	1711	4279	8843	15118	23390	33659	43358	50774	57050
48"	1867	4667	9645	16490	25513	36713	47292	55361	62225

Table 10
FLOW COEFFICIENTS C_v
CLASS 600 STD. RATING

Valve Size	DEGREES OF DISC OPENING								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
3"	5	16	31	51	84	122	151	169	182
4"	8	23	43	70	116	169	209	234	252
6"	26	78	147	242	397	579	717	803	864
8"	35	104	197	324	532	775	960	1076	1157
10"	62	185	350	576	947	1379	1709	1915	2059
12"	85	255	481	793	1302	1897	2350	2633	2831
14"	104	312	589	971	1595	2323	2878	3225	3468
16"	128	383	723	1192	1958	2851	3532	3958	4256
18"	152	456	862	1420	2332	3397	4208	4715	5070
20"	175	524	990	1630	2678	3900	4831	5413	5821
24"	349	1046	1977	3256	5349	7791	9651	10814	11628



INHERENT FLOW CHARACTERISTICS
PERCENT OF FULL OPEN C_v VS. DEGREES OF DISC OPENING

CLASS 150 VALVES

FIGURE 12
2" THRU 6"




FIGURE 13
8" AND LARGER




FIGURE 14
CLASS 300 VALVES
ALL SIZES





FIGURE 15
CLASS 600 VALVES
ALL SIZES





HYDRODYNAMIC TORQUE
OF
HIGH PERFORMANCE TRUNNION VALVES

The increased use of High Performance Trunnion (Offset Butterfly) Valves has caused increased use in high flow applications and therefore, a need for a more accurate prediction of the Hydrodynamic Torque behavior of this type of valve. Improper actuator sizing, structural damage and control instability are all possible consequences of using inaccurate Hydrodynamic Torque data.

The Trunnion Valve is essentially a modified butterfly valve with the rotary stem offset from the disc sealing surface. See Figure 1. Normally, this style of valve exhibits high opening and closing torques with operating torques depreciating as the valve disc rotates 90° to the fully open position. However, on occasions where a considerable quantity of fluid is being pumped through the valve, the Hydrodynamic Torque may exceed the opening torque or be of sufficient magnitude that the actuator will be unable to further open the valve.

Realizing the importance of having accurate Hydrodynamic Torque data, Posi-Seal International, Inc. in North Stonington, Conn. launched an extensive R&D program in order to obtain this data. At Posi-Seal's new Hydraulics Laboratory, (See Figure 2 for schematic of lab), Hydrodynamic Torque data was measured on valve sizes 1 1/2" through 14" for valve classes 150 through 600 lb. Additional data was taken on a 14" - 900 and a 14" - 1500 lb. valve. Data was recorded for both preferred and non-preferred fluid flow, measured at every 10 degrees of valve rotation. In order to obtain the Hydrodynamic Torque factors, the valve torque was measured while both opening and closing the valve. By averaging the above data, stem packing and bearing friction torques were negated and pure Hydrodynamic Torque was obtained. The above measured torque when divided by the differential pressure across the valve yielded the Hydrodynamic Torque factor for that particular valve at that angular location. This data was statistically analyzed on Posi-Seal's



technical mini computer and equations were developed from which Hydrodynamic Torque factors were calculated for all sizes and classes of high performance Trunnion Valves.

Based upon the flow testing performed at Posi-Seal, the following general observations concerning Hydrodynamic Torque of Trunnion Valves can be made:

- (1) For preferred flow, the Hydrodynamic Torque will always want to close the valve. See Figure 3.
- (2) For non-preferred flow, the Hydrodynamic Torque will, through 70° to 80° of valve rotation (the exact location varies with valve class), want to close the valve. Beyond this point, the Hydrodynamic Torque will want to open the valve. See Figure 4.
- (3) Except for the 90° valve location where the Hydrodynamic Torque factors are of equal magnitude for both preferred and non-preferred flow but of opposite sign, the non-preferred Hydrodynamic Torque factors are considerably less in magnitude than those for preferred flow. See Figures 3 and 4.
- (4) All of the Hydrodynamic Torque factors (for both preferred and non-preferred flow) decrease with increase in valve class, ex: Hydrodynamic Torque factors for a 600 lb. valve are significantly less than those for a 150 lb. valve. See Figures 3 and 4.
- (5) The Hydrodynamic Torque factors increase approximately proportional to the cube of the valve size. (The exact amount varies depending upon valve class).

The total Trunnion Valve Torque at some angular position (other than opening or closing) is in actuality a summation of three separate torques, stem packing torque, bearing friction torque and the Hydrodynamic Torque discussed above. Except for small size valves (6" and less), the stem packing torque is a small percentage of the total valve torque. For large sized valves, above approximately 45°, the Hydrodynamic Torque is the major component of the total valve torque, below 45° bearing friction torque becomes the major contributor. All three components must be considered in order to accurately evaluate a valve's performance.

In order to better understand the reason for Hydrodynamic Torque occurring, one must visualize the valve's disc as an airfoil. The Hydrodynamic Torque generated at some angle is a composite of fluid flow lift and drag forces acting over the disc's surface. The general formulas for lift and drag being:



$$F_D = C_D P \frac{AV^2}{2} \quad (\text{Drag})$$

$$\text{and } F_L = C_L P \frac{AV^2}{2} \quad (\text{Lift})$$

Where:

C_D, C_L - Drag and lift coefficients which are related to the geometry of flow obstruction. (Disc)

P - density of the fluid medium

A - projected or surface area of flow obstruction (Disc)

V - velocity of fluid medium

Both the lift and drag forces are dependent upon the shape of the valve disc, its orientation to the flow stream and the direction of fluid flow. As the valve angle is decreased, or flow is reversed, both the magnitude and location of these forces shift causing a change in the resultant Torque. As the valve angle is further decreased the drag forces will increase while the lift forces will deteriorate due to increased turbulence and a breakdown of the flow stream along the downstream side of the valve disc. See Figures 5 and 6.



FIGURE No. 1
SCHEMATIC
OF
HIGH PERFORMANCE TRUNION VALVE








FIGURE NO. 2
SCHEMATIC OF POST-SEAL
RESEARCH & DEVELOPMENT
LABORATORY





HYDRODYNAMIC TORQUE
VS
VALVE ANGLE




REFERRED
DIRECTION



HYDRODYNAMIC TORQUE
VS
VALVE ANGLE

PERCENT OF HYDRODYNAMIC TORQUE AT 90°



NON PREFERRED DIRECTION







FIGURE 5








FIGURE 6



SHAPE FACTOR VS. POWER FACTOR



T = HYDRODYNAMIC TORQUE
 D = DISC. GAGE DIA. (IN.)
 K1 = SHAPE FACTOR

$$= \frac{E1 + E2}{D}$$


K2 = POWER FACTOR

$$= B_0 + B_1 K1$$

B₀, B₁ = COEFFICIENTS DETERMINED BY LINEAR REGRESSION ANALYSIS OF EMPIRICAL DATA

OR:

$$= K2 \frac{\ln[TLK1]}{\ln D}$$



B₀ = +4.6028 PER LEAST SQUARE REGRESSION ANALYSIS
 B₁ = -5.9150

$$K2 = 4.6028 - 5.915 K1$$

FIGURE 7



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Page

HYDRODYNAMIC TORQUE DETERMINATION

Calc. By

Jensen

DATE: 12/12/77

Checked By

VALVE SIZE: 3" ISO

VALVE DIRECTION: STEM-UPSTREAM / ~~STEM-DOWNSTREAM~~

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 68 °F

DISC-TYPE & DWG:

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	($\frac{Q}{P}$) / PS
0					
10		42		+45	1.1
20		41		+55	1.3
30		39		+60	1.5
40		36		+75	2.1
50		33		+85	2.6
60		31.5		+100	3.2
70		27	27	+140	5.2
80		22		+155	7.0
90		19		+140	7.4
90		19		+120	6.7
80		22		+140	6.7
70		25	27	+145 110	4.5
60		34		+100	2.9
50		42.5		+80	1.9
40		40.5		+60	1.5
30		42		+30	0.7
20		45		+10	0.2
10		46		0	0
0					

OPENING

CLOSING

PACKING TORQUE: 10 IN-LB OPENING

5 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
 ENGINEERING CALCULATIONS

NON-PREFERRED DIRECTION


Page

By

Checked By

HYDRODYNAMIC TORQUE
 VS.
 VALVE ANGLE

% OF HYDRODYNAMIC TORQUE OF 150 LB CLASS
 VALVES AT 90° POSITION



— MEANS TORQUE IS
 OPENING DISC
 + MEANS TORQUE IS
 CLOSING DISC

VALVE ANGLE

ESTIMATED 1500 LB CLASS

ESTIMATED 900 LB CLASS

150 LB CLASS

600 LB CLASS

500 LB CLASS




NON PREFERRED DIRECTION

Page

By

Checked By

HYDRODYNAMIC TORQUE
VS.
VALVE ANGLE





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

BY NON-PREFERRED DIRECTION

Checked By ØANSEN

8/15/78

ANGLE	VALVE SIZE = % TORQUE @ 90°			AVG.
	10"=150	8"=150	12"=150	
90	(-378.5) -1.0	(-178) -1.0	(-468.5) -1.0	-1.0
80	(-117) -3.09	(+38.7) +3.17	(+205) +0.44	-0.16
70	(+112) +2.86	(+63.35) +3.56	(+170.5) +3.85	+3.46
60	(+94) +2.49	(+32.55) +1.83	(+118.5) +2.53	+2.28
50	(+47.5) +1.15	(+15.05) +0.85	(+32) +0.79	+0.93
40	(+15.5) +0.41	(+8.35) +0.47	(+25) +0.62	+0.5
30	(+14) +0.37	(+4.775) +0.27	(+21.5) +0.46	+0.37
20	(+2) +0.05	(+3.125) +0.18	(+24) +0.51	+0.25
10	(0) +0	(+2.165) +0.12	(+2) +0.04	+0.05



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

By NON-PREFERRED DIRECTION

Checked By

ΦANSEN 8/8/78

ANGLE	VALVE SIZE = % OF TORQUE @ 90°				AVG.
	5" = 7.50	6" = 1.50	8" = 3.00	10" = 3.00	
90	-40.95 (-2.0)	-65.1 (-2.0)	-107.3 (-2.0)	-217 (-2.0)	-2.0
80	0 (0)	-22.9 (-.444)	-31.25 (-.291)	-133 (-.613)	-.337
70	+4.335 (+.106)	+1.3 (+.02)	+20.85 (+.194)	-55 (-.025)	+.074
60	+3.91 (+.095)	+6.55 (+.101)	+21.4 (+.199)	+44.5 (+.205)	+.15
50	+1.375 (+.034)	+4.1 (+.063)	+23.8 (+.222)	+40.5 (+.187)	+.127
40	-.27 (-.007)	+3.7 (+.057)	+11.85 (+.110)	+15.5 (+.071)	+.093
30	-.585 (-.014)	+3.25 (+.05)	+6.25 (+.058)	+1 (+.005)	+.025
20	-.45 (-.011)	+.5 (+.008)	+5.35 (+.050)	+1 (+.005)	+.009
10	-.645 (-.016)	+4.6 (+.077)	+1.65 (+.015)	-2 (+.009)	+.020



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

BY NON-PREFERRED DIRECTION

Checked By

QANSEN 8/16/78

ANGLE	VALVE SIZE = % OF TORQUE AT 90°			
	6"=600	8"=600	10"=600	AVG.
90	-46.775 -75 (-1.0)	-75 -75 (-1.0)	-129.45 -129.45 (-1.0)	(-1.0) (-1.0)
80	-20.57 -28.75 (-1.0)	-52.5 -52.5 (-1.0)	-101.2 -101.2 (-1.0)	-64.1 -64.1
70	+2.93 +2.68 +0.63 (+0.63)	-82.5 -82.5 (-1.0)	+87.5 +87.5 (+1.0)	+0.07 +0.07
60	+11.93 +12.55 +0.62 (+0.62)	+13.1 +13.1 (+1.0)	+28.75 +28.75 (+1.0)	+2.17 +2.17
50	+12.435 +12.26 +0.175 (+0.175)	+17.1 +17.1 (+1.0)	+28.85 +28.85 (+1.0)	+2.39 +2.39
40	8 (+1.21)	+18.05 +18.05 (+1.0)	+25.7 +25.7 (+1.0)	+2.04 +2.04
30	+1.91 (+0.04)	+14.65 +14.65 (+1.0)	+9.1 +9.1 (+1.0)	+0.9 +0.9
20	-3.1095 (-0.06)	+13.9 +13.9 (+1.0)	+2.6 +2.6 (+1.0)	+0.46 +0.46
10	-2.212 (-0.047)	+7.2 +7.2 (+1.0)	+1.5 +1.5 (+1.0)	+0.21 +0.21



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS


Page

By PREFERRED DIRECTION

Checked BY

GANSEN E/E/TE

HYDRODYNAMIC TORQUE
VS.
VALVE ANGLE





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

DESIGNED BY PREFERRED DIRECTION

CHECKED BY DANSEN

8/8/78

ANGLE VALVE SIZE - % TORQUE @ 90°

ANGLE	6"=600	8"=600	10"=600	AVG.
90	(7.3) 1.0	(7.5)* 1.0	(8.2)* 1.0	1.0
80	(46.2) 9.8	(91.7) 1.22	(138.15) 1.02	1.07
70	(33.7) 7.1	(101) 1.35	(134.65) 9.9	1.02
60	(16.8) 3.5	(61.5) 5.3	(100.2) 7.4	.64
50	(9.6) 2.0	(46.4) 6.2	(76.9) 5.7	.46
40	(6.4) 1.3	(25.6) 3.4	(52.1) 3.8	.28
30	(5.6) 1.2	(25) 3.7	(36.8) 2.9	.25
20	(3.6) .8	(9.4) 1.3	(24.2) 1.8	.13
10	(2.5) .62	(4) .61	(4.65) .63	.01

* BASED ON NON-PREFERRED DIRECTION



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

By PREFERRED DIRECTION

Checked By

ΦANSEN 8/8/78

ANGLE	VALVE SIZE - % TORQUE @ 90°				AVG (ALL)	AVG (EX. 10'S)
	5"=150	6"=150	8"=300	10"=300		
90	(28) 1.0	(54.62) 1.0	(95.45) 1.0	(180.5) 217 1.0	1.0	1.0
80	(30) 1.07	(60.4) 1.11	(103.6) 1.08	(271.5) 1.5	1.79	1.09
70	(18) .64	(41.5) .75	(77) .81	(205.5) 1.14	.84	.73
60	(9) .32	(27.64) .51	(39.2) .41	(141) .78	.505	.41
50	(5.2) .19	(4.5) X 45°	(30.3) .32	(79) .44	.32	.26
40	(3.35) .12	(8.54) .16	(18.1) .19	(39) .22	.17	.16
30	(2.05) .07	(6.32) .12	(9.6) .10	(22.5) .13	.11	.10
20	(1.115) .04	(4.35) .08	(4.35) .05	(13.5) .08	.06	.06
10	(.465) .02	(.85) .02	(3.5) .04	(4.5) .03	.02	.01

* 5" & 6" = 150# ARE EQUIVALENT TO 300# CLASS VALVES



POST-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUES

Page

By: PREFERRED DIRECTION

Checked By

ØAKSEN

8/7/78

ANGLE	VALVE SIZE - % TORQUE @ 90°					AVG.
	10" - 150 ⁽²⁾	12" - 150 ⁽²⁾	8" - 150	10" - 150 ⁽¹⁾	12" - 150 ⁽¹⁾	
90	(245) 1.0	(467.)(333) 1.0	(214) 1.0	(317) 1.0	(350) 1.0	1.0
80	(327) 1.27	(425) 2.5, 1.28	(137) 1.5	(326) 1.03	(434) 1.29	1.25
70	(227) .93	(345) 1.04	(83) 1.0	(234) .74	(322) .92	.91
60	(122) .50	(186) .56	(-)	(118) .37	(183) .52	.49
50	(59) .24	(104) .31	(-)	(57) .18	(77) .22	.24
40	(30) .12	(87) .26	(-)	(32) .10	(34) .10	.15
30	(16) .07	(33) .10	(-)	(25) .08	(24) .07	.08
20	(9) .03	(26) .08	(-)	(14) .04	(18) .05	.05
10	(3) .01	(11) .03	(-)	(8) .02	(-) .03	.02

(?)

DELETE
NOT GOOD
DATA



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page

Calc. By

Dunn

DATE: 12/16/77

Checked By

VALVE SIZE: 150

VALVE DIRECTION: ~~STEM UPSTREAM~~ STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON/BUNA

WATER TEMPERATURE (TANK): 68 °F

DISC TYPE & DWG:

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	($\frac{IN-LB}{IN^2}$) / PS
0					
10		43		+45	1.0
20		41		+45	1.1
30		38.5		+40	1.0
40		36		+45	1.3
50		32		+55	1.7
60		35		+60	1.7
70		25		0	0
80		19		-75	-3.9
90		23		-90	-3.9
90		23		-90	-3.9
80		19.5		-75	-4.5
70		21		-40	-1.0
60		27.5		-10	-0.4
50		36		+10	+0.3
40		28.5		0	0.0
30		30.5		-15	-0.5
20		32		-15	-0.5
10		32		-15	-0.5
0					

PACKING TORQUE: 20 IN-LB OPENING


0 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

File 3-15010 HYDRODYNAMIC TORQUE CURVE Page _____

Calc. By C. L. W. S. (SEM - UP STREAM) Checked By _____






POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

3" 150LB. - HYDRODYNAMIC TORQUE CURVE

Page

Calc. By C. LIVERS (STEM-DOWN-STREAM) Checked By





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title: HYDRODYNAMIC TORQUE DETERMINATION Page

By: DATE: 12/5/77 Checked By:

VALVE SIZE: 4" - 150

VALVE DIRECTION: STEM UPSTREAM ~~STEM DOWNSTREAM~~

VALVE SEAL TYPE: TEFLON/BUNA

WATER TEMPERATURE (TANK): 65 °F

DISC TYPE: EDWA

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X		X
10		46.5		+50
20		42.5		+75
30		37		+75
40		31		+75
50		32		+100
60		25.5		+125
70		17.5		+140
80		11.5		+150
90		8.7		+125
90		X		X
90		8.5		+75
80		11		+125
70		16.5		+125
60		27		+125
50		31.5		+85
40		35		+50
30		36.3		+40
20		37.8		0
10		38.8		-60
0		X		X

PACKING TORQUE: 5 IN-LB OPENING
5 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page 3

By RAY MARSHALL DATE: 11-17-77 Checked By _____

VALVE SIZE: 4" 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON/RUNA

WATER TEMPERATURE (TANK): _____ °F

DISC TYPE & DWA: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X		X
10		30.5		+75+40
20		32		+40
30		30.5		+45
40		30.5		+60
50		35		+80
60		27		+50
70		18		+49
80		11		-10
90		8.5		-55
		X		X
90		8.7		-80
80		11		-30
70		17.5		0
60		27		+15
50		35		+45
40		43.5		+25
30		29.5		+10
20		27		-5
10		28		0
0		X		X

PACKING TORQUE: 10 IN-LB OPENING
5 IN-LB CLOSING




POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Page

Title 4" 150LB HYDRODYNAMIC TORQUE CURVE


Calc. By C. LIVORSI (STEM UPSTREAM) Checked By _____





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title: 4" 150LB HYDRODYNAMIC TORQUE CURVE Page: 2 of 2
 Calc. By: C. Livorsi (STEM DOWN STREAM) Checked By:





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page _____

By T. CORY DATE: _____ Checked By: _____

CONST. UPSTREAM PRESS.

VALVE SIZE: 6" 850-300

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEF / BUNA

WATER TEMPERATURE (TANK): 57 °F

DISC TYPE & DWG: 2 

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10	18.1	12		-50
20	18.1	14		0
30	18.6	17.5		50
40	18.1	17.8		70
50	18.7	15		100
60	18.7	14		300
70	18.5	12.5		500
80	18.3	11.5		700
90	18.4	11		600
90	18.6	12.8		700
80	18.4	12.5		750
70	18.4	12.5	550	700
60	18.4	13		440
50	18.7	15		300
40	18.4	12.5		150
30	18.4	14		125
20	18.3	11.5		100
10	18.1	13.5		80
0				


OPENING
CLOSING

OPENING
CLOSING

PACKING TORQUE: IN-LB OPENING
IN-LB CLOSING



PREFERRED DIRECTION





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page _____

By _____

DATE: _____

Checked By _____

VALVE SIZE: 6" 150 300

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 66 °F

DISC TYPE & DWG: 2 

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	
0					
10		38.5		-180	
20		4.9		-150	
30		6.2		-80	
40		7.3		-110	
50		8.2		160	19.5
60		6.5	23	200 - 540	308.5
70		8.75	15	500 - 650	457.4
80		8.5	11.2	530 - 650	62.3
90		9.1	8.5	500 - 500	549.5
90		9.1	8.5	510 - 500	
80		11.5	11	700 - 600	108.5
70		16.7	16.2	730 - 750	437.4
60		14.5	22.6	350 - 520	241.2
50		14.5		150	2.4
40		12.5		60	
30		1.5		60	
20		34		90	
10		50.5		25	
0					

OPENING

CLOSING

PACKING TORQUE: _____ IN-LB OPENING

_____ IN-LB CLOSING




POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page _____

By R. PHANSEN DATE: 9/20/77 Checked By _____

VALVE SIZE: 6" - 150/300

VALVE DIRECTION: ~~STEM UPSTREAM~~ / STEM DOWNSTREAM

VALVE SEAL TYPE: TEF/BUNA  TYPE 2

WATER TEMPERATURE (TANK): 63° F

DISC TYPE & DWG:

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	($\frac{1}{2}$) / PS
0		X		X	
10		44.5		+175	3.9
20		30.0		+75	2.5
30		11		+75	6.2
40		11		+90	8.2
50		10.2		+45	4.1
60		9.7		+45	4.1
70		5.7		+15	2.6
80		9.2		-275	-2.8
90		8.4		-550	-6.5
		X		X	
90		8.5		-550	-6.4
80		9.0		-260	-2.8
70		23.5		+200	0.11
60		23.5		+200	8.1
50		22.5		+85	3.8
40		18.5		-15	-1.8
30		19.0		-5	-1.3
20		31.5		-110	-3.5
10		28.5		-150	-5.1
0		X		X	

OPENING

CLOSING


PACKING TORQUE: 10 IN-LB OPENING
10 IN-LB CLOSING



Title HYDRODYNAMIC TORQUE CURVE Page

Calc. By C. LIVORSI (STEM DOWN STM) Checked By

6" 150 LB





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page 5

By C. LIVORSI DATE _____ Checked By _____

VALVE SIZE: 8" ISOLB

VALVE DIRECTION: STEM UPSTREAM

VALVE SEAL TYPE: _____

WATER TEMPERATURE (TANK): 71 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	($\frac{1}{2}$) / 9
0	69.5	65		400	
10		59.5		100	1.6
20		56		4.25	7.6
30		51.5		5.50	10.7
40		43		7.75	16.8
50		31		7.75	25
60		18		7.40	41.1
70		8.5		7.00	92
80		4.5		6.50	144
90		2.5		6.00	240
90		2.0		3.75	187
80		3.0		4.00	137
70		6.0		5.00	83
60		12.5		5.50	42
50		26.5		5.75	21
40		38.5	37 400	40.0	10
30		37.5	47 350	30.0	7
20		41.5	54 400	30.0	7
10		54.5		10.0	1
0				3.75	

PACKING TORQUE: 160 IN-LB OPENING

80 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page 6

Loc. By C. Livorsi DATE _____ Checked By _____

1st pump

VALVE SIZE: 8" 150

VALVE DIRECTION: ~~STEM UPSTREAM~~ / STEM DOWNSTREAM

VALVE SEAL TYPE: _____

WATER TEMPERATURE (TANK): 70 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P _i UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	
0				900 ^{1/2}	
10		58		350	6.0
20		56		350	6.2
30		54		375	7
40		40		415	10
50		28.5		450	15
60		15		460	30
70		7.5	AP @ 75° = 8.5 T @ 75° = 600	450	60
80		5.3	AP @ 85° = 4.5 T @ 85° = 6	410	77
90		2.6		450	17
90		3.0		550	18
80		3.0	AP @ 85° = 2.5 T @ 85° = 360	0	0
70		7.5		500	66
60		16	AP @ 75° = 5.5 T @ 75° = 375	550	34
50		28		400	14
40		39.5		250	6
30		46		100	2
20		54.5		0	0
10		58		100	1
0				900 ^{1/2}	

PACKING TORQUE: 150 IN-LB OPENING

: 100 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

8" 150 LB

Title HYDRODYNAMIC TORQUE (PREFERRED) Page

Calc. By C. LIVORSI

Checked By


300

200

PSI

100

0 20 40 60 80 100





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

8"-150

Title HYDRODYNAMIC TORQUE CURVE (UNPREFERED) Page _____

Calc. By C. Livorsti Checked By _____

150

100

50

0


50

100

150

200

20 40 60 80 100





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION (F1) Page _____

alc. By RO DATE: 6/17/97 Checked By _____

VALVE SIZE: 10" x 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON BUNA / DISC TYPE: Z

WATER TEMPERATURE (TANK): 98° °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB	
0	54.9	51	0	41250 / 1150 / 1200	
10	54.9	50.5	395	850	16.5
20	30	25.5	895	550	21.6
30	16	11.5	1030	350	30.4
40	8.5	3.6	1100	150	41.7
50	25	15	3560	550-900	60
60	18.5	6.3	3590	850	134.5
70	16.0	3.2	3590	800	250
80	15.0	2.2	3580	800	363.6
90	41	75.0	2685	600	600
	45	1.5	2623	390	75
90	40	1.5	2623	150	125
80	40	2.0	2663	250	94.7
70	41	3.0	2720	275	95
60	41	4.0	2620	300	57.2
50	42	7.0	2538	350-400	22
40	45	17.0	2260	375	10
30	51	32.0	1800	225	
20	54	51	1195	0	
10	61	56	360	0	
0					

PACKING TORQUE: 50 IN-LB OPENING

50 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION (2) page

Calc. By AC DATE: 6/17/77 Checked By _____

VALVE SIZE: 10" - 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / BUNA DISC TYPE: 2

WATER TEMPERATURE (TANK): 80 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0	32.8	16.5	218	329
10	44.5	19.4	222	200
20	54.5	10.5	1670	578
30	42.8 ^{1.6}	10.5	1740	600
40	22.2	1.5	2217	400
50	16.6	7.5	2727	450
60	20.2	6.0	3587	750
70	17.6	3.5	3594	700
80	16.6	2.5	3596	700
90	16.0	1.75	3595	450
90	↓	↓	↓	300
80	16.3	2.0	3583	650
70	17.3	3.0	3597	700
60	19.8	6.0	3599	725
50	26.5	17.5	3572	800
40	49.5	14.0	2140	450
30	57.2	11.0	1170	300
20	62.1	14.0	732	300
10	65.9	15.0	311	200
0				

DATE

23.4
26.7
60
125
200
280
259
171
325
233
125

PACKING TORQUE: 50 IN-LB OPENING

50 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

#3

HYDRODYNAMIC TORQUE DETERMINATION

Page

Calc. By

DATE: 6/20/77


Checked By

VALVE SIZE: 10" 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 78 °F

DISC TYPE & DWG: 2 

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0	31.5 / 31.5			
10	45.7 / 46.3	33 / 23.5	300 / 232	850 / 150
20	17.5 / 17.2	17.5		700
30	8.5			450
40	12.5			700
50	7.0			575
60	5.0			675
70	2.5			625
80	2.0			725
90	1.5			550
90		1.5		400
80		2.0		575
70		3.0		650
60		6.0		600
50		13.0		450
40		26.0 / 18.5		300 / 150
30		23		100
20		23		275
10		33.5		600
0				

1100/175
40
53
51
82
135
250
363
361
26
25
27
100
35
12/8
-4
-12
-18

PACKING TORQUE: 50 X IN-LB OPENING
50 X IN-LB CLOSING



Title HYDRODYNAMIC TORQUE DETERMINATION

Calc. By _____ DATE: 6/20/77 Checked By _____

CAVITATION measurements - CONTROL VALVE
WIDE OPEN

VALVE SIZE: 10"=150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 77 °F

DISC TYPE & DWG: 2

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X		X
10		51		1200
20		50.5		1400
30		43.5		1575
40		28.5		1450
50		13.5		1100
60		6.25		925
70		3.0		825
80		2.25		800
90		2.0		550
90		1.75		375
80		2.25		600
70		3.5		625
60		6.75		650
50		14.25		525
40		28.5		275
30		44.5		200
20		51.5		550
10		58.5		1100
0				

PACKING TORQUE: 50 X IN-LB OPENING
50 X IN-LB CLOSING



PCSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page


calc. By D. [unclear] DATE: 6/21/77 Checked By

VALVE SIZE: 10" - 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON/BUNA

WATER TEMPERATURE (TANK): 76 °F

DISC TYPE & DWG: 2 

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		42.5		800
20		28		650
30		11.5		425
40		13.0		525
50		10.5		700
60		6.5		775
70		3.5		550
80		1.7		175
90		1.7		625
90		1.8		700
80		1.8		50
70		3.0		+200
60		6.5		+450
50		13.5		+275
40		8.5		-75
30		16.5/19/30.5		-50 / -50 / -275
20		17.5		-325
10		18.5		-350
0				

OPENING

CLOSING

PACKING TORQUE: 50 IN-LB OPENING

50 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page _____

Calc. By John

DATE: 6/2/77

Checked By _____

Full open - Control Valve

VALVE SIZE: 10" - 150

VALVE DIRECTION: OPEN UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / Buna

WATER TEMPERATURE (TANK): 80 °F

DISC TYPE & DWG: 2

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		57.5		+1050
20		47.7		+850
30		39.5		+750
40		26.5		+800
50		14.5		+925
60		7.0		+800
70				
80				
90				
90				
80				
70				
60		6.5		+350
50		13.5		+200
40		25		0
30		39.5		-450
20		51.0		-700
10		58.5		-800
0				

PACKING TORQUE: 50 IN-LB OPENING

50 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS


TORQUE VS. VALVE ANGLE

10° - 150°

Page

Calc. By R. QANSEN

Checked By





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By C. LIVORSI DATE Checked By

VALVE SIZE: 12" 450

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON

WATER TEMPERATURE (TANK): °F

DISC TYPE & DWG:

OPENING

CLOSING

VALVE ANGLE DEGREES	Δ P (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0				
10	50	1400	28	
20	36.5	1300	36	
30	20.5	850	41	
40	20.5	1000	49	
50	8.5	850	100	
60	3.5	825	236	
70	2.3	750	326	
80	1.5	760	467	
90	1.0	500	500	
90	1.0	200	200	
80	1.0	400	400	
70	1.5	475	317	
60	3.5	750	129	
50	8.0	425	53	
40	17.5	325	19	
30	36.5	225	6	
20	48.5	0	0	
10	55	550	10	
0				

PACKING TORQUE: 150 IN-LB OPENING
200 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION

Page 2

Calc. By C. Livors

DATE: _____

Checked By _____

VALVE SIZE: 12" 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON

WATER TEMPERATURE (TANK): _____ °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	6.2	1800		
10	41.5	950	2.3	
20	2.5	900	3.6	
30	1.2	550	4.6	
40	2.5	350	14.0	
50	3	400	13.3	
60	3.5	650	18.6	
70	1.8	600	33.3	
80	1.2	600	500	
90	0	300	33.3	
90	0	0	0	
80	1	350	3.50	
70	1.4	500	35.7	
60	2.2	500	18.5	
50	2.4	550	7.4	
40	16.5	550	3.3	
30	18.5	350	1.9	
20	30.6	450	1.5	
10	24.5	50	2	
0	6.2	1200		

PACKING TORQUE: 150 IN-LBS OPENING

150 IN-LBS CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

File HYDRODYNAMIC TORQUE DETERMINATION Page _____
Calc. By C. LIVORSI DATE: 7-7-78 Checked By _____

VALVE SIZE: 12"-150"

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON

WATER TEMPERATURE (TANK): 67 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	62	700		
10	27	550	76	
20	5	300	60	
30	10	450	45	
40	7.7	450	58	
50	5.5	350	63	
60	4.0	650	162	
70	1.9	450	236	
80	1.2	200	166	87° = 0
90	.8	300	375	
90	.8	450	562	
80	.8	100	125	
70	1.6	200	72.5	
60	4.0	300	25	
50	9.5	10.0	11	
40	16	0	0	
30	30	50	2	
20	44	550	13	
10	53	1150	22	
0	63	100	2	

PACKING TORQUE: 125 IN-LB OPENING

150 IN-LB CLOSING



Title HYDRODYNAMIC TORQUE CURVE 12" 150

Page

Calc. By C. LIVORSI

Checked By

STEM DOWNSTREAM

200

100

0

-100


-200

-300

-400

-500

-600





Title: 12-150 STEM UP STREAM HYDRO DYNAMIC TORQUE CURVE Page

Calc. By: C. LIVORSI

Checked By: CURVE

500

A OPENING

400

B CLOSING

300

200

100

0

20

40


60

80

100

END POINT →

ANGLE OF OPENING
DEGREE






POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Re 12" 150 (PREFERED) HYDRODYNAMIC TORQUE CURVE Page

Calc. By C. LIPORSI

Checked By





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page _____

Calc. By _____

DATE: _____

Checked By _____

VALVE SIZE: 14" - 150

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: _____

WATER TEMPERATURE (TANK): 65 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0				
10	49.5	525	11	21.5 475
20	41	700	17	7 400
30	26.5	900	34	20.5 800
40	16	750	47	
50	7.2	750	104	
60	3	700	233	
70	1.5	600	400	
80	1	300	300	
90	.6	-275	-458	
90	.6	-275	-458	
80	.7	-50	-71	
70	1.3	300	231	
60	3	500	167	
50	7.2	450	62.5	
40	15.6	200	13	
30	26.6	150	6	
20	23.6	400	17	
10	42.5	-300	-7	22 - 200
0				

PACKING TORQUE: 5 FT-LB HOLD OPENING

: 5 FT-LB HOLD CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS


File 14" 150 STEM DOWN STREAM

Page

Calc. By C. LINDERSI

Checked By

400
300
200
100
0
-100
-200
-300
-400





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title TORQUE VS. VALVE ANGLE

Page

Calc. By

R. QANSEN

Checked By

10°-150°

STEM UPSTREAM
CONTROL VALVE REGULATED

TORQUE [IN-IN]
[PSI]

+300


+200

+100

0

10 20 30 40 50 60 70 80 90

VALVE ANGLE





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Page

Title VALVE TORQUE = 10⁵ - 150

Calc. By

Checked By


CONTROL VALVE WIDE OPEN

STEM UPSTREAM

TORQUE

1000

1000





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page

Calc. By C. LIVERSI DATE: 2/78 Checked By _____

VALVE SIZE: 8" 300 LB

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: STD / TEFLON

WATER TEMPERATURE (TANK): 64 °F

DISC TYPE & DWG: _____

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	62	650		
10	58.5	350	6.0	
20	51.5	450	8.7	
30	45	600	13.3	
40	32.5	700	21.5	
50	20	700	35	
60	18	650	36.1	
70	9.0	750	83.3	
80	6.5	750	115.4	
90	5.5	700	127.3	
90	5.5	350	63.6	
80	6.0	550	91.7	
70	8.5	600	70.6	
60	13.0	550	42.3	
50	19.5	500	25.6	
40	30.5	450	14.7	
30	43	250	5.8	
20	52	0	0	
10	59	150	2.5	
0	62	550		

OPENING

CLOSING

PACKING TORQUE: 200 IN-LB OPENING
200 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

HYDRODYNAMIC TORQUE DETERMINATION

Page _____

Calc. By C. LIVORSI DATE: 2/78 Checked By _____

VALVE SIZE: 8" 300 LB

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: STD. TEFLON

WATER TEMPERATURE (TANK): 64°F

DISC TYPE & DWG: _____

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	63	600		
10	60.5	450	7.4	
20	51.5	550	10.7	
30	36	450	12.5	
40	22.5	350	15.5	
50	10.5	350	33.3	
60	7.0	300	42.8	
70	7.0	250	50	
80	5.0	0	0	0-TORQUE @ 78°
90	5.0	500	100	
90	4.8	550	114.6	
80	4.0	250	62.5	
70	6.0	50	8.3	
60	8.5	0	0	0-TORQUE @ 65°
50	17.5	250	14.3	
40	30.5	250	8.2	
30	44	0	0	
20	50.5	0	0	
10	60.5	250	4.1	
0	65	600		

OPENING

CLOSING


PACKING TORQUE : 200 IN-LB OPENING

200 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title: 8" 300 LB. HYDRO DYNAMIC TORQUE CURVE Page _____
Calc. By: C. LIVORSI Checked By: _____






8-300 HYDRODYNAMIC TORQUE CURVE

Page

Calc. By: C. LivoRST (UNPREFERRED) Checked By:



VALVE ANGLE



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page


Calc. By GANSEN DATE: 8/1/77 Checked By

VALVE SIZE: 10" 300

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNST






VALVE SEAL TYPE: TEFLON/BUNA

WATER TEMPERATURE (TANK): 83 °F

DISC TYPE & DWG: 2 

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		58.5		+700
20		47.5		+450
30		37.5		+300
40		25		+600
50		10		725
60		7.5		575
70		4.5		200
80		2.5		250
90		3		500
90		3		825
80		3		575
70		4.5		275
60		7		0
50		12		+175
40		23		50
30		37.5		300
20		51		300
10		57.5		600
0				

PACKING TORQUE: 175 IN-LB OPENING
250 IN-LB CLOSING



Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By Q. JENSEN DATE: 7/20/77 Checked By

VALVE SIZE: 10" 300

VALVE DIRECTION: STEM UPSTREAM / STEADY

VALVE SEAL TYPE: TEFLON / BODA

WATER TEMPERATURE (TANK): 87 °F

DISC TYPE & DWG: 2

OPENING

CLOSING


VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE IN-LB + TENDING TO CLOSE - TENDING TO OPEN
0		X		X
10		36		600
20		26		700
30		35		7350
40		72.5		1200
50		11		1050
60		6		1050
70		4.5		1100
80		2.5		900
90		2.5		650
90		2		7
80		2.5		250
70		3		550
60		4.5		750
50		7.5		800
40		12		750
30		76		650
20		12.5		75
10		26		0
10		55-20		450-300
0		X		X

PACKING TORQUE: 200 IN-LB OPENING

250 IN-LB CLOSING



TORQUE VS. VALVE ANGLE





Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By GANSER DATE 3/31/77 Checked By

VALVE SIZE 3" 600

VALVE DIRECTION STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE TET ON / BONA

WATER TEMPERATURE (TANK) 67 °F

DISC TYPE & DWG

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		42		+60
20		38.5		+30
30		34.5		+30
40		34		+25
50		30.5		+40
60		39		+30
70		31.5		0
80		25.5		-5
90		22.5		-40
90		22.5		-60
80		25		-45
70		31.5		-25
60		39		-5
50		28		0
40		30.5		0
30		41.5		-5
20		46.5		-10
10		47.5		-25
0				

PACKING TORQUE: 10 IN-LB OPENING
5 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page _____

Calc. By Pherson DATE: 13/1/77 Checked By: _____

VALVE SIZE: 3" 600

VALVE DIRECTION: (STEM UPSTREAM) / STEM DOWNSTREAM

VALVE SEAL TYPE: TETAN / BUNA

WATER TEMPERATURE (TANK): 68 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		54		+75
20		52		+60
30		43.5		+75
40		40.5		+75
50		43.5		+115
60		37.5		+120
70		31.5		+145
80		26		+160
90		23		+145
90		23		+140
80		26.5		+125
70		31		+115
60		36		+100
50		43.5		+75
40		38.5		+45
30		41.5		0
20		43		0
10		44		-55
0				

PACKING TORQUE: 10 IN-LB OPENING

5 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title: HYDRODYNAMIC TORQUE DETERMINATION Page: _____

Calc. By: OWSEN DATE: 11/14/77 Checked By: _____

VALVE SIZE: 4" 600

VALVE DIRECTION: (STEM UPSTREAM) / STEM DOWNS

VALVE SEAL TYPE: TEFLON / EPR

WATER TEMPERATURE (TANK): _____ °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		---		---
10		49		+275
20		35		+275
30		34		+250
40		23.5		+175
50		26.5		+175
60		26		+250
70		22		+275
80		17		+250
90		16.5		+150
90		---		---
90		16.5		+75
80		17		+150
70		21.5		+125
60		27.5		+50
50		35.5		-10
40		25		-50
30		39		-100
20		48.28		-250 - 200
10		26.5		-200
0		---		---

PACKING TORQUE: 15 IN-LB OPENING

5 IN-LB CLOSING



HYDRODYNAMIC TORQUE DETERMINATION

Page

By GAUSEN DATE: 11/3/77 Checked By

VALVE SIZE: 4" 600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: TEFLON / EPR

WATER TEMPERATURE (TANK): 68 °F

DISC TYPE & DWG:

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X		X
10		43		+75
20		40.5		+25
30		37		+50
40		41.5		+50
50		39		+50
60		31		+25
70		23.5		-25
80		19		-75
90		17.5		-125
90		X		X
80		18.5		-100
70		23.5		-50
60		30.5		-25
50		39.5		-25
40		47		0
30		50		-25
20		49.5		-75
10		50		-150
0		X		X

OPENING

CLOSING

PACKING TORQUE: 250 IN-LB OPENING

250 IN-LB CLOSING



Title: HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By: Jansen DATE: 8/7/77 Checked By:

VALVE SIZE: 6" - 600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTR

VALVE SEAL TYPE: TEFLON / Buna

WATER TEMPERATURE (TANK): 83 °F

DISC TYPE & DWG:

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE IN-LB + TENDING TO CLOSE - TENDING TO OPEN
0		X		X
10		44		+200
20		33		+150
30		27.5		+250
40		25		+400
50		19.5		+450
60		20.5		+450 +2.95
70		15		+250 +6.67
80		10.5 / 8.5		0 -250
90		15.5		650
90		X		X
90		75.5		850
80		19.0		525
70		18.5		200
60		26		50
50		28		50
50		33		0
30		34		-275
20		32.5		-350
10		39		-350
0		X		X

PACKING TORQUE: 175 IN-LB OPENING

225 IN-LB CLOSING



Title HYDRODYNAMIC TORQUE DETERMINATION Page 1

Calc. By Jensen DATE: 2/19/77 Checked By

VALVE SIZE: 6-600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: FERON / BUNA

WATER TEMPERATURE (TANK): 85 °F

DISC TYPE & DWG. NO. wa 600

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X	X	X
10		30.5	57.5	+250 6.6
20		33	58.5	+350 9.1
30		24	55.5	+300 12.5
40		25	47.5	+300 12
50		26.5	44.5	+400 15.1
60		20	32.5	+450 22.5
70		19.5	28.5	+650 33.3
80		19.2	19.0	+1025 53.4
90		14.8	14.8	+750 (30.7)
90		X	X	X
90		14.8	14.8	+650 (43.5)
80		18.3	18.8	+750 38.4
70		24.2	24.4	+825 34.1
60		20.5	21.5	+225 11
50		24.5	43.5	+100 4.1
40		34.5	50.5	+25 7
30		34.5	55.5	50 1.4
20		38.5	58	75 1.9
10		34.0	60.5	275 3.1
0		X	X	X

PACKING TORQUE: 75 IN-LB OPENING

25 IN-LB CLOSING



HYDRODYNAMIC TORQUE V.S. ANGLE

Page

Calc. By J. CORY 8/23/77 Checked By

6" - 6.00


PREFERRED DIRECTION

TORQUE FACTOR (INT. LB. SI)

80
70
60
50
40
37.3
30
27.5
20
15.1
10
0

0 10 20 30 40 50 60 70 80 90

VALVE ANGLE



ANGLE	FACT
0	0
10	8
20	20
30	40
40	70
50	31.0
60	17.0
70	34.0
80	46.0
90	47.0



HYDRODYNAMIC TORQUE - V.S. ANGLE


Page

Calc. By J COOKY 8/23/77 Checked By

6" - 600

NON PREFERRED DIRECTION

150
140
130
120
110
10
-10
-20
-30
-40
-50
-60



ANGLE	FACTOR
0	0
10	-3
20	-3
30	0
40	7
50	12
60	12
70	4
80	-22



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title: HYDRODYNAMIC TORQUE DETERMINATION Page _____

Calc. By: C. Livorsi

DATE: _____

Checked By: _____

VALVE SIZE: 8" 600#

VALVE DIRECTION: STEM UPSTREAM / STEM DOWN

VALVE SEAL TYPE: URATHANE

WATER TEMPERATURE (TANK): 69° F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	0	1600		
10	5.0	500	-10	
20	11	250	-22.7	
30	11.5	300	-26.1	
40	11.0	350	-31.8	
50	9.5	325	-34.2	
60	5.7	200	-35.4	
70	6.5	-125	19.2	72° TORQUE WENT
80	5.0	-125	-25	NEG
90	6.0	-300	-50	
90	6.0	-600	-100	
80	5.0	-400	-80	
70	7.0	-250	-35.7	
60	11.2	-700	-8.9	
50	18.5	-10	0	
40	23.5	700	4.3	
30	31.0	100	3.2	
20	39	-200	5.1	
10	5.7	-250	4.4	
0	0	-1100		

PACKING TORQUE: 150 IN-LB OPENING

150 IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By C. LIVOCESI DATE: _____

Checked By _____

VALVE SIZE: 8" 600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWN

VALVE SEAL TYPE: URATHANE

WATER TEMPERATURE (TANK): 71 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0	67	7800		
10	50.5	400	7.9	
20	16	300	19.8	
30	5	250	50	
40	16	400	40	
50	9	600	66.7	
60	6.0	500	83.3	
70	4.2	600	142.9	
80	3.0	400	133.3	
90	4.6	300	65.2	
90	5.0	0	0	
80	4.8	200	50	
70	5.5	225	59.1	
60	8.0	325	40.6	
50	11.5	300	26.1	
40	9.0	100	14.1	
30	19.0	115	6.1	
20	19.0	0	0	
10	49.0	350	7.1	
0	67	1800		

PACKING TORQUE: 150 IN-LB OPENING


: 100 IN-LB CLOSING



8" 600 LB

HYDRODYNAMIC TORQUE CURVE (NON-PREF DIRECTION) Page

Calc. By C. LIVORSI Checked By






8" 600 L.B.

HYDRODYNAMIC TORQUE CURVE (PERF. DIRECTION) Page

By C. LIPRST.

Checked By





ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page _____

Calc. By WALLEN DATE: 8/3/77 Checked By _____


Control Valve - regulated

VALVE SIZE: 10" 600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWN

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 84 °F

DISC TYPE & DWG: 2 

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0				
10		47.385		+900
20		34.255		+1200
30		23.25		+1550-1500
40		14.24		+1500-1750
50		14.14.4		+1500-1550
60		10.59.8		+1450-1350
70		7.3		+1400
80		5.2		+1200
90		4.4		+800
85		4.8		0
80		4.4		+200
70		5.9		+450
60		8.8		+550
50		13.0		+600
40		20.8		+650
30		33		+450
20		40.4		+50
10		39		-550
0				

PACKING TORQUE: 350 IN-LB OPENING

400 IN-LB CLOSING



Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By James DATE: 8/5/77 Checked By:

Control valve regulated

VALVE SIZE: 10" 600

VALVE DIRECTION: OPEN UPSTREAM / STEM DOWN

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 88° F

DISC TYPE & DWG: 2

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE + TENDING TO CLOSE - TENDING TO OPEN IN-LB
0		X		X
10		46		+100
20		31.5		+900
30		27.5		+900
40		24.5		+1500
50		14.0		+1100
60		9.1		+950 +800
70		5.8		+600 +400
80		4.3	4.2	-23.81 +250 -100
90		4.4		250
90		X		X
90		4.7		-950
80		4.2		-750
70		6.4		-550
60		9.6		-450
50		14.4		-300
40		26.5		-250
30		27.5		-400
20		32		-750
10		37		-800
0		X		X

PACKING TORQUE: 59450 IN-LB - OPENING

450 IN-LB - CLOSING



Title HYDRODYNAMIC TORQUE DETERMINATION Page

Calc. By Damen DATE: 8/5/77 Checked By


Control valve wide open

VALVE SIZE: 10" - 600

VALVE DIRECTION: STEM UPSTREAM / STEM DOWN

VALVE SEAL TYPE: TEFLON / BUNA

WATER TEMPERATURE (TANK): 88 °F

DISC TYPE & DWG: 2 

OPENING

CLOSING

VALVE ANGLE DEGREES	P ₁ UPSTREAM PSIG	ΔP PSI	Q GPM	TORQUE IN-LB + TENDING TO CLOSE - TENDING TO OPEN
0	1	X		X
10		57		+1500
20		48.5		+950
30		37		+825
40		25.5		+850
50		14.5		+900
60		9.4		+700
70		6.5		+250
80		4.3		0 - 25
90		4.6		300
		X		X
90		11.7		1350
80		4.2		800
70		6.4		550
60		9.3		500
50		14.0		325
40		24.5		325
30		37.2		575
20		49.0		900
10		57.5		1025
0	2	X	R	X

PACKING TORQUE: 650¹⁵⁰ IN-LB OPENING

460¹⁵⁰ IN-LB CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page 1

Calc. By C. LIVORSI DATE: 9-1-78 Checked By _____

VALVE SIZE: 14" 1500 LB

VALVE DIRECTION: STEM UPSTREAM / STEM DOWNSTREAM

VALVE SEAL TYPE: METAL

WATER TEMPERATURE (TANK): 77 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS) FT-LBS	FT IN-LBS PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0				
10	59.5	190	3.2	
20	54.5	195	3.6	
30	40.5	205	5.1	
40	24.5	205	8.4	
50	17.5	190	10.9	
60	12.0	175	14.6	
70	9.5	165	17.4	
80	8.0	160	20.0	
90	7.5	145	19.3	
90	8.0	-35	-4.4	
80	7.5	-20	-2.7	
70	8.0	-5	-0.6	
60	8.5	-5	-0.6	
50	11.5	-5	-0.4	
40	17.5	-10	-0.6	
30	31.0	-50	-1.6	
20	44.5	-105	-2.4	
10	52.5	-210	-4.0	
0				

PACKING TORQUE: 70 FT-LBS IN-LBS OPENING

70 FT-LBS IN-LBS CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

Title HYDRODYNAMIC TORQUE DETERMINATION Page _____

Calc. By G. LIYORSI

DATE: 9-1-78

Checked By _____

VALVE SIZE: 14" 1500 LB

VALVE DIRECTION: STEM UPSTREAM / STEM DOWN

VALVE SEAL TYPE: METAL

WATER TEMPERATURE (TANK): 77 °F

DISC TYPE & DWG: _____

OPENING

CLOSING

VALVE ANGLE DEGREES	ΔP (PSIG)	TORQUE (IN-LBS)	IN-LBS / PSI	COMMENTS + TENDING TO CLOSE - TENDING TO OPEN
0				
10	57.5	150	2.6	
20	48.5	190	3.9	
30	39.0	200	5.1	
40	28.5	170	6.7	
50	16.5	130	7.9	
60	12.5	90	7.2	
70	9.0	50	5.5	
80	7.5	25	3.3	
90	6.8	15	2.2	
90	7.0	-115	-16.4	
80	7.0	-115	-16.4	
70	7.2	-95	-13.2	
60	8.0	-90	-11.3	
50	11.5	-70	-6.1	
40	19.5	-65	-3.3	
30	32.0	-70	-2.2	
20	45.0	-100	-2.2	
10	54.0	-125	-2.3	
0				

PACKING TORQUE: 70 ft-LBS IN-LBS OPENING

: 70 ft-LBS IN-LBS CLOSING



POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS

14" 1500 LB HYDRODYNAMIC TORQUE CURVE Page

By C. LIVORSI

Checked By

PERFERED

LBS
SI of ΔP

25

20

15

10

5


0

5

10

20 40 60 80 100

VALVE ANGLE
DEGREES OPEN





POSI-SEAL INTERNATIONAL, INC.
ENGINEERING CALCULATIONS


14" 1500 LBS HYDRODYNAMIC TORQUE CURVE

Page

BY C. LIVORSI

Checked By

NON PREFERRED



VALVE ANGLE
DEGREES OPEN





POSI-SEAL INTERNATIONAL, INC.

Innovators in Flow Control

TECHNICAL BULLETIN NO. 1A Operating torque values and Actuator sizing

JUNE 82

TORQUE VALUES TO OPEN AND SHUT

The Posi-Seal Trunnion Valve is a low torque valve which normally reaches its highest torque when opening. This torque value will vary with the seat material and stem packing selected in addition to the maximum operating differential pressure (ΔP) across the valve.

Torque values to open and shut for standard Posi-Seal Trunnion Valves are listed in Tables 1, 2 and 3, and are denoted as T_1 , T_2 , and T_3 .

T_1 and T_2 torque values are due to the stem packing and seat material selected and are added together to determine preload torque.

The static pressure torque factor T_3 is the static pressure torque per $\text{PSI}\Delta P$. This factor (T_3) is multiplied by the maximum operating ΔP or maximum line pressure to obtain the torque value due to pressure.

To obtain the maximum torque to open or shut the T_1 , T_2 , and T_3 ΔP values are simply added together.

EXAMPLE:

A. Requirement — What is the maximum opening torque of a 12" Class 150 valve with teflon chevron packing, a teflon seal ring with rubber back-up ring and a maximum ΔP of 200 PSI .

B. Solution — From Table 1

$$T_1 = (B) = 70 \text{ in. lbs.}$$

$$T_2 = (G) = 986 \text{ in. lbs.}$$

$$T_3 = 10.10 \text{ in. lbs. per } \text{PSI}\Delta P = 10.10 \times 200 = 2020 \text{ in. lbs.}$$

$$\text{Total opening torque} = T_1 + T_2 + (T_3 \times \text{PSI}\Delta P) = 70 + 986 + (10.10 \times 200) = 3076 \text{ in. lbs.}$$

Although the valve opening torque is normally the highest operating torque used in actuator sizing, it is often necessary with flowing liquids to check for total hydrodynamic torque. Refer to Section II for data on calculating total hydrodynamic torque.



TABLE I
CLASS 150 STANDARD RATING

VALVE SIZE	PRELOAD TORQUE = $T_1 + T_2$								STATIC PRESSURE TORQUE PER PSI T_3	
	T_1			T_2					316 M.S.	REXNORD
	A	B	C	E	F	G	H	J		
.....
3"	302	28	227	122	73	61	244	280	0.24	.16
4"	338	31	254	218	131	109	436	501	0.50	.33
6"	454	42	340	510	306	255	1020	1173	1.56	1.04
8"	529	49	397	902	541	451	1804	2074	3.23	2.15
10"	680	63	510	1398	839	699	2796	3215	6.44	4.29
12"	756	70	567	1972	1183	986	3944	4535	10.10	6.73
14"	832	77	624	2424	1454	1212	4848	5575	13.66	9.11
16"	907	84	680	3164	1898	1582	6328	7277	19.44	12.96
18"	1058	98	794	3994	2396	1997	7988	9186	28.64	19.09
20"	1210	112	907	4914	2948	2457	9828	11302	40.28	26.85
24"	1512	140	1134	7564	4538	3782	15128	17397	77.48	51.65
30"	1814	168	1361	11982	7189	5991	23964	27558	147.28	98.19
36"	2268	210	1701	17426	10456	8713	34852	40080	267.76	178.51
42"	2419	672	1814	23795	14277	11897	47590	54728	390.00
48"	2722	756	2041	30864	18518	15432	61728	70987	569.00
54"	2722	756	2041	39849	23909	19924	79698	91653	734.70
60"	3024	840	2268	49280	29568	24640	98561	113345	1010
66"	3326	924	2495	59937	35962	29969	119875	137856	1351
72"	3629	1008	2722	71355	42813	35677	142709	164115	1754

CLASS 150 150PSI RATING

VALVE SIZE	PRELOAD = $T_1 + T_2$								STATIC PRESSURE TORQUE PER PSI T_3	
	T_1			T_2					316 M.S.	REXNORD
	A	B	C	E	F	G	H	J		
24"	1210	112	907	7194	4316	3597	14388	16546	58.96	39.31
30"	1512	140	1134	12038	7223	6019	24076	27687	123.32	82.21
36"	1663	154	1247	17420	10452	8710	34840	40066	196.28	130.85
42"	1966	546	1474	23846	14308	11923	47693	54847	317.50
48"	2268	630	1701	31069	18642	15535	62139	71460	477.30
54"	2268	630	1701	39849	23909	19924	79698	91653	612.12
60"	2268	630	1701	49484	29691	24742	98969	113814	760.30
66"	3024	840	2268	59937	35962	29969	119875	137856	1228
72"	3024	840	2268	71661	42997	35830	143322	164820	1468

Valve torque (opening) = $T_1 + T_2 + (T_3 \times \text{PSI} \Delta P)$

Valve torque (closing, on-off service) = $T_1 + T_2 + (.5T_3 \times \text{PSI} \Delta P)$

Valve torque (closing, modulating service) = $T_1 + T_2 + (T_3 \times \text{PSI} \Delta P)$

When the operating ΔP used for actuator selection is less than the maximum line pressure, contact the factory for sizing torque.

NOTES:

- T_1 (A) Asbestos jam packing
- (B) Teflon Chevron packing
- (C) Graphite jam packing
- T_2 (E) Urethane seal ring with rubber back-up ring, Metal seal ring with and without rubber back-up ring, Kel-F seal ring without rubber back-up ring
- (F) Teflon seal ring with Teflon back-up ring, Tefzel seal ring with rubber back-up ring
- (G) Teflon seal ring with rubber back-up ring
- (H) Metal seal ring with Teflon insert and rubber back-up ring
- (J) Metal seal ring with urethane, Tefzel, or Kel-F insert and rubber back-up ring



TABLE 2
CLASS 300 STD. RATING

VALVE SIZE	PRELOAD TORQUE = T ₁ + T ₂								STATIC PRESSURE TORQUE PER PSI T ₃	
	T ₁			T ₂					316 M.S.	REXNORD
	A	B	C	E	F	G	H	J		
.....
3"	302	28	227	122	73	61	244	280	0.24	.16
4"	338	31	254	218	131	109	436	501	0.50	.33
6"	454	42	340	510	306	255	1020	1173	1.56	1.04
8"	756	70	567	750	450	375	1500	1725	3.84	2.56
10"	907	84	680	1242	745	621	2484	2857	7.64	5.09
12"	1058	98	794	1722	1063	886	3544	4076	12.70	8.47
14"	1210	112	907	2160	1296	1080	4321	4968	17.71	11.81
16"	1361	126	1021	3164	1898	1582	6328	7277	29.16	19.44
18"	1512	140	1134	3602	2161	1801	7204	8285	36.90	24.60
20"	1814	168	1361	4534	2720	2267	9068	10428	55.74	37.16
24"	2117	196	1588	7564	4538	3782	15128	17397	108.46	72.31
30"	2722	252	2041	10764	6458	5382	21528	24757	198.45	132.30
36"	3024	280	2268	16278	9767	8139	32556	37439	333.46	222.31
42"	3175	294	2381	23402	14041	11701	46804	53825	503.30
48"	4234	392	3175	30383	18230	15192	60766	69881	871.40

Valve torque (opening) = T₁ + T₂ + (T₃ × PSIΔP)

Valve torque (closing, on-off service) = T₁ + T₂ + (.5T₃ × PSIΔP)

Valve torque (closing, modulating service) = T₁ + T₂ + (T₃ × PSIΔP)

When the operating ΔP used for actuator selection is less than the maximum line pressure, contact the factory for sizing torque.

NOTES:

- T₁ (A) Asbestos jam packing
(B) Teflon Chevron packing
(C) Graphite jam packing

- T₂ (E) Urethane seal ring with rubber back-up ring, Metal seal ring with and without rubber back-up ring, Kel-F seal ring without rubber back-up ring
(F) Teflon seal ring with Teflon back-up ring, Tefzel seal ring with rubber back-up ring
(G) Teflon seal ring with rubber back-up ring
(H) Metal seal ring with Teflon insert and rubber back-up ring
(J) Metal seal ring with urethane, Tefzel, or Kel-F insert and rubber back-up ring



TABLE 3
TORQUE VALUES (In. Lbs.)
Class 600 Posi-Seal Trunnion Valves

VALVE SIZE	PRELOAD TORQUE ($T_1 + T_2$)									STATIC PRESSURE TORQUE PER PSI T_3	
	T_1				T_2					316 M.S.	REXNORD
	A	B	C	D	E	F	G	H	J		
3"	342	AVAILABLE ON APPLICATION	257	95	120	72	NOT AVAILABLE IN CLASS 600	AVAILABLE ON APPLICATION	276	0.27	.18
4"	454		340	126	202	121			465	0.63	.42
6"	529		397	147	496	298			1141	1.77	1.18
8"	907		680	252	770	462			1771	4.73	3.15
10"	1058		794	294	1234	750			2838	8.85	5.9
12"	1361		1021	378	1724	1034			3965	15.89	10.59
14"	1512		1134	420	2078	1247			4779	21.29	14.19
16"	1814		1361	504	2698	1619			6205	33.17	22.11
18"	2117		1588	588	3532	2119			8124	50.64	33.76
20"	2419		1814	672	4238	2543			9747	69.4	46.27
24"	2722		2041	756	6422	3853			14770	118.4	78.93

Valve torque (opening) = $T_1 + T_2 + (T_3 \times \text{PSI} \Delta P)$

Valve torque (closing, on-off service) = $T_1 + T_2 + (.5T_3 \times \text{PSI} \Delta P)$

Valve torque (closing, modulating service) = $T_1 + T_2 + (T_3 \times \text{PSI} \Delta P)$

When the operating ΔP used for actuator selection is less than the maximum line pressure, contact the factory for sizing torque.

NOTES:

- T_1 (A) Asbestos jam packing
 (B) Teflon Chevron packing – available on application
 (C) Graphite jam packing
 (D) Teflon jam packing
- T_2 (E) Metal seal ring with and without rubber back-up ring, Kel-F ring without rubber back-up ring
 (F) Tefzel seal ring with rubber back-up ring
 (G) Not available on Class 600
 (H) Metal seal ring with Teflon insert and rubber back-up ring – available on application
 (J) Metal seal ring with Tefzel, or Kel-F insert and rubber back-up ring (urethane insert available on application)



TOTAL VALVE OPERATING HYDRODYNAMIC TORQUE

As previously stated the valve opening torque is normally the highest operating torque used for actuator sizing and selection. However, when flowing liquids, it is often necessary to calculate the total valve operating hydrodynamic torque.

The location of the maximum valve operating torque (total hydrodynamic torque) is a result of the overall system operating parameters in addition to the particular valve disc hydrodynamic torque characteristics.

When the ratio of thru valve ΔP to total system ΔP is high, generally above 25 percent, the maximum valve operating hydrodynamic torque will occur at or about the 70° to 80° disc open position. As this ratio decreases, the maximum valve operating hydrodynamic torque will shift towards the 0° shut position.

To allow for system operating variables it is recommended that the maximum valve operating hydrodynamic torque (TH_T) be calculated at both the 20° and 80° disc open position.

The total valve operating hydrodynamic torque (TH_T) is the summation of three torque components. These components are: stem packing torque (T_1), stem bearing friction torque (static pressure torque per $PSI\Delta P$) and the disc hydrodynamic lift and drag torque. Torque values T_1 and T_3 can be found in Tables 1 thru 3.

Extensive flow testing has shown that the disc hydrodynamic lift and drag torque values are dependent upon the direction of flow entering the valve. With liquid flow entering the valve from the stem side, with the seal retaining downstream, the disc hydrodynamic lift and drag torque value (T_4) is positive to the full open position acting to return the disc to the shut position. Liquid flow entering the valve from the opposite direction, seal retaining ring up stream, results in a torque value that remains positive, acting to return the disc to the shut position, until about the 70° to 80° open position. At this point the torque value becomes negative acting to move the disc to the full open position. With liquid flow in this direction the disc hydrodynamic lift and drag torque values are designated as T_5 . Also, test results have shown that flowing liquids in this direction results in a positive T_5 value that is lower than the corresponding T_4 value with flow in opposite direction.



By utilizing torque values T_1 and T_3 along with the applicable disc hydrodynamic lift and drag torque values T_4 or T_5 listed in Tables 4 thru 9, the total valve operating hydrodynamic torque TH_T can be calculated as follows:

RETAINING RING DOWNSTREAM

$$TH_T = T_1 + (T_3 \Delta P) + (T_4 \Delta P) G_f$$

RETAINING RING UPSTREAM

$$TH_T = T_1 + (T_3 \Delta P) + (T_5 \Delta P) G_f$$

TH_T = Total valve operating hydrodynamic torque, in. lbs.

T_1 = Packing torque, in. lbs. Tables 1, 2, and 3.

T_3 = Stem bearing friction torque (static pressure torque per $PSI \Delta P$), in. lbs. Tables 1, 2, and 3.

T_4 = Disc hydrodynamic lift and drag torque, in. lbs. Flow into valve with retaining ring downstream.

T_5 = Disc hydrodynamic lift and drag torque, in. lbs. Flow into valve with retaining ring upstream.

ΔP = Differential pressure across valve, PSI.

G_f = Specific gravity of liquid at flowing conditions.

G_r = $\frac{\text{Density of liquid at flowing conditions}}{\text{Density of water at standard conditions}}$

EXAMPLE:

A. Requirement — What is the total valve hydrodynamic torque of a 12" CLASS 150 Valve with teflon chevron packing, flowing water into the valve from the stem side (retaining ring downstream) with a calculated ΔP of 10 PSI at the 70° disc open position.

B. Solution —

$$TH_T = T_1 + (T_3 \Delta P) + (T_4 \Delta P) G_f$$

$$TH_T = 70 + [10.10 (10)] + [692 (10)] 1.0$$

$$TH_T = 7091 \text{ in. lbs.}$$

Where —

$$T_1 = 70 \text{ in. lbs.}$$

$$T_3 = 10.10 \text{ in. lbs.}$$

$$T_4 = 692$$

$$G_f = 1.0$$

NOTE:

When in doubt about the maximum total valve hydrodynamic torque for a specific application, contact Posi-Seal factory for assistance.



TABLE 4

CLASS 150 STD RATING

Seal Retaining Ring Downstream
Disc Hydrodynamic Lift & Drag Torque - T_4

VALVE SIZE	T_4 VS. OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
.....
3"	0	0	0	0	1	2	5	6	5
4"	0	0	1	1	3	6	12	16	13
6"	1	2	4	8	13	27	51	68	56
8"	4	10	16	30	49	100	185	247	204
10"	6	16	26	49	79	161	300	399	330
12"	15	38	60	114	182	372	692	920	761
14"	23	59	94	177	283	579	1075	1430	1182
16"	41	102	164	307	492	1005	1876	2482	2052
18"	64	162	259	486	778	1590	2953	3927	3245
20"	99	248	397	746	1193	2437	4526	6019	4974
24"	214	536	858	1610	2576	5259	9768	12988	10734
30"	462	1156	1850	3469	5551	11334	21049	27988	23131
36"	1884	4710	7537	14132	22611	46164	85734	113998	94213
42"	2281	5704	9127	17114	27383	55908	103829	138058	114098
48"	3265	8164	13063	24494	39191	80016	148602	197592	163299
54"	7388	18471	29554	55414	88662	181020	336180	447008	369428
60"	11165	27913	44661	83740	133984	273552	508026	675506	558270
66"	14942	37355	59768	112066	179306	366084	679972	904005	747112
72"	22995	57488	91981	172465	275945	563388	1046293	1391225	1149773
CLASS 150 150 PSI RATING									
24"	255	637	1020	1913	3061	6251	11609	15437	12758
30"	857	2144	3431	6433	10293	21016	39030	51897	42890
36"	1792	4480	7168	13441	21505	43907	81542	108424	89607
42"	3202	8007	12811	24021	38434	78469	145729	193772	160142
48"	5412	13530	21648	40591	64946	132598	246254	327437	270609
54"	7336	18341	29346	55025	88040	179749	333820	443871	366835
60"	14428	36072	57715	108216	173146	353506	656512	872945	721442
66"	14942	37355	59768	112066	179306	366084	679972	904005	747112
72"	30124	75310	120496	225931	361490	738044	1370653	1822516	1506212

1. T_4 values = in. lbs. per PSIΔP.
2. All T_4 values are positive acting to shut valve.
3. 0 T_4 values $\cong < 1$.



TABLE 5

CLASS 150 STD. RATING

Seal Retaining Ring Upstream
Disc Hydrodynamic Lift & Drag Torque - T_s


VALVE SIZE	T_s VS. DISC OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
.....
3"	0	0	0	0	0	1	1	0	-5
4"	0	0	0	0	1	3	4	0	-13
6"	0	1	2	2	5	13	19	-1	-56
8"	2	4	8	10	18	46	69	-4	-204
10"	3	6	13	16	29	75	112	-6	-330
12"	7	15	30	38	68	175	258	-15	-761
14"	11	23	47	59	106	271	402	-23	-1182
16"	20	41	82	102	184	471	697	-41	-2052
18"	32	64	129	162	292	746	1103	-64	-3245
20"	49	99	198	248	447	1144	1691	-99	-4974
24"	107	214	429	536	966	2468	3649	-214	-10734
30"	231	462	925	1156	2081	5320	7864	-462	-23131
36"	942	1884	3768	4710	8479	21669	32032	-1884	-94213
42"	1140	2281	4563	5704	10268	26242	38793	-2281	-114098
48"	1632	3265	6531	8164	14696	37558	55521	-3265	-163299
54"	3694	7388	14777	18471	33248	84968	125605	-7388	-369429
60"	5583	11165	22330	27913	50244	128402	189812	-11165	-558270
66"	7471	14942	29884	37355	67240	171835	254018	-14942	-747112
72"	11497	22995	45990	57488	103479	264447	390922	-22995	-1149773
CLASS 150 150 PSI RATING									
24"	127	255	510	637	1148	2934	4337	-255	-12758
30"	428	857	1715	2144	3860	9864	14582	-857	-42890
36"	896	1792	3584	4480	8064	20609	30466	-1792	-89607
42"	1601	3202	6405	8007	14412	36832	54448	-3202	-160142
48"	2706	5412	10824	13530	24354	62240	92007	-5412	-270609
54"	3668	7336	14673	18341	33015	84372	124724	-7336	-366835
60"	7214	14428	28857	36072	64929	165931	245290	-14428	-721442
66"	7471	14942	29884	37355	67240	171835	254018	-14942	-747112
72"	15062	30124	60248	75310	135559	346428	512112	-30124	-1506212

T_s values = in. lbs. per PSI Δ P.

- Except as noted, T_s values are positive acting to shut valve.
- Negative (-) T_s values act to move the disc to the full open (90°) position.
- 0 T_s values \cong < 1.



TABLE 6
CLASS 300 STD RATING



Seal Retaining Ring Downstream
Disc Hydrodynamic Lift & Drag Torque - T_d


VALVE SIZE	T_d VS. DISC OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
.....
3"	0	0	0	0	1	2	5	6	5
4"	0	0	1	1	3	6	12	16	13
6"	1	2	4	8	13	27	51	68	56
8"	1	4	7	11	21	34	57	81	68
10"	3	9	17	27	51	81	136	192	162
12"	7	21	39	60	113	179	298	422	355
14"	9	29	54	84	158	250	416	590	495
16"	12	37	68	105	198	313	520	737	620
18"	28	86	158	244	460	726	1208	1711	1438
20"	30	92	169	261	493	778	1294	1833	1540
24"	41	125	229	355	668	1054	1754	2485	2088
30"	143	429	788	1218	2292	3618	6019	8526	7165
36"	287	861	1579	2441	4596	7253	12065	17092	14363
42"	686	2058	3773	5381	10976	17321	28812	40817	34300
48"	429	1287	2359	3646	6864	10832	18018	25526	21451

1. T_d values = in. lbs. per PSIΔP.
2. All T_d values are positive acting to shut valve.
3. 0 T_d values $\cong < 1$.



TABLE 7

CLASS 300 STD RATING



Seal Retaining Ring Upstream
Disc Hydrodynamic Lift & Drag Torque - T_s


VALVE SIZE	T_s VS. DISC OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
.....
3"	0	0	0	0	0	1	1	0	-5
4"	0	0	0	0	1	3	4	0	-13
6"	0	1	2	2	5	13	19	-1	-56
8"	0	1	2	6	8	10	4	-22	-68
10"	1	3	6	14	21	24	11	-53	-162
12"	3	7	14	31	46	53	24	-117	-355
14"	4	9	19	44	64	74	34	-163	-495
16"	6	12	24	55	80	93	43	-204	-620
18"	14	28	57	129	187	215	100	-474	-1438
20"	15	30	61	138	200	231	107	-508	-1540
24"	20	41	83	187	271	313	146	-689	-2088
30"	71	143	286	644	931	1074	501	-2364	-7165
36"	143	287	574	1292	1867	2154	1005	-4739	-14363
42"	343	686	1372	3087	4459	5145	2401	-11319	-34300
48"	214	429	858	1930	2788	3217	1501	-7078	-21451

1. T_s values = in. lbs. per PSI Δ P.
2. Except as noted, T_s values are positive acting to shut valve.
3. Minus T_s values are negative and act to move the disc to the full open (90°) position.
4. 0 T_s values $\cong < 1$.



TABLE 8

CLASS 600 STD RATING



Seal Retaining Ring Downstream
Disc Hydrodynamic Lift & Drag Torque - T_d


VALVE SIZE	T_d VS. DISC OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
3"	0	0	0	0	0	0	0	0	0
4"	0	0	0	0	0	0	0	0	0
6"	0	1	3	3	6	8	13	14	13
8"	0	5	10	12	19	27	44	46	43
10"	1	13	26	29	48	67	107	112	105
12"	1	20	38	43	71	99	158	165	154
14"	2	27	52	58	96	133	213	223	208
16"	2	36	69	78	128	178	284	298	279
18"	3	43	83	93	153	214	341	358	334
20"	3	41	79	88	146	203	324	340	317
24"	12	166	319	357	587	818	1303	1367	1278

1. T_d values = in. lbs. per PSI Δ P.
2. All T_d values are positive acting to shut valve.
3. 0 T_d values $\cong < 1$.



TABLE 9

CLASS 600 STD RATING



Seal Retaining Ring Upstream
Disc Hydrodynamic Lift & Drag Torque - T_s

VALVE SIZE	T_s VS. DISC OPEN POSITION								
	10°	20°	30°	40°	50°	60°	70°	80°	90°
3"	0	0	0	0	0	0	0	0	0
4"	0	0	0	0	0	0	0	0	0
6"	0	0	1	2	3	2	0	-6	-13
8"	0	2	3	8	9	9	-2	-22	-43
10"	1	5	9	21	24	22	-6	-55	-105
12"	1	7	13	30	35	32	-9	-82	-154
14"	2	10	18	41	48	43	-12	-110	-208
16"	2	13	25	55	64	58	-16	-147	-279
18"	3	16	30	66	76	70	-20	-177	-334
20"	3	15	28	63	73	66	-19	-168	-317
24"	12	63	115	255	293	268	-76	-677	-1278

1. T_s values = in. lbs. per $\text{PSI}\Delta P$.
2. Except as noted, T_s values are positive acting to shut valve.
3. Negative (-) T_s values act to move the disc to the full open (90°) position.
4. 0 T_s values $\cong < 1$.

III. AERODYNAMIC TORQUE

Aerodynamic torque resulting from gaseous flow is negligible compared to Hydrodynamic torque. However, when in doubt concerning a specific application (such as applications where flow is sonic) consult the factory.

IV. ACTUATOR SELECTION

Published torque values for Posi-Seal Trunnion Valves include adequate safety factors and do not require additional safety factors. However, when sizing actuators for specific valve torque requirements, decrease the published actuator torques by at least 10% to allow for a realistic safety factor in actuator selection. When selecting fail safe actuators, the torque output at the end of the actuator spring stroke (ending torque) should be used as the basis for actuator selection. When the operating ΔP used for actuator selection is less than maximum line pressure, contact the factory for sizing torque.

