



Duquesne Light

Nuclear Construction Division
Robinson Plaza, Building 2, Suite 210
Pittsburgh, PA 15205

2NRC-5-006

(412) 787-5141

(412) 923-1960

Telecopy (412) 787-2629

January 15, 1985

United States Nuclear Regulatory Commission
Washington, DC 20555

ATTENTION: Mr. George W. Knighton, Chief
Licensing Branch 3
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2
Docket No. 50-412
Fracture Prevention of Containment Boundary (GDC-51)

Gentlemen:

Mr. B. K. Singh has recently informed Duquesne Light Company (DLC) that Attachments I and II to DLC letter 2NRC-3-087 from Mr. E. J. Woolever to Mr. H. R. Denton, dated November 14, 1983, are missing from the records. In accordance with Mr. Singh's request, attached is a copy of both of these attachments.

Mr. Singh has also informed DLC that the MTEB Reviewer, Mr. J. Halapatz, has indicated that GDC 51 is satisfied and that there are no related SER Open Items. This submittal of Attachments I and II is accordingly only for record purposes.

DUQUESNE LIGHT COMPANY

By E. J. Woolever
E. J. Woolever
Vice President

JJS/wjs
Attachment

cc: Mr. B. K. Singh, Project Manager (w/a)
Mr. G. Walton, NRC Resident Inspector (w/a)

8501210084 850115
PDR ADDCK 05000412
A PDR

Boo

TECHNICAL SUMMARY GDC-51
BEAVER VALLEY POWER STATION - UNIT 2
DUQUESNE LIGHT COMPANY

J.O. No. 12241

1. Lowest Service Metal Temperature

The lowest service metal temperature (LSMT) for appurtenances of the containment liner, equipment hatch, and personnel airlock is identified as +70°F during normal operating maintenance.

The LSMT for the main steam piping and valve is 120°F and the feed-water piping and valves is 120°F. The LSMT in this evaluation applies during hot hydrostatic testing. The 120°F is a minimum value for hot hydrotest of the system and the actual test temperature would be higher to assure that the minimum is not violated.

2. Containment Pressure Boundary Materials

The materials of the containment pressure boundary reviewed within the context of GDC51 were:

a. Equipment Hatch; Personnel Airlocks

Equipment hatch bolt flange, 5 1/2 in. SA 516 Gr. 60 normalized, is identified as a limiting material. Summer 1977 addenda of ASME Class 2 rules would assign as Tndt of 0°F and an LPSMT of +58°F. However, CMTR indicates that the material was DWT tested to a measured NDT of -10°F, which would assign a lowest permissible service metal temperature (LPSMT) of +48°F to the material, allowing adjustment for thickness.

Personnel airlock head ring, 5 1/2 in. SA516 Gr 70 quenched and tempered, is identified as a limiting material. CMTR indicates that the material was DWT tested to a measured NDT of -10°F. Summer 1977 addenda of ASME Class 2 rules would assign an LPSMT of +48°F to the material, allowing adjustment for thickness.

b. Sleeves

(1) SA 333 Gr. 6 is applied in penetration sleeves with a max wall of 0.937 in., (18 in. electrical penetration). CMTR indicates that the material was normalized and DWT tested to a measured Tndt of -10°F. Summer 1977 addenda of ASME Class 2 rules would assign an LPSMT of +20°F to the material.

(2) SA 155 KCF60, 1/2 in. thick, (pens. 90 and 91) is exempted from testing as the material is less than 5/8 in. in thickness.

(3) SA 537 Cl. 2, 1 1/4 wall thickness (pens 73, 74, 75) is identified as a limiting material. CMTR indicates the material was quenched and tempered and DWT tested to a measured Tndt of -10°F. Summer 1977 addenda of ASME Class 2 rules would assign an LPSMT of +20°F to the material.

c. Flued Heads

SA 508 Class 1, max axial thickness of 9 in. main steam, is identified as a limiting material. CMTR indicates that the material was normalized and quenched and tempered and DWT tested to a measured Tndt of -30°F. Summer 1977 addenda Class 2 rules would assign an LPSMT of +45°F to the material allowing adjustment for thickness.

SA 508 Class 1, max axial thickness of 7 in. feedwater, is identified as a limiting material. CMTR indicates that the material was DWT tested to a measured Tndt of -40°F. Summer 1977 addenda Class 2 rules would assign an LPSMT of +27°F, allowing adjustment for thickness.

d. Process Pipe

Process pipes are integral with flued head forgings in flued head penetrations.

Process pipes, penetrating and welded to liner, were reviewed as sleeves with max wall of .432 in.

e. Multiple Penetration Header Plate

Limiting material is identified as SA 350 Gr. LF2, 2 1/4 in. thickness. CMTR indicates that the material was quenched and tempered and DWT tested to a measured Tndt of -10°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +20°F to the material.

f. Main Steam/Main Feedwater Systems

- (1) Main Steam System (MK MSS 169/170/171-1
169/170/171-3)

Piping:

SA106, 30 in. x 1.875 in. wall, by Cameron, normalized with no CVN. NUREG 0577 Fig. B.7, given that the material normalized, would place the Tndt in that population at or below the Table 4.4 NDT of +40°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +70°F to the material.

Fittings: (MK MSS 169/170/171-2 TYP)

Tee: SA234 WPCW, 30 in. x 1.875 in. minimum wall, applying SA106 Gr. C fittings quenched and tempered no CVN. NUREG 0577 Fig. B.7 would assign the material a Tndt in that population below +40°F (Table 4.4). Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +70°F to the material.

Bosses: SA105, normalized, -2 1/2 in. max thickness typical. NUREG 0577 Table 4.4 assigns a (NDT +1.3T)NDT of -5°F. Summer 1977 Addenda ASME Class 2 rules would assign an LPSMT of +25°F.

Headers(Relief Valve) MSS 105/106/107-1

SA106 Gr C, 35.945 nominal OD x 30.000 in. minimum I.D. x 2.750 in. wall by Cameron, normalized. NUREG 0577 Fig. B.7 would assign an NDT in that population at or below 40°F of Table 4.4, given that the material is normalized. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +75°F, allowing adjustment for thickness.

Header Cap:

SA234 WPC, 36 in. OD x 2.75 in. minimum wall, applying SA106 Gr.C with no CVN normalized. NUREG 0577 Fig. B.7 would assign an NDT in that population at or below +40°F of Table 4.4. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +75°F, allowing adjustment for thickness.

Header W/N Flanges

SA105, 6 in. x 1500 lb, normalized per CMTR. NUREG 0577 Table 4.4 assigns a (NPT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +30°F.

Main Steam Isolation Valve (HYV-101A/B/C)

Body: SA350 Gr. LF2: normalized, quenched, and tempered with a 2.28 in. minimum design thickness. NUREG 0577 Table 4.4 would assign a Tndt in the population below -28°F, given that the material was quenched and tempered. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +19°F, allow adjustment for thickness.

Bonnet: SA350 Gr. LF2, normalized, quenched, and tempered, 6.5 in. minimum design thickness. NUREG 0577 Table 4.4 would assign a Tndt in the population below -25°F, given that the material was quenched and tempered. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +37°F, allowing adjustment for thickness.

Ball: Exempt - fabricated from austenitic stainless steel

Bolting: NA

Reducers: Ht216492 also applied for the bonnet, thus the reducers have the same heat treat as bonnet. The minimum design thickness is 1 7/8 in. Therefore the bonnet is limiting.

(2) Main Feedwater (105/106/107-1)

Pipe: SA106 Gr. C, 16 in. Sch. 80 (0.843 in. wall thickness) by Phoenix Steel. No heat treat nor CVN. However, Phoenix practice (as developed from Salem 2 review) discharges pipe to cooling at or above AR₃. Material can reasonably be characterized as normalized. NUREG 0577, Fig. B.7 would assign the material a NDT in that population at or below the NDT of +40°F of Table 4.4. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +70°F.

Fittings

Fittings: 3/4, 1 1/2, and 2 in. X3000 lb socket weld bosses of SA105 normalized with a wall thickness less than 2 1/2 in. NUREG 0577 Table 4.4 assigns a (NDT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +25°F.

Feedwater Check Valve (VCW-06082V305/306/307)

Body: SA 216 Gr WCB, 1.094 in. minimum wall design thickness, normalized, and tempered. NUREG 0577 Fig. B.2 data would locate the Tndt of the material in the population at or below the Table 4.4 NDT of +35°F, taking into account the size effort. Summer 1977 addenda, ASME Class 2 rules would assign an LPSMT of +65°F.

Disc: SA 216 Grade WCB, less than 2 1/2 thick, normalized and tempered. LPSMT same as as check valve body.

Cover: SA 515 Gr. 70, 3 1/2 in. thick, normalized. NUREG 0577 Fig. B.7 data would locate the Tndt in the Table 4.4 population above the NDT. Assuming a (NDT +1.3T) NDT of +77°F, Summer 1977 Addenda, ASME Class 2 rules would assign an LPMST of +122°F, allowing adjustment for thickness.

Bolts and Nuts: The bolts and nuts used in assembly of the check valve are SA-193 B7 and SA-194 2H respectively. NUREG 0577 Table 4.6 categorizes the material as having the least susceptibility to brittle fracture.

Feedwater Islation Valve (2FWS-HYV157 A/B/C)

Body: SA 105, 22 1/2 in. dia x 1.008 in. wall, normalized. NUREG 0577 Table 4.4 assigns a (NDT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +25°F.

Bonnet: SA 105, 2.935 in. in thickness, normalized. NUREG 0577 Table 4.4 assigns a (NDT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +35°F, allowing adjustment for thickness.

Neck: SA 105, 1.015 in. in thickness, normalized. NUREG 0577 Table 4.4 assigns a (NDT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPMST of +25°F.

Retainer: SA 105, less than 2 1/2 in. in thickness, normalized. NUREG 0577 Table 4.4 assigns a (NDT +1.3T) NDT of -5°F. Summer 1977 addenda ASME Class 2 rules would assign an LPSMT of +25°F.

Gate: SA 351 Gr. CF8M, 10 in. x 1500 lb gate, casting. This is an austenitic stainless steel material and exempt from testing.

GDC-51 Fracture Prevention of Containment Pressure Boundary (Criterion 51)

Component System	Item (In)	Thick. (In)	Material	Heat Treatment	Impact Type	Nureg 0577	NDTT (°F)	LPMST (°F)	LMST (°F) See Note
Equip. Hatch	Bolt Flange	5 $\frac{1}{2}$	SA 516 GR 60	Normalized	DWT -10°F	NA	-10	+48	+70
Personnel Air Lock	Head Ring	5 $\frac{1}{2}$	SA 516 GR 70	Quenched Tempered	DWT -10°F	NA	-10	+48	+70
Sleeves	Elect. Pent. 18".	0.937	SA 333 GR 6	Normalized	DWT -10°F	NA	-10	+20	+70
	Pen 90 & 91	0.500	SA 155 KCF 60	Exempt - less than 5/8" wall thickness					
	Pen. 73 74, 75	2 $\frac{1}{4}$	SA 537 CL 2	Quenched & Tempered	DWT -10°F	NA	-10	+20	+70
Flued Heads	Main Steam	9(axial)	SA 508 CL 1	Normalized Quenched Tempereid	DWT -30°F	NA	-30	+45	+70
	Feed Water	7(axial)	SA 508 CL 1	Normalized Quenched Tempered	DWT -40°F	NA	-40	+27	+70
Process		Integral with flued heads - see flued heads							
	Welded	0.432	(See Electrical Penetration for limiting Case)						
Multiple Penetration	Header Plate	2 $\frac{1}{2}$	SA 350 GR LF2	Quenched Tempered	DWT -10°F	NA	-10	+20	+70
Main Steam	Piping	1.875	SA 106 GR C	Normalized	NA	Fig.B.7 Table 4.4	+40	+70	+120
	Tee Fitting	1.875	SA 234 WPCW	Quenched Tempered	NA	Fig.B.7 Tbl.4.4	+40	+70	+120
	Boss Fitting	2 $\frac{1}{2}$ Max.	SA 105	Normalized	NA	Tbl.4.4	-5	+25	+120

GDC-51 Fracture Prevention of Containment Pressure Boundary (Criterion 51)

Component System	Item (In)	Thick. (In)	Material	Heat Treatment	Impact Type	Nureg 0577	NDTT (°F)	LPMST (°F)	LMST (°F) See Note
Main Steam (Cont)	Header (Relief Valve)	2.75	SA 106 GR. C	Normalized	NA	Fig.B.7 Tbl 4.4	+40	+75	+120
	Header Cap	2.75	SA 234 WPC	Normalized	NA	Fig.B.7 Tbl 4.4	+40	+75	+120
	Header Weld Neck Flange	3.25	SA 105	Normalized	NA	Tbl 4.4	-5	+30	+120
	Isolation Valve Body	2.28	SA 350 GR. LF2	Normalized Quenched Tempered	NA	Tbl 4.4	-28	+19	+120
	Isolation Bonnet	6.5	SA 350 GR LF2	Normalized Quenched Tempered	NA	Tbl 4.4	-25	+37	+120
	Isolation Valve Ball			Exempt - fabricated from austenitic stainless steel					
	Isolation Valve Reducers	1 7/8		Same heat as bonnet, therefore bonnet is limiting					
Main Feed Water	Piping	0.843	SA 106 GR. C.	Normalized	NA	Fig.B.7 Tbl 4.4	+40	+70	+120

GDC-51 Fracture Prevention of Containment Pressure Boundary (Criterion 51)

Component System	Item (In)	Thick. (In)	Material	Heat Treatment	Impact Type	Nureg 0577	NDTT (°F)	LPMST (°F)	LMST (°F) See Note
Main Feed Water	Fitt - ings	2 $\frac{1}{4}$ max.	SA 105	Normalized	NA	Tbl4.4	-5	+25	+120
	Check Valve Body	1.094	SA 216 GR WCB	Normalized Tempered	NA	Fig.B.2 Tbl4.4	+35	+65	+120
	Check Valve Disc	2 $\frac{1}{4}$ max	SA 216 GR 70	Normalized	NA	Fig.B.2 Tbl4.4	+35	+65	+120
	Check Valve Cover	3 $\frac{1}{4}$ max.	SA 515 GR 70	Normalized	NA	Fig.B.7 Tbl4.4	+77	+122	+120
	Check Valve Bolts & Nuts	1 3/8 max.	SA 193 B7 SA 194 2H	NA	NA	Tbl4.4	Least Susceptibility to Failure		
	Isolation Body	1.008	SA 105	Normalized	NA	Tbl4.4	-5	+25	+120
	Isolation Valve Bonnet	2.935	SA 105	Normalized	NA	Tbl4.4	-5	+35	+120
	Isolation Neck	1.015	SA 105	Normalized	NA	Tbl4.4	-5	+25	+120
	Isolation Valve Retainer	Less than 2 $\frac{1}{4}$	SA 105	Normalized	NA	Tbl4.4	-5	+25	+120

GDC-51 Fracture Prevention of Containment Pressure Boundary (Criterion 51)

Attachment II

INDEX OF CMTR's

<u>Section</u>	<u>Item</u>
1.	Equipment Hatch
2.	Personnel Air Lock
3.	Sleeve Electrical Pen. 18"
4.	Sleeve Pen. 73,74,75
5.	Flued Heads Main Steam
6.	Flued Heads Feed Water
7.	Multiple Penetration Header Plate
8.	Main Steam Piping
9.	Main Steam Tee Fitting
10.	Main Steam Boss Fitting/Header/Header Cap/ Header Weld Neck Flange
11.	Main Steam Isolation Valve Body/Bonnet/ Valve Ball/Valve Reducers
12.	Main Feed Water Piping/Fittings
13.	Main Feed Water Check Valve Body/Disc/Cover
14.	Main Feed Water Isolation Valve Body/Bonnet/ Neck/Retainer

SECTION 1

(U.S.)

Un States Steel Corporation

131 71

ID - 6010

TEST REPORT OF

HOHSTEAD DISTRICT

USS ORDER NO LA16610

LOAD TALLY OR
INVOICE NO 163-29945

US CIVIL ORDER NO 214 1/30/74

CAR OR TRUCK NO PLE 009506

SHIPPER NO. & DATE 54060 10/30/74

160

PITTSBURGH DES MOINES STEEL CO
NEVILLE ISLAND BRANCH
PITTSBURGH PA 15225TO
SHIP
PITTSBURGH DES MOINES STEEL CO
NEVILLE ISLAND PAASME SA-510 WINTER 1972 ADDENDA GRADE 50 PR V9 TO POM SPEC HS-7
2012 UTD 12/7/73 NORM XAC UEGAS DWT NO BREAK @ 10 LONG ULTRAS
CHIC INSPECT SA-578 LEVEL I, 100% SCAN. ADDL SET TEST NORM STR RELWILL CERT T/H ANALYSIS TEST RESULTS PER SPEC 3 T/R TO SOLD TO
LITH ANN KIESE INCL CUST SPECNTHIS REPORT HAS BEEN CHECKED AND FOUND
TO COMPLY WITH APPLICABLE SPECIFICATIONS

Signed

John B. Ravello Date 3-20-75

WE HEREBY CERTIFY
THAT THE CHEMICAL ANALYSIS
AND 608 TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CHA-
TAINED IN THE RECORDS OF
THE COMPANY.

SIGNATURE H. W. MAXSON, CH. MET.

012121

DATE 10/30/74

0604

NO	HEAT NO	TEST OR PRICE IDENTITY NO.	MATERIAL DESCRIPTION					YIELD PT. PSI.	TENSILE STR. PSI.	ELONGATION %		E. RED OF AREA
			NO. PCN	THICKNESS OR SECTION	WIDTH, DIAM. OR FT. WT.	LENGTH	WEIGHT			IN B	IN 2	
01	5H7457	215349 **BC ***BC	1	6.0000	96	176	28720	• 39.6 • 41.1	71.3 67.7	29.0 31.0		E
								P.3.-LONG. NDT @ -10 DEG. F. PASSED. *P.3.-LONG. NDT @ -10 DEG. F. PASSED.				

ID 6010

ABOVE VALUES EXPRESSED IN K.S.I.

**PLATE NORMALIZED @ 1652 DEG. F. PLUS OR MINUS 25 DEG. F. MTD. 180.0 MINUTES. AIR COOLED.

***PLATE NORMALIZED @ 1652 DEG. F. PLUS OR MINUS 25 DEG. F. MTD. 180.0 MINUTES. AIR COOLED.

**TEST SPECIMENS STRESS RELIEVED @ 1125 DEG. F. PLUS OR MINUS 25 DEG. F. MTD. 10.00 HRS. FCE COOLED TO BELOW 600 DEG. F. HEATING RATE 100 DEG. F. PER HOUR. COOLING RATE 100 DEG. F. PER HOUR. AIR COOLED.

ULTRASONIC INSPECTION--OK REPORT ATTACHED.

*YIELD POINT @ .0050 EXT.

MIN. SIZE TESTS ACCORDING TO CONSTRUCTION CONTRACTS & REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

* B OR H INDICATE COMPLIANCE OF BEND OR HONO TESTS, RESPECTIVELY

ITEM NO	TYPE	C	M	P	S	T	S	Cu	N	Cr	Mo	Si	Ni	V
5H7457	LAUL	19	106	010	014	25								

BEAVER VALLEY - UNIT NO. 2
DUQUESNE LIGHT COMPANY
ID. NO. 02241 28V-65
CONTAINMENT LINER AND
MIT EMBODIMENTS
PITTSBURGH, PA
STEEL CO.

AVG GR SIZ 08

A-225

SECTION 2

IRWIN STEEL FABRICATORS
CANTON, OHIO 44708

COATESVILLE, PA. 19320
TEST CERTIFICATE

MILL ORDER NO.
66933-1

CUSTOMER P.O.
I-3224

DP 9275 DM
4/10

CONSIGNEE:

THIS MATERIAL HAS BEEN MANUFACTURED AND TESTED IN ACCORDANCE WITH PURCHASE ORDER REQUIREMENTS AND SPECIFICATION. SA-516 GR. 70 ASME CODE SECT. 2 & 3 SUB NE 1974 EDIT'N THRU WINTER 1974 ADDENDA

BEND TEST O.K. HOMOGENEITY TEST

MELT NO.	CHEMICAL ANALYSIS							
	C	MN	P	S	Cu	Si	Ni	Cr
D1563	26	96	008	020		21		
C5744	25	95	007	020		21		
THIS MATERIAL IS IDENTICAL AND COMPLIES WITH ASME SPECIFICATION								
SA-516 GR. 70 Sect II - 1974 Edition Thru Winter 1974 Addenda								
<i>Left</i> 9-25-78								
IRWIN STEEL FABRICATORS								

SET #1 OF 2

SIS

Q	V	T	AL	S	GRA
					FAVER VALLEY - UNIT NO. 2 DUQUESNE LIGHT COMPANY I.O. NO 12241 2BV-65 CONTAINMENT LINER AND MAT EMBEDMENTS POM STEEL CO. PITTSBURGH, PA

PERSONNEL AIR LOCK

PHYSICAL PROPERTIES

MELT NO.	SLAB NO.	YIELD ST. PSI F100	TENSILE PSI F100	% ELONG. IN 2"	% R.A.	BHN	IMPACT			FRACTURE APPEARANCE	DESCRIPTION
							LV-10°F.	IMPACT	% SHEAR		
D1563	6	492 533	730 765	32			75 .065	75 .068	73 .067	60-60-60	1- 5-1/2" X 54 X 32
"	5	495 487	750 745	30	30		38 .040	42 .034	3 .037	30-30-30	1- 5-1/4" X 60 X 16
C5744	6	535 544	790 801	31	30		68 .063	71 .066	73 .067	60-60-60	1- 4-1/4" X 78 X 16
LONG. DROP HEIGHT TESTS PER E208 (SIZE P3) 0°F., EXHIBIT NO BREAK N.D.T. IS 10°F. OR BELOW											

WJW
02 OCT 30 1978

Supervision Test

IRWIN STEEL
CANTON OHIO 44708

TEST CERTIFICATE

MILL ORDER NO.
66933-1

CI
I-324

ER.P.O.

4/11

This material has been manufactured and tested in accordance with purchase order requirements and specifications.

SAFE

BEND TEST

HOMOGENEITY TEST

SHEET 12 OF 2

CHEMICAL ANALYSIS

MELT NO.	C	MN	P	S	CU	SI	NI	CR	MO	V

PHYSICAL PROPERTIES

IMPACTS

MELT NO.	SLAB. NO.	YIELD PSI Y130	TENSILE PSI #100	% ELONG. IN	% R.A.	BHN	IMPACTS

PLATES AND TESTS HEATED 1625-1675°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED, THEN TEMPERED 1220°F., HELD 1/2 HR. PER INCH MIN. AND WATER QUENCHED.

TESTS STRESS RELIEVED BY HEATING WITHIN A RATE OF 100°F. PER HR. TO 1100-1200°F., HELD 8 HRS. AND FURNACE COOLED WITHIN A RATE OF 100°F. PER HR. TO 800°F.

I hereby certify the above information is correct.

A	B	C	D
VALLEY - UNIT NO. 2 THE LIGHT COMPANY O 12241 2BV-65 SUBSTANTIAL AND AT EMBEDMENTS PDA STEEL CO. PITTSBURGH, PA			

DESCRIPTION	
<i>G. A. APPROVED</i> <i>WJW</i> IRWIN STEEL FABRICATORS	2 9 7 2

WJW
02

OCT 30 1978

AH
SUPERVISOR TESTER

SECTION 3

A-560



NUCLEAR PRODUCTS DIVISION OF

capitol
 PIPE & STEEL PRODUCTS, INC.

July 12

MATERIAL CERTIFICATION

ID - 3912

Item: 18" S/80 SMLS ASME SA-333 GR 6

 BEAVER VALLEY - UNIT NO. 2
 DUQUESNE LIGHT COMPANY
 J.O. NO 12241 2BV-65
 CONTAINMENT LINER AND
 MAT EMBEDMENTS
 PDM STEEL CO.
 PITTSBURGH, PA

Heat Number: B93318 UNITED STATES STEEL CORP

Other Identification: PDM P.O.# 299474
Contract# 13691

Specification: ASME SA-333 GR 6

Material Identification:

Paint Stencil	Mfgr Name
	Specification
	Size, Sch Heat LT
	Seamless
	PO# 299474
	Contract# 13691
	Item# 39 Detail AH
	Item# 40 Detail AJ
	Item# 41 Detail AK

We Certify that the above listed material conforms to the
 requirements of ASME SA-333 GR. 6 and PDM Specifications
 MS- 9.9.2 Dated 2/21/74.

F.I.D. # 3912 *


 J. L. R.
 6-23-75

MS-9.9.2, 4-16-75

 Sworn to and subscribed before me
 this 12th day of July 1974
 by Holger Feldman

 E. C. Hinkle
 NUCLEAR DIVISION



United States Steel Corporation

**STANDARD SWORN TEST REPORT
TUBULAR PRODUCTS**

Seamless pressure pipe
Production Normalized @ 1600°F for 11.6 in.
Capitol Pipe & Steel Products Inc.

115" 5/80 1-26

National.

۱۰

5-21-74 DATE

GRADE
E ASME-SA 33
L4.6. ASTMA 33
CUSTOMER NO.
65893-00N
U.S. STEEL ORDER NO.
KE 63055
INVOICE NO.
356-03065

PENNSYLVANIA
ALLEGHENY

אנו מודים לך על עזרתך.

DAY OF Friday - 1977
JULY 11, 1977 EXMURY PUBLIC LIBRARY

PERMIT EXPIRES Aug. 21, 1968, County Public - - - -
St. Lucie, Florida County

BEING DULY SWEORN ACCORDING TO
LAW DEPOSES AND SAYS THAT THE FIGURES SET FORTH ABOVE ARE COR-
RECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

1980-1981 Year End Survey Report

THE PUBLIC RECORDS

United States Steel Corporation, Harmarville, Pennsylvania 15638

PITTSBURGH TESTING LABORATORY

ESTABLISHED 1891
650 POPLAR STREET, PITTSBURGH, PA. 15220PLEASE REPLY TO:
P. O. BOX 1246
PITTSBURGH, PA. 15236AS A MUTUAL AGREEMENT IS MADE, THE PUBLIC AND PRIVATE, ALL REPORTS
ARE SUBMITTED AS THE PROPERTY OF THE LABORATORY FOR CLIENTS, AND AUTHENTICATION
FOR PUBLICATION OR DISTRIBUTION CONCERNING THE EXAMINATION OR INSPECTION OF RECORDS
OR REPORTS IS RESERVED EXCLUSIVELY WITHIN THE LABORATORY.CLIENTS NO. L-66651-A3
Release #105

AREA CODE 412 TELEPHONE 922-4259

LABORATORY NO. 746532

ORDER NO. PG-17500
REPORT NO. 1REPORT
OF
LONGITUDINAL DROP WEIGHT TEST

DATE 2-1-74

REPORT TO:

Capitol Pipe & Steel Products Inc.
Nuclear Products Division
730 Superior Avenue
Carnegie, Pennsylvania 15106BEAVER VALLEY - UNIT NO. 2
DUQUESNE LIGHT COMPANY
J.O. NO 12241 2BV-65
CONTAINMENT LINER AND
MAT EMBEDMENTS
PDM STEEL CO.
PITTSBURGH, PA

REPORT FOR:

P.D.M. RN-9651-A P16507
P.Q. 249474

MATERIAL INFORMATION:

6-24-75 TYPE ASTM A333 Gr. 6
SIZE 18" SCH. 40 HT B93312

SPECIFICATION:

ASTM E-208 Part. 31

Test Temp. not higher than -10°F

Material Identification	Heat No.	Test	Results
1	B93318	P2 Drop Weight	Accepted
2	B93318	P2 Drop Weight	Accepted
3	B93318	P2 Drop Weight	Accepted

Test Temp. -10°F

Pitts. Des-Moine Co.
P.O. 299474
Ch# P-16507
Detail AH
Capitol S.O.# RN-9651-A
Item# 39

WE ARE PLEASED TO ANNOUNCE
THE PURCHASE OF THE
TEST CENTER
CAPITAL PIPE & STEEL CO.
PRODUCTS INC.
SIGNED *Donald D. McDonald* 6-19-75

6/28/74

Date of Test

Earl Gallagher, Manager
Physical Tests Department

cc: 4-Client
Attn: Mr. Brinner

ID-3912

SECTION 4

(USS) Uni. States Steel Corporation

TEST REPORT OF

WORKS HOMESTEAD DISTRICT

PLATES

CORRECTED REPORT 12-18-75

136

LOAD TALLY OR
INVOICE NO 163-18913

USS ORDER NO LA89835

CUSTOMER ORDER NO 735 7/2/75

CAR OR TRUCK NO BU 009840

SHIPPER NO & DATE 55890 12/04/75 160

PITTSBURGH DES MOINES STEEL CO
NEVILLE ISLAND BRANCH
PITTSBURGH PA 15225PITTSBURGH DES MOINES STEEL CO
NEVILLE ISLAND PAP.D.M. DES MOINES SPECN HS 10-15 REV D DTD 12/10/74 QUENCH & TEMPER W (SA537 CP2)
TEST SPECIMENS STRESS RELIEVED AT 1125 DEG F + CR -25 DEG F HOLDING
FOR 8 HRS + TEMP. W/SR IN ACCORD W/ASME CODE CASE SEC I (SEE DRD)

013057

HILL CERTIFIED T/H - ANALYSIS - REPORT TEST RESULTS PER SPEC 3
T/H TO SOLD TO ATTN ANN WIESEWE HEREBY CERTIFY
THAT THE CHEMICAL ANALYSIS
AND/OR TESTS SHOWN IN THIS
REPORT ARE CORRECT AS CON-
TAINED IN THE RECORDS OF
THE COMPANY.

SIGNATURE M.W. MAXSONA CH. MET.

DATE

12/05/75

ITEM NO	HEAT NO	TEST OR PIECE IDENTITY NO	MATERIAL DESCRIPTION					YIELD PT PSI	TENSILE STR PSI	ELONGATION %	% RED OF AREA	A B C D E
			NO PCS	THICKNESS OR SECTION	WIDTH DIA. OR FT WT	LENGTH	WEIGHT					
01	72A467	246911 BC TC	1	1 1/4	85	324	11222	9733	* 74.3 * 70.9	89.0 86.3	38.0 38.0	B
		ABOVE TEST SPECIMENS STRESS RELIEVED AT 1125 DEG F, MTD 8.00 HRS COOLING RATE 300 DEG F. PER HOUR. TEST SPECIMENS CHARGED COLD, HEATING RATE 300 DEG. F. PER HOUR.										
		ABOVE VALUES EXPRESSED IN K.S.I.										
02	72A467	246913 BC TC	1	1 1/4	72	324	11221	8261	* 75.1 * 75.7	90.0 90.5	30.0 34.0	B
		ABOVE TEST SPECIMENS STRESS RELIEVED AT 1125 DEG F, MTD 8.00 HRS COOLING RATE 300 DEG F. PER HOUR. TEST SPECIMENS CHARGED COLD, HEATING RATE 300 DEG. F. PER HOUR.										
		ABOVE VALUES EXPRESSED IN K.S.I.										
		PLATES CHARGED COLD. AUSTENITIZED @ 1600 DEG F. PLUS OR MINUS 25 DEG F. MAINTAINED 70.5 MINUTES. WATER QUENCHED COLD. TEMPERED @ 1200 DEG F. PLUS OR MINUS 25 DEG F. MAINTAINED 87.5 MINUTES. AIR COOLED.										
		P3-2 DMT'S OK @ -10 DEG F. 100 % SHEAR RATE										
		* YIELD POINT P .0050 EXT.										

CIRCLE SIZE TESTED ACCORDING TO COMPANY RECORDS CONFORMS TO THE REQUIREMENTS OF THE SPECIFICATION LISTED ABOVE

* B OR H INDICATE COMPLIANCE OF BEND OR HOMO TESTS, RESPECTIVELY

HEAT NO	C	Mn	P	S	Si	Cu	Ni	Mo	Sn	N	V	FEARVER VALLEY - UNIT NO	CO	AVG OR BIZ OR FIN GRM PRACT
72A467	0.18	1.24	0.08	0.22	0.32	0.25	0.20	0.14	0.05	0.11		NO 12241	304-45	Pittsburgh-Des Moines Steel Co.

RECEIVED

DEC 23 1975

Quality Assurance Department

SECTION 5

13671

**REVISED DOCUMENT
PACKAGE
AUG 19 1976**

FORM NO. 1057B

A-734



NATIONAL FORGE COMPANY

PAGE : 1 OF 2

MATERIAL CERTIFICATION DOCUMENTATION PACKAGE

Customer: PITTSBURGH-DES MOINES STEEL COMPANY

Forge Div. Irvine Erie

Purchase Order No.: 122375 Item 4

Foundry Div.

Drawing No.: SKYB54, REV. E1 AND 183303 A, REV. 5

NFC Order No.: 60-A-1833

Nomenclature: FLUED HEAD PENETRATION NO. 1

NFC Serial No.: 03-001

Specification: 1971 EDITION ASME CODE, SECTION II, SA-508 CLASS I, MODIFIED BY PDM SPEC. MS 61.6 DTD 11/15/74 AND ASME CODE SECTION III CLASS II THRU W-72

NATIONAL FORGE COMPANY DOCUMENTS APPROVED AND USED ON THIS CONTRACT

Ultrasonic Procedure: UT-60-1833, DTD 6/6/75

Magnetic Particle Procedure: MT-60-1833, DTD 6/3/75

Heat Treat Procedure: LT-60-A-1833, OB, DTD 5/29/75

Impact Test Procedure: LT-60-A-1833-0A, DTD 5/29/75

Forging Test Drawing:

Other: HYDROSTATIC TEST PROCEDURE: 61-GP-09-006, REV. B & TEST AGENDA 60-1833, REV. 3, DTD 3/2/76

DOCUMENTATION PACKAGE TABLE OF CONTENTS

- 3 Chemistry/Mechanical/NDT Data
- Transition Curve
- Heat Treatment Charts/Table IV Form
- Dimensional Data
- Forging Material Log
- Heat Stability Data

- Photomicrographs
- Test Material (Sep. Cover)
- U-1A Form
- U-2 Form
- Other

BFAVER VALLEY - UNIT NO 2

DUQUESNE LIGHT & POWER CO.

10 NO 12241 7-7-55

CONTAINMENT LINE #2 ID

MAT ENCLOSURE

P.O. BOX 1000

PITTSBURGH, PA

This is to certify that the material identified above has been processed, tested and inspected in accordance with the requirements of the purchase order and applicable specifications, including any amendments and conforms to the requirements thereof.



Date: 8/11/76

R. S. Nowack

Authorized Company Representative

8/11/76

NATIONAL FORGE COMPANY
CITY CONTROL DEPARTMENT

MATERIAL CERTIFICATION REPORT NO. 0- 05439

NFC SHOP NO. 69

CUSTOMER

CUSTOMER ORDER NO.

33

SERIAL NO. 03-001

PITTSBURGH-DES MOINES STEEL COMPANY

122375

ID-A3100

REV NO. 1050 B

Page 2 of 2

CHEMICAL ANALYSIS

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	V	Al	Cu	Co	Ti			
4-4962	.22	1.24	.008	.006	.22	.12	.17	.04	.02		.06	.007				
CHECK	.22	1.24	.009	.006	.23				.02							

MECHANICAL PROPERTIES

LEGEND	SPECIMEN IDENT. NO.	TENSILE psi	YIELD psi	% ELONG	% R/A	GRAIN SIZE	HARDNESS
L - LONG	LA 12:00	79,750	59,500	30.5	73.3	7-10	
R - RAD	LB 6:00	78,600	60,500	31.0	74.5		
X - TRAN							
Y - TANG							

MANUFACTURING NOTES AND HEAT TREATMENT DATA

DROP WEIGHT TESTS	OPERATION	TO	HRS HOLD	IMPACT DATA			
				*F	FT. LBS.	% SHEAR	LATERAL EXPANSION
2 NO BREAK @ 2000	NORMALIZED	1680	8	LA 12:00		155.0	.74
1 BREAK @ 3000	AUSTENITIZED	1550	8			197.0	.101
TNDT	QUENCHED IN WATER					141.0	.111
	TEMPERED	1240	8	LB 6:00		57	.095
						121.0	.084
						131.0	.093
						126.0	.090

BEAVER VALLEY
DUESSENGUT CO.
CONTAINERS LTD.
PITTSBURGH, PA
NO. 1224
214-451-1000
MAIL ENCL. DUE
COURTESY OF
PITTSBURGH, PA

ULTRASONIC INSPECTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY WITH NO REPORTABLE INDICATIONS.

MAGNETIC PARTICLE INSPECTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY WITH NO REPORTABLE INDICATIONS.

HYDROSTATIC TESTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY

TENSILE SPECIMEN SIZE = .505"

ROUND FLUTED INGOT MOLD

FREE OF MERCURY CONTAMINATION

COPIES OF ACTUAL TEST DATA AVAILABLE FOR REVIEW.

ID-A3100

SECTION 6



NATIONAL FORGE COMPANY

PAGE 1 OF 2

MATERIAL CERTIFICATION DOCUMENTATION PACKAGE

Customer: PITTSBURGH-DES MOINES STEEL COMPANY

Forge Div. Irvine Erie

Purchase Order No.: 122375

Foundry Div.

Drawing No.: SKWB54, REV. E1 & 183305 A, REV. 3

NFC Order No.: 60-A-1833

Nomenclature: FLUED HEAD PENETRATION [REDACTED]

NFC Serial No.: 05-001

Specification: 1971 EDITION ASME CODE, SECTION II, SA-508, CLASS I, MODIFIED BY PDM SPEC. MS 61.6 DTD 11/15/74 & ASME CODE SECTION III, CLASS II II THRU W-72

NATIONAL FORGE COMPANY DOCUMENTS APPROVED AND USED ON THIS CONTRACT

Ultrasonic Procedure: UT-60-1833, DTD 6/6/75

Magnetic Particle Procedure: MT-60-1833, DTD 6/3/75

Heat Treat Procedure: HT-60-A-1833, OB, DTD 5/29/75

Impact Test Procedure: LT-60-A-1833-0A, DTD 5/29/75

Forging Test Drawing:

Other: HYDROSTATIC TEST PROCEDURE: 61-GP-99-006, REV. B & TEST AGENDA 60-1833, REV. 3, DTD 3/2/76

DOCUMENTATION PACKAGE TABLE OF CONTENTS

3 Chemistry/Mechanical/NDT Data	Photomicrographs
Transition Curve	Test Material (Sep. Cover)
Heat Treatment Charts/Table IV Form	U-1A Form
Dimensional Data	U-2 Form
Forging Material Log	Other
Heat Stability Data	

This is to certify that the material identified above has been processed, tested and inspected in accordance with the requirements of the purchase order and applicable specifications, including any amendments and conforms to the requirements thereof.

REVIEWED AND APPROVED
R. S. Newark
Date: 4/21/76

R. S. Newark

Authorized Company Representative

Date: 4/21/76

C CITY CONTROL DEPARTMENT

MATERIAL CERTIFICATION REPORT NO. 0- 04657

NFC SHOP NO. 60-

CUSTOMER

SERIAL NO. 05-001

ITSBURGH-DES MOINES STEEL COMPANY

CUSTOMER ORDER NO. 122375

Page _____ of _____

CHEMICAL ANALYSIS

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	V	Al	Cu	Co	Ti						
4-4956	.22	1.15	.011	.007	.26	.17	.19	.05	.02										
CHECK	.23	1.18	.011	.007	.26				.02										

MECHANICAL PROPERTIES

LEGEND	SPECIMEN IDENT. NO.	TENSILE psi	YIELD psi	% ELONG	% R/A	GRAIN SIZE	HARDNESS
L - LONG	LA 12:00	83,750	67,000	.2	27.0	74.9	
R - RAD	LB 6:00	86,000	67,500	30.0	75.5		
X - TRAN							
Y - TANG							

MANUFACTURING NOTES AND HEAT TREATMENT DATA

DROP WEIGHT TEST RESULTS	OPERATION	TO °F	HRS. HOLD	SPCMN. IDNT. NO.	IMPACT DATA		
					*F	FT. LBS.	% SHEAR
2 NO BREAK @	NORMALIZED	1650	6	L	126.0	67	.085
1 BREAK @	AUSTENITIZED	1550	6		170.0	100	.095
	QUENCHED IN WATER				185.0	100	.107
	TEMPERED	1240	6	L 6:00	139.0	74	.095
					144.0	77	.087
					188.0	100	.095

CERTIFIED UNIT NO. 2

TESTED FOR: 100% 100%

100% 100% 100%

(100%) 100% 100%

ULTRASONIC INSPECTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY
WITH NO REPORTABLE INDICATIONS.MAGNETIC PARTICLE INSPECTED PER APPROVED PROCEDURE AND FOUND TO BE
SATISFACTORY WITH NO REPORTABLE INDICATIONS.HYDROSTATIC TESTED PER APPROVED PROCEDURE AND FOUND TO BE SATISFACTORY
WITH NO REPORTABLE INDICATIONS.

TENSILE SPECIMEN SIZE = .505"

ROUND FLUTED INGOT MOLD

FREE OF MERCURY CONTAMINATION

COPIES OF ACTUAL TEST DATA AVAILABLE FOR REVIEW.

SECTION 7



Lenape Forge Division
Energy Products Group
 GULF-WESTERN MANUFACTURING COMPANY

P.O. Box 536, West Chester, Pennsylvania 19380
 PHONE 215-793-1500 TWX 510-663-0372 TELEX 083-5453

A-444

MATERIAL TEST REPORT S. O. No. 0110-5 LENAPE, PA., June 9, 1975

URCHASER Pittsburgh-Des Moines Steel Company DISTRIBUTOR Same

URCHASER'S ORDER NO. Contract 13691 DISTRIBUTOR'S ORDER NO. Same

ITEM NO.	QTY.	PRODUCT	SPEC.	HEAT OR CODE NO.	REMARKS
1	4	8.625" Dia. x 2-1/4" Lg. Penetration (Ref. Dwg. SKWB33A, Rev. A)	SA350-LF2 as modified by Customer's P.O. PIM Spec. MS-15.13.1 dated 9/6/74 (Sec. II and III ASME Code 1971 Edition thru Winter 1972 Adden- da Class 2)	B13QT	M/O 332H-1,2,3,4 (Serial #'s 55, 56, 57, and 97) PAVER VALLEY - UNIT NO. 2 DUQUESNE LIGHT COMPANY I.O. NO 12241 ZBV-65 CONTAINMENT LINER AND MAT ENCLADMENTS PDM STEEL CO. PITTSBURGH, PA
2	2	8.625" Dia. x 2-1/4" Lg. Penetration (Ref. Dwg. SKWB33B, Rev. A)		B13QT	M/O 333H-1 and 2 (Serial #'s 105 and 110)



J. L. R.
9-16-75

CHEMICAL ANALYSIS AND MECHANICAL PROPERTIES

HEAT NO.	C	MN	P	S	SI	CR	NI	MO	REMARKS
313QT	.25	1.34	.010	.014	.27	---	---	---	Ladle Check HEAT TREATMENT: HT-2, Rev. 2 1650°F±25°F for 3 hrs.- Water Quench 1250°F±25°F for 3 hrs.- Air Cool Test specimens were stress relieved as follows: Held @1125°F±25°F for 3 hrs. Heating from and cooling to 600°F @100°F/hr. max.
	.23	1.27	.013	.016	.27	---	---	---	

HEAT NO.	TENSILE R.T.	YIELD	ELONG % IN 2"	R.A. %	S.H.N.	IMPACT V-Notch @-10°F	REMARKS
313QT	79,040	49,920	30.0	64.5		37-27-29	.034-.028-.029 20-10-10 P-3 dropweight specimens: Two (2) no breaks per for- ging per heat @-40°F. ATTACHMENTS: Magnetic Particle Inspection Heat Treat Charts

I hereby certify the above results to be correct
contained in the records of the Company.

L.J. Litton

SECTION 8

FORM NPP-I DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
 As Required by the Provisions of the ASME Code Rules, Section III, Div. I N-1141-3267

located by	Power Piping Company, Donora, PA 15033	Order No.	N-1141
2. Fabricated for	Beaver Valley Power Station, Unit 4?	Order No.	2BV-58, J.O. No. 12241
3. Owner	Duquesne Light Company, Pittsburgh, PA	4. Location of Plant	Shippingport Borough, PA
5. Piping System Identification	Main Steam and Safety Valve Header (MSS)	MSS-170-1/1002-170-45	ISO 100207
(a) Drawing No.	RP-2 B, E, F	Prepared by	Stone & Webster Engineering Corp.
(b) National Board No.	N/A		Boston, Massachusetts
6. The material, design, construction, and workmanship complies with ASME Code Section III, Class	2		
Edition	1971	Addenda Date	Winter 1972
Case No.	N/A		
Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report <small>(Name of Part - Item number, Manufacturer's name and identifying stamp)</small>			

Shop Hydrostatic Test By Field psi.

8. Description of piping inspected

1 Pc. - 30" I.D. X 1.875" M.W. SMLS. C.S. Pipe, SA 106, Gr. C, Item #4, L.C. No. P-1783,
 Ht. ID L-5616, Ser. #35461-YU, Lgth. = 0'-11 $\frac{1}{2}$ " Lg.

Welding Electrode L.C. No. E-88, E-108, E-109

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE

Date April 30, 1982 Signed Power Piping Company By *Alice C Hartillia*
 Certificate of Authorization Expires January 7, 1983 Certificate of Authorization No. N-1623

CERTIFICATE OF SHOP INSPECTION

N-1141-3267

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of PENNSYLVANIA and employed by Lumbermens Mutual Casualty Co. of Long Grove, IL have inspected the piping described in this Data Report on 4-30, 1982, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III. By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-30 1982
H. E. Howell
 Inspector

Commissions

PA 2/30

National Board, State, Province and No.

FORM NPP-1 (back)

9. Description of Field Fabrication

10. Field Hydrostatic Test _____ psi.

We certify that the field fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.
Class _____ Edition _____ Addenda Date _____ Case No. _____

Date _____, 19_____. Signed _____ By _____
(NPT Certificate Holder) _____ (Representative) _____

Symbol Expires _____ 19_____
Our Certification of Authorization to use the _____
Certificate of Authorization No. _____

CERTIFICATE OF FIELD FABRICATION INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of _____
and employed by _____ of _____

have compared the statements in this Data Report with the described piping and state that the parts referred to as data items
_____ not included in the certificate of shop inspection have been inspected by me and that to the best of my
knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable section of the ASME CODE SECTION III.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping described in this
Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind
arising from or connected with this inspection.

Date _____, 19_____

Commissioner _____

National Board, State, Province and No. _____

CERTIFICATE OF TEST ON PIPE MATERIAL

POWER PIPING COMPANY
BEAVER AVENUE
TSBURGH, PA 15233

CORRECTED REPORT.
2/12/80

Cameron
IRON WORKS, INC.

P. O. BOX 1212
HOUSTON, TEXAS 77001

ASME QUALITY SYSTEM CERTIFICATE
(MANUFACTURER) NO. N-2209 EXPIRES 10-27-81
ALL OPERATIONS WERE PERFORMED BY CIW & MEET THE REQUIREMENTS
OF THE MATERIAL SPECIFICATION AND SEC. III, DIV. 1. DATE 30 JAN. 1980

CUSTOMER ORDER NO. 225550-N-1141	C.I.W. SALES ORDER NO. F-9985	SPECIFICATION ASME SA106 GR.C; ASME SEC. III, CL.2 WITH NO IMPACTS AND POWER PIPING SPEC. N-1141-01, REV. A
CIW PART NO. DESCRIPTION OF MATERIAL D.O.	86-9985-341-300 SEAMLESS PIPE X.D. 30.000" WALL 1.875" M.W.	

HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS									
		C	MN	P	S	SI	CR	NI	MO	CU	CO
L 5616		.24	.84	.008	.018	.22					

T NO.	QUANTITY OR SERIAL NO.	TEST LOC.	TENSILE PSI	YIELD PSI	ELONG	MECHANICAL PROPERTIES BAR SIZE	LCT NO.
L 5616	7	T-A	73,900	44,400	32.1	56.5 OK .505	1812

FORG. SER.#	TEST LOT#	HEAT#
P-780-35461YZ	1812	L 5616
P-781-35461YY	"	"
P-781-35461YX	"	"
P-785-35461YW	"	"
P-783-35461YU	"	"
P-779-35462YZ	"	"
P-778-35462YY	"	"

EACH LENGTH OF PIPE HYDROSTATICALLY TESTED AT 2800 PSI FOR 5 SEC. AND FOUND
ACCEPTABLE.

HEAT TREATMENT: 1600F., HELD 1 HR. AT TEMP. AIR COOLED.

SWORN TO BEFORE ME THIS

12TH DAY OF FEB. 1980.

G. A. Toussaint
NOTARY PUBLIC
G. A. TOUSSAINT

I CERTIFY THESE TESTS TO BE CORRECT AS CON-
TAINED IN THE RECORDS OF THE COMPANY.

H. H. Wright
METALLURGICAL REPRESENTATIVE

STATE OF TEXAS
HARRIS COUNTY, TEXAS
C.I.W. 1044-A C-1000-1000-1000-1000

DUQ. LIGHT CO. BEAVER VALLEY E9082/gt
P.O. NO. 2 BV-5B. J.O. NO. 12241 PIPE FAB.

AUTH. NO.
4-1141

Lotter Control No. 4-1141

Page 1 of 1

SECTION 9

FORM NM-1 DATA REPORT FOR TUBULAR PRODUCTS AND FITTINGS WELDED WITH FILLER METAL
As required by the Provisions of the ASME Code Rules

1. Manufactured by	Tube Turns, 2900 W. Broadway, Louisville, Ky. 40210	(Name and address of manufacturer of tubular products)
2. Manufactured for	Power Piping Co. Donora, Pa. 15033	(Name and address of purchaser)
3. Identification-Manufacturer's Serial No.	13692	Block Out (Part & Drawing No.) NA
		1982
4. (a) Manufactured according to Mat'l Spec.	SA234-WPCW	Steel Board No.: Purchase Order No. 32403-N-1141 (if applicable)
(b) Description of Product Inspected	30" Nominal ID 1.875 MW Tee	(SA or SB)
(c) Applicable ASME Code: Section III, Edition	1971	Addenda date N-72 Case No. NA Class 2
5. Remarks:	Plate formed into cylinder, welded, and formed to shape (Brief Description of Fabrication)	

CERTIFICATE OF COMPLIANCE

We certify the statements made in this report are correct and the products defined in this report conform to the requirements of the ASME Material Specification listed above on line 4 (a). The radiographic film and a radiographic report showing film locations are attached to the Certified Material Test Reports provided for the material covered by this report.

Date 4-20 1982 Signed Tube Turns By J. Light
 (Manufacturer)


ASME Certificate of Authorization No. N-1111 to use the NPT Symbol expires 6/16/84
 (Date)

CERTIFICATE OF INSPECTION


I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Kentucky and employed by HSBIA & I Co.
 of Hartford, CT have inspected the products described in this Manufacturer's Partial Data Report on 4-22 1982 and state that to the best of my knowledge and belief, the Manufacturer has produced this product in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the product described in this Manufacturer's Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-22 1982 Commissions KY593 PA WC 2560
J. Light Inspector's Signature
 National Board, State, Province and No.



Q. LIGHT CO., BEAVER VALLEY NO. 2
 J. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.



TO
POWER PIPING CO.
829 BEAVER AVE.
PITTSBURGH, PA 15233


TO
POWER PIPING CO.
6TH ST. GATE
DONORA, PA 15033

DETAILED ANALYSIS REPORT

Tube Turns Division

LOUISVILLE, KY APRIL 20, 1982
TUBE TURNS ORDER NO. 080361

CUSTOMERS' ORDER NO. 32403-N-1141

DESCRIPTION	HEAT TREATMENT	YIELD STRENGTH PSI	TENSILE STRENGTH PSI	PERCENT ELONGATION IN 2 IN.	PERCENT REDUCTION IN AREA	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	HEAT OR LOT NO	MADE FROM MATERIAL OF CHEMISTRY AND TENSILE PROPERTIES OF SPECIFICATION
ITEM 1 3 PCS. 10" NOMINAL ID 1.875" MW TEE ITH ENDS SIZED TO 34" NOMINAL D AND BEVELED PER SK-101 REV. 9	A	66000 70000 71000	92500 96000 98000	23 20 21	57 54 52	.31 .31 .30	.87 .86 .86	.018 .019 .018	.023 .021 .021	.15 .15 .15					TO161FA TO161FB TO161FC SA106/C SA106/C SA106/C	
A234 WPCW TRIAL NOS. 13690, 13691, 13692	A															
ATTACHMENTS: OMN MM-1 FIELD MATERIAL TEST REPORTS RADIOGRAPHY REPORT RADIOGRAPHY PROCEDURE ULTRASONIC EXAM REPORT MAGNETIC PARTICLE REPORT																
ASME SECTION III CLASS 2 1971 EDITION WITH ADDENDA THROUGH WINTER 1972																
DUQ. LIGHT CO. BEAVER VALLEY NO. 2 P.O. NO. 2 BV-59, J.O. NO. 12241, PIPE FAB.																
STANDARD ROUND TEST SPECIMEN 1 ANNEALED 2 NORMALIZED AND STRESS RELIEVED 3 STRESS RELIEVED 4 QUENCHED AND TEMPERED 5 HOT FORGED 6 HEAT TREAT PER ORDER SPECIFICATION																
ANL REVIEW DATE 5-18-82																
SUBSCRIBED AND SWEARN TO BEFORE ME THIS DAY OF 19																
NOTARY PUBLIC																
HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION																
 S. D. VITATOE - QUALITY CONTROL																

STANDARD ROUND TEST SPECIMEN

1 ANNEALED

2 NORMALIZED


3 NORMALIZED AND STRESS RELIEVED

4 STRESS RELIEVED

5 QUENCHED AND TEMPERED

6 HOT FORGED

7 HEAT TREAT PER ORDER SPECIFICATION



NOTARY PUBLIC

SECTION 10

FORM NPP-I DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*

As Required by the Provisions of the ASME Code Rules, Section III, Div. I

#1141-6321

Fabricated by	Power Piping Company, Donora, PA 15033	Order No.	1141
Fabricated for	Beaver Valley Power Station, Unit #2	Order No.	2BV-58 J.O. No. 12241
Owner	Duquesne Light Company, Pittsburgh, PA	Locat. in of Plant	Shippingport Borough, PA
Piping System Identification	Main Steam And Safety Valve Header (MSS)	MK-MSS-170-3/100E-170-106	ISO 100207
(a) Drawing No.	RP-2B, E, F	Prepared by	Stone & Webster Engineering Corp.
(b) National Board No.	N/A		Boston, Massachusetts
6. The material design, construction, and workmanship complies with ASME Code Section III, Class 2			
Edition	1971	Advisory Date	Winter 1972
Case No. N/A			
Remarks: Manufacturers Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:			

* shop Hydrostatic Test By Field psi

8. Description of piping inspected

1 Pcs. - 30" I.D. x 275" M.W. Smis. C.S. Pipe SA-106, Gr. C Item #1, L.C. No. P-1787
 Ht. ID 4-5015 Ser. #374527, Lgth. = 7'-11" 16
 ✓ - 2" 3000# F.S. S/W Weld Boss, SA-105, Item #21, L.C. No. M-3992, Ht. ID ABX
 ✓ - 1 1/2" 3000# F.S. S/W Weld Boss, SA-105, Item #22, L.C. No. M-5029, Ht. ID ACE
 ✓ - 3/4" 3000# F.S. S/W Weld Boss, SA-105, Item #23, L.C. No. M-5029, Ht. ID ADE;
 Item #24, L.C. No. M-5029, Ht. ID ADE; Item #25, L.C. No. M-5029, Ht. ID ADE;
 Item #26, L.C. No. M-5029, Ht. ID ADE; Item #27, L.C. No. M-5029, Ht. ID ADE
 ✓ - 6" (X-Stg.) F.S. W-O-L SA-105, X 30" I.D. (1.875" M.W.), Item #32, L.C. No.
 M-7507, Ht. ID 386.5
 ✓ - 3" (X-Stg.) X 30" I.D. (1.150" M.W.), F.S. W-O-L SA-105, Item #33, L.C. No.
 M-3965, Ht. ID 416AA

NOTE: Welding Electrode L.C. No. E-49, E-84, E-111, E-112, E-115

RECEIVED

JUL 9 1982

Stone & Webster
Engineering Corporation
Document Review

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE

Date 6-30-82 Signed Power Piping Company By *T. J. Hartman*
Certificate of Authorization No. N-1623

Certificate of Authorization Expires January 7, 1983

CERTIFICATE OF SHOP INSPECTION

N-11416321

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of PENNSYLVANIA and employed by Lumbermens Mutual Casualty Co. of Long Grove, IL, have inspected the piping described in this Data Report on June 30, 1982, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.

Date June 30, 1982

SBD

Commissions

PA 2275

National Board Seal, Printer and No.

The Colonial Machine Company, Inc.

P. O. Box 290 — Pleasantville, Pa. 16341

Phone (814) 589-7033

JAN. 29, 1982

POWER PIPING COMPANY
P.O. BOX 11
DONORA, PA 15033

CERTIFIED MILL TEST REPORT

ITEM		ITEM		DATE SHIPPED
ITEM		ITEM		1/29/82
ITEM	MATERIAL-SPEC.	SHIPPED	HEAT NO.	CMC CODE
1	ASME SECTION II & III CLASS 2 (1971 EDITION THRU SUMMER 1973 ADDENDA) ASME SA105 NORMALIZED	15	55684	ADE
1 3/4" 3000# S/W WELD BOSSES PER SK 102, REV. 3				
REQ. NO. 2-P-26				

ITEM	C	MN	P	S	SI	CR	NI	MO	CU	CB	T1	B	N	OTHER ELEMENTS
1	.26	.80	.015	.029	.23									

RECEIVED

JUL 9 1982

1942-1 Master
E-S Spring Corporation
Document Review

ITEM	TENSILE	2% YIELD	ELONG.	% R.A.	HARDNESS	REMARKS:
1	74500	46500	31.0	59.8	BHN 156	

THE ABOVE MATERIAL HAS BEEN FURNISHED IN ACCORDANCE WITH OUR QUALITY ASSURANCE PROGRAM, LATEST REVISION DATED 2/27/80, DESIGNED TO SATISFY THE REQUIREMENTS OF ASME SECTION III SUBARTICLE NA-3700/NCA-3800, AS AUDITED AND APPROVED BY POWER PIPING ON 8/28/80, AND THE REQUIREMENTS OF YOUR SPEC. N-1141-01 REV. 5, AND THE PROVISIONS OF 10 CFR PART 21.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-53, J.O. NO. 12241, PIPE FAB

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements covered by the specification and your purchase order.

ANI REVIEW
ANI <u>W.L.S.</u>
DATE <u>1-29-82</u>

THIS DOCUMENT HAS BEEN CHECKED AND FOUND TO FULLY COMPLY WITH THE APPLICABLE SPECIFICATIONS BY <u>W.L.S.</u> DATE <u>1-29-82</u>
--

By _____

ERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

DATE 10/21/79	DISTRICT 379 CLE	CUSTOMER'S PURCHASE ORDER NUMBER CM 4837 ADD	DATE MO. DAY YR 060679 1 1	ITEM SAP	DATE WANTED	SHIPPING PROMISE WEEK OF: 10/21/79	SALES ORDER NO. 80108
------------------	---------------------	---	----------------------------------	-------------	-------------	--	--------------------------

COMPETITIVE FREIGHT FROM PRICE IN EFFECT AT TIME OF SHIPMENT

TERMS OF PAYMENT: % OF 1% OF MILL VALUE

10 DAYS. NET 30 DAYS

CLASS

RD 7-3-79

M M P D

PPD/COL SHIP VIA

CUST TRK - IN TRK LOADS

NUCLEAR

COLONIAL MACHINE COMPANY, INC.
BOX 290
ASANTVILLE, PA 16341

SHIP TO: (SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)

ADVISE WHEN READY.

KC 11/6/79

PIECES	LBS. 7,500	SIZE AND SHAPE 1 1/2" RD SHORTS	STD. X	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
					MULTS	STD. PLUS MINUS
10						

CT DESCRIPTION

NORM MS

HARDNESS

ADDIT. MACRO/MICRO REQ.

IE 187 MAX BHN

NORM CHG NO. AND ASME-SA-
5 (W78A)POWER PIPING COMPANY
ORDER NO. 34692-N-1141

MAX.

MPC (206)

PART

SPECIFICATION ASME-SA-105 77 (W78A) ASME-NCA-
3800(W78A) & CFR-21 (10/19/78) 30
MAX CARBON

PA. NO. & MARK

INSPECTION

OUR CUSTOMER'S OTHER

X

ORDER NUMBER

CUSTOMER

COPPERWELD

80108

DATE
11/5/79

COPPERWELD

STEEL COMPANY
351 / WARREN, OHIO 44482

TEST REPORT

for a Copperweld product

mr

RECEIVED

AI

GRAN

SIZE

6-6

1526 Mod SIL KLD

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	RECEIVED	AI	GRAN
55684	.26	.80	.015	.029	.23				JUL 9 1982		
(ADE)	/	/	/	/	/				1650 - 2 hrs.		
	1	2	3	4	5	6	7	8	9	10	11
										12	DODGE
											15 16 20 24 28 32 36

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
46,500	74,500	.2	31.0	59.8	156	ASME Quality Systems Certificate (Materials) No. 2211, expires 10-20-81

DUQ. LIGHT CO., BEAVER VALLEY
P.O. NO. 2 BV-53, J.C. NO. 1224, TYPE

156
157
Surface unless otherwise noted

Mercury is not used in the production or testing of Copperweld Steel materials.

Normalize - 1650 - 2 hrs.

MATERIAL PRODUCED AND CERTIFIED TO SPECIFICATIONS SHOWN
ABOVE. NO ADDITIONAL CERTIFICATION IS IMPLIED OR WARRANTED.

HIS CERTIFICATE NOTARIZED WHEN REQUIRED

ANN

REVIEW
24.82
Heat Code RD
Norm. Charge No 3A-137A

Notary Public do hereby certify that
his affidavit was subscribed and sworn to before me by duly authorized
representative of Copperweld Steel Company.

his day of

We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

THIS DOCUMENT
CHIEKED AND APPROVED
BY (initials)
SP. APPROVED
BY (initials)

Supv. Met. Lab.
Nov. 5, 1979

AT COMMISSION EXPIRES

NOTARY PUBLIC



Bonney Forge Division

Energy Products Group
CARLINVILLE, ILLINOIS

Log No. _____

Page 1 of 3

PHONE 217/854-9611

CUSTOMER: Power Piping
CUSTOMER'S Order No.: 15600-N-1141
SHIPPED TO:

Date July 25, 1978

Bonney Order No. 9830

Mark

Item No.	Quantity No.	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks:
1	6	416AA	<p style="text-align: center;"><u>ASME SA105-Gr.II</u></p> <p>32.500 (1.150MW) x 3 (.300) Weldolet <u>Ladle Analysis:</u> C.25 Mn.81 P.009 S.017 Si.19 T/S 75,550 Y/S 48,110 El 36.5 Ra 65.4 ✓ <u>Mill Heat No:</u> 65595 <u>Brinell Hardness:</u> 143 ✓</p> <p style="text-align: right;">RECEIVED</p> <p style="text-align: right;">JUL 9 1982</p> <p style="text-align: right;">Stone & Webster Engineering Corporation Document Review</p> <p>This certifies that the fittings supplied were normalized by heating to within 1625°F and 1675°F for 3/4 hr. per inch of thickness (1 hr.min.) followed by cooling in still air.</p> <p>This certifies that the fittings supplied are in complete accordance with the ASME Boiler and Pressure Vessel Code, Section III, Class 2, 1971 edition including winter 1972 addenda; SA105; NB2130; Power Piping Purchasing Spec. N-1141-01, Rev. 4 dated 10-6-77 and the purchase order requirements.</p>

D.L. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.X8
by *Phil Simpson Jr.*
Bonney Forge Division
Energy Products Group
Carlinville, Illinois
QUALITY ASSURANCE MANAGER
PHIL SIMPSON

Auth. No. N-1141

Ledger Control No. M-3458 Thru M-3461

Page 1 of 1



Bonney Forge Division

Energy Products Group
CARLINVILLE, ILLINOIS

Log No. _____

Page 1 of 1

PHONE 217/854-9611

CUSTOMER: Power Piping

Date Feb. 25, 1982

CUSTOMER'S Order No.: 34973-N-1141

Bonney Order No. 9505

SHIPPED TO:

Mark

Item No.	Quantity No.	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks:
			ASME SA105N
1 M-7606 76072	386B		30 (1.875) x 6 XS Weldolet C.26 Mn.81 P.015 S.024 Si.26 T/S 82,017 Y/S 58,441 El 27.1 Ra 64.8
M-76081	318B		C.26 Mn.81 P.015 S.024 Si.26 T/S 81,442 Y/S 56,250 El 22.8 Ra 49.4

JUL 1982

DUQ. LIGHT CO. BIRMINGHAM, AL.
P.O. NO. 2 BIRMINGHAM, AL.

This certifies that the fittings supplied were normalized by heating to within 1625°F and 1675°F for 3/4 hr. per inch of thickness (1 hr.min.) followed by cooling in still air.

The above fittings are in accordance with ASME Section III, Class 2, 1971 edition thru summer 1973 addenda; and NCA-3800.

Fittings supplied are in complete accordance with the purchase order specifications and were manufactured in accordance with the Quality Assurance Program audited to NCA-3800 and approved by W.R.Nicolls, Divisional Q.A. Mgr., June 1981.

Carlinville Plant QA Manual Rev. 3 dated 5/20/81.

This certifies that the provisions of 10 CFR Part 21 are applicable.

THIS DOCUMENT HAS BEEN CHECKED AND FOUND TO COM- PLY WITH THE APPLICABLE SPECIFICATIONS
BY <u>Mark</u> DATE <u>5/4/82</u>

PAR
FEB 3 1982

by

Bonney Forge Division
Energy Products Group
Carlinville, Illinois

D. J. Kaelin
QUALITY ASSURANCE MANAGER

Autli. No. 44-1000 Ledger Control No. 211-3464-1111

The Colonial Machine Company, Inc.

P. O. Box 290 — Pleasantville, Pa. 16341

Phone (814) 589-7033
SEPT. 1, 1978

POWER PIPING COMPANY
P. O. BOX 11
DONORA, PA 15033

CERTIFIED
MILL TEST REPORT

ORDER NO.	OUR ORDER NO.										DATE SHIPPED				
16381-N-1141	11973										9/1/78				
EM	TYPE	MATERIAL-SPEC.										SHIPPED	HEAT NO.	CMC CODE	
ASME SECTION III CLASS 2 (WITH ALL ADDENDA TO AND INCLUDING THE WINTER OF 1972) IN ACCORDANCE WITH SPEC. N-1141-01 REV. 4 <u>ASME SA105</u>													.		
2" 3000# S/W BOSSES PER SK 102 REV. 2													20	91337	ABX
EM	C	MN	P	S	SI	CR	NI	NAO	CU	CB	T1	CO	OTHER ELEMENTS		
	.22	.83	.008	.018	.22										
													RECEIVED		
													JUL 9 1978		
													Eng.	Supervisor	

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

00-16151-00000000

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements as covered by the specification and your purchase order.

By Pharmacy of Waukesha

PERIWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

DISTRICT		CUSTOMER'S PURCHASE ORDER NUMBER	DATE MO DAY YY	ITEM	DATE WANTED	SHIPPING PROVISION WEEK OF:	AMOUNT
471	12	4250	082377	5 11	WK 11/6/77	11/6/77	18278

NETS: 1. DISCOUNTIVE FREIGHT FROM PRICE: IN EFFECT AT TIME OF SHIPMENT

TERMS OF PAYMENT 4 OR 1% OF MILL VALUE

25

10 DAYS+NET 30 DAY

— 1 —

COLONIAL MACHINE COMPANY
BOX 290
SANTANVILLE, PENNSYLVANIA 16341

SHIP TO: (SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)

ADVISE WHEN READY

PIECES	LESS	SIZE AND SHAPE		SIZE TOLERANCE PLUS	PURPOSE	CUSTOMER'S FIRST CHOICE
	30,000	3 1/16"Ø	X	MINUS	MACHINING	
101		SIMILAR		MULTS		LENTH TOLERANCE PLUS
CT DESCRIPTION		MPG	PART			
NORM MS		(206)	ASTM A 105 ASTM A 696 GR B '(EXC COND)			
HARDNESS		ADDT. MACRO/MICRO REQ.	SPECIFICATION NO. ASTM E-34-105 SECTION 2, AS /A SA-696 GR B SECTION 2 EXC COND			
IE		187 MAX BHN	STRAIGHTNESS		INSPECTION	
			OUTS	CUST. DOWNS	OTHER	
			X			
RECEIVED			PAINT & MARK			
100% MIN BDL		JUL 9 1982	STAMP HEAT NUMBER			
100% MAX BDL						

COPPERWELD
STEEL COMPANY
P.O. BOX 1111 WARREN, OHIO 44482

TEST REPORT

ORDER NUMBER	
CUSTOMER	COPPERWELD
MR	18278

DE						CODE	SPEC'N / DESCRIPTION								DATE	
1026 Mod DII															11/10/77	
HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Pb	Al					GRAN SIZE
1337 (ABX)	.22	.83	.008	.018	.22											5-
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	36
	23	21	17	15	13	12	11	10		7		7		5	4	3
														3	2	2

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
7,000	73,500		34.0	67.0	149	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machi- fe. Inc. on August 1972
UQ. LIGHT CO. BEAVER VALLEY NO. 2 LO. NO. 2 BV-58 LG. NO. 12241 PIPE BAR						*Surface unless otherwise noted

S. CERTIFICATE NOTARIZED WHEN REQUIRED

, a Notary Public do hereby certify that
affidavit was subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

day of

POWER PIPING COMPANY
ORDER NO. 16381-N-1141 ITEM 1

~~W.M.~~ hereby certify that the above data are correct as contained in the records of Copperweld Steel Company.

✓✓✓

HERRON TESTING LABORATORIES INC

3000 REED ROAD - CLEVELAND, OHIO 44128
TELEPHONE 216-451-1995

Purchase Order No. CM4357

File No. K 3589

January 6, 1978

Test of 1-13/16" Dia. Steel Coupon, per ASME-SA350, Gr. LF1 and LF2,
Heat No. 91337 (ABX)

Client THE COLONIAL MACHINE COMPANY, INC.

Attention Mr. Barry W. Mallory

CHEMICAL ANALYSIS

Carbon	0.22%
Manganese	0.86%
Phosphorus	0.003%
Sulphur	0.020%
Silicon	0.23%

POWER PIPING COMPANY
ORDER NO. 16381-N-1141 ITEM 1

HERRON TESTING LABORATORIES, INC.

Dee Carpenter

The laboratory is expressly limited to findings based upon material, information, and/or specifications furnished by client and excludes any express or implied warranties as to the fitness of the material and/or process so subjected to examination and/or analysis; a for any particular purpose or use.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

RECEIVED

JUL 9 1982

Stone & Webster
Engineering Corp.
Document Control

Audi. No. N-1141

Ledger Control No. N-3412 Thru N-3414 Page 3 of 3

The Colonial Machine Company, Inc.

P. O. Box 290 — Pleasantville, Pa. 16341

Phone (814) 589-7033

JUNE 13, 1979

POWER PIPING COMPANY
829 BEAVER AVE.
PITTSBURGH, PA

FOR: SAME, DONCRA, PA

CERTIFIED
MILL TEST REPORT

OUR ORDER NO. 20601-N-1141 | OUR ORDER NO. 13315 | DATE SHIPPED 6/13/79

ITEM	MATERIAL-SPEC.	SHIPPED	HEAT NO.	CMC CO.
	ASME SECTION III CLASS 2 (1971 EDITION THRU WINTER 1972 ADDENDA). AND POWER PIPING SPEC. N-1141-01 REV. 4 <u>ASME SA105</u>			
1	2" 3000# S/W BOSSES PER SK 102 REV. 2 M-5014 THRU M-5023	10	91337 —	ABX
2	1-1/2" DITTO M-5024 THRU M-5033	10	91337 —	ACE
3	3/4" DITTO M-5034 THRU M-5053	20	91337 —	ACD

ITEM	TENSILE	% YIELD	% ELONG.	% R.R.	HARDNESS	REMARKS:
1	73500	47000	34.0	67.0		RECEIVED
2	71000	45500	36.0	64.7		JULY 9 1952
3	74500	52000	35.0	65.9		
						Engineering Corporation
DUQ. LIGHT CO., BEAVER VALLEY NO. 2 P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.						
						HARTFORD B.I.B.C. INSPECTION

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements as covered by the specification and your purchase order.

By Rosamary C. Dilks

PART NO.	DESCRIPTION	CUSTOMER'S PURCHASE ORDER NUMBER	DATE MO. / DAY / YE	ITEM	DATE WANTED	SHIPPING PROMISE		SALES ORDER NO.
						WEEK OF:	11/6, 77	
3077 CLE	4250		082377	4 11	WK 10/30/77			18276

ALL COMMODITIES FREIGHT FROM		PRICE IN EFFECT AT TIME OF SHIPMENT		TERMS OF PAYMENT: % OF MILL VALUE				SALES ORDER NO.	
PEN. NO.	NSP			'10 DAYS NET 30 DAYS				18276	

COMMODITY		PPG	PCN	SHIP VIA	CLASS			
STEEL BARS	X	CUST TRK	-	IN TRK LOADS				

SHIP TO:				(SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)			
E COLONIAL MACHINE COMPANY P BOX 290 EASANTVILLE, PENNSYLVANIA 16341				ADVISE WHEN READY			

PIECES	.15	SIZE AND SHAPE	STD	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
		10,000 2 9/16"Ø	X		MACHINING	

MATERIAL DESCRIPTION		MPG	PART	APTH. NO.
NORM HS		(206)	ASTM A 105 ASTM A 696 GR B (EXC COND)	
IE HARDNESS 187 MAX BHN		ADDT. MACRO/MICRO REQ.	SPECIFICATION NO. ASME-SA-TUS SECTION 2. AS 11 SA-696 GR B SECTION 2 EXC COND	

STRAIGHTNESS		INSP. INSPECTION	APTH. NO.
		X	

PAINT & MARK		APTH. NO.
STAMP HEAT NUMBER		

INSTRUCTIONS		APTH. NO.	ORDER NUMBER
CORRECTED COPY 3/7/78			CUSTOMER
TEST REPORT		MR	COPPERWELD

DE	CODE	SPEC'N / DESCRIPTION	DATE
E 1026 Mod DH			10/20/78

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Pb	AI	GRAN SIZE
91337 (ACF)	.22	.83	.008	.018	.22			JUL 9 1982		5-7
	1	2	3	4	5	6	7	8	9	
	23	21	17	15	13	12	11	10	7	

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
45,500	71,000		36.0	64.7	146	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machine Co., Inc. on August 2, 1977

a Copperweld product

HIS CERTIFICATE NOTARIZED WHEN REQUIRED

a Notary Public do hereby certify that
is affidavit is subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

it day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITEM 2

We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

Robert Charles
SUPV. MET LAD.

ITEM #	DISTRICT	CUSTOMER'S PURCHASE ORDER NUMBER	DATE MO DAY	ITEM	DATE WANTED	SHIPPING PROXIMITY WEEK OF	SALES ORDER NO.
53077	CLE	4250	082377 2	11	WK 10/30/77	10/30/77	18274
28 MIL IN CONVENTIONAL FREIGHT FROM		PRICE: IN EFFECT AT TIME OF SHIPMENT		TERMS OF PAYMENT: % OF M.V. OF MILL VALUE			
ARSEN	HGP			10	30	DAYS NET	DAYS
TELL	BARS	X	SHIP VIA	CUST TRK - IN TRK LOADS			
				CLASS			

TO THE COLONIAL MACHINE COMPANY
0 BOX 290
LEASANTVILLE, PENNSYLVANIA 16341

SHIP TO (SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)
ADVISE WHEN READY

Pieces	135	SIZE AND SHAPE	STD X	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
6,000		1 1/2" x 6"			MACHINING	
2/101		SHORTS		AVLTS		STD PLUS MINUS
DUCT DESCRIPTION				MPG	PART	
R NORM MS				(205)	ASTM A 105 ASTM A 696 GR B (EXC COND)	
HARDNESS		ADDT. MACRO/MICRO REQ.		SPECIFICATION NO.	ASM E-5A-105 SECTION 2. AS/N- SA 696 GR B SECTION 2 EXC COND	
TNE	187 MAX BHN			STRAIGHTNESS	INSPECTION	
WEIGHT				PAINT & MARK		
1,000# MIN BDL 1,000# MAX BDL				POWER PIPING COMPANY ORDER NO. 20601-N-1141 ITEM 3		

CORRECTED COPY 3/7/78

TEST REPORT

ORDER NUMBER

CUSTOMER COPPERWELD

ITEM 18274

COPPERWELD
STEEL COMPANY
K 351 / WARREN, OHIO 44482

GRADE	CODE								SPEC'N / DESCRIPTION										DATE		
HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mn	P	Cr	Si	Ni	Cr	Pb	Al			GRAIN SIZE			
91337 (ACD)	.22	.83	.003	.018	.22									JUL 9	1982			5-7			
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32	36
	23	21	17	15	13	12	11	10		7	7		5		4	3	3	2	2		
YIELD PSI	TENSILE PSI		OFFSET %	ELONG. %	R.A. %	HARDNESS*				OTHER DATA											
52,000	74,500			35.0	65.9	149				Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual											

a Copperweld product intended to meet NAS700 as
audited by The Colonial Machine Co., Inc. on
August 2, 1977

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

I, a Notary Public do hereby certify that
this affidavit was subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

this day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

MAR 12 1978

✓-1

HERRON TESTING LABORATORIES, INC.
AN INTEGRAL MEMBER OF THE AMERICAN SOCIETY FOR TESTS AND MATERIALS
CERTIFIED BY THE AMERICAN SOCIETY FOR TESTS AND MATERIALS

Purchase Order No. CM4357

File No. K 3589

January 6, 1978

Test of 1-13/16" Dia. Steel Coupon, per ASME-SA350, Gr. LF1 and LF2,
Heat No. 91337 (ABX, ACF & ACD)

Client THE COLONIAL MACHINE COMPANY, INC.

Attention Mr. Barry W. Mallory

CHEMICAL ANALYSIS

Carbon	0.22%
Manganese	0.86%
Phosphorus	0.003%
Sulphur	0.020%
Silicon	0.23%

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITS. 1 THRU 3

HERRON TESTING LABORATORIES, INC.

Dee Carpenter

The testing is expressly limited to findings based upon material, information, and/or specifications furnished by client and excludes any express or implied warranties as to the fitness of the material and/or process so subjected to examination and/or analysis for any particular purpose or use.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

RECEIVED


JUL 9 1982

Engineering Corporation
Document Review

AUDIT NO. 14-5053 Rev. 2 Page 5 of 5

CERTIFICATE OF TEST ON PIPE MATERIAL

POWER PIPING COMPANY
320 BEAVER AVENUE
BURGH, PA 15233

Cameron 
IRON WORKS, INC.

P. O. BOX 1212
HOUSTON, TEXAS 77001

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)
NO. 2209 (EXPIRATION DATE OCT. 27, 1981)

ALL OPERATIONS WERE PERFORMED BY CIW & MEET THE REQUIREMENTS OF THE LISTED MATERIAL SPECIFICATION AND SEC. III, DIV. 1.

DATE 6 FEB. 1980

CUSTOMER ORDER NO	C.I.W SALES ORDER NO	SPECIFICATION
22550-N-1141	F-9985	ASME SA106 GR. C; ASME SEC. III, CLASS 2 WITH NO. IMPACTS AND POWER PIPING SPEC. N-1141-01, REV. A

PART NO. DESCRIPTION OF MATERIAL	R6-9985-341-300 SEAMLESS PIPE O.D. 30.000" X壁厚 1.875" M.W.
---	--

HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS									
		C	MN	P	S	SI	CR	NI	MO	CU	CO
5616		.24	.84	.008	.018	.22					

QUANTITY OR SERIAL NO.	TEST LOC.	TENSILE PSI	MECHANICAL PROPERTIES						LOT NO.
			YIELD PS	ELONG	RED AREA	FLAT- TENING TEST	BAR SIZE		
5616	2	T-A	.2%	2 "	V	OK	.505	1812	

FORG. SER. # TEST LOT# HEAT #
254612-1 1812 L 5616
254622-1 " "

RECEIVED

JUL 9 1982


Engineering Corporation
Document Review


EACH LENGTH OF PIPE HYDROSTATICALLY TESTED AT 2800 PSI FOR 5 SEC. AND FOUND ACCEPTABLE.

H.P.T. TREATMENT: 1600F., HELD 1 HR. AT TEMP. AIR COOLED.

I, HERB AND SWANSON, DO BEFORE ME THIS
6TH DAY OF FEB. 1980

CERTIFY THESE TESTS TO BE CORRECT AS CON-
TAINED IN THE RECORDS OF THE COMPANY


HERB AND SWANSON


HALLQUIST
METALLURICAL ENGINEER, P.A.T.V.
E69251/vc

DUQ. LIGHT INDUS. VALLEY NO. 2
P.O. NO. 2 EV-58, J.C. NO. 12241, PIPE FAB.

The Colonial Machine Company, Inc.

P. O. Box 290 — Pleasantville, Pa. 16341

Phone (814) 589-7033

JAN. 29, 1982

POWER PIPING COMPANY
P.O. BOX 11
DONORA, PA 15033

CERTIFIED MILL TEST REPORT

OUR ORDER NO.	OUR ORDER NO.	DATE SHIPPED		
34692-N-1141	17066	1/29/82		
ITEM	MATERIAL-SPEC.	SHIPPED	HEAT NO.	CMC CODE
1	ASME SECTION II & III CLASS 2 (1971 EDITION THRU SUMMER 1973 ADDENDA) ASME SA105 NORMALIZED 3/4" 3000# S/W WELD BOSSES PER SK 102, REV. 3	15	55684	ADE

REQ. NO. 2-P-26

ITEM	C	MN	P	S	SI	CR	Ni	Mo	Cu	Cr	Ti	CD	N	OTHER ELEMENTS
	.26	.80	.015	.029	.23									

RECEIVED

JUL 9 1982

10-14-A Minister
E.S. Energy Corporation
Document Review

ITEM	TENSILE	2% YIELD	ELONG.	G. R.A.	HARDNESS	REMARKS:
1	74500 ✓	46500 ✓	31.0 ✓	59.8 ✓	BHN 156 ✓	

THE ABOVE MATERIAL HAS BEEN FURNISHED IN ACCORDANCE WITH OUR QUALITY ASSURANCE PROGRAM, LATEST REVISION DATED 2/27/80, DESIGNED TO SATISFY THE REQUIREMENTS OF ASME SECTION III, SUBARTICLE NA-3700/NCA-3800, AS AUDITED AND APPROVED BY POWER PIPING ON 8/28/80, AND THE REQUIREMENTS OF YOUR SPEC. N-1141-01 REV. 5, AND THE PROVISIONS OF 10 CFR PART 21.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements is covered by the specification and your purchase order.

ANI REVIEW
ANI <u>SWL</u>
DATE <u>1-2-1982</u>

THIS DOCUMENT HAS BEEN CHECKED AND FOUND TO FULLY APPLY WITH THE APPLICABLE SPECIFICATIONS BY <u>SWL</u> DATE <u>1-2-1982</u>

By _____

Ledger Control No 22-7524 Thru 4-25-82

Page 2 of 2

UPPERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

COPPERWELD STEEL COMPANY - WARREN, OHIO 44483		CUSTOMER'S PURCHASE ORDER NUMBER		DATE MO. DAY YR	ITEM	DATE WANTED	SHIPPING PROMISE WEEK OF:	SALES ORDER NO.
ITEM	DISTRICT							
10379 CLE	CM 4837 ADD			060679 1 1	SAP		10/21/79	80108
COMMODITY FREIGHT FROM PRICES IN EFFECT AT TIME OF SHIPMENT				TERMS OF PAYMENT: 4 OR 1% OF MILL VALUE				
BP				10 DAYS NET 30 DAYS				
STEEL BARS		PPD. COL. SHIP VIA	X	CUST TRK - IN TRK LOADS		SHIP TO:	NUCLEAR 20 7-3-74	
THE COLONIAL MACHINE COMPANY, INC. P.O. BOX 290 LEASANTVILLE, PA 16341				ADVISE WHEN READY			(SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)	
IT	QUANTITY	LEN.	SIZE AND SHAPE	STD.	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION	
	7,500		1 1/2" RD	X		MACHINING		
WIDTH				SHORTS		MULTS	STD. LENGTH TOLERANCE PLUS MINUS	
2/10"								
DUCT DESCRIPTION				MFG. PART				
R NORM MS				(206)		SPECIFICATION ASME-SA-105 77 (W78A) ASME-NCA		
HARDNESS		ADDIT. MACRO/MICRO REQ.				3800(W78A) 10 CFR-21-(10/19/78) 30		
INE 187 MAX BHN						MAX CARBON		
NORM CHG NO. AND ASME-SA-		STRAIGHTNESS						
05 (W78A)								
POWER PIPING COMPANY ORDER NO. 34692-N-1141				PA. & MARK		INSPECTION QUAL. CLAS. (Q.C. OTHER)		
T MAX.						<input checked="" type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>		
COPPERWELD STEEL COMPANY								
TEST REPORT for a Copperweld product								
ORDER NUMBER CUSTOMER COPPERWELD 80108								

TEST REPORT

for a Copperweld product

三

80108

DATE
11/5/79

RECEIVED										GRADE	
HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	CO	AI	
55684 (ADE)	.26	.80	.015	.029	.23				JUL 9 1982 10-12 % Welsler Engineering Co., Inc. Demand		6-
	1	2	3	4	5	6	7	8	9	10	11
										12	15-30
										16	20
										24	28
										32	36
YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*			OTHER DATA			
46,500	74,500	.2	31.0	59.8	156			ASME Quality Systems Certification (Materials) No. 2211, expires 10-20-81			
DUQ. LIGHT CO. BEAVER VALLEY NO P.O. NO. 2 BV-53, J.C. NO. 10144, PIPE					H.R.B.			Mercury is not used in the production or testing of Copperweld Steel materials. Normalize - 1650 - 2 hrs.			
					*Surface unless otherwise noted						

MATERIAL PRODUCED AND CERTIFIED TO SPECIFICATIONS SHOWN
ABOVE. NO ADDITIONAL CERTIFICATION IS IMPLIED OR WARRANTED.

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

..... a Notary Public do hereby certify
that the foregoing affidavit was subscribed and sworn to before me by John D. Bly, duly authorized
representative of Copperweld Steel Company.

this day o

NOTARY PUBLIC

THIS DOCUMENT IS BEING
CHECKED AND KEPT
BY THE LIBRARY OF THE
SOCIETY FOR
BIOLOGICAL SCIENCES
mku 2/5/62

Verbal Xfer
SUPV. MET. LAB.
Nov. 5, 1979



Bonney Forge Division
Energy Products Group
CARLINVILLE, ILLINOIS

Lot No. _____

Page 1 of 3

PHONE 217/854-9611

CUSTOMER: Power Piping
CUSTOMER'S Order No.: 15600-N-1141
SHIPPED TO:

Date July 25, 1978
Bonney Order No. 9830
Mark

Item No.	Quantity No.	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks:
1	6	416AA	<p style="text-align: center;"><u>ASME SA105-Gr.II</u></p> <p>32.500 (1.150MW) x 3 (.300) Weldolet <u>Ladle Analysis:</u> C.25 Mn.81 P.009 S.017 Si.19 <u>T/S</u> 75,550 <u>Y/S</u> 48,110 <u>E1</u> 36.5 <u>Ra</u> 65.4 <u>Mill Heat No:</u> 65595 <u>Brinell Hardness:</u> 143 ✓</p> <p style="text-align: right;">RECEIVED</p> <p style="text-align: right;">JUL 9 1982 Stand & Webster Engineering Corporation Document Review</p> <p>This certifies that the fittings supplied were normalized by heating to within 1625°F and 1675°F for 3/4 hr. per inch of thickness (1 hr.min.) followed by cooling in still air.</p> <p>This certifies that the fittings supplied are in complete accordance with the ASME Boiler and Pressure Vessel Code, Section III, Class 2, 1971 edition including winter 1972 addenda; SA105; NB2130; Power Piping Purchasing Spec. N-1141-01, Rev. 4 dated 10-6-77 and the purchase order requirements.</p>

LIGHT CO., BEAVER VALLEY NO. 2
U.S. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

X-

Bonney Forge Division
Energy Products Group
Carlinville, Illinois

by Phil Simpson
 QUALITY ASSURANCE MANAGER
 PHIL SIMPSON

Auth. No. 11-1141

Ledger Control No. M-3958 Thru 10-31-83

Page 1 of 2



Bonney Forge Division
Energy Products Group
CARLINVILLE, ILLINOIS

Log No. _____

Page 1 of 1

PHONE 217/854-9611

CUSTOMER: Power Piping
CUSTOMER'S Order No.: 34973-N-1141
SHIPPED TO:

Date Feb. 25, 1982

Bonney Order No. 9505

Mark

Item No.	Quantity No.	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks:
			ASME SA105N
1 M-7606 5 76072	386B		30 (1.875) x 6 XS Weldolet C.26 Mn.81 P.015 S.024 Si.26 T/S 82,017 Y/S 58 441 El 27.1 Ra 64.8
M-76071	318B		C.26 Mn.81 P.015 S.024 Si.26 T/S 81,442 Y/S 56,250 El 22.8 Ra 49.4

JUL 1 1982

tion
W

DUQ. LIGHT CO. BEVERLY HILLS, CA
P.O. NO. 2 SW 55 10 10

This certifies that the fittings supplied were normalized by heating to within 1625°F and 1675°F for 3/4 hr. per inch of thickness (1 hr. min.) followed by cooling in still air.

The above fittings are in accordance with ASME Section III, Class 2, 1971 edition thru summer 1973 addenda; and NCA-3800.

Fittings supplied are in complete accordance with the purchase order specifications and were manufactured in accordance with the Quality Assurance Program audited to NCA-3800 and approved by W.R.Nicolls, Divisional Q.A. Mgr., June 1981.

Carlinville Plant QA Manual Rev. 3 dated 5/20/81.

This certifies that the provisions of 10 CFR Part 21 are applicable.

THIS DOCUMENT HAS BEEN
CHECKED AND FOUND TO COM-
PLY WITH THE APPLICABLE
SPECIFICATIONS
BY <u>M. Karp</u> DATE <u>5/4/82</u>
SPCC

AN/
PC 3/11/82

Bonney Forge Division
Energy Products Group
Carlinville, Illinois
by D. L. Kehl
QUALITY ASSURANCE MANAGER

Auth. No. JK-1111 Ledger Control No. JK-2400 Thru JK-2400 Page 1 of 1

The Colonial Machine Company, Inc.

P. O. Box 290 — Pleasantville, Pa. 16341

Phone (814) 589-7033
SEPT. 1, 1978

POWER PIPING COMPANY
P. O. BOX 11
DONORA, PA 15033

CERTIFIED
MILL TEST REPORT

OUR ORDER NO.		OUR ORDER NO.	DATE SHIPPED		
	16381-N-1141	11973			9/1/78
ITEM	TYPE	MATERIAL-SPEC.	SHIPPED	HEAT NO.	CMC CODE
		ASME SECTION III CLASS 2 (WITH ALL ADDENDA TO AND INCLUDING THE WINTER OF 1972) IN ACCORDANCE WITH SPEC. N-1141-01 REV. 4 <u>ASME SA105</u>			
1		2" 3000# S/W BOSSES PER SK 102 REV. 2	20	91337	ABX

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

~~00-16121-0003744~~
ИСР-161

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements as covered by the specification and your purchase order.

6781-103
By Barney C. Wadsworth

COPPERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

ITEM NO.	DESCRIPTION	CUSTOMER'S PURCHASE ORDER NUMBER	DATE		ITEM	DATE WANTED	SHIPPING PROVISIONS WEEK OF	SALES ORDER NO.
			MO	DAY				
163077	CLE	4250	082377	6	11	WK 11/6/77	11/6/77	18278

OT COMPETITIVE FREIGHT FROM PRICE IN EFFECT AT TIME OF SHIPMENT

TERMS OF PAYMENT: X OR IN 1/2 OF MILL VALUE

NSP

10 DAYS NET 30 DAYS

CLASS

STEEL BARS X CUST TRK - IN TRK LOADS

SOLD TO:
THE COLONIAL MACHINE COMPANY
P O BOX 290
LEASANTVILLE, PENNSYLVANIA 16341SHIP TO: (SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)
ADVISE WHEN READY

ITEM	PIECES	LB'S	SIZE AND SHAPE	STD	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST CHOICE
		30,000	3 1/16"Ø	X		MACHINING	

NOTES: 3/16" STD

LENGTH TOLERANCE
PLUS MINUS

2/10+

ITEM	PRODUCT DESCRIPTION	HARDNESS	ADDT. MACRO/MICRO REQ.	MPG	PART	SPECIFICATION NO.
1	R NORM MS	187 MAX BHN		(206)		ASTM A 105 ASTM A 696 GR B (EXC COND)

ITEM	SPECIFICATION NO.
1	ASTM E-34-75 SECTION 2 AS MEASURED

ITEM	SPECIFICATION NO.
1	SA-696 GR B SECTION 2 EXC COND

RECEIVED

ITEM	STRAIGHTNESS	INSPECTION
1	X	OUTSIDE CUSTOM OTHER

ITEM	PAINT & MARK
1	STAMP HEAT NUMBER

COPPERWELD
STEEL COMPANY
DX 351 / WARREN, OHIO 44482

TEST REPORT

MR

ORDER NUMBER	CUSTOMER	COPPERWELD
		18278

GRADE	CODE	SPEC'N / DESCRIPTION	DATE
E 1026 Mod DII			11/10/77

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Pb	Al	GRAIN SIZE
91337 (ABX)	.22	.83	.008	.018	.22							5-7

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32	26
23	21	17	15	13	12	11	10	7	7	7	5	4	3	3	2	2				

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
47,000	73,500		34.0	67.0	149	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machine Co., Inc. on August 10, 1977

DUQ. LIGHT CO. BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, LO. NO. 12241 PIPE FAB

a Copperweld product

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

, a Notary Public do hereby certify that
the affidavit was subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

his _____ day of _____

POWER PIPING COMPANY
ORDER NO. 16381-N-1141 ITEM 1MAY 10, 1977
hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

OCT 11 1977

✓✓

HERRON TESTING LABORATORIES, INC.
1000 E. 10TH STREET • PINEVILLE, KENTUCKY 41071
CONTRACTORS AND ENGINEERS SINCE 1910

Purchase Order No. CN4357

File No. K 3589

January 6, 1978

Test of 1-13/16" Dia. Steel Coupon, per ASME-SA350, Cr. LF1 and LF2,
Heat No. 91337 (ABX)

Client THE COLONIAL MACHINE COMPANY, INC.

Attention Mr. Barry W. Mallory

Audi. No. M-1141

Ledger Control No. M-3175 Thru M-3994 Page 2 of 3

CHEMICAL ANALYSIS

Carbon	0.22%
Manganese	0.86%
Phosphorus	0.003%
Sulphur	0.020%
Silicon	0.23%

POWER PIPING COMPANY
ORDER NO. 16381-N-1141 ITEM 1

HERRON TESTING LABORATORIES, INC.

Dee Carpenter

The finding is expressly limited to findings based upon material, information, and/or specifications furnished by client and excludes any express or implied warranties as to the fitness of the material and/or process so subjected to examination and/or analysis for any particular purpose or use.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

RECEIVED

JUL 9 - 1982

Stone & Webster
Engineering Corp.
Document Review

The Colonial Machine Company, Inc.

P. O. Box 290 - Pleasantville, Pa. 16341

Phone (814) 589-7033

JUNE 13, 1979

POWER PIPING COMPANY
829 BEAVER AVE.
PITTSBURGH, PA

FOR: SAME, DONCRA, PA

CERTIFIED
MILL TEST REPORT

YOUR ORDER NO.	20601-N-1141	OUR ORDER NO.	13315	DATE SHIPPED	6/13/79
----------------	--------------	---------------	-------	--------------	---------

MATERIALS SPEC.

SHIPPED

6/13/79

CMAC COO

~~ASME SECTION III CLASS 2 (1971 EDITION THRU WINTER 1972 ADDENDA).~~
~~AND POWER PIPING SPEC. N-1141-01 REV. 4~~

1	2"	30004 S/W BOSSES PER SK 102 REV. 2 M-5014 THRU M-5023	10	91337	ABCF
2	1-1/2"	DITTO M-5024 THRU M-5033	10	91337	ACF
3	3/4"	DITTO M-5034 THRU M-5053	20	91337	ACD

ITEM	TENSILE	% YIELD	% ELONG.	% R.A.	HARDNESS	REMARKS:
1	73500	47000	34.0	67.0		RECEIVED
2	71000	45500	36.0	64.7		JUL 9 1962
3	74500	52000	35.0	65.9		
DUQ. LIGHT CO., BEAVER VALLEY NO. 2 P.O. NO. 2 BV-58, J.O. NO. 12241 PIPE FAB.						Eng. Testing Corporation HARTFORD 3 B.R. 1 CO. INVESTIGATION

P: We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements as covered by the specification and your purchase order.

By Rosemary C. Williams

COPPERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

SHIP DATE	ITEM NO.	CUSTOMER'S PURCHASE ORDER NUMBER	DATE MO DAY YE	ITEM	DATE WANTED	SHIPPING PROMISE WEEK OF:	SALES ORDER NO.
083077 CLE	4250	4250	082377 4 11	WK 10/30/77	11/6/77	18276	

COMPUTER FREIGHT FROM PRICE: IN EFFECT AT TIME OF SHIPMENT

TERMS OF PAYMENT: % OF IN. OF MILL VALUE

10 DAYS NET 30 DAYS

NSP APP CO. SHIP VIA

STEEL BARS X CUST TRK - IN TRK LOADS

CLASS

SOLD TO:
THE COLONIAL MACHINE COMPANY
P O BOX 290
PLEASANTVILLE, PENNSYLVANIA 16341

SHIP TO: (SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)
ADVISE WHEN READY

LEN	Pieces	.IN	SIZE AND SHAPE	STD	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
		10,000	2 9/16" G	X	MU.12	MACHINING	

NOTE	SHORTS	STD	LENGTH TOLERANCE PLUS MINUS
2/101			

PRODUCT DESCRIPTION	MPG	PART	Auth. No.
R NORM MS	(206)	ASTM A 105 ASTM A 696 GR B (EXC COND)	J-1141

NAME	HARDNESS	ADDIT. MACRO/MICRO REQ.	SPECIFICATION NO.	SECTION
INE	187 MAX BHN		ASME-E-SA-T05	SA-696 GR B SECTION 2 EXC COND

NAME	STRAIGHTNESS	INSPECTION
		OUR/CUST/DOV/OTHER X

NAME	PAINT & MARK	STAMP HEAT NUMBER
0000# MIN BDL 0,000# MAX BDL		

EICAL INSTRUCTIONS										ORDER NUMBER
COPPERWELD STEEL COMPANY OX 351 / WARREN, OHIO 44482										CUSTOMER COPPERWELD

CORRECTED COPY 3/7/78
TEST REPORT

MT

18276

GRADE	CODE	SPEC'N / DESCRIPTION	DATE
E 1026 Mod DH			10/20/78

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Pb	Al	GRAN SIZE
91337 (ACF)	.22	.83	.008	.018	.22					5-7
	1	2	3	4	5	6	7	8	9	
	23	21	17	15	13	12	11	10	7	

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
45,500	71,000		36.0	64.7	146	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machine Co., Inc. on August 2, 1977

a Copperweld product

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

a Notary Public do hereby certify that
I, [REDACTED], a Notary Public do hereby certify that
I, [REDACTED] subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

this [REDACTED] day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

[Signature]
John [REDACTED]
SUPV. MET LAB

Auth. No. J-1141

Ledge Copy No. M-5014

Page 1 of 3

Rev. 2

Page 2 of 3

5

COPPERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

SHIP DATE 08/30/77	DISTRICT CLE	CUSTOMER'S PURCHASE ORDER NUMBER 4250	DATE MO DAY YR 082377 2 11	ITEM NO.	DATE WANTED WK 10/30/77	SHIPPING EXCLUSIVE WEEK OF: 10/30/77	SALES ORDER NO. 18274
FC	COMMODITY FREIGHT FROM HSP	PRICE IN EFFECT AT TIME OF SHIPMENT	TERMS OF PAYMENT: % OF INV. OR MILL VALUE 10 DAYS NET 30 DAYS				
TA.	STEEL BARS	PPG COL. X	SHIP VIA CUST TRK - IN TRK LOADS				CLASS

TO THE
THE COLONIAL MACHINE COMPANY
P O BOX 290
PLEASANTVILLE, PENNSYLVANIA 16341

SHIP TO
(SAME AS "SOLD TO" UNLESS OTHERWISE NOTED)
ADVISE WHEN READY

FEET	PIECES	135 6,000	SIZES AND SHAPE 1 1/2" G	STEP X	SIZE TOLERANCE PLUS MINUS	PURPOSE MACHINING	CUSTOMER'S FIRST OPERATION
LENGTH 12/10'			SHORFS		MULTS	STD	LENGTH TOLERANCE PLUS MINUS
PRODUCT DESCRIPTION HR NORM MS				MPG (205)	PART	ASTM A 105 ASTM A 696 GR 3 (EXC COND)	
GRAIN	HARDNESS	ADDT. MACRO/MICRO REQ.			SPECIFICATION NO.	ASM E-5A-105 SECTION 2. AS A SA 696 GR B SECTION 2 EXC COND	
F/T/NF	187 MAX BHN				STRAIGHTNESS	INSPECTION	
TAG					QUALITY CONTROL OTHER	X	
BUNDLE	6,000# MIN BDL 10,000# MAX BDL			PAINT & MARK	POWER PIPING COMPANY ORDER NO. 20601-N-1141 ITEM 3		

CORRECTED COPY 3/7/78

COPPERWELD
STEEL COMPANY
BOX 351 / WARREN, OHIO 44482

TEST REPORT

ORDER NUMBER

CUSTOMER COPPERWELD

18274

GRADE	CODE	SPEC'N / DESCRIPTION	DATE
E 1026 Mod DH			10/28/77

HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mn	P	Cr	Ni	Pb	Al	Grain Size
91337 (ACD)	.22	.83	.008	.018	.22					JUL 9	1982			5-7

JOINT	YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*		OTHER DATA																			
						1	2		3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32	26
	52,000	74,500				23	21	17	15	13	12	11	10		7	7		5	4	3	3	2	2				

MECHANICAL PROP.	YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*		OTHER DATA																		
						1	2		3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32
	52,000	74,500				35.0	65.9		149																	

a Copperweld product intended to meet NAS700 as audited by The Colonial Machine Co., Inc. on August 2, 1977

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

, a Notary Public do hereby certify that affidavit was subscribed and sworn to before me by a duly authorized representative of Copperweld Steel Company.

this day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

We hereby certify that the above data are correct as contained in the records of Copperweld Steel Company.

MY COMMISSION EXPIRES

NOTARY PUBLIC

John Clegg
SUPERVISORY LAB

MAR 12 1978

Aut. No. 2-1141

Lead Control No. M-5014 Thru M-5053

Page 5 of 5

HERRON TESTING LABORATORIES, INC.
1017 E. 100th Street, CLEVELAND, OHIO 44106
CONCENTRATION ANALYSIS, PARTS PER MILLE

Purchase Order No. CM4357

File No. K 3589

January 6, 1978

Test of 1-13/16" Dia. Steel Coupon, per ASME-SA350, Gr. LF1 and LF2,
Heat No. 91337 (AB, ACF & ACD)

Client THE COLONIAL MACHINE COMPANY, INC.
Attention Mr. Barry W. Mallory

CHEMICAL ANALYSIS

Carbon	0.22%
Manganese	0.86%
Phosphorus	0.003%
Sulphur	0.020%
Silicon	0.23%

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITS. 1 THRU 3

HERRON TESTING LABORATORIES, INC.

Lee Carpenter

The information is expressly limited to findings based upon material, information, and/or specifications furnished by client and excludes any express or implied warranties as to the fitness of the material and/or process so subjected to examination and/or analysis for any particular purpose or use.

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

RECEIVED

JUL 9 1982

Engineering Corporation
Document Review

CERTIFICATE OF TEST ON PIPE MATERIAL

Cameron 
IRON WORKS, INC.

IRON WORKS, INC.

P. O. BOX 1213

HOUSTON, TEXAS 77001

BEAVER PIPING COMPANY
BEAVER AVENUE
TSBURGH, PA 15233

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS)
NO. 2209 (EXPIRATION DATE OCT. 27, 1981)

ALL OPERATIONS WERE PERFORMED BY CIW & MEET THE REQUIREMENTS OF THE LISTED MATERIAL SPECIFICATION AND SEC. 111, DIV. 1.

5 FEB. 1980

CUSTOMER ORDER NO. 101-A SALES ORDER NO.
22550-N-1141 F-9985

SPECIFICATION

ASME SA106 GR. C; ASME SEC. III,
CLASS 2 WITH NO. IMPACTS AND POWER
PIPING SPEC. N-1141-01, REV. A

C.W PART NO. 86-9985-341-300 PIPIN
DESCRIPTION OF MATERIAL SEAMLESS PIPE
S.D. 30.000" x 1.875" M.W.

CHEMICAL ANALYSIS

HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS									
		C	MN	P	S	SI	CR	NI	MO	CU	CO
L 5616		.24	.84	.008	.018	.22					

T NO.	QUANTITY OR SERIAL NO.	TEST LOC.	YIELD PS			MECHANICAL PROPERTIES			LOT NO.
			TENSILE PS	.2%	ELONG	RED AREA	FLAT- TENING TEST	BAR SIZE	
L 5615	2	T-A	73,900	44,400	32.1	56.5	OK	.505	1812

FORG. SET. #	TEST LOT#	HEAT #
354612-17716	1812	L 5516
354622-17717	"	"

RECEIVED

JUL 9 1932

Engineering Document Review

✓ EACH LENGTH OF PIPE HYDROSTATICALLY TESTED AT 2800 PSI FOR 5 SEC. AND FOUND ACCEPTABLE.

HEAT TREATMENT: 1600F., HELD 1 HR. AT TEMP. AIR COOLED.

~~CONFIDENTIAL - SUBJECT TO DECISION OF THE ATTORNEY GENERAL~~

IDENTIFY THESE TESTS TO BE CORRECT AS FROM
THE RECORDS OF THE COMPANY.

6TH DAY OF FEB. 1980

Hillcrest
METALLURGICAL EQUIPMENT

~~ALL INFORMATION CONTAINED~~

299851/vc

DUQ. LIGHT COMPANY, VALLEY NO. 2
P.O. NO. 2 5V-53, I.C. NO. 12241, PIPE FAB.



Bonney Forge Division
Energy Products Group
CARLINVILLE, ILLINOIS

Log No. _____ Page 1 of 1

PHONE 217/854-9611

CUSTOMER: Power Piping
CUSTOMER'S Order No.: 34973-N-1141
SHIPPED TO:

Date Feb. 24, 1982
Bonney Order No. 9505
Mark

Item No.	Quantity No.	Bonney Lot No.	Grade or Specification No. Chemical Analysis, Physical Properties, Remarks:
2	3	358B	ASME SA105 30 x 4 (1.875xXS) Weldolet C.23 Mn.72 P.013 S.021 Si.21 T/S 75,218 Y/S 50,962 El 22.1 Ra 44.4


DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-53, J.O. NO. 12241, PIPE FAB.

The above fittings are in accordance with ASME Section II Class 2, 1971 thru summer 1973 addenda; and NCA-3800.

Fittings supplied are in complete accordance with the purchase order specifications and were manufactured in accordance with the Quality Assurance Program edited to NCA-3800 and approved by W.H.Nicolls, Divisional Q.A. Mgr., June 1981.

Carlinville Plant QA Manual Rev. 3 dated 5/20/81.

This certifies that the provisions of 10 CFR Part 21 are applicable.



Bonney Forge Division
Energy Products Group
Carlinville, Illinois

D.L. Hall
QUALITY ASSURANCE MANAGER

Part No. 22-222

Ledger Control No. 22-222

FORM NPP-I DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
 As Required by the Provisions of the ASME Code Rules, Section III, Div. I N-1141-6322

1. Fabricator	Power Piping Com., Inc., Donora, PA 15033	Order No	N-1141
2. Purchaser	Beaver Valley Power Station, Unit #2	Order No	2BV-58, J.O. No. 12241
3. Location	Duquesne Light Company, Pittsburgh, PA	Location of Plant	Shippingport Borough, PA
4. Pipe System Identification	Main Steam And Safety Header(MSS)	MK-MSS-41-1/1002-041-107	
5. Drawing No.	RP-2B & E & F	Prepared by	Stone & Webster Engineering Corp.
6. No. and Rev. No.	N/A	Boston, Massachusetts	
7. The material design combination and workmanship complies with ASME Code Section III, Class 2			
8. Date	1971	Addenda Date	Winter 1972
9. Commissioned Manufacturer Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this Report			
10. Description	By Field	psi	
11. Description of piping inspected			

- 1. Pcs. - 30" I.D. x 1.875" Min Wall Smls. C.S. Pipe, SA-106, Gr. C, Item No. 4, L.C. No. P-1750, Ht. ID L-5616, Serial # 35461-YZ, Lgth. = 2' - 11 3/16" lg.
- 1. - 4" (X-Stg.) on 30" I.D.(1.875" IW) F.S. W-O-L SA-105, Item No. 20, L.C. No. M-7602, Ht. ID 358-B

NOTE: Welding Electrodes L.C. No. E-69, E-88, E-107, E-108, E-111

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE

Date June 10, 1982 Signed Power Piping Company By Alice J. Fastella N-1023
 Certificate of Authorization Expires January 7, 1983 Certificate of Authorization No. _____

CERTIFICATE OF SHOP INSPECTION		N-1141- 6322
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of <u>PENNSYLVANIA</u> and employed by <u>Lumbermens Mutual Casualty Co.</u> of <u>Long Grove</u> , <u>IL</u> , have inspected the piping described in this Data Report on <u>6-10-82</u> , 19 <u>82</u> and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III. By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.		
Date	<u>6-10-82</u>	Commissioner
<u>Jay T. Bell</u>		PA. 54

CERTIFICATE OF TEST ON PIPE MATERIAL

POWER PIPING COMPANY
829 BEAVER AVENUE
PITTSBURGH, PA 15233

CORRECTED REPORT
2/12/80

P. O. BOX 1212
HOUSTON, TEXAS 77001

P. O. BOX 1212
HOUSTON, TEXAS 77001

ASME QUALITY SYSTEM CERTIFICATE
(MANUFACTURER) NO. N-2209 EXPIRES 10-27-81
ALL OPERATIONS WERE PERFORMED BY CIW & MEET THE REQUIREMENTS
OF THE MATERIAL SPECIFICATION AND SEC.III,DIV.1. DATE 30 JAN. 1980

CUSTOMER ORDER NO 225550-K-1141	C.I.W. SALES ORDER NO F-9985	SPECIFICATION ASME SA106 GR.C; ASME SEC. III, CL.2 WITH NO IMPACTS AND POWER PIPING SPEC. N-1141-01, REV. A
C. I. PART NO DESCRIPTION OF MATERIAL C.P. S.D. P.D. WALL 1.875" M.W.	66-9985-341-300 SEAMLESS PIPE	

HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS										
		C	MN	P	S	SI	CR	NI	MO	CU	CO	TI
L 5616		.24	.84		.008	.018	.22					

HEAT NO.	QUANTITY OR SERIAL NO.	TEST LOC.	YIELD PSI		MECHANICAL PROPERTIES				LOT NO.
			TENSILE PSI	.2%	% ELONG	% RED. AREA	FLAT- TESTING SIZE		
L 5616	7	T-A	73,900	44,400	32.1	56.5	OK	.505	1812

<u>FORG. SER. #</u>	<u>TEST LOT#</u>	<u>HEAT#</u>
F-1780 - 35461YZ	1812	L 5616
F-1782 - 35461YY	"	"
F-1781 - 35461YX	"	"
F-1785 - 35461YW	"	"
F-1773 - 35461YU	"	"
F-1779 - 35462YZ	"	"
F-1774 - 35462YY	"	"

EACH LENGTH OF PIPE HYDROSTATICALLY TESTED AT 2800 PSI FOR 5 SEC. AND FOUND ACCEPTABLE.

HEAT TREATMENT: 1600F., HELD 1 HR. AT TEMP. AIR COOLED.

SUBSCRIBED AND SWEARN TO BEFORE ME THIS

12TH DAY OF FEB. 1980.

I CERTIFY THESE TESTS TO BE CORRECT AS CONTAINED IN THE RECORDS OF THE COMPANY.

H. C. Shantz
METALLURGICAL REVIEWER

DUQ. LIGHT CO., BEAVER VALLEY 5-10 C/ft
NO. 2 RIVER TO NO. 19541 SIDE BAR

FORM NPP-I DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES

1. Fabricated by	Power Piping Company, Donora, PA 15003	Order No	N-1141	
2. Fabricated for	Beaver Valley Power Station, Unit #2	Order No	2BV-58, J.O. No. 12241	
3. Owner	Con Edison Duquesne Light Company, Pittsburgh, PA	Location of Plant	Shippingport Borough, PA	
4. Pipe System Identification	Main Steam Safety Valve Header (MSS)	MK-MSS-106-1/1002-106-46		
(a) Drawing No	RP-2B, 2E	Prepared by	Stone & Webster Engineering Corp.	
(b) Narram. Board No.	N/A		Boston, Massachusetts	
6. The material, design, construction, and workmanship complies with ASME Code Section III, Class	2			
Editor	1971	Addenda Date	Winter 1972	
			Case No.	N/A
Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:				

- 7 Snap Hydrostatic Test By Field _____
 8 Description of engine inspected _____

- 1 Pcs. - 35.945" Nom O.D. x 30.000" Min I.D. Smls. C.S. Extruded Header, SA-106, Gr. C, Item No. 1, L.C. No. M-5607, Ht. ID KMMM

2 - 36" x 2.672" M.W. Smls. C.S. Cap, SA-234, WP-C, Item No. 7, L.C. No. M-5611, Ht. ID KMKO; Item No. 10, L.C. No. M-5612, Ht. ID KMKO

5 - 6" 1500# F.S. Long W/N Flg. R/F SA-105, Item No. 17, L.C. No. M-1789, Ht. ID TPOK, Serial # 609381-601; Item No. 18, L.C. No. M-1790, Ht. ID TPOK; Serial # 609381-601; Item No. 19, L.C. No. M-1791, Ht. ID TPOK; Serial # 609381-601; Item No. 20, L.C. No. M-1792, Ht. ID TPOK, Serial # 609381-601; Item No. 21, L.C. No. M-1793, Ht. ID TPOK; Serial # 609381-601

DEC 03 1981

St. John's College

NOTE: Welding Electrodes L.C. No. E-69, E-88, E-89, E-90, E-106, E-105, E-108, E-110

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Power Piping Company

Date January 7, 1903 Signed John C. Dill

Certificate of Authorization Expires JANUARY 1, 1955

Section of the described piping conforms with the requirements of SECTION III
Alice J. Partilla

A-1000

CERTIFICATE OF SHOP INSPECTION

N-1141- 3255

I, the undersigned, holding a valid commission issued by the Maritime Board of Boiler and Firetube Vessel Inspection and/or the State or Province of PENNSYLVANIA, and maintained by Liebherrmann Mutual Casualty Co., of Long Beach, California,

inspected the piping described in this Data Report on 11-22-1, 1905, and note that to the best of my knowledge and belief, the NPS Certificate Holder has constructed this piping in accordance with the applicable subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping to this Date I mention. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury, property damage or loss of any kind arising from or connected with this inspection.

Date - 11-22-51 10 AM

Comments

PLATE 1

*CORRECTED REPORT 2-18-82

C. P. MANN

CHICAGO FLOOR PIPING COMPANY

829 Beaver Avenue
Pittsburgh, Pennsylvania 15211

CUSTOMER ORDER NO. 16208-N-1141

CHUB CHBDE# NO. 802403

PACKING LIST NO.

Auth No N-114

JOURNAL OF POLYMER SCIENCE: PART A-1

NUCLEAR

Our Item 1A, 1B, 1C

WILLIAMSON 83 749-997-175-91

REFERENCES

MEAT TREATMENT FOR HEPATITIS PRO

[View all reviews](#) | [Write a review](#)

Design for AMTE Sect. III Class 2

1100 PSIG @ 360° F. 1971 Winter 33

וְעַל-מִזְבֵּחַ תְּמִימָה תְּמִימָה תְּמִימָה תְּמִימָה

Number W-1938 Expires 11/23/22

3. *On the other hand, the author's statement that*

REMARKS: This Certifies that the requirements of Section III including the Winter of 1972 and specification No. N-1141-01 have been met

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
R.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

SUBSCRIBED AND SWORN TO BEFORE ME

DAY OF October 19 79
Siegfried Heischt
NOTARY PUBLIC

CERTIFICATE OF TEST ON PIPE MATERIAL

G & W ENERGY PRODUCTS
6TH & CHESTNUT STREETS
OSAWATOMIE, KS 66064

Cameron

IRON WORKS, INC.
P. O. BOX 1242
HOUSTON, TEXAS 77001

*SUPPLEMENTARY REPORT 6/12/79.

ASME QUALITY SYSTEM CERTIFICATE
(MANUFACTURER) NO. N-2209 EXPIRES 10-27-81ALL OPERATIONS WERE PERFORMED BY CIW & MEET THE REQUIREMENTS
OF THE MATERIAL SPECIFICATION AND SEC. III, DIV. 1.


DATE 30 MAY 1979.

CUSTOMER ORDER NO.	C.I.W. SALES ORDER NO.	SPECIFICATION
12-2203	F-9598	ASME SA106 GR. C; ASME SEC. III, CLASS 2 THRU WINTER 1972 ADDENDUM; NO IMPACTS
CIW PART NO. DESCRIPTION OF MATERIAL	86-9598-358-300 SEAMLESS PIPE G.O.	X.I.D. 30.000" X WALL 2.750" M.W.
<hr/>		
HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS
		C MN P S SI CR NI MO CU CO TI
J 7984		.26 .90 .014 .019 .23

HEAT NO.	QUANTITY OR SERIAL NO.	TEST LOC.	TENSILE PSI	YIELD PSI .2%	MECHANICAL PROPERTIES				LOT NO.
					ELONG	RED. 2"	FLAT. AREA	BAR TESTING SIZE	
J 7984	3	TRANS.	79,200	44,300	28.4	52.5	OK	.505	933

FORG. SER. # TEST LOT#

33801	933
33802	933
33803	933

KMM


MATERIAL HAS BEEN MANUFACTURED IN ACCORDANCE WITH NA-3700.

*Test material from heat treated pipe.

*Heat Treatment: 1600F., held 1 hr. at temp. Air cooled.

*Each length of pipe hydrostatically tested at 2800 psi for 5 sec. and found acceptable.

DUR. LIGHT CO. BEAVER VALLEY I.D. 2 802404
D.O. NO. 2 EV-58, J.C. NO. 12241, PEE FAE

SUBSCRIBED AND SIGNED TO PERFORM THIS

30TH

DAY OF MAY 1979.

John D. Cameron
Quality Control Manager
Kawartha Power and Light Board, Ontario, Canada

CERTIFY THAT THE TESTS PERFORMED ARE AS
STATED IN THE ACCORDING TO


P-2530

16

CUSTL Power Piping Company
829 Beaver Avenue
Pittsburgh, Pennsylvania 15233

CUSTOMER ORDER NO. 16208-N-1141

PACKING LIST NO. 01174



FPG Special Products Division

Box B
Jla, Kansas 66071
913/294-5331

Material SA- -W.P.C.

SPECIFICATION NO. FABR. MPS-B2

HEAT TREATMENT

Design per SAME SECT. III CLASS 2

1100 PSIG @ 560° F. 1971 Winter 72

Quality System Certificate (Material)
Number N-1938 Expires 11/25/80

HEAT NUMBER	PHYSICAL PROPERTIES				CHEMICAL ANALYSIS							DESCRIPTION	
	YIELD POINT OR YIELD STRENGTH AT _____ % OFFSET, PSI	TENSILE STRENGTH PSI	ELONG. IN _____ %	RED. OF AREA %	C	MN	P	S	SI	MO	CR	NI	
Item 2	(SIX) -	36" OD x 2.672" M. W. Cap											
KMKO	46500	78000	28		.33	.74	.020	.023	.20				36" OD Weld Caps
		(scd 2" Rd)											
BHN:	188	192	190	192	190	190							

REMARKS: This Certifies that the requirements of Section III including the
Winter of 1972 and specification No. N-1141-01 have been met.

UT per NB-2530, SA-577 & SA-578. Acceptable

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

MARGARET MAISCH	
STATE NOTARY PUBLIC	
Miami County, Kansas	
My Appointment Expires:	
9-16-82	

SUBSCRIBED AND SWORN TO BEFORE ME

30th DAY OF

Oct. 1979

Margaret Maisch

NOTARY PUBLIC



CUSTOM ALLOY CORPORATION

MATERIAL MANUFACTURERS TEST REPORT

Heat Code: CH-E

Revised 5/25/79

PRODUCT DESCRIPTION		CUSTOMER DATA	
Item CAP	*	Name	Capitol Pipe & Steel Products
Size 36" OD		P.O. No.	D-87961-35N
Wall 2 3/4" MW		Tag No.	12-3523
Grade WPC		Job No.	N-11792-1
Specifications ASME SA234 WPC per Section III Class 2, 1971 Edition thru Winter 1972 Addenda			

*3" Straight flange & square cut ends.

CHEMICAL ANALYSIS

	C	Mn	P	S	Si	Cr	Ni	Mo	Cb		
Ladle	.33	.74	.020	.023	.20						
Check											

* MECHANICAL PROPERTIES *

Yield Point PSI	Tensile Strength PSI	Elong. in 2"	Red. of Area %		Starting Material Control No.	Starting Material conforms to the chemical and tensile requirements of
500	78,000	28.0			CAC 9150	

MILL HEAT NO: 401E 8311 - Bethlehem Steel Corporation

REMARKS: (A) Heat Treatment: Normalize at 1650°F ± 25°F, held at temperature for 1 hr. per inch, then cooled in still air.

(B) Hardness: HB 76

(C) We certify these items were manufactured under a Quality System meeting the requirements of ASME Section III, Par. NCA-3800.

(D) U.T. Procedure: NB-2530, SA-577 and SA-578. Longitudinal and Shear Wave. - Satisfactory

2A Hours
2F

NUCLEAR KNLCO

JUN - 4 1979

JANET P. SHERMAN
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires May 31, 1979State of New Jersey
County of Hunterdon

and subscribed before me this

-8 day of May 1979
Janet P. Sherman
NOTARY PUBLIC OF NEW JERSEY
My Commission Expires -DUQ. LIGHT CO., BEAVER VALLEY INC.
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPEAcceptance and Approval by Customer
Representative/Inspector

I certify the above product has been manufactured in accordance with all applicable parts of the above specification and standards.

CUSTIM ALLOY CORPORAION

File No. N-1141 Ledger Control No. M-5609 Third M-5614 Page _____ of _____
 Custom Alloy Corporation • 1000 • Salt Lake City, UT 84101 • Telephone 201-432-7111 • TWX: 510-235-3362 • TELEX: 13-6456
 * Revised 5/25/79 CFC NO: 9150
 REAT NO: N/A

ULTRASONIC TEST REPORT

STONER: pitol Pipe & Steel	INSPECTOR/LEVEL II	DATE:
3 NO: -11792-1	EXAMINER/LEVEL III <i>G. D. Tracy</i>	DATE: 3/21/79
EM: isk	CUSTOMER APPROVAL	DATE:
OCEDURE: * SA-577, SA-578, NB-2530		
ST EQUIPMENT: tautkramer USIP-11	SUPPLIES: Exosen 14	
NSDUCER SIZE: dia and 1/2 x 1	TYPE: Gamma	FREQUENCY: 2½ MHz
IBRATION STANDARD CONFIGURATION: Reflection and 3% Buttress Notch		
CE LEVEL (%): and DAC Curve	90° and 45°	

The following material has been inspected and accepted in accordance with the above procedure:

6 fittings Accepted



KM/KO

*2A Lbne
ZF*

NUCLEAR


DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

EXHIBIT

CONTINUED

DRAFTING DIVISION

G & W ENERGY PRODUCTS GROUP




BHN-188

AS-BUILT DRAWING

INSP. BY

Klaes DATE 8-7-79



DETAIL "A"

UN--CONTROLLED

NOTES:

1. DESIGN PER ASME SECT III CL 2 1100 PS.IG. @ 560°F.
2. FAB'R. PER MPS-B2
3. MAT'L. SA-234-W.P.C.
(6) REQ'D.


P&Q. LIGHT CO. BEAVER VALLEY NO. 2
P.O. NO. 2 BV-53, J.O. NO. 12241 PIPE FAB

10-13-78 P&Q CUST.

REV. DATE DESCRIPTION BY CH.

THIS DRAWING IS THE PROPERTY OF
G&W ENERGY PRODUCTS GROUP
GULF & WESTERN MANUFACTURING COMPANY

and is loaned upon condition that it is not to be reproduced
or copied, in whole or in part, or used for forming information
to be sold, or for any other purpose detrimental to the interests of
G&W Energy Products Group, and is to be returned when no longer
needed. The equipment shown herein is protected by
copyright and is controlled by G&W Energy Products Group, Gulf & Western
Manufacturing Company and any infringer on such patents is
liable to prosecution.



NUCLEAR

Engineered Systems Division
GULF & WESTERN MANUFACTURING COMPANY

36" O.D. X 2.672" M.W. CAP


POWER PIPING CO.

DR. -	JOB. - 12724	P.O. NO. - 3108-N-1111
CH. -	FILE	DRAWING NO.
APP. -	DATE	ITEM
SCALE -	7-17-78	REV.


102404 2 1

SHEET A-1 OF 1

EXTERNS
ORIGINATED
BASCHEE SYSTEMS DIVISION
G & W ENERGY PRODUCTS GROUP



AS-BUILT DRAWING



DETAIL "A"

UN-CONTROLLED

NOTES:

1. DESIGN PER ASME SECT III CL 2 1100 PS.IG @ 560°F.
2. FAB'R. PER MPS-B2
3. MAT'L. SA-234-W.P.C.
- (6) REQ'D.

AQ. LIGHT CO. BEAVER VALLEY NO. 2
AQ. NO. 2 BV-58, J.O. NO. 12241, PIPE TAB

10-13-78 PER CUST.

BY	DATE	DESCRIPTION	BY CH.
----	------	-------------	--------

THIS DRAWING IS THE PROPERTY OF
G & W ENERGY PRODUCTS GROUP
GEI & WESTERN MANUFACTURING COMPANY

It is understood and agreed that it is not to be reproduced
or copied, in whole or in part, nor for furnished
to others, or for any other purpose, without the written consent of
G & W Energy Products Group, and is to be returned upon request.
The equipment shown herein is protected by patents and
is manufactured by G & W Energy Products Group, GEI & Western
Manufacturing Company and any infringement on such patents is
liable to prosecution.




36"O.D.X2.672" M.W. CAP

POWER PIPING CO.


DR. - 1/1	JOB. - 12774	P.O. NO. - 3108-N-1171
CH. - U.Y.	FILE	DRAWING NO. - 102401
APP. - C	DATE	ITEM NO. - 2
SCALE - 1/1	7-17-78	SHEET A-1 OF 1

EXKRSIS
CERTIFIED
DAMSAFE SYSTEMS DIVISION
G & W ENERGY PRODUCTS GROUP



AS-BUILT DRAWING

INSP. BY R. Hess DATE 8-7-79



DETAIL "A"

NOTES:

1. DESIGN PER ASME SECT III CL 2 1100 PSIG @ 560°F.
2. FAB'R. PER MPS-B2
3. NAT'L. SA-234-W.P.C.
(6) REQ'D.

~~BB~~ LIGHT CO., BEAVER VALLEY NO. 2
 NO. 2 PV-58, LO. NO. 12241, PIPE FAB.

10-13-79 PER CUST.

EV. DATE DESCRIPTION BY CH.

THIS DRAWING IS THE PROPERTY OF
 G & W ENERGY PRODUCTS GROUP
 Gulf & Western Manufacturing Company

It is understood upon condition that it is not to be reproduced
 or copied, in whole or in part, or used for furnishing information
 to others, or for any other purpose detrimental to the interests of
 G & W Energy Products Group, and it is to be returned upon request.
 The equipment shown herein is protected by patents issued
 or controlled by G & W Energy Products Group, Gulf & Western
 Manufacturing Company and any infringement on such patents is
 liable to prosecution.




36" O.D. X 2.672" M.W. CAP


POWER PIPING CO.

DR. -	JOB #	P.O. NO.
CH.	FILE	DRAWING NO.
APP.	DATE	ITEM #
SCALE	7-17-79	SHEET A-1 OF 1

**ENGINNEERING
DEPARTMENT
ENGINEERED SYSTEMS DIVISION
G & W ENERGY PRODUCTS GROUP**



AS-BUILT DRAWING



NOTES:

- DESIGN PER ASME SECT III CL 2 1100 PSIG @ 560°F.
- FAB'R. PER MPS-B2
- MAT'L. SA-234-W.P.C.
(6) REQ'D.

GULF LIGHT CO BEAVER VALLEY NO. 2
NO. 2 BV-58, JO. NO. 12241, PIPE FAB.

10-13-78 PER CUST.

REV. DATE DESCRIPTION BY CH.

THIS DRAWING IS THE PROPERTY OF
G & W ENERGY PRODUCTS GROUP
Gulf & Western Manufacturing Company

This drawing was prepared in good faith, in whole or in part, for internal information of others, or for any other persons designated in the interests of G & W Energy Products Group, and is to be returned upon request. The equipment shown herein is protected by patents owned or controlled by G & W Energy Products Group. Gulf & Western Manufacturing Company and its employees or stockholders are liable to prosecution.

UN-CONTROLLED

NUCLEAR
Engineered Systems Division
GULF & WESTERN MANUFACTURING COMPANY


36" O.D. X 2.672" M.W. CAP

POWER PIPING CO.

DR. NO.	JOHNSON 7-24	P.O. NO.	3108-N-1171
CH. NO. (P)	FILE	DRAWING NO.	ITEM NO.
APP. NO.	DATE	502404-1	2
SCALE	7-17-78	SHEET A-1 OF	1


EXCERGIES
DETERMINED

BALANCE SHEETS DIVISION
G & W ENERGY PRODUCTS GROUP



AS-BUILT DRAWING

INSP. BY K Ross DATE 8-7-79



DETAIL "A"

NO MOUNTABILITY REQUIRED
NO MOUNTING TABS

NOTES:

UN--CONTROLLED

- DESIGN PER ASME SECT III CL 2 1100 PSIG @ 560°F.
- FAB'R. PER MPS-B2
- MAT'L. SA-234-W.P.C
- (6) REQ'D.

WQ. LIGHT CO., FEATHER VALLEY NO. 2
D. NO. 2 PV-59, LO. NO. 12241, PIPE FAB.

10-13-78 PGZ CUST.

102 DATE DESCRIPTION BY CH.

THIS DRAWING IS THE PROPERTY OF
G & W ENERGY PRODUCTS GROUP
Gulf & Western Manufacturing Company

It is issued upon condition that it is not to be reproduced
or copied, in whole or in part, or used for furnishing information
to others, or for any other purpose detrimental to the interests of
G & W Energy Products Group, and is to be returned upon request.
The equipment shown herein is protected by patents owned
or controlled by G & W Energy Products Group, Gulf & Western
Manufacturing Company and any infringement of such patents is
liable to prosecution.



NUCLEAR


Engineered Systems Division
GULF & WESTERN MANUFACTURING COMPANY

36"O.D.X2.672" M.W. CAP

POWER PIPING CO.


DR. -	JOB NO. 2474	P.O. NO. 15108-N-1171
CH. ... 07.	FILE	DRAWING NO.
APP. - C	DATE	ITEM NO. 2
SCALE -	7-17-78	SHEET A-1 OF 1

**EXHIBIT
CERTIFIED
DRAFTING SYSTEMS DIVISION
G & W ENERGY PRODUCTS GROUP**



AS-BUILT DRAWING

INSP. BY R. Ross DATE 8-7-79



DETAIL "A"

UN-CONTROLLED

NOTES:

1. DESIGN PER ASME SECT III CL 2 1100 PS.IG @ 560°F.
2. FAB'R. PER MPS-B2
3. MAT'L. SA-234-W.P.C
- (6) REQ'D.

1. LIGHT CO. BEAVER VALLEY NO. 2
NO. 2 RV-58 J.O. NO. 12241, PIPE FAB.

10-13-78 PER CUST.

REV. DATE DESCRIPTION BY CH.

THIS DRAWING IS THE PROPERTY OF
G & W ENERGY PRODUCTS GROUP
GULF & WESTERN MANUFACTURING COMPANY

It is understood condition that it is not to be reproduced
or copied, in whole or in part, or used for furnishing information
to others, or for any other purpose detrimental to the interests
of G & W Energy Products Group, and is to be returned upon request.
The equipment shown herein is protected by patents awarded
or controlled by G & W Energy Products Group, Gulf & Western
Manufacturing Company and any reference to such patents is
subject to prosecution.

NUCLEAR
Engineered Systems Division
GULF & WESTERN MANUFACTURING COMPANY

36" O.D. X 2.672" M.W. CAP

POWER PIPING CO.

DR. -	JOB # 27-74	P.O. NO. 13208-N-1171
CH. 1, 1/2	FILE	DRAWING NO. 802404-2
APP. - C	DATE	ITEM 1
SCALE - 1/16	7-17-79	SHEET A-1 OF 1

Year To . Procession Acceptance



Taylor Forge Division
Energy Products Group

© 2007, 2011 by Pearson Education, Inc.

SWANSON FLOWER PIPING CO.

820 BEAVER AVE

829 BEAVER AVE.
PITTSBURGH, PA. 15231

Auth. No. 11-11

Ledger Control No. M-1704 Thru

1000 Hrs. 1

March 8, 2013

SPECIFICATION NO. ASME SA103

APPENDIX B

ANALYSIS OF THE NORMALIZED

ESTATE PLANNING

829 BEAVER AVE.

PITTSBURGH PA 15233

CUSTOMER ORDER NO. 4402- N1141

OUR ORDER NO. 60938

PACKING LIST NO. 61364

REMARKS

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB

SUBSCRIBED AND SWORN TO BEFORE ME

THIS 27 DAY OF FEBRUARY 1976

Linda A. Clark
NOTARY PUBLIC

Colony Post Office, San Saba County, Texas
By Commissioner E. C. F. 1927

Paul D. Shuler



CHIKE ADABETOR

SECTION 11

FORM NPV-1 MANUFACTURERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
(As Required by the Provisions of the ASME Code, Section III, Div. 1)

1. Manufactured by Fluid Systems Division - Gulf + Western Manufacturing Company
 (Name and Address of Manufacturer)
 Stone & Webster Engineering Corporation, Boston, MA ✓
 2. Manufactured for Stone & Webster Engineering Corporation, Boston, MA
 (Name and Address of Purchaser or Owner)
 ✓
 3. Location of Installation Beaver Valley Unit #2 Shippensburg, PA
 (Name and Address)
 ✓
 4. Pump or Valve Valve ✓ Nominal Inlet Size 24 ✓
 (inch) ✓ Outlet Size 24 ✓

(a) Model No. Series No. or Type	(b) Manufacturers' Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built
(1) Ball Valve	6246 ✓	N/A ✓	E-24-900-8 ✓	2 ✓		1980 ✓
(2)			- Rev. B ✓			
(3)				DUQUESNE LIGHT CO.		
(4)				STONE & WEBSTER ENG.		
(5)				BEAVER VALLEY UNIT 2		
(6)				QBV-211		
(7)			J.O. 12241 P.O. NO.			
(8)				2 MSS-HYDRO		
(9)				MARK NO.		
(10)				150 - Gulf West Corp		

5. Main Steam Line Trip Valve ✓ VENDOR'S NAME
(Brief description of service for which equipment was designed)

6. Design Conditions 1100
(Pressure) psi 558
(Temperature) °F or Valve Pressure Class _____ (1)

7. Cold Working Pressure 2220 psi at 100°F.

8. Pressure Retaining Pieces

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in Items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1 (Back)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bottling N/A			DUQUESNE LIGHT CO. STONE & WEBSTER ENG. BEAVER VALLEY UNIT 2 2BV 211 J. O. 12241 P.O. NO. WAV. NO. 2MS HYV101 ESD - Gulf + Western
(d) Other Parts Trace 8H/HT#C17396	SA 479 Type 316	Vitco	Pipe Plug (Qty. 2) VENDOR'S NAME

9. Hydrostatic test 3350 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components. Section III, Div. I, Edition 74.
 Addenda None, Code Case No. N/A, Date 10 Nov 80
 Signed Fluid Systems Division by Raymond L. All - QA Manager
 (Manufacturer)
 Our ASME Certificate of Authorization No. 1209 to use the N symbol expires 9/8/81
 (N) (NFV) (Date)

CERTIFICATION OF DESIGN

Design information on file at EPG G+WStress analysis report (Class 1 only) on file at N/ADesign specifications certified by (1) Carl Otto RichardsonPE State PA Reg. No. 016297EStress analysis certified by (1) N/APE State N/A Reg. No. N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by HSBICL Co. of Hartford, Connecticut have inspected the pump, or valve, described in this Data Report on 11-10 19 80 and state that to the best of my knowledge and belief, the Manufacturer has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 11-10 19 80

(Inspector)

Commissions MA946 WC 108 ✓ PP

(Nat'l Bd., State, Prov. and No.)

MATERIAL IDENTIFICATION

<u>ITEM</u>	<u>SERIAL NUMBER</u>	<u>HEAT NUMBER</u>	<u>COMMENT</u>
BODY	0004	57117	
BONNET	3	216492	
BALL	2	2896	
REDUCER	2	216492	
REDUCER	5	216492	put #s away from well sizes
SEAT RETAINER	1A to 1D	79708/EPZD	
P.R. BOLTING	N/A	N/A	
OTHER PIPE PLUG	8H	C17396	
SEAT-	6	PO 919	ADDED TO LIST PER QA REQUEST
SEAT-	2	PO 917	NOT REQUIRED - RA INFO ONLY RVA 10/7/80

Verified:

F.S.D.: Raymond V. Allen 10/7/80 CUST: _____ A.N.I. VJL 10-7-80

Final Dimensional Inspection:

Drawing: E-24-900-8 Rev.: B Accepted: FSD A. Jensen 10-7-80
Ref N&O-14 CUST Verifiable 10-7-80

Cleaning and Preservation:

Spec.: PS 1105 Rev.: 2 Accepted: FSD Raymond V. Allen 11/1/80
CUST Verifiable 11-7-80

Painting:

Spec.: PS 1105 Rev.: 2 Accepted: FSD G. Jones 11-24-80
CUST Verifiable 11-24-80

Packaging:

Spec.: PS 1105 Rev.: 2 Accepted: FSD R. Allen 11/12/80
CUST Verifiable 11/12/80

Product Approval and Certification

By: Raymond V. Allen Title: QA Manager Date: 12 Nov '80

DUQUESNE LIGHT CO.
 DEAVER VALLEY POWER STATION
 UNIT No. 2
 P. O. No. 2BV-211
 MAIN STEAM LINE TRIP VALVE
 MARK No. 2MSS-HYV101

Form 14b
1/10/80

3.0.2

THE Grinnell

RADIOGRAPHIC EXAMINATIONS

System of Register No. 24-900 VALUE BODYN		Plate No. 7004	Held No. 5	Pipe Size and Schedule 30.5 x 1.75"	Welder No. N/A								
TECHNIQUE	Videos											Interpretation	
	Source											ACC: ✓	
	Source Curved or LTP & RL											✓	
	Source Size of Focal Spot											✓	
	Source Focal Distance											✓	
	Time											✓	
	Actual Weld Thickness											✓	
	Insulator											✓	
	Sensitivity											✓	
	Shim Thickness											✓	
Film Size											✓		
Film Type											✓		
Viewing Technique	Single <input type="checkbox"/>	Double <input type="checkbox"/>											✓
Screens	Front												✓
	Back												✓
Development	88" Kodak S min.												✓
	Automatic												✓
Welding Procedure												✓	

INTERPRETATION

File Interval	Defect Type										Comments
	L1	A2	S	E	UL	UC	C	CR	T	BL	
A-D											
D-G											
G-J											
J-M											
M-P											
P-S											
S-X											
X-T											
T-N											

MARK FROM Pb FILTER AND OVERLAP

COVERAGE FOR ACCESS T

DENSITY ACCEPTABLE TO REFERENCE STANDING (RTE-0) (SKETCH)

4.2 A2

* SEE ATTACHED TECHNIQUE SHEET # EPG-1

LP - Lack of Penetration UC - Under Cut
 LF - Lack of Fusion C - Crater
 S - Slag CR - Crack
 P - Porosity T - Tonguten
 BT - Burn Thru BL - High-Low

ENERGY PRODUCTS GROUP

Gulf & Western Mfg. Co.

235 Kilvert Street

Warwick, R.I.

Quality Assurance Dept.

John J. Tighe 12-28-78
Signed Date

DUQUESNE LIGHT CO.

BEAVER VALLEY POWER STATION

UNIT NO. 2

P. O. NO. 2BV-211

MAIN STEAM LINE TRIP VALVE

MARK NO. 2MSS-HVY103

W.J.T. 3-8-79

Dec. 14 1978 By J. Giarrusso
 Interpreted by J. Giarrusso
 Dec. 15 1978 By J. Giarrusso
 Interpreted by J. Giarrusso
 Dec. 15 1978 By J. Giarrusso

Customer EPG
 Contract 3334
 Inspection Standard RTE-1 REV 05-77
 Date 12-20-78

Location Warwick, R.I.
 Job No. 21-2932
 RTE-1 (5.3.1)
 Acceptance No. 5320770

CERTIFICATE OF TESTS

DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 2BV-211
MAIN STEAM LINE TRIP VALVE
MARK NO. ASME-QUALITY SYSTEM CERTIFICATE (MANUFACTURER)
NO. N-1261 EXPIRES 10-27-78.

Baby CMT is S.U.C.
Cameron
IRON WORKS, INC
P. O. BOX 1212
HOUSTON, TEXAS 77001


CUSTOMER ORDER NO. 9701 C.I.W. SALES ORDER NO. F-20022-1 SPECIFICATION ASME Sec. III Part A, SA350 Gr. LF2 ASME Sec. III, Cl. 2 74 Edition. Process per Energy Products Group Specification, MS-1153 Rev. E

DESCRIPTION OF MATERIALS 24" Valve Body Dwg. # D-112-000-0924 Rev. E

C.I.W. PART NUMBER 66350-01 Rev. C

HEAT NO.	LOCATION OR SERIAL NO.	CHEMICAL ANALYSIS						
		C	MN	P	S	SI	CR	NI
57197		.20	1.17	.008	.006	.23		

O.K / 2BV-211



ALL OPERATIONS WERE PERFORMED BY C.I.W. & MEET THE REQUIREMENTS OF THE LISTED MATERIAL SPECIFICATION AND SEC. III DIV. I.

No weld repairs performed.

NTITY R SERIAL NO.	HEAT NO.	Tensile PSI	MECHANICAL PROPERTIES					Test Lot#
			.2 % Offset Yield PSI	% Elong. 2 In.	% Red. Area	Bar Size		
3	57197	75,200	52,700	32.5	71.0	.505	#0007	

V-Match Charpy Impact Test Results:

Form Ser.#	Test Lot#	Test Temp.	Ft.Lbs.	Lat. Exd.	% D/F
00004	0007	40°F.	86.0	72 MILS	455
0005	0007	40	82.0	64	40
0006	0007	40	95.0	71	45

Parts ultrasonically examined in accordance with approved procedure FU-212 Rev. B with Fig. 4, dated 1-24-78, and Addenda I dated 8-18-78 and found acceptable. Report attached.

Parts magnetic particle examined in accordance with approved procedure FI-75, dated 1-8-74 with Addenda I dated 5-18-78 and found to be acceptable. Report attached.

A. N. I. REVIEW
BY *[Signature]* DATE 10-4-78
 INITIAL FINAL

Heat treatment was in accordance with approved Procedure FH-455 N/C. INITIAL FINAL

HEAT TREATMENT:

- 1650°F., held 3 hrs. at temp. Air cooled.
- 1600°F., held 3 hrs. at temp. Water quenched.
- 1200°F., held 6 hrs. at temp. Air cooled.

treat furnace reports attached.

CRIMSON AND BROWN TO BEFOR ME THIS
28th DAY OF September 1978

[Signature]
NOTARY PUBLIC
G. A. TOWNSHEND
My Commission Expires June 1, 1979

I CERTIFY THESE TESTS TO BE CORRECT AS CONTAINED
IN THE RECORDS OF THE COMPANY.

METALLURGICAL ENGINEER H. O. WRIGHT, *[Signature]*

WALL THICKNESS MEASURING PROCEDURE MW 5-1A

PART DWG N^o D-112-000-0924039
 PART NAME 24"-900" BODY
 MATERIAL SA 350 GR. LF-2
 T-SERIAL N^o 0004

HEAT N^o 57197

INSPECTED BY John Triggs

DATE 3-1-79

CUSTOMER Q/A

DATE



DUQUESNE LIGHT CO.
 BEAVER VALLEY POWER STATION
 UNIT No. 2
 P. O. No. 23V-211
 MAIN STEAM LINE TRIP VALVE
 MARK No. 2MSS-HYV101

ZONE AREA	MIN DIM.	METHOD *	ACTUAL DIM. & LOCATION							
			1	2	3	4	5	6	7	8
A	3.60 INCH	U	4.075	4.075	4.128	4.092	4.067	3.995		
B	3.60 INCH	U	4.260	4.390	4.525	4.440	4.275	4.185		
-	3.60 INCH	U	4.170	4.250	4.300	4.165	4.113	4.160		
E	2.59 INCH	U	5.505	5.510	4.935	5.054	5.150	5.180	5.037	5.260
F	2.79 INCH	U	5.600	5.599	5.998	5.997				
G	2.59 INCH	U	5.250	5.060	4.500	5.000	5.050	4.760	4.450	4.830
							/			

TYPE INSTRUMENT Branson 303B NO. 1094

CALIBRATION STANDARD SA 350 LF2 4"X6"X7" BLOCK #1094

off min 2.9

TYPE TRANSDUCER Aerotech

TRANSDUCER SIZE .750

TRANSDUCER FREQUENCY 1 MHZ

LEVEL I


COUPLANT Erosen #30

OPERATOR John Triggs

* C = DIAL CALIPER

U = ULTRASONIC

J.J. ANI
3-1-79SUPPLEMENT 5
SPECIFICATION PS-1056
SHEET 5 OF 5 Rev 3



Forged Products Division

6505 N. HOUSTON-ROSSLYN ROAD
HOUSTON, TEXAS 77091
GULF-WESTERN MANUFACTURING COMPANY

CERTIFIED TEST REPORT

G.O.R.

PAGE 1 OF 2

TO:
ENERGY PRODUCTS GROUP
FLUID SYSTEMS DIVISION
235 KILVERT STREET
WARWICK, RHODE ISLAND 02886

SHIPPED
SALE

*TR 14471
IR 14471
P.O. 0186*

DATE SHIPPED	CUSTOMER'S ORDER NO.			SHIP ORDER NO.	SHIPPED VIA	COLLECT <input type="checkbox"/> PREPAID <input type="checkbox"/>
10/5/78	P.O. 10103			SEI1-1700		
QUANTITY	ITEM NUMBER	DESCRIPTION	ITEM NUMBER	DESCRIPTION	ITEM NUMBER	DESCRIPTION
3	25826	1-3	216492 ✓	ROUGH MACHINED COUPLET FORGINGS TO FINISH PER Dwg. 0240-000-0924000 REV. 0		
2	25825		216492 ✓	7" X 10" X 24" TEST BARS		
MATERIAL HAS BEEN MANUFACTURED IN ACCORDANCE WITH ASME BOILER & PRESSURE VESSEL CODE, SECTION III, CLASS 2 REQUIREMENTS 1974 EDITION WITH NO ADDENDA. MATERIAL WAS MANUFACTURED PER MATERIAL SPECIFICATION AS-1041 REV. 1 DTD 12/3/76 AND CONFORMS TO THE REVISED MATERIAL SPECIFICATION AS-1041 REV. 3 DATED 6/6/78 UNDER CHANGE ORDER #3 DATED 8/21/78. MATERIAL HAS BEEN HEAT TREATED PER CHANGE ORDER #3 DTD 8/21/78 AND AS-1041 REV. 3 DATED 6/6/78 UTILIZING LINDHOLM/COOK HEAT TREATMENT PROCEDURE 41478 APPROVED BY FLUID SYSTEMS DIVISION.						
DUQUESNE LIGHT CO. VALLEY POWER STATION						

CHEMICAL ANALYSIS									
HEAT NO	MILL SOURCE	C	MN	PHOS	SUL	SL	Ni	CR	CU
216492	SHARON	.21	.14	.015	.015	.27			

PHYSICAL PROPERTIES							TESTING IN. - MM		
YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	ELONG.	RED OF AREA %	HARDNESS	TYPE CHARPY	TEMP °F	ABSRB ENERGY FT./LBS	LATERAL EXP (MILS)	SHEAR
26,000	52,100	33.0	68.2		V-NOTCH	+40°F	83.0-26.0-61.0	.020	50
								.030	50
								.020	50

MISCELLANEOUS TESTING

TYPE OF TEST		G.S.
ELECTRIC PARTICLE EVALUATION PER ACT FLUORIMETRIC METHOD OF EAG-PROCEDURE 41478 REV. 2 8/21/78/79, ACCEPTABLE WITHIN NO REPEATABLE INDICATIONS.		<i>W.J. LANZ 3-8-79</i>

SEARCHED INDEXED SERIALIZED FILED

216 DAY OF OCTOBER 19 78


MONINA M. HENDON

Notary Public in Harris County, Texas

My Commission Expires June 19, 1980

I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE AT
THE OFFICE OF FORGED PRODUCTS, INC., AND THAT THIS STEEL WAS
MANUFACTURED AND FORGED IN THE UNITED STATES OF AMERICA

W.J. LANZ



Forged Products Division

6505 N. HOUSTON-ROSSLYN ROAD

HOUSTON, TEXAS 77091

GULF-WESTERN MANUFACTURING COMPANY

CERTIFIED TEST REPORT


PAGE 2 OF 2

6.0.B

ENERGY PRODUCTS GROUP
 FLUID SYSTEMS DIVISION
 235 KILVERT STREET
 WARWICK, RHODE ISLAND 02886

SAME
 SHIPPED
 TO

DATE SHIPPED			CUSTOMER'S ORDER NO		SHOP ORDER #		SHIPPED VIA		COLLECT <input type="checkbox"/> PREPAID <input type="checkbox"/>	
ITEM	QUANTITY	ITEM NO.	ITEM GUIDE					DESCRIPTION		
3	25026	1-5	216492	ROUGH MACHINED BONNET FORGINGS TO FINISH PER DWS. 0248-000-0024000 REV. 0						
2	25026		216492	7" X 10" X 24" TEST BARS MATERIAL WAS PHYSICALLY TESTED FOR TENSILE REQUIREMENTS AND CHARPY V-NOTCH IMPACT REQUIREMENTS @40°F PER MATERIAL SPECIFICATION AS-1041 REV. 3 DTD 6/6/78. CHARPY V-NOTCH WAS PERFORMED AT +40°F PER INSTRUCTIONS OF L. CAFFON MATERIAL WAS RET FLUORESCENT MAGNETIC PARTICLED TESTED PER EPG-PROCEDURE 41.411 REV. 2 DTD 7/15/78 AND MATERIAL SPECIFICATION AS-1041 REV. 3 DTD 6/6/78 UNDER CHANGE ORDER #3 DTD 8/21/78 DRAWINGS SUBMITTED OF "AS SHIPPED" ROUGH MACHINED FORGINGS AND TEST BAR PER AS-1041 REV. 3 DTD 6/6/78 UNDER CHANGE ORDER #3 DTD 8/21/78.						



FLUORESCENT LIGHT CO.
POWER STATION

CHEMICAL ANALYSIS

HEAT NO	MILL SOURCE	C	MN	PHOS	SUL	SIL	NI	CR	CU	MO	
1											
2											
3											

PHYSICAL PROPERTIES

YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	ELONG.	RED OF AREA %	HARDNESS	TYPE CHARPY	TEMP °F	ABSRB ENERGY FT./LBS	LATERAL EXP (MILS)

MISCELLANEOUS TESTING

TYPE OF TEST		G.S.

OF 115TH DAY OF OCTOBER 19 70

I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE AT THE OFFICE OF FORGED PRODUCTS, INC. AND THAT THIS STEEL WAS MANUFACTURED AND FORGED IN THE UNITED STATES OF AMERICA

MONNA M. HENDON
Notary Public in Harris County, Texas

LINDBERG/COOK
HEAT TREATING
COMPANY

P. O. BOX 24147 • HOUSTON, TEXAS 77029 • 713/672-6601



Division of
LINDBERG
CORPORATION

CERTIFICATION OF HEAT TREATMENT

- FORGED PRODUCTS
- HOUSTON, TEXAS
-

NUCLEAR

WE HEREBY CERTIFY THAT THE PARTS DESCRIBED WERE GIVEN THE FOLLOWING HEAT TREATMENT

		TIME AT HEAT	COOLANT
ANNEALED	°F		
NORMALIZED	1600 °F	12 HRS	AIR
QUENCHED	1600 °F	12 HRS	WATER
DRAWN	1200 °F	16 HRS	AIR
NITRIDED	°F		
STRESS RELIEVED	°F		

HARDNESS TEST 156-196 BHN% OF PCS. TESTED 100%

We further certify that heat treatment described above is true and correct and that temperatures and test results were obtained with standard approved methods.

Subscribed and sworn to before me this
2 ND day of OCTOBER, 19 78

J. J. Gamble
in and for the County of Harris, State of Texas


My Commission Expires

9/30/80

BONNETS TO FIN PER DWG#D-248-
000-0924000 3) TEST BARS 7x10x
24"LG SPEC. NO. 41478 -
MATERIAL: SA350LF2
HT# 216492
CAL. DATE 9/14/78 -

(Signature)
LINDBERG/COOK HEAT TREATING COMPANY

Paul Gamble
PAUL GAMBLE
PLANT SUPERINTENDENT



DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 2BV-211
MAIN STEAM LINE TRIP VALVE
MARK No. 2MSS-HYV101

6.0E

WeldEx


NUCLEAR

TO Forged ProductsREPORT NO. 104-7 P. O. NO. 9637 JOB NO. 25826MATERIAL SPECIFICATION A-350 LF-2, HT # 216492 PC# 1-3 INCLUSIVEP.O. #0186 MATERIAL: ROUGH MACHINED BONNET FORGINGS (3)TENSILE TEST

<u>Specimen No.</u>	<u>Y. S. (psi)</u>	<u>T. S. (psi)</u>	<u>% Elong.</u>	<u>% R. A.</u>
1	52,600	82,100	33.6	68.2

CHARPY V-NOTCH IMPACT TEST

Test Temperature: +40°F



<u>Specimen No.</u>	<u>Ft. Lbs.</u>	<u>Percent Shear</u>	<u>Lateral Exp.</u>
1	83.0	50.0	.060
2	98.0	50.0	.069
3	81.0	50.0	.060

THIS MATERIAL CONFORMS TO ASME SA350 LF2 & MS-1041 REV. 3 DATED 6/6/78

DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 23V-211
MAIN STEAM LINE TRIP VALVE
MARK No. 2MSS-HYV101

MEETS SPECIFICATION: XX YES NO NABy: Richard C. DivenDate: 10-5-78

6.0C

INVOICE DATE 01-03-77	F.O. DATE 12-27-76	F.O. NO. H-03198	CUST. CODE 62812	OPER. CODE 0785	PROD. CODE 721	INVOICE NO 3044	
SHIP TO X 35001PM 11500 N. HOU-290- HOUSTON, PA. 15230 DUE 01-29-77			DWS RATING	INVOICE DATE 1-26-77			
			TERMS NET 30 DAYS	A LATE PAYMENT CHARGE WILL BE ASSESSED MONTHLY ON BALANCE DUE ON OUR NET 30 DAY TERMS.			
S STEEL CORPORATION OF TEXAS 11500 N. HOU-290- HOUSTON, TX 77091			S H I P T O	STEEL CORPORATION OF TEXAS C/O FORGED PRODUCTS 11500 N. HOU-290- HOUSTON, TX 77091			
REQUESTED SHIP DATE 01-24-77		DATE SHIPPED 1-26-77	FROM Farrell, Pa.	VEHICLE IDENTIFICATION			
METHOD RAIL		MIN. WT. 80000	F.O.B. FARRELL	ROUTE CONRAIL % ST. LOUIS % % FT. WORTH % FWD. 004 PC 564982			
TAX	DEF.	FIN.	OTHER	BALANCE DUE 418.00	PREPAID OR COLLECT PREPAID	WT. 200000	DATE ARR LF 01-24-77

SPECIFICATIONS & DESCRIPTION

UF YOUR P.O. ITEM NO. 1
 PRODUCT - HOT ROLLED SEMI-FINISHED
 STEEL, BLOCKS, ALLOY, ELECTRIC
 FURNACE VACUUM DEGAS, FORGING QUALITY
 SPECIFICATION - EF-A-350 LF-2-A
 C .30 MAX, M1 .95/.1.35, P .035 MAX,
 S .04 MAX, SI .15/.30-A/.045 MIN
 SPECIAL INFORMATION - FORGED PRODS #7208
 CARRIER - CUNDYL
 DIMENSIONS - 36.000 X 32.000 X 29000
 PIECE WT - 29000 MINIMUM
 ARTLTY - 200,000 LBS

P.O.#0185
 MATERIAL: ROUGH MACHINED BONNET FORGINGS
 HEAT NO.: 216492 ✓
 JOB NO.: 25826
 THIS MATERIAL CONFORMS TO ASME SB350 LF2 &
 MS-1041 REV. 3 DATED 6/6/78

Edward F. Blk


HEAT NO.	B/L NO.	UFTS SKIDS	PCS. COILS	WEIGHT SHIPPED	THEO. WEIGHT
216492	096878	5	5	158140	79,670

Plus Prepaid Freight

A N A L Y S IS	C	MN	P	S	sf	e1
1	26	1.74	.015	.015	.27	.056
2						
3						
4						

WE HEREBY CERTIFY THAT MA
 COVED BY THIS INVOICE WE
 DUCED IN CONFORMITY WITH THE
 CABLE PROVISIONS OF THE FAIR
 STANDARDS ACT OF 1935, AS AM
 AND THAT PRICES CHARGED
 ARE NOT IN EXCESS OF THOSE
 CHARGEABLE UNDER THE
 STABILIZATION PROGRAM.

DUOTEST 11-11	
Temp	STEAMER P.S.I. CO. P.S.I.
Elastic Yld.	STEAMER P.S.I. POWER STATION P.S.I.
Elevation	LINE NO. 2
Hardness	H. O. M. 2000
Cond	100%
Size	7 - 8 LINE END VALVE
	100% IN 2000



I certify that the above figures are a true and correct copy of those contained in the record of this Corporation.



PART D/N & NS

D-248-000-0924000

PART NAME

24" 900" BONNET

MATERIAL

SA 350 LF-2

PART SERIAL NO.

#3

HEAT NO 216492

6.1

INSPECTED BY b. williams


DATE

3-2-79

CUSTOMER G/A

DATE

ZONE A	MINIMUM DIM.	METHOD *	ACTUAL DIM.	ZONE B	MINIMUM DIM.	METHOD *	ACTUAL DIM.
START	6.5	C	6.633	START	2.19	C	4.450
30°			6.634	90°			4.440
60°			6.635	180°			4.445
90°			6.631	270°	2.19	C	4.448
120°			6.626				
150°			6.627				
180°			6.623	ZONE C	MINIMUM DIM.	METHOD *	ACTUAL DIM.
210°			6.624	START	4.4	C	5.555
240°			6.625	90°			5.552
270°			6.629	180°			5.553
300°			6.638	270°	4.4	C	5.554
330°	6.5	C	6.635				



STAMP STARTING POINTS
 A @ C ON C - USE LOW
 STRESS STAMP - MEASURE
 IN A CLOCKWISE DIRECTION.

A - 12 POINTS
 B - 4 POINTS
 C - 4 POINTS

NO. 1275

DUQUESNE LIGHT CO.
 BEAVER VALLEY POWER STATION
 UNIT No. 2
 P. O. No. 23V-211
 MAIN STEAM LINE TRIP VALVE
 MARK No. 2MSS-HVV101

LEVEL 1 ✓

TYPE INSTRUMENT DIAL CALIPER
 CALIBRATION STANDARD 6" LENGTH STD.
 TYPE TRANSDUCER N/A
 TRANSDUCER SIZE N/A
 TRANSDUCER FREQUENCY N/A
 COUPLANT N/A
 OPERATOR b. williams

1 = DIAL CALIPER
 2 = ULTRASONIC

SUPPLEMENT E
 SPECIFICATION PS-1056
 SHEET 3 OF 5 Rev. 3

CUSTOME EBV Systems Division 235 Kilvert St. Warwick, R.I. 02886				24"-900# BALL EH1798N	S Same P PRLS/NK4601 TO	JUN 24 1977 FLUID GLOW MACHINERY 235 KILVERT ST. WARWICK, RI 02886
				CODE 200	MARK FOR P.O.	
TELE	COLLECT XX	VIA Truck	SHIP DATE			TERMS Net 30 days
CUSTOMER EBV Systems Division				D.F. ORDER NO. 1-04292		
QUANTITY 3	C.R. 1	PATTERN NO. D-004-000-0924005-A	CUSTOMER ORDER NO. 6110			
PART PER 1	MOLDS 2	B/P NO.	UNIT WGT. 4450	TOTAL WGT. 13,350	OPEN. 25	
CUST. SPECIFICATIONS SA351 CF8M VT-MSS-SP55, pract.				METAL 514	H.T. CODE H4	ROUTING CODE 128
CUST. REC'D. 12/23/76				TEST BARS		
SALESMAN 05						
BUYER Lockwood				3 K.B.		
CUST. REC'D. 3/1/77						
(2) 2 copies T.R. & docu., Subm. 2 rgh TB/ht. (8) Melt & Lab use 514 metal with 8/15% ferrite, aim for 11% ferrite using Schaeffler diagram, No weld. design for nucl. H.T. Water Quench 1950°F H.T. chart req. Submit sample and obtain RT results before production. Notify EBV quality Control 5 days before pouring						

CERTIFICATION OF CHEMICAL & PHYSICAL TESTS-HEAT TREATMENT-N.D.E. TESTS

HEAT NO. 2896	SERIAL NO'S.	QUANTITY IN HEAT 1	DATE POUR'D 5-4-77			
CHEMICAL ANALYSIS-NAT. SPEC. SA351 CF8M						
CS	MN 90	SI 1.1	CR 0131, 014 19.07	NH 11.49	MO 2.40	FER 10%
TENSILE PROPERTIES						
UT 1900	V.D. 48	A.S. 450	EL. 4070	R.A. 170	BHN RANGE	
IMPACT TEST (FT.-LBS.)				BEND TEST		
TEMP. F°	1	2	3	AVG.	DEG.	TYPE NO. RESULTS
IMPACT TEST (M.L.E.)				SHEAR CORROSION TEST		
TEMP. F°	1	2	3	AVG.	TYPE	RESULTS
REMARKS: Casting's heat treated at Dodge Foundry All heat treat charts are filed in QC lab 2. Part # H TEST ROLL						

NON-DESTRUCTIVE TESTS AND RELEASE REPORT

N.D.E. SPECIFICATIONS			SER. NO. 2896	APP'D. 1	DATE 5/77	REPORTS ATTACHED
VT PER MSS-SP55						DET. VALVE LIGHT CO.
MT-LPT PER						DIMENSIONAL LAYOUT
RT PER						DET. VALLEY POWER STATION
UT PER						MT-LPT WELD REPAIR MAP
ER	Ferrite % (Schaeffler diagram) = 10%		EBV Systems			DET. WELD REPAIR MAP
REMARKS:	Heat Treat Procedure		Date 8-22-77			DET. SHOT SCRATCH & TEC.
			Sign 8/1/77			DET. FILM & READER SHEETS
HEAT TREAT PROCEDURE	48.05 + 48.51		2896	5-27-77		DET. WELD REPAIR MAP
REMARKS: Heat Treat Procedure			THIS REPORT CERTIFIES THAT THESE RESULTS COMPLY WITH THE REQUIREMENTS OF THE SPECIFICATIONS AND ORDER.			
			Signature: Date: 5/16/77			
			SUPERVISOR OFFICE: DODGE FOUNDRY & MACHINE CO.			



PRL Industries, Inc.

CORNWALL, PENNSYLVANIA 17016 / TELEPHONE (717) 273-6787 / TELEX 84-2372

©

HEAT TREAT CERTIFICATION

page 1 of 8

HEAT TREAT FURNACE NO. C

CUSTOMER EPG DATE 7-5-78

P. O. NO. 1051D PRL FILE NO. 2797

DESCRIPTION 24" Ball Castings PATTERN NO. D-004-000-0924005 R/A

MATERIAL ASME SA351 CF8M

CASTING INFORMATION

PRL NO.


K46D

CUSTOMER SER. NO.

2

HEAT NO.

2896 ✓



DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 23V-211
MAIN STEAM LINE TRIP VALVE
MARK No. 2MSS-HYV101

Heat Treat Procedure PRL HTB, Rev. D, Add. 198 H.T. Process Solution Anneal

Charge No. M-17 Charge Temp 600°

Time to Equilibrium 8 hrs 30 mins Htg. Rate NA °/hr.

Holding Temperature Range 2050°F ± 25°

Time at Temp. 1 hrs Clg. Rate NA °/hr.

Cooling Data Water Quench thru 1600° to below 800° within 4 minutes.

Thermocouple Information Thermocouples in contact with castings.


Original Heat Treat Charts are maintained at PRL Industries, Inc.

Heat Treated by Metlab Form No. 148, Rev. 1

Approved by A

Q	P	3
---	---	---

 Date 7-12-78



Forged Products Division

6505 N HOUSTON-ROSSLIN ROAD

HOUSTON, TEXAS 77091

GULF-WESTERN MANUFACTURING COMPANY

CERTIFIED TEST SHEET

PAGE 1 OF 2

8.0 A

TO: ENERGY PRODUCTS GROUP
 FLUID SYSTEMS DIVISION
 235 KILVERT STREET
 WARWICK, RHODE ISLAND 02886

SHIPPING TO: ESBARLESNE LIGHT CO.
 BEAVER VALLEY POWER STATION
 UNIT No. 2
 P. O. No. 2BV-211

ITEM: MAIN STEAM LINE TRIP VALVE

SHIPPED 10/5/78		CUSTOMER'S ORDER NO. P.O. #0187		SHOP ORDER #EH1798N		MADE A.D. 2MSS-HYV101	SHIPPED VIA COLLECT PREPAID	
QUANTITY	HEAT NO.	HEAT SOURCE	DESCRIPTION					
6	25827	I-6	216492	ROUGH MACHINED REDUCER FORGINGS TO FINISH PER DWG. C254-000-0924320 REV. D SUBMITTED PER CHANGE ORDER #2 DTD 8/10/77				
2	25827		216492	6" X 9" X 24" TEST BARS MATERIAL HAS BEEN MANUFACTURED IN ACCORDANCE WITH ASME BOILER & PRESSURE VESSEL CODE, SECTION III; CLASS 2 REQUIREMENTS 1974 EDITION WITH NO ADDENDA MATERIAL WAS MANUFACTURED PER MATERIAL SPECIFICATION MS-1038 REV. 2 DTD 2/23/78 AND CONFORMS TO THE REVISED MATERIAL SPECIFICATION MS-1038 REV. 4 DTD 6/6/78 UNDER CHANGE ORDER #4 DTD 8/21/78 MATERIAL HAS BEEN HEAT TREATED PER CHANGE ORDER #4 DTD 8/21/78 AND MS-1038 REV. 4 DTD 6/6/78 UTILIZING LINDBERG/COOK HEAT TREATMENT PROCEDURE 41478 APPROVED BY FLUID SYSTEMS DIVISION.				
				ASME Quality System Certificate No. N-1777 Exp. 6-10-80 <i>[Signature]</i> ANZ <i>[Signature]</i> 3-8-79				

CHEMICAL ANALYSIS

HEAT NO	MILL SOURCE	C	MN	PHOS	SUL	SIL	Ni	CR	CU	MO	
216492	SHARON	.24	1.14	.015	.015	.27					

PHYSICAL PROPERTIES

YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	% ELONG	% RED OF AREA	HARDNESS	TYPE CHARPY	TEMP °F	ABSRU ENERGY FT./LBS	LATERAL EXP. (MILS)	% SHEAR
50,000	75,000	32.4	69.3		V-NOTCH	+10° F	130.0-111.0-143.0	.092	100
								.080	60
								.086	100

MISCELLANEOUS TESTING


TYPE OF TEST	G-S
MAGNETIC PARTICLE EXAMINATION PER WET FLUORESCENT METHOD OF EPG-PROCEDURE 41.411 REV. 2 DID 7/15/76 ACCEPTABLE WITH NO REPORTABLE INDICATIONS.	

SUBSCRIBED AND SWORN TO BEFORE ME

5th DAY OF OCTOBER 1978

MONNA M. HENDON

Notary Public in Harris County, Tex.
My Commission Expires June 19, 1980I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE AT
THE OFFICE OF FORGED PRODUCTS INC. BY THAT THIS STEEL WAS
MANUFACTURED AND FURNISHED IN THE UNITED STATES OF AMERICA*Edward F. Bick*
NOTARY PUBLIC
My Commission Expires June 19, 1980



Forged Products Division

6505 N. HOUSTON-ROSSLYN ROAD

HOUSTON, TEXAS 77091

GULF-WESTERN MANUFACTURING COMPANY

CERTIFIED TEST SHEET

8.0-A

PAGE 2 OF 2

TO:
SOLD TO:
ENERGY PRODUCTS GROUP
FLUID SYSTEMS DIVISION
235 KILVERT STREET
WARWICK, RHODE ISLAND 02886

SHIPPING SAME
PEACER VALLEY POWER STATION
UNIT No. 2
P.O. No. 26V-211
MAIN STEAM LINE TRIP VALVE

DATE SHIPPED		CUSTOMER'S ORDER NO		SHIP TO		MARK		SHIPPED VIA		COLLECT CARRIED	
ITEM	QUANTITY	ITEM	QUANTITY	ITEM	QUANTITY	ITEM	QUANTITY	ITEM	QUANTITY	ITEM	ITEM
6	25827	I-6	216492	ROUGH MACHINED REDUCER FORGINGS TO FINISH PER DWG. C254-000-0924320 REV. D SUBMITTED PER CHANGE ORDER #2 DTD 8/10/77							
2	25827		216492	6" X 9" X 24" TEST BARS MATERIAL WAS PHYSICALLY TESTED FOR TENSILE REQUIREMENTS AND CHARPY V-NOTCH IMPACT REQUIREMENTS @+40°F PER MATERIAL SPECIFICATION MS-138 REV. 4 DTD 6/6/78. CHARPY V- NOTCH WAS PERFORMED AT +40°F PER INSTRUCTIONS OF L. CAPRON.							

(A handwritten note is placed over the second row of the table, containing the following text and a signature):

ENERGY PRODUCTS GROUP
Gulf & Western Mfg. Co.
235 Kilvert Street
Warwick, R.I.
Quality Assurance Dept.
Date: 11-9-78
Signed [Signature]

MATERIAL WAS WET + FLUORESCENT MAGNETIC PARTICLE TESTED
PER EPG PROCEDURE 41.411 REV. 2 DTD 7/15/76 AND MATERIAL
SPECIFICATION MS-1038 REV. 4 DTD 6/6/78 UNDER CHANGE
ORDER #3 DTD 8/21/78.

DRAWINGS SUBMITTED OF "AS SHIPPED" ROUGH MACHINED FORGINGS
AND TEST BAR PER MS-1038 REV. 4 DTD 6/6/78 UNDER CHANGE
ORDER #4 DTD 8/21/78.

CHEMICAL ANALYSIS

HEAT NO.	MILL SOURCE	C	MN	PHOS	SUL	SIL	Ni	CR	CU	MO	
1											
2											
3											

PHYSICAL PROPERTIES

YIELD STRENGTH (PSI)	TENSILE STRENGTH (PSI)	ELONG	RED OF AREA	HARDNESS	TYPE CHARPY	TEMP °F	ABSRB ENERGY FT /LBS	LATERAL EXP (MILS)
1								
2								
3								

MISCELLANEOUS TESTING

TYPE OF TEST	G.S.
1	
2	
3	

SIGNED AND SWORN TO BEFORE ME

5th DAY OF OCTOBER 1978

I CERTIFY THAT THIS IS A TRUE COPY OF ORIGINAL TEST SHEET NOW ON FILE
AT THE GULF & WESTERN MANUFACTURING COMPANY AND THAT THIS STEEL WAS
MANUFACTURED IN THE UNITED STATES OF AMERICA

Monna M. Hendon
Notary Public in Harris County, Texas
My Commission Expires June 19, 1980


Edward F. B.
Quality Control

LINDBERG/COOK
HEAT TREATING
COMPANY

P. O. BOX 24147 • HOUSTON, TEXAS 77029 • 713/672-6601

CERTIFICATION OF HEAT TREATMENT

- FORGED PRODUCTS
- HOUSTON, TEXAS
-



WE HEREBY CERTIFY THAT THE PARTS DESCRIBED WERE GIVEN THE FOLLOWING HEAT TREATMENT

	TIME AT HEAT	COOLANT
UNNEALED	"F	
ORMALIZED 1600	8 HRS	AIR
QUENCHED 1600	8 HRS	WATER
DRAWN 1200	10 HRS	AIR
NITRIDED	"F	
STRESS RELIEVED	"F	

HARDNESS TEST **163-187 BHN** OF PCS. TESTED **100%**

We further certify that heat treatment described above is true and correct and that temperatures and test results were obtained with standard approved methods.

Subscribed and sworn to before me this

28 TH day of **SEPTEMBER**, 19 **78**

John McDonald
Notary Public
in and for the County of Harris, State of Texas

My Commission Expires **9/30/78**

DATE: **9/13/78**

CERTIFICATION NO. **54216**

CUSTOMER'S ORDER NO. **25827**

OTHER ORDER NOS.: **P.O. # 0187**

NUMBER OF PARTS: **NINE (9)**

PART NUMBERS: **6) EGH MACHINED**

FORGED REDUCER TO FIN PEE

DTG C-254-000-0924325 REV. D

3) TEST RINGS 6 x 9 x 24" LG

SPEC. NO. 4145C

MATERIAL: SA350-LF 2

HTM 216492

FURN. CALIB. 9/14/78

LINDBERG COOK HEAT TREATING COMPANY

Paul Gable

PAUL GABLE
PLANT SUPERINTENDENT

DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 20V-211
MAIN STEAM LINE TRIP VALVE
MARK No. 21055-HYV101

S.O.D.

WeldEx

NUCLEAR

PAGE 2 OF 2



TO Forged Products
 REPORT NO 8-2317 P. O. NO. 9637 JOB NO. 25827
 MATERIAL SPECIFICATION SA-350 LF-2, HT.#216492 PC# 1-6 INCLUSIVE
P.O. # 0187 MATERIAL: ROUGH MACHINED REDUCER FORGINGS (6 pc)

CHARPY V-NOTCH IMPACT TEST

Test Temperature: +40°F

<u>Specimen No.</u>	<u>Ft. Lbs.</u>	<u>Percent Shear</u>	<u>Lateral Exp.</u>
1	130.0	100.0	.092
2	111.0	60.0	.080
3	143.0	100.0	.086

THIS MATERIAL CONFORMS TO ASME SA350 LF2 & MS-1038 REV. 4 DATED 6/6/78

MEETS SPECIFICATION: YES NO NABy: Richard OliverDate: 10-3-78

8.03

P.T.O. DATE	P.O. DATE	P.O. NO.	CUST. CODE	OPER. CODE	PCO. CODE	INVOICE NO.
01-03-77	12-27-76	H-03198	62812		0785	721 3044
REMIT TO 5501 N MICH DETROIT, MI 48230 DU-240-			DWS RATING	INVOICE DATE 1-26-77		
			TERMS NET 30 DAYS	A LATE PAYMENT CHARGE WILL BE ASSESSED MONTHLY ON BALANCES DUE ON OUR NET 30 DAY TERMS.		

S C STEEL CORPORATION OF TEXAS L1000 N KUHN IN HOUSTON-KUSSLYN RD HOUSTON, TX 77091		S H I P T O	STEEL CORPORATION OF TEXAS L/U FORGED PRODUCTS 8000 N HOUSTON-KUSSLYN RD HOUSTON, TX 77091	SOLD TO SHIP TO SPECIAL
REGISTRATION DATE SHIPPED DATE	UL-24-77 1-26-77	FROM	VEHICLE IDENTIFICATION	
SHIP VIA RAIL	MIN. WT. 80000	F.O.B. FARRELL	ROUTE	
TAX DRF. FEN.	OTHER BALANCE DUE 418.00	PREPAID OR COLLECT PREPAID	WT. 200000	DATE ARR LF 01-24-77 PC 554982
SPECIFICATIONS & DESCRIPTION				


UF YOUR P.U. ITEM NO. 1
 PRODUCT - HOT ROLLED SEMI-FINISHED
 STEEL, BLUMS, ALLOY, ELECTRIC
 FURNACE VACUUM DEVS, FORGING QUALITY
 SPECIFICATION - EF-A-350 LF-2-3
 C .30 MAX, HN .95/.1.35, P .035 MAX,
 S .04 MAX, SI .15/.30-A1-.045 AND
 SPECIAL INFORMATION - FORGED PRODS #7208
 CARRIER - GUNDLÄ
 DIMENSIONS - 34.0000 X 32.000 X 29000#
 PIECE WT - 29000 MINIMUM
 JACKET WT - 200,000 LBS

P.O. #0187
MATERIAL: ROUGH MAC NED REDUCER
FORGINGS (6 pc)
HEAT NO.: 216492
JOB NO.: 25827
THIS MATERIAL CONFORMS TO ASME SA350 LF2 &
MS-1038 REV. 4 DTD 6/6/78 *E7521-1978*

HEAT NO.	B/L NO.	UFTS SKIDS	PCS. COILS	WEIGHT SHIPPED	THEO. WEIGHT
216492	096878	5	5	158140	
		Plus Prepaid Freight		79.670	

WE HEREBY CERTIFY THAT NO
COVERED BY THIS INVOICE WERE
DULLED IN CONFORMITY WITH THE
CABLE PROVISIONS OF THE FAIR
STANDARDS ACT OF 1938, AS AMENDED,
AND THAT PRICES CHARGED
ARE NOT IN EXCESS OF THOSE
INITIALLY CHARGEABLE UNDER THE FAIR
PRICE STABILIZATION PROGRAM.

Temp.	P.S.I.	P.S.I.
Elastic Yld.	100 P.S.I.	CO.
Elongation	100% 100%	TIC P.S.I.
Hardness	HR AVER 40-45	
Tensile	N.M. IN	
Chain Size	7 - 8 - 10 - 11 - 12 - 13	SIZE
	1. 2. 3.	SIZE
	1. 2. 3. 4. 5.	SIZE
	MARK NO. 1	



8.0 D

WeldEx


NUCLEAR

PAGE 1 OF 2

TO Forged ProductsREPORT NO. 8-2317 P. O. NO. 9637 JOB NO. 25827MATERIAL SPECIFICATION SA-350 LF-2, HT # 216492 PC# 1-6 INCLUSIVEP.O. # 0187 MATERIAL: ROUGH MACHINED REDUCER FORGINGS (6 pc)TENSILE TEST

<u>Specimen No.</u>	<u>Y. S. (psi)</u>	<u>T. S. (psi)</u>	<u>% Elong.</u>	<u>% R. A.</u>
<u>1</u>	<u>50,000</u>	<u>75,900</u>	<u>32.4</u>	<u>69.3</u>

THIS MATERIAL CONFORMS TO ASME SA350 LF2 & MS-1038 REV. 4 DATED 6/6/78

MEETS SPECIFICATION: XX YES NO NABy: Richard Oliver
Date: 9-28-78

sh

CERTIFIED TEST REPORT

10.0 A

VITCO NUCLEAR PRODUCTS INC. 4445 HAMANN PARKWAY, WILLOUGHBY, OH 44094
PHONE AREA CODE 216 946 9560

Energy Products Group
235 Kilvert Street
Warwick, Rhode Island 02886

DATE SHIPPED	VITCO ORDER NUMBER	CUSTOMER ORDER NUMBER
2/21/79	6130	01759

ITEM (1) 76 Pcs. 3/4"-14 NPT Pipe Plug
Drawing # A-156-000-0075000 Rev. A

(Trace # 8H)

SPECIFICATION ASME-SA-479 Type 316 ASME Boiler and Pressure Vessel Code, Section III,
Division I, 1974 Edition through Winter of 1976 Addenda Class 1

• CHEMICAL COMPOSITION

ITEM	HEAT NO.	C	Mn	P	S	Si	Cr	Mo	Ni	Cu	Fe	Al	Ti	Co
1	C17396	.053	1.79	.020	.019	.58	17.45	2.85	12.46	.13				.29

PHYSICAL COMPOSITION

ITEM	TENSIL STRENGTH PSI	YIELD PSI. 2%	ELONG. % IN 2"	RED. AREA %	HARDNESS	HEAT TREAT DATA
1	82,500	35,630	55.0	71.6	Rb 72/74	Heat Treat 1950°F for 30 Min.
						Hydrogen Quench - Rapid

ADDITIONAL SPECIFICATION REQUIREMENTS OR SPECIAL TESTS

ATTACHMENT


UNIVERSAL CYCLOPS STEEL MILL TEST REPORT FOR HEAT # C17396.

Conforms to ASME Section III, 74 Edition No Addenda

PC 1-15-80

DUQUESNE LIGHT CO.
BEAVER VALLEY POWER STATION
UNIT No. 2
P. O. No. 20V-211
MAIN STEAM LINE TRIP VALVE
MARK No. 2VSG-H/VIC

ENERGY PRODUCTS GROUP
Gulf & Western Mfg. Co.
235 Kilvert Street
Warwick, R.I.
Quality Assurance Dept.


Signed 1-15-80
Date


WE CERTIFY THAT THE ABOVE MATERIAL IS COMMERCIALLY FREE FROM MERCURY
CONTAMINATION AND MEETS THE REQUIREMENTS OF SPECIFICATION ASME-SA-479
Type 316 AND YOUR ORDER # 01759.

THE ABOVE TESTS CONFORM TO THE REQUIREMENTS OF THE SPECIFICATION LISTED

SWORN TO AND SUBSCRIBED BEFORE ME
THIS _____ DAY OF _____ BY A DULY
AUTHORIZED AGENT OF VITCO NUCLEAR
PRODUCTS INC.

WE HEREBY CERTIFY THAT THE ABOVE DATA IS A TRUE COPY
OF THE DATA FURNISHED US BY THE PRODUCING MILL OR
SUPPLIER OR OF THE DATA RESULTING FROM TESTS PERFORMED
IN APPROVED LABORATORIES AND MEETS THE REQUIREMENTS
OF THE SPECIFICATION NOTED

VITCO NUCLEAR PRODUCTS INC.



150-30 DAYS PAY = 1% DISCOUNT ON S		IF PAID ON OR BEFORE		10.0 B		S/L RD.	
INVOICE NUMBER 11513-015-0106		CUST. DUE DATE 11/21/74		RTG. CTLL. NO. * * *		MILL ENTRY DATE 11/22/74	
CUST. CODE NO.	DUNS FOLE	STATE/CITY	GOVT. RATING	MARKETING	PROD. OFF.	DIST. BY MN.	SHPPG. & INV. DATE 75 035
						INVOICE NUMBER DS7-3462	

WILLIAMS AND COMPANY, INC.
1 PENNSYLVANIA AVENUE
PITTSBURGH PA 15233

SHIPPED TO
WILLIAMS AND COMPANY, INC.
901 PENNSYLVANIA AVENUE
PITTSBURGH PA 15233

BRIDGEVILLE AVELLA EXPRESS
BRIDGEVILLE

F/E

SHIPPING INSTRUCTIONS

1 MAX BUNDLES PAINT ONE END YELLOW
2 TAG WITH CUST NO., SIZE, HEAT, TYPE, FIN, COND, WEIGHT PER BUNDLE

PRICE B/D	OTHER	TEST REPORT INSTR.	ANAL.	PHYSICALS	NO. T/R	CLRT.	NOTARIZED
SALES DEPT	2 S/M				3		
NO.	QUAN. ORDERED PCS. OR WT.	SIZE AND DESCRIPTION	HEAT NO.	QUAN. SHIPPED NET WEIGHT	PRICE	AMOUNT	

UNILOY 316 CENTERLESS GROUND BARS

1500# 1-1/8" RD X 12/14 FT CI7396

AMS-5648L, QQS 763D AMEND 1 COND A,
PHY OF MILS 7720, ASTM-A-276,
ASTM-A-479, ASME-SA-479 SECTION II ONLY

1.125" RD

DUQUESNE LIGHT CO.

BEAVER VALLEY POWER STATION
UNIT No. 2

P. O. No. 2BV-211

MAIN STEAM LINE TRIP VALVE

MARK No. 2MSS-HV-CT-17458

1.125" RD

Centerless Ground

C	MN	SI	S	P	CR	W	V	NI	MO	CO	CI
7093	.053	1.79	.53	.019	.020	17.45			12.46	2.85	.29
OTHER PROPERTIES											
7093	HARDNESS	YIELD	TENSILE*	% EL.	% R.A.	BENDS					
	BRIN 207/223	.22 78,800	94,000	36.5	72.7						
Resistance to intergranular Corrosion: Satisfactory Free from Continuous Carbide Network.											

STRESS	RUPTURE
STRESS-PSI	TEMP.-F.

HARDENABILITY	TREATMENT	STRESS-PSI	TEMP.-F.	TIME-HRS.

ENERGY PRODUCTS GROUP Gulf & Western Mfg. Co. 235 Kilvert Street WARRINGTON, PA	Q.A. APPROVED
--	------------------

I CERTIFY THAT THIS IS A TRUE AND CORRECT
COPY OF THE TESTS SHOWN ON OUR LABORATORY
RECORDS.

BY J. P. C.
AUTHORIZED SIGNATURE

QUALITY CONTROL REPRESENTATIVE

TEST REPORT

TRK & BH

103



Taylor Forge Division

GULF + WESTERN INDUSTRIAL PRODUCTS COMPANY
P.O. Box 485 Chicago, Illinois 60690

SUBSCRIBED AND SIGNED IN THE NAME OF THE ILLINOIS KOMIKY ASSOC.

9.0A

5

DAY OF -

July

19. 72

MENTAL FELICITY

三

ITEM CUST. CO. QTY DATE ENTR'D BY PAGE/PACKING LIST OUR INVOICE NO.

EBY SYSTEMS DIV.
235 KILVERT STREET
WARWICK, RHODE ISLAND 02886

SPECIFICATION NO. ASME SA-182-50 per ASME Code
HEAT TREATMENT Sect. III Cl. 2, 1974 Edit.
and Nat'l Spec. No. MS-1043

HEAT TREATMENT

Rev. 0

Normal

IT 103881 Ed 13/20/36 1600

REMARKS: Proc. HT-107984 Dtd 12/20/78. 1600°F.
3 hrs - Air cooled. 1350°F. 6 hrs - Air cooled.
Forgings were heat treated at TF Cicero and
original charts are maintained in Q.C. Dept.



Heat Treat Charts and Steel Mill reports attached.

Part has been visually and dimensionally examined and is in full compliance with purchase order and specification requirement.

0036
TE-107934

BEST WAY PPD

38-0140

PROMISED		ROUTE	BEST WAY PPD	
ORDER NO.	ITEM NO.	PRODUCT NO.	QUANTITY	DESCRIPTION
				TEST REPORTS (PER TEST REPORT DATA SHEET)
134-601 F-T-W-C 12-#7				35.563" OD X 32.250" ID X 8" THICK TYPE 410 RING ROUGH MACHINED MATERIAL: ASME SA182-F6 PER ASME CODE
4/1/77 N/S		HT-EPZD		SECT. XIICLASS 2 1974 EDITION & E&V MATERIAL SPEC. MS 1043 REV. D DWG. C-250-000-0024000A ENERGY PRODUCTS GROUP NO REPAIR WELDING ALLOWED ED & Western Mfg. Co. 235 Kilvert Street Warwick, R.I. Quality Assurance Dept.
				CHG. NO. #270
			ITEM NO. 1	
		DUQUESNE LIGHT CO. BEAVER VALLEY POWER STATION UNIT No. 2 P. O. No. 18V-211 MAIN STEAM LINE TRIP VALVE MARK No. 2M55-3YV101		 EBV Systems Date 7-26-77 Sign [Signature]  EBV Systems Date 7-26-77 Sign [Signature]

TECHNOLOGY CORPORATION

P.O. BOX 552 • READING, PA. 19603

CERTIFICATE OF TESTS

40B

DATE: 3/31/75

"CORRECTED COPY"

TAYLOR FORGE
 GULF WESTERN INDUSTRIES
 PO BOX 435
 CHICAGO, IL 60690

ATTN: MET. DEPT.

QUOTER ORDER NO.	CARL. ORDER NO.	DATE SHIPPED									
PRODUCT DESCRIPTION	SPECIFICATION										
TYPE 410 HR UNANLD FORGE BILLET	ASTM-A132 GR F5 MOD 51.75 MAX										
WEIGHT	SIZE	HEAT NO.	C	MN	SI	P	S	CR	NI	MO	CU
.7053	10.000"	79708	.10	.41	.36	.010	.011	12.41	.53	.05	.04
	RCS										
									AL	SN	N
									.012	.003	.035

YIELD STRENGTH, KSI @ .2%
 TENSILE STRENGTH, KSI
 ELONGATION IN 2 "%.
 REDUCTION OF AREA, %
 HARDNESS BRINELL

CAPABILITY ENERGY PRODUCTS GROUP
 Gulf & Western Mfg. Co.
 235 Kilvert Street
 Warwick, R.I.
 Quality Assurance Dept.

197

1-27-75
Date

V Systems

7-26-77

Signature

BRINELL HARDNESS AS SHIPPED - 172

HARDENABILITY: 1750°F, AIR TREAT - ROCKWELL C 40

DUQUESNE LIGHT CO.
 BEAVER VALLEY POWER STATION
 UNIT No. 2
 P. O. No. 2BV-211
 MAIN STEAM LINE TRIP VALVE
 NO. 2MSS-HYV101

RELEASED AS SEC II CL
DATE 4/1/77SLH/IN 5
HS 1

THIS INFORMATION TO BE TRUE AND
 AS CONTAINED IN THE RECORDS OF
 COMPUTER TECHNOLOGY CORPORATION

STATE OF PENNSYLVANIA
 COUNTY OF BERKS

Subscribed and sworn to before me

this _____ day of _____ 19____

Authorized Representative

NOTARY PUBLIC

MY COMMISSION EXPIRES _____

SECTION 12

FORM NPP-1 DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES*
As Required by the Provisions of the ASME Code Rules, Section III, Div. 1 N-1141-5301

Fabricated by	Power Piping Company, Donora, PA 15033	Order No	N-1141
Fabricated for	Beaver Valley Power Station, Unit #2	Order No	2BV-58, J.O. No. 12241
Owner	Duquesne Light Company, Pittsburgh, PA	4. Location of Plant	Shippingport Borough, PA
5. Piping System Identification Steam Generator Feedwater MK FWS-107-01/1017-107-01 ISO-101701 <small>(Brief description of intended use, main identifier)</small>			
6(a) Drawing No.	RP-17 B	Prepared by	Stone & Webster Engineering Corp.
6(b) National Board No.	N/A	Boston, Massachusetts	
6. The material, design, construction, and workmanship complies with ASME Code Section III, Class <u>2</u>			
Edition	1971	Addenda Date	Winter 1972 Case No. N/A
Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report <small>(Name of Part -- Item number, Manufacturer's name, and identifying stamp)</small>			
<ul style="list-style-type: none"> - Shop Hydrostatic Test <u>By Field</u> psi. - Description of piping inspected <u>1 Pcs. - 16" Sch. 80 SMLS. C.S. Pipe, SA-106, Gr. C, Item No. 3, Lgth. = 2'-0" lg., L.C. No. P-1544, Ht. ID 66521, Tube Serial No. 1-6695</u> 			

*2/17/80
AFC
2/17/80
2/17/80
2/17/80*

NOTE: Welding Electrodes L.C. No. E-57, E-62

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date February 5, 1980 Signed Power Piping Company By Alice L. Lanier
Certificate of Authorization Expires January 7, 1980 Certificate of Authorization No. N-1623
Letter of Extension to February 15, 1980

CERTIFICATE OF SHOP INSPECTION

N-1141- 5301

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of PENNSYLVANIA and employed by HARTFORD STEAM BOILER INSPECTION & INSURANCE COMPANY of HARTFORD, CONN. have inspected the piping described in this Data Report on 2/17/80, in 10, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

2/17/80

Michael R. Gardner Commissioned 2/17/80

2/87



Capitol
PIPE & STEEL PRODUCTS CO.
Division of BOWLINE Corporation

STAINLESS STEEL PIPING MATERIALS FOR HIGH TEMPERATURE AND LOW TEMPERATURE APPLICATIONS

301 CITY LINE AVENUE • AREA CODE 215 • TE 9-4300
BALA-CYNWYD, PENNSYLVANIA 19004

CAPITAL PIPE CERTIFICATE OF COMPLIANCE

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS) NUMBER N-936

EXPIRATION DATE: May 6, 1981

MATERIAL: 16" sch. 80 SA 106 GRADE C /

HEAT NO: 68521 /

MANUFACTURER: Phoenix Tube Division /

This Certification affirms that the content of the attached report(s) is correct and accurate and that all test results and operations performed are in compliance with the below listed Specifications:

1. ASME CODE SECTION II - 1971 EDITION INCLUDING ADDENDA THROUGH WINTER 1972, FOR ASME SA 106 GRADE C MATERIAL.
2. ASME CODE SECTION III - 1971 EDITION INCLUDING ADDENDA THROUGH WINTER 1972, ARTICLE NC-2550 FOR CLASS 2 MATERIAL.
3. POWER PIPING SPECIFICATION N-1111-01, REVISION 4

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 EV-53, I.O. NO. 12241, PIPE FAB.

REFERENCE: Power Piping
P/C# 19063-N-1141
Capitol S/C# 1111-01-01
IT# -2

D. A. Yilf /
QUALITY ASSURANCE

PHOENIX STEEL CORPORATION

PIPE DIVISION
PHOENIXVILLE, PENNA.

CERTIFICATE OF INSPECTION AND TESTS

DATE: 4-27-79	DATE SHIPPED: 4-26-79	MILL ORDER NO. T-6695-B2	SHIPPING LIST NO. 113D
Capitol Pipe & Steel Products Co.		CUSTOMER ORDER NO. S94994-00N	
		CAR NO.	
		MATERIAL: SEAMLESS <input checked="" type="checkbox"/> PIPE <input type="checkbox"/> TUBE, HOT FINISHED	
Power Piping Co.		SPECIFICATION: ASTM A-106-C-77, ASME SA-106-C (O.H.)	

PCS. OD WALL LENGTH TOTAL FT. TOTAL WT. HEAT NO.
 16.000" x .844" 68521

The material was produced in accordance with a Q.A. Program as audited by Capitol's annual vendor evaluation program.

AT NO.	C	Mn.	P.	S.	Si.	Cu.	Ni.	Cr.	Mo.	V
1521	.27	.95	.013	.025	.25	Ladle Analysis				
1521	.32	.80	.012	.014	.19	Product Analysis				

Power Piping Co.
P.O. #19063-N-1141
S.O. #RN-1241-A9
Item #2

AT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	% RA	ROCKWELL	HARDNESS	BRINELL	GRAIN SIZE
521	82.3	51.3	28.00 (.505" Test Specimen)					

DUQ. LIGHT CO. BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.C. NO. 12241, PIPE FAB.

4-27-79

CAPITOL PIPE
QUALITY
ASSURANCE
6
ACCEPTED

MIN DISTANCE - 16TH		ROCKWELL C		FLATTENING		OK		HYDROSTATIC PSI		2535
2	4	6	8	10	12	14	16	20	24	32

PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S REPORTS ARE AS SHOWN ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PRESCRIBED BY THE SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. IN CONSIDERATION OF THE ABOVE, THE ABOVE MATERIALS HAVE BEEN APPROVED AS FULFILLING THE REQUIREMENTS OF SAID SPECIFICATIONS.

R. W. Pickles
ENGINEER OF TESTS

FORM NFP-1 DATA REPORT FOR FABRICATED NUCLEAR PIPING SUBASSEMBLIES

As Required by the Provisions of the ASME Code Rules, Section III, Div. I

Fabricated by	Power Piping Company, Donora, PA 15033	Order No.	N-1141
2. Fabricated for	Beaver Valley Power Station, Unit #2	Order No.	2BV-58, J.O. No. 12241
3. Owner	Duquesne Light Company, Pittsburgh, PA	Location of Plant	Shippingport Borough, PA
5. Piping System Identification	Steam Generator Feedwater Line SP-2A1-2024 IS-1141-01		
(a) Drawing No.	Prepared by Stone & Webster Engineering Corp.		
(b) National Board No.	N/A	Boston, Massachusetts	
6. The material, design, construction, and workmanship complies with ASME Code Section III, Class			
Edition	1971	Addenda Date	Winter 1974
Case No.	N/A		
Remarks: Manufacturers Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report	(Name of item - item number, Manufacturer's name, and identifying stamp)		

7. Shop Hydrostatic Test By Field psi.

8. Description of piping inspected (Indicate - mark no. - material spec. - size pipe size - schedule thickness - length - fittings - flanges etc.)

1 PC - 16 Sch 40 300# STS Pipe, 8A-100, GL, Item No. 100, Serial No. 10095
 1 PC - 300# P.S. E/W Weld Boss, SR-105, Item No. 105, Serial No. M-1016,
 1 PC - 3/4" 300# P.S. E/W Weld Boss, SR-105, Item No. 105, Serial No. M-5039, H.P. (D.A.C.D.)

Summ
-
of
etc
etc

NOTE: Welding Electrodes L.C. No. E-57, E-62, E-63, E-64

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date January 31, 1980 Signed Power Piping Company By
 Certificate of Authorization Expires January 7, 1980 Certificate of Authorization No. N-1623
 Letter of Extension to February 15, 1980

CERTIFICATE OF SHOP INSPECTION N-1141-2/1/80

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of PENNSYLVANIA and employed by HARTFORD STEAM BOILER INSPECTION & INSURANCE COMPANY of HARTFORD, CONN., have inspected the piping described in this Data Report on 2/1/80, 1980, and state that to the best of my knowledge and belief, the NPT Certificate Holder has constructed this piping in accordance with the applicable subsections of ASME Code, Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from inspection with this inspection.

2/1/80John T. K. Tanabe

Commissioner

PA 2137

National Board State of CONN and No.

PHOENIX
TUBE DIVISION

Phoenix
PIPE & STEEL PRODUCTS CO.

BALTIMORE, BROWNSVILLE, CINCINNATI,
CLARKSBURG AND CHICAGO, CHICAGO, CHICAGO, CHICAGO

301 CITY LINE AVENUE • AREA CODE 215 • TE 9-4330
BALA-CYNWYD, PENNSYLVANIA 19004

CAPITOL PIPE CERTIFICATE OF COMPLIANCE

ASME QUALITY SYSTEM CERTIFICATE (MATERIALS) NUMBER N-936

EXPIRATION DATE: May 6, 1981

MATERIALS: 1010 SCH. 40 ~~106 GRADE C~~

STATION: 605

MANUFACTURER: Phoenix Tube Division

This Certification affirms that the content of the attached report(s) is correct and accurate and that all test results and operations performed are in compliance with the below listed Specifications:

1. ASME CODE SECTION III - 1971 EDITION INCLUDING ADDENDA THROUGH WINTER 1972, FOR ASME SA 106 GRADE C MATERIAL.
2. ASME CODE SECTION III - 1971 EDITION INCLUDING ADDENDA THROUGH WINTER 1972, ARTICLE IC-2550 FOR CLASS 2 MATERIAL.
3. POWER PIPING SPECIFICATION N-1141-01, REVISION 4

PW&G DIVISION, BEAVER VALLEY NO. 2
P.O. BOX 2 197-31, J.C. HOB. MECHANICAL PIPE FAB.

REFERENCE: POWER PIPING
P/O# 197-31-N-1141
CAPITAL S/C# N-1141-1
IT# +2

R. A. Wilson
QUALITY ASSURANCE

Auth. No. Ledger Control No. Thru Page of

PHOENIX STEEL CORPORATION
CHARLOTTE, NORTH CAROLINA

CERTIFICATE OF INSPECTION AND TESTS

DATE: 4-27-72	DATE SHIPPED: 4-26-72	MILL ORDER NO.: T-6695-B2	SHIP TO ADDRESS: 1132
Capitol Pipe & Steel Products Co.		CUSTOMER ORDER NO.: S94994-00N	
Power Piping Co.		CAR NO.	
		MATERIAL: ERW/LESS <input checked="" type="checkbox"/> PIPE <input type="checkbox"/> TUBE, HOT FIN COATED	
		SPECIFICATION: ASTM A-106-C-77, ASME SA-106-C (C.H.)	

NO. PCS.	00	WALL	LENGTH	TOTAL FT.	TOTAL WT.	HEAT NO.
	16.000"	x .344"				68521

The material was produced in accordance with a Q.A. Program as audited by Capitol's annual vendor evaluation program.

HEAT NO.	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	V
68521	.27	.95	.013	.025	.25	1/4" Ladle Analysis				
68521	.32	.80	.012	.014	.19	Product Analysis				

Power Piping Co.
P.O. #10062-N-1141
S.O. #AM-1241-A9
Item #2

HEAT NO.	TENSILE (KSI)	YIELD (KSI)	% ELONG. IN 2"	G RA	ROCKWELL	HARDNESS	BRINELL	GRAIN S. 10
68521	82.3	51.3	28.00" (.505" Test Specimen)					

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 6 BW-50, HQ. NO. 12241, PIPE FAB.

9 1979
6
ACCEPTED

MIN. DISTANCE + 16TH	ROCKWELL C	FLATTENING	OK	HYDROSTATIC PSI	2035
1 2 4 6 8 10 12 14 16 20 24 28 32					

PHOENIX STEEL CORPORATION HEREBY CERTIFIES THAT THE ABOVE MATERIALS HAVE BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE REQUIREMENTS IN THE APPLICABLE SPECIFICATIONS AND THE RESULTS OF SUCH INSPECTION AND TESTS AS CONTAINED IN THE COMPANY'S RECORDS ARE AS STATED ABOVE. FOR PROPERTIES OR CHARACTERISTICS FOR WHICH NO METHODS OF INSPECTION OR TESTING ARE PROVIDED BY THE SPECIFICATIONS, THE STANDARD MILL INSPECTION AND TESTING PRACTICES OF THE PHOENIX STEEL CORPORATION HAVE BEEN APPLIED. AND UPON FLAW INSPECTION AND TESTS, THE ABOVE MATERIALS HAVE BEEN DETERMINED AS FULFILLING THE REQUIREMENTS OF THIS CERTIFICATE.

R. W. Peck
ENGINEER OF TESTS

The Colonial Machine Company, Inc.

P. O. Box 290 - Pleasantville, Pa. 16341

Phone (814) 589-7033

SPRINGFIELD COMPANY
121 STATE ST.
SPRINGFIELD, MASS.

FCC: SAB, CCA, PA

C E R T I F I E D
M I L L T E S T R E P O R T

YOUR ORDER NO.	20 000-1141	OUR ORDER NO.	13315	DATE SHIPPED	6/13/79
----------------	-------------	---------------	-------	--------------	---------

2025 RELEASE UNDER E.O. 14176

1	2	50004 S/A BOSSES PER SK 102 REV. 2	11-5014 THRU 11-5023	10	91337 *	ALX
2	1-1/2"	DITTO	11-5024 THRU 11-5033	10	91337 *	ACT
3	3/4"	DITTO	11-5034 THRU 11-5052	20	91337 *	ACI

ITEM C MN P S SI CR NI MO CU CB TI CO N OTHER ELEMENTS

ITEM	TENSILE	% YIELD	% ELONG.	% R.A.	HARDNESS	REMARKS:
1	73500	47000	54.0	67.0		
2	71000	45500	36.0	64.7		
3	74500	52000	35.0	65.9		

- DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 EV-58, J.O. NO. 12241, PIPE FAB.

© 1998-2000

We hereby certify that the information contained hereon has been taken from the original mill test report from the producing mill, which is now on file in our office. We also certify that the material and the items as listed above meet the specification and all requirements as covered by the specification and your purchase order.

B-5

UPPER OLD STEEL COMPANY - WARREN, OHIO 44452

SALES ORDER

CUSTOMER PURCHASE ORDER NUMBER		DATE NO. DAY	ITEM	DATE SHIPPED	SHIPPING INFO WEEK OF	SHIP TO ADDRESS	
McGOWAN, CLE	4250	082377 6 11	WK 11/6/77	11/6/77		18278	
PRICE IN EFFECT AT TIME OF PAYMENT		TERMS OF PAYMENT & OPENING VALUE					
WATERSON, J. P.		10 DAYS NET 30 DAYS					
S... S...	BARS	X CUST TRK - IN TRK LOADS	SHIP TO: (SAME AS SOLD TO UNLESS OTHERWISE STATED)				
THE COLONIAL MACHINE COMPANY P O BOX 290 PLEASANTVILLE, PENNSYLVANIA 16341		ADVISE WHEN READY					

WT	INCHES	SIZE AND SHAPE	STD	PURPOSE	CUSTOMER APPROVAL	
		3 1/16"Ø	X	MACHINING		
WEIGHT		INCHES		INCHES	INCHES	
10/101						
PRODUCT INFORMATION		MPG	PART			
HR NORM MS		(206)	ASTM A 105 ASTM A 696 GR B (EXC COND)			
GRAN	HARDNESS	ADMIT HARDNESS TEST REQ.	SPECIFICATION: ASTM E-34-105 SECTION 2, ASME SA-696 GR B SECTION 2 EXC COND			
FINE	187 MAX BHN					
TAG			STRAIGHTNESS	CLASS/CUST APPROVAL		
END USE			PAINT & MARK			
6,000# MIN BOL 10,000# MAX BOL			STAMP HEAT NUMBER			

COPPERWELD
STEEL COMPANY
EDY 351 / WARREN, OHIO 44482

TEST REPORT

MR

ORDER NUMBER	
CUSTOMER	COPPERWELD

18278

HEAT NO.	CODE												DATE								
	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Pb	Al	GRAN SIZE									
91337 (AEX)	.22	.83	.008	.018	.22	-							5-11/10/77								
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32	36
	23	21	17	15	13	12	11	10		7	7		5	4	3	3	2	2			

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*		OTHER DATA
					149		
47,000	73,500		34.0	67.0			Normalise - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machine Co., Inc. on August 1977

a Copperweld product

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITEM 1

I, a Notary Public do hereby certify that
the above was subscribed and sworn to before me by a duly authorized
representative of Copperweld Steel Company.

Revd. 1/1/78
hereby certify that the above data are correct as con-
cerns the records of Copperweld Steel Company.

the day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-53 J.C. NO. 12241 FEB 1978.

C.P.W. 00-1

COPPERWELD STEEL COMPANY - WARREN, OHIO 44482

SALES ORDER

ITEM NO.	ITEM DESCRIPTION	DATE MO DAY YY	ITEM	DATE WANTED	SHIPPING F.P.O./WEEK OF	ITEM NO.
051077 CLE	4250	082377 4 11	WK 10/30/77	11/6/77	16276	

U.S. MIL. CONTRACTS ARE SHIPPED FROM PRICE IS EFFECT AT TIME OF SHIPMENT

TERMS OF PAYMENT: A/C IN 30 DAYS

WARREN, OHIO

10 DAYS NET 30 DAYS

CLASS

STL EARS

X CUST TRK - IN TRK LOADS

SHIP TO: SAME AS SOLD TO UNLESS OTHERWISE NOTED

THE COLONIAL MACHINE COMPANY
P O BOX 290
PLEASANTVILLE, PENNSYLVANIA 16341

ADVISE WHEN READY

ITEM NO.	SIZE AND SHAPE	STD X	SIDE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
2/101	10,000 2 9/16" C			MACHINING	
2/101	SHREWS				STD LENGTH TOLERANCE PLUS MINUS
2/101	(206)				
R NORM HS	HARDNESS ADD'L MACRO MICRO REQ.			PART	ASTM A 105 ASTM A 696 GR B (EXC COND)
LINE	187 MAX BHN			SPECIFICATION NO.	ASTM A 105 SECTION 2. AS /I SA-696 GR B SECTION 2 EXC COND
ANGLE	0.0005 MIN BOL 0.0005 MAX BOL			STRAIGHTNESS	IN INSPECTION
ANGLE				PAINT & MARK	
ANGLE				STAMP HEAT NUMBER	

EQUAL INTEGRATION

COPPERWELD
STEEL COMPANY
55 3811 WARRREN, OHIO 44482CORRECTED COPY 3/7/78
TEST REPORTORDER NUMBER
CUSTOMER COPPERWELD
18276

GRADE		CODE	SPEC'N / DESCRIPTION												DATE						
HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Pb	Al	GAUGE SIZE		NO.							
91537 (ACF)	.22	.83	.008	.018	.22										5-7						
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	20	24	28	32	36
	23	21	17	15	13	12	11	10		7	7		5	4	3	3	2	2			

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
45,500	71,000		36.0	64.7	146	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual intended to meet NA3700 as audited by The Colonial Machine Co., Inc. on August 2, 1977

a Copperweld product

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

I, _____, a Notary Public do hereby certify that
I have subscribed and sworn to before me by a duly authorized
agent of Copperweld Steel Company.this _____ day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 EV-58, J.C. NO. 10241, PIPE FAB.POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITEM 2We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.C. L. Cleland
Copperweld Steel Company

REF ID	CUSTOMER'S PURCHASE ORDER NUMBER	DATE NO. DAY	ITEM	DATE WANTED	SHIPPING F.O.B. WEEK OF	SALES UNIT
3077 CLE	4250	062377 2 11	WK 10/30/77	10/30/77	18274	
ITEMS OR EQUIPMENT ON THIS QUOTE ARE SUBJECT TO PRICE INCREASE AT TIME OF SHIPMENT		TERMS OF PAYMENT: 90% BY BILL VALUE 10 DAYS NET 30 DAYS				
EL 84RS	X CUST TRK - IN TRK LOADS			CLASS		
THE COLONIAL MACHINE COMPANY P O BOX 290 PLEASANTVILLE, PENNSYLVANIA 16341			SHIP TO ADVISE WHEN READY		SAME AS SHIP TO UNLESS OTHERWISE NOTED	

UNIT	INCHES	SIZE AND SHAPE	STL	SIZE TOLERANCE PLUS MINUS	PURPOSE	CUSTOMER'S FIRST OPERATION
	6,000	1 1/2" S	X		MACHINING	

LENGTH	SHAPES	STL	SIZE TOLERANCE PLUS MINUS	END LENGTH PLUS MINUS
12/101				

PRODUCT DESCRIPTION	MPN	PART
HR NORM MS	(205)	ASTM A 105 ASTM A 696 GR B (EXC CO)
GRAN	HARDNESS	SPECIFICATION NO.
FINE	157 MAX BHN	ASM-E-SA-105 SECTION 2. AS M/A- SA-696 GR B SECTION 2 EXC COND
TAG		STRAIGHTNESS
BUNDLE		PERIODIC INSPECTION
6,000# MIN BDL		X
10,000# MAX BDL		

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITEM 3

CORRECTED COPY 3/7/78

ORDER NUMBER

CUSTOMER COPPERWELD

18274

TEST REPORT

COPPERWELD
STEEL COMPANY
P.O. BOX 391 / WARREN, OHIO 44482

E						CODE	SPEC'N / DESCRIPTION										DATE
E 1026 Mod DH																	10/28/77
HEAT NO.	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Pb	Al	GRAIN SIZE					
91337 (AOD)	.22	.83	.005	.018	.22												5-7
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	36
	23	21	17	15	13	12	11	10		7	7		5	4	3	3	2

YIELD PSI	TENSILE PSI	OFFSET %	ELONG. %	R.A. %	HARDNESS*	OTHER DATA
52,000	74,500		35.0	65.9	149	Normalize - 1600 - 2 hrs. Material was produced in accordance with Copperweld Quality Assurance manual

*Surface unless
otherwise noted
Intended to meet NAS 100 as
a Copperweld product
audited by The Colonial
Machine Co., Inc. on
August 2, 1977

THIS CERTIFICATE NOTARIZED WHEN REQUIRED

We hereby certify that the above data are correct as contained
in the records of Copperweld Steel Company.

day of DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-59, J.O. NO. 12241 PIPE FAB.

John Chase
SUPERVISOR
COPPERWELD STEEL COMPANY

15

HERRON TESTING LABORATORIES, INC.
AN INDEPENDENT, FULLY EQUIPPED
TESTING LABORATORY

Purchase Order No. CH4337

File No. K 3589

January 6, 1978

Spec. 1-13/16" Dia. Steel Coupon, per ASME-SA350, Gr. LF1 and LF2,
Heat No. 91337 (AS, LF, ACC)

Client THE COLONIAL MACHINE COMPANY, INC.
Attention Mr. Barry W. Mallory

CHEMICAL ANALYSIS

Carbon	0.22%
Manganese	0.86%
Phosphorus	0.003%
Sulphur	0.020%
Silicon	0.23%

POWER PIPING COMPANY
ORDER NO. 20601-N-1141 ITS. 1 THRU 3

HERRON TESTING LABORATORIES, INC.

Allen Caperton

THIS REPORT IS EXPRESSLY LIMITED TO FINDINGS BASED UPON MATERIAL, INFORMATION, AND OR SPECIMENS FURNISHED BY CLIENT AND EXCLUDES ANY EXPRESS
OR IMPLIED WARRANTIES AS TO THE FITNESS OF THE MATERIAL AND/OR PROCESS SO SUBJECTED TO EXAMINATION AND OR APPROVAL FOR ANY PURPOSE AND WHETHER OR NOT

DUQ. LIGHT CO., BEAVER VALLEY NO. 2
P.O. NO. 2 BV-58, J.O. NO. 12241, PIPE FAB.

ANNUAL NO. _____ Ledger Control No. M-5014 thru M-5053 Rev. 1 Page 5 of 1

SECTION 13

FORM RPV-1 IN CERTIFICATE HOLDER'S DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
 As Required by the Provisions of the ASME Code, Sec. III, Div. 1

1. Manufactured by Atwood & Morrill Co., Inc. Salem, MA 01970
 (Name and Address of Certificate Holder)

2. Manufactured for Stone & Webster
 (Name and Address of Purchaser or Owner)

3. Location of installation Beaver Valley Power Station Shipping Port, PA
 (Name and Address)

4. Pump or Valve Valve Nominal Inlet Size 16 (inch) Outlet Size 16 (inch)

(a) Model No.	(b) N Certificate Holder's Serial No.	(c) Canadian Registration No.	(d) Drawing No.	(e) Class	(f) Nat'l. Bd. No.	(g) Year Built

(1)	16" Check Valve	7-13540	N/A	13540-03-F	2	N/A	1979
(2)				Rev. 4			
(3)							
(4)							
(5)							
(6)							
(7)							
(8)							
(9)							
(10)							

5. 16" Check Valve Deep Water
 (Brief description of service for which equipment was designed)

6. Design Conditions 1170 psu 450 °F or Valve Pressure Class N/A (1)
 (Pressure) (Temperature)

7. Cold Working Pressure 1440 psu at 100°F.

8. Pressure Retaining Pieces

	Mark No.	Material Spec. No.	Manufacturer	Remarks
9				
10	1a) Castings			
Body	Mt. # F3896 Rt. # S1580	SA 216, Gr. WCB	Quaker Alloy	S/N 7-13540
Disc	Mt. # F3987 Rt. # S1317	SA 216, Gr. WCB	Quaker Alloy	S/N 7-13540
Brg. Cover	Mt. # E8765 Rt. # S1356	SA 216, Gr. WCB	Quaker Alloy	S/N 7-13540
Brg. Cover	Mt. # E8765 Rt. # S1308	SA 216, Gr. WCB	Quaker Alloy	S/N 8-13540

10	1b) forgings			

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size 8 1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM RPV-1 (Rev. 1)

Mark No.	Material Spec. No.	Manufacturer	Remarks
(c) Bolting			
Cover Bolting			
Studs	SA 193, Gr. B7	Jos. Dyson & Sons	C89
Nuts	SA 194, Gr. 2H	Jos. Dyson & Sons	C11
Bearing Cover Bolting:			
Studs	SA 193, Gr. B7	Jos. Dyson & Sons	E97
Nuts	SA 194, Gr. 2H	Jos. Dyson & Sons	D01
(d) Other Parts			
Cover	A 515, Gr. 70	U.S. Steel Corp.	S/N 7-13540
Mfg. # 656744			

8. Hydrostatic test 2175 psi. Disk Differential test pressure 1500 psi.

CERTIFICATE OF COMPLIANCE

We certify that the statements made in this report are correct and that this pump, or valve, conforms to the rules of construction of the ASME Code for Nuclear Power Plant Components, Section III, Div. I, Edition 1974, Addenda Summer 1974. Code Case No. N/A. Date N/A.

Signed Atwood & Morrill Co., Inc by Walter F. Brown Feb 23, 79
 (In Certificate Holder) Quality Control Manager
 Our ASME Certificate of Authorization No. N-1766 to use the N symbol expires 5-20-80
 (Date)

CERTIFICATION OF DESIGN

Design information on file at Stone & Webster Engineering Corp.
 Stress analysis report (Class 1 only) on file at _____

Design specifications certified by (1) Faruk A. Gopalani
 PE State Pennsylvania Reg No 21966E
 Stress analysis certified by (1) N/A
 PE State N/A Reg No N/A

(1) Signature not required. List name only.

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Massachusetts and employed by H.S.B.L. Co. of Hartford, CT, have inspected the pump, or valve, described in this Data Report on Feb 23rd 1979 and state that to the best of my knowledge and belief, the Certificate Holder has constructed this pump, or valve, in accordance with the ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the equipment described in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Feb 23rd 1979

4 D
 Inspector

Commission No. 22254-1196 PA W.C. 2582
 Natl Bd State Prov and No.

10030

13540-03
Gddy/6*MATERIAL
TEST
REPORTQUAKER ALLOY CASTING CO.
Division of Maspeth Corp.
Manufacturing & Trade

ITEM NUMBER	6717-3-30223-009
AMT 3187 PURCHASE	10-2-78
SMB SA216 GR. WCB	
ADDITIONAL INFORMATION:	
FCT	
ab	

Atwood and Morrill Co.

CONTROL NO.	84025
HEAT SERIAL	F3896-4
BT NO.	S1580

CHEMICAL COMPOSITION

C	.25 ✓
Mn	.81 ✓
Si	.36 ✓
P	.017 ✓
S	.010 ✓
Cr	
Ni	
Mo	
Cu	

MECHANICAL PROPERTIES

TENSILE, KI	77.6 ✓
YIELD, KI	62.5 ✓
ELONG. %	29.5 ✓
RED. OF AREA, %	51.1 ✓
ENERGY, IN FT	
LAT. STR. —	
SHEAR, KI	
TEST TEMP. °	

PIECES SHIPPED

1

I HEREBY CERTIFY THAT THE ABOVE INFORMATION IS CORRECT.

R. Grupach /0-2-78
RECORDED 10-2-78

STATE OF PENNSYLVANIA, COUNTY OF UNION, I, I,
KNOWN TO AND SUBSCRIBED BEFORE ME
AUGUST 10, 1978
R. Grupach /0-2-78
Leverett

THIS

DAY OF

19

S. BATES ALLOY CASTING CO., HYDROSTIC, PA.

CUSTOMER Atwood & Nuttall PURCHASE ORDER AM-13187 CONTRACT NO.
 SHOP ORDER G411-03 Q DESIGNATION 070 PATTERN NO. 6717-3-30223-000
 MATERIAL SPEC. & GRADE ASME SA216 GR. WCB DESCRIPTION body SIZE 1
 PART NO. F3394 CASTING SERIAL NO. F3394-4 R.T. SERIAL NO. S1590
 NUCLEAR CLASS 2 PCS. COVERED ON THIS REPORT 1 SOURCE INSPECTION Atm. SW

✓ HEAT TREATMENT RECORD

PROCESS*	N	T	PWHT
			letter dated 8/17/78
PROCEDURE	QAP-HT.P1.1 Rev.G Same		QAP-Ws.P1.3.3.1 Rev.E &
DATE	5-16-78	5-22-78	9-25-78
FURNACE	Flynn&Drefinn	Gas Machine	Gas Machine
CHARGE NO.	FD-5-16-78-1	GM-5-22-78-1	GM-9-25-78-1
CHARGE TEMP.	250°F	75°F	150°F
TIME TO EQUIL. TEMP.	3 hrs.35 min.	1 hr.15 min.	45 min.
HOLDING TEMP.(RANGE)	1700°-1720°F	1350°F	1175-1225°F
TIME AT TEMP.	6 hrs.15 min.	6 hrs.5 min.	5 hrs.20 min.
COOLING DATA	Air	Air	Air

REMARKS _____

ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *N = Normalize or homogenize
- Q = Quench or harden
- T = Temper
- SA = Solution Anneal
- PWHT = Post Weld Heat Treat (Stress Relieve)

PREPARED BY S. Bates
 Quaker Alloy Casting Co.

TITLE Q.C.Dept.
 DATE 10-2-78
 DUQUESNE LIGHT CO.
 STONE & WEBSTER END
 BEAVER VALLEY UNIT 2
 FORM 12241 PO NO. 28Y-20
 MARK NO. 1001

QUAKER ALLOY CASTING CO., KIERNSTON, PA.

CUSTOMER Atwood & Morrell PURCHASE ORDER AM-16253 CONTRACT NO. _____
 SHOP ORDER G411-03 Q DESIGNATION Q70 PATTERN NO. 6717-3-30223-009
 MATERIAL SPEC. & GRADE ASME SA216 Gr. WCB DESCRIPTION Body SIZE 16"
 HEAT NO. F3896 CASTING SERIAL NO. F3896-4 R.T. SERIAL NO. S1580
 NUCLEAR CLASS 2 PCS. COVERED ON THIS REPORT 1 SOURCE INSPECTION ATW.

HEAT TREATMENT RECORD

PROCESS*	PWHT	
PROCEDURE	QAP-Ws.P1.3.3.1 Rev.E & Add.7B0808	
DATE	12-28-78	
FURNACE	Gas Machine	
CHARGE NO.	GM-12-28-78-4	
CHARIE TEMP.	505°F	DINNIESNE LIGHT CO. STONE & WEBSTER ENG. BEAVER VALLEY UNIT 2
TIME TO EQUIL. TEMP.	45 Mins.	
HOLDING TEMP. (RANGE)	1200°F	10-12341 PG NO. 28V-20
TIME - T TEMP.	4 Hrs. 20 Min.	MATERIAL NO. VQ-1010-A-2
COOLING DATA	Air	VENDOR'S NAME Atwood & Morrell

REMARKS _____

ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *
 - Normalize or homogenize
 - Quench or harden
 - Temper

- SA
 - Solution Anneal

PWHT = Post Weld Heat Treat (Stress Relieve)

PREPARED BY J. Spangler
 Quaker Alloy Casting Co.

TITLE Q.C. Clerk

DATE 1-5-79

ALL
D.C.B
8
1-5-79
Lave II

DUQUESNE LIGHT CO.

STONE & WEBSTER ENGR.

BEAVER VALLEY UNIT 2

10 12941 PO NO. 286-20

BLOCK NO. Tech Works-8-2


7-ZONE'S NAME *Thomas J. Neill*




Z = POINT OF MIN. THICKNESS

VIEW LOOKING INTO BONNET
WITH ANGLES TAKEN FROM
POINT OF MIN. WALL THICKNESS

POINT OF MIN. THICKNESS



VIEW LOOKING INTO OUTLET-
WITH ANGLES TAKEN FROM
POINT OF MIN. WALL THICKNESS



X = POINT OF MIN. THICKNESS
VIEW LOOKING INTO INLET-
WITH ANGLES TAKEN
FROM POINT OF MIN. WALL THICKNESS

NOTE:- ALL DIMENSIONS WILL BE RECORDED AS
FRACTIONS TO THE NEAREST 1/16 INCH.

Inspected by- *444 QC 11*

Approved by- _____

Date - *2-17-79*

Date- *1 3/32*

S.O. #3540 ITEM 03 CUSTOMER NO. 286V-20-3 SERIAL NO. 447-3540

ZONE LOCATION	1	2	3	4	5	6	7	8	9	10	11	12
A	1 5/16	1 4/8	1 3/8	1 1/4								
B					7 3/16	7 3/16	7 1/8	7 3/16	7 3/16	7 3/16	7 3/16	
C												

7 - 01
C.R.
C.R. CONTRACT NO.

WELDING INSPECTION REPORT

AS-1 Report

NO. 112241-1
VERIFIED BY: L. M. HANAUER
Date: 8-24-79

PO. DATE	11/28/79	CENTER	BIN-1, 8, Q
SUPPLIER NO.	42737	SELL. CROWN NO.	PROD. NO.
40-11140 PA. 13120	1/03/78	4112982	103-23392
J. S. STEEL SUPPLY DIV UNITED STATES STEEL CORP P.O. BOX 276 BOSTON, MASS 02115	61016		160

ASME A-213-74 & ASME SA-513 SUMMER 1973 ADDENDA 6A 70 ASME B16.11
11/1 1976 EDITION 4 THRU 11/1976 ADDENDA 20 ASME B16.11
JN 11/1976, 2610, 2530 CLASS 2 1/2 PRESSURE VESSEL O (1976 ON)
PLATES
WELLS, RA/SA 4150 WALT SNOW T/W ANALYSIS T/C/L ASME CERT NAR
JN 1/2 - 15 1/4 ACCORDANCE WITH NC2130

ASME A-213-74 & ASME SA-513 SUMMER 1973 ADDENDA 6A 70 ASME B16.11 11/1 1976 EDITION 4 THRU 11/1976 ADDENDA 20 ASME B16.11 JN 11/1976, 2610, 2530 CLASS 2 1/2 PRESSURE VESSEL O (1976 ON) PLATES WELLS, RA/SA 4150 WALT SNOW T/W ANALYSIS T/C/L ASME CERT NAR JN 1/2 - 15 1/4 ACCORDANCE WITH NC2130	DATE 11/28/78 STATE OF PENNSYLVANIA COUNTY OF ALLEGHENY SUBSIDIARY AND SNOW TO BIRON THIS DAY OF
--	--

John J. Hanauer

MATERIAL DESCRIPTION	QUANTITY	WEIGHT	TEST NO.	TEST ON PROD. QUANTITY	TEST PT			ELONGATION %			% RED. OF AREA		
					1/4"	1/2"	3/4"	1/4"	1/2"	3/4"	1/4"	1/2"	3/4"
ABOVE PLATE NORMALIZED @ 1652 DEC. F. RUE OR MITUS 25 DEC. F. MID. @ 150.0 MINUTES.	1	20011 652746	7316237	BC	* 42.0	76.0	79.0	OK					
" ASME QUALITY SYSTEM CERTIFICATE (MATERIALS) N-1285 JANUARY 5, 1979."													
SPEC: NORMALIZED. NO WELD REPAIR PERMITTED. QUALITY ASSURANCE CERTIFICATION REQUIRED													
REPORT OF CHEMICAL & PHYSICAL ACCEPTED:													
BT-114-77-A-1													
DATE 8-16-79													
ATWOOD & NORRILL CO. INC.													
Quality Assurance													
RECEIVED													
AUG 21 1979													
Stone & Webster Engineering Corp. Document Review													
740	741	C	N	F	S	Y	N	Q	CO				
740	741	20	74	005	019	20							
744	HEAT 29	76	005	019	20								

He certify that the contents of this report and all operations performed by our subcontractors are in compliance with the requirements of the ASME Code Section III, 1979 Edition throughout Summer 1974 inclusive.

John J. Hanauer

W.F. Emerson 8-16-79
Atwood & Norrill Co.
V.P. Manager

135 37-0000-2

MIN-WALL - COVER
0067

Note: Refer to Shop Drawing for Min Wall Requirements
and Actual Configuration of Cover

Procedure Used: 601-1375

Code Ref.: ASME SECTION I


M74ELW/S24AH

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

I.D. 12241 PO NO. 28V-20

MAP NO. VCHW060-A-2

Vendor's Name Atwood + Assoc.



Inspected by-



Approved by-

Date - 2-15-79

Date-

$t_m = 3\frac{1}{2}$ "

S.O. 13540 ITEM 03 CUSTOMER NO. 28V20-3 SERIAL NO. 7-13540

Heat No. 65C944

LOCATION		
A	<u>374</u>	
B	<u>374</u>	
C	<u>374</u>	

QUAKER ALLOY CASTING CO., KIRKSTON, PA.

S/N 7-1574

CUSTOMER Atwood & Morris PURCHASE ORDER AM-1318, CONTRACT NO. _____
SHOP ORDER GL11-03 Q DESIGNATION Q70 PATTERN NO. 12772-3
MATERIAL SPEC. & GRADE ASME SA216 Gr. WCB DESCRIPTION Bearing Cover
HEAT NO. E87105 CASTING SERIAL NO. E87105-9 R.T. SERIAL NO. 51251
NUCLEAR CLASS 2 PCS. COVERED ON THIS REPORT 1 SOURCE INSPECTION AM & Stone

CERTIFIED MATERIAL TEST REPORT

The records enclosed in this folder comprise the certified Material Test Report for the subject material.

AFFIRMATION

We certify that the contents of this report are correct and accurate and that all test results and operations performed by Quaker Alloy Casting Company, applicable products purchased from Material Manufacturers or Material Suppliers, or sub-contracted services are in compliance with the material specification and appropriate material requirements of the

ASME Code 1974

through Summer 1974 Addenda, Section III,
as stipulated in the procurement documents.

R. Preisch

Quaker Alloy Casting Company

8-11-78

Date

✓ DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2
1012241 PO NO. ABV-20
TX NO VCHW0160-A-2
WORKS NAME Atwood + Morris

8-11-78
Level II



HSB
ANI

4P 12-7-78

0069



QUAKER ALLOY CASTING CO.
A Division of MARSCO Corp.
MUTTONTOWN, PA. 15207

Atwood and Morrill Co.

13540-03
SIN 7-13540
BEARING COVER

MATERIAL
TEST
REPORT

CONTROL NO	PATTERN NO	DATE
AM13187	12772-3	7-27-78
SPECIFICATION		ASME SA216 GR.WCB
		Q70

ADDITIONAL INFORMATION

sb

REPORT OF
CHEMICAL & PHYSICAL
ACCEPTED
BY J. L. Sharp
DATE 8/30/78
ATWOOD & MORRILL CO., INC.
Quality Assurance

MECHANICAL PROPERTIES	
TENSILE, psi	71,0 ✓
YIELD, psi	44,0 ✓
ELONG, %	27.5 ✓
RED. OF AREA, %	51.2 ✓
ENERGY, INCH	
LAT EXP, mm	
SHEAR, %	
TEST TEMP, °F	

PIECES SHIPPED

1

I HEREBY CERTIFY THAT THE ABOVE INFORMATION IS CORRECT.

R. Ampach 8-11-78

STATE OF PENNSYLVANIA, COUNTY OF UNION, I, DO
SWORN TO AND SUBLSCRIBED BEFORE ME

8-11-78
Lavelle

ALLOY CASTING CO., INC.

Customer Atwood & Morrell PURCHASE ORDER AM-14-27 CONTRACT NO.

SHOP ORDER C411-03 Q DESIGNATION Q70 PATTERN NO. 12772-3

MATERIALS SPEC. & GRADE ASME SA216 Gr. MC3 DESCRIPTION Bearing Cover

Part No. E87165 CASTING SERIAL NO. E87165-9 R.C. SERIAL NO. S1356

NOMINAL CLASS 2 PCS. COVERED ON THIS REPORT 1 SOURCE INSPECTION AM & Stone &

Webster

HEAT TREATMENT RECORD

PROCESS*	N	T	
PROCEDURE	QAP-HT.P1.1 Rev.G	6 letter dated 8/17/78 Same	
DATE	5-18-78	6-21-78	
FURNACE	Surface Comb.	Eclipse 232	
CHARGE NO.	SI-5-18-78-2	E2-6-21-78-3	
CHARGE TEMP.	1150°F	1230°F	
TIME TO EQUIL. TEMP.	1hr.40 min.	1 hr.45 min.	
HOLDING TEMP.(RANGE)	1685°-1720°F	1330°-1350°F	
TIME AT TEMP.	3 Hrs.15 min.	3 hrs.20 min.	
COOLING DATA	Air	Air	

REMARKS _____

ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *N = Normalize or homogenize
- Q = Quench or harden
- T = Temper
- SA = Solution Anneal
- PHT = Post Weld Heat Treat (Stress Relieve)

PREPARED BY S. Bates
Quaker Alloy Casting Co.

TITLE Q.C. Dept.

DATE 7-27-78
DUQUESNE LIGHT CO.

STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

10 12241 PB NO. 2BV-20

MARK NO VCHD 60 - A-9

QUAKER ALLOY CASTING CO., HENDERSON, KY. 42226
S-13540

CUSTOMER Atwood & Morton PURCHASE ORDER AM-1380 CONTRACT NO.
SHOP ORDER G411-03 Q DESIGNATION 670 PATTERN NO. 12772-3
MATERIAL SPEC. & GRADE ASME SA216 Gr. WCB DESCRIPTION Bearing Covers
HEAT NO. E871-5 CASTING SERIAL NO. E871-5-7 R.T. SERIAL NO. S1278
NUCLEAR CLASS 2 PCS. COVERED ON THIS REPORT 1 SOURCE INSPECTION AM & Stone & Web

CERTIFIED MATERIAL TEST REPORT

The records enclosed in this folder comprise the certified Material Test Report for the subject material.

AFFIRMATION

We certify that the contents of this report are correct and accurate and that all test results and operations performed by Quaker Alloy Casting Company, applicable products purchased from Material Manufacturers or Material Suppliers, or sub-contracted services are in compliance with the material specification and appropriate material requirements of the

ASME Code 1974

through Summer 1974 Addenda, Section III,
as stipulated in the procurement documents.


R. Anupach

Quaker Alloy Casting Company

8-11-78

Date

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2
I.D. 12241 P.O. NO. 2BV-20
MARK NO. VCW040-A2
VENDOR'S NAME Atwood & Morell



Atwood and Morrill Co.

0077

QUAKER ALLOY CASTING CO.
a division of MARCO Corp.
MUTTONTOWN, PA. 15107



13540-63

BEARING CYL

MATERIAL
TEST
REPORT

CONTROL NO.	84027	TEST NO.	13540-3540
HEAT SERIAL	E8765-7	DATE TESTED	7-27-78
BT NO.	S1308	PROCEDURE	Q70

ADDITIONAL INFORMATION:

sb

CHEMICAL COMPOSITION

C	.24 ✓
Mn	.58 ✓
Si	.38 ✓
P	.013 ✓
S	.022 ✓
Cr	
Ni	
Mo	
Cu	

MECHANICAL PROPERTIES

TENSILE, psi	71,0 ✓
YIELD, psi	14,0 ✓
ELONG. %	27.5 ✓
RED. OF AREA %	51.2 ✓
ENERGY, IN. LBS	
LAT. EXP. -%	
SHEAR %	
TEST TEMP. °F	
PIECES SHIPPED	1

"I HEREBY CERTIFY THAT THE ABOVE INFORMATION IS CORRECT."

R. Rumpach 8-11-78

STATE OF PENNSYLVANIA, COUNTY OF FRANCIS, U.S.
SWORN TO AND SUBSCRIBED BEFORE ME

A&M
B.C.B
8

8-11-78
Level III

WITNESS Atwood & Morris

PURCHASE ORDER AM-1316 / CONTRACT NO.

SHIP ORDER 6411-03

Q DESTINATION 070 PATTERN NO. 12772-3

MATERIAL SPEC. & GRADE ASME SA215 Gr. MCB

DESCRIPTION Bearing Cover

ITEM NO. E87105 CASTING SERIAL NO. E87105-7

P.C. SERIAL NO. 51308

WEAR CLASS 2 PCS. COVERED ON THIS REPORT SOURCE INSPECTION A&M & Stone

HEAT TREATMENT RECORD

PROCESS*	N	T	
PROCEDURE	QAP-HT.P1.1 Rev.g Same	& letter dated 8/17/78	
DATE	5-18-78	6-21-78	
FURNACE	Surface Comb.	Eclipse 232	
CHARGE NO.	SI-5-16-78-2	E2-6-21-78-3	
CHARGE TEMP.	1150°F	1230°F	
TIME TO EQUIL. TEMP.	1 hr.40 min.	1 hr.45 min.	
HOLDING TEMP.(RANGE)	1685°-1720°F	1330°-1350°F	
TIME AT TEMP.	3 hrs.15 min.	3 hrs.20 min.	
COOLING DATA	Air	Air	

REMARKS

ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *N - Normalize or homogenize
- Q - Quench or harden
- T - Temper
- SA - Solution Anneal
- P-WT - Post Weld Heat Treat (Stress Relieve)

I.O. 12241 P.U. NO. 28V-20

MARK NO VCH060-A-2

VENOR'S NAME Atwood & Morris

PREPARED BY S. Bates
Quaker Alloy Casting Co.

TITLE Q.C. Dept.

DATE 7-27-78

8-11-78
Level II

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

115-90-0
Date

CUSTOMER Atwood & Mottill PURCHASE ORDER AM-13187 CONTRACT NO. 3474

SHOP ORDER G411-03 Q DESIGNATION 070 PATTERN NO. 16246

MATERIAL SPEC. & GRADE ASME SA216 Gr. WCB DESCRIPTION Disc SIZE

HEAT NO. F3997 CASTING SERIAL NO. F3997-4 R.T. SERIAL NO. 5B17

NUCLEAR CLASS 2 PCS. COVERED ON THIS REPORT SOURCE INSPECTION A & M Shop
Maha.

CERTIFIED MATERIAL TEST REPORT

The records enclosed in this folder comprise the certified Material Test Report for the subject material.

AFFIRMATION

We certify that the contents of this report are correct and accurate and that all test results and operations performed by Quaker Alloy Casting Company, applicable products purchased from Material Manufacturers or Material Suppliers, or sub-contracted services are in compliance with the material specification and appropriate material requirements of the

ASME Code 1974

through Summer 1976 Addenda, Section III,
as stipulated in the procurement documents.

R. Amstach
Quaker Alloy Casting Company

8-11-78

Date


DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2
10.12241 P.O. NO. 2BV-20
MARK NO. KCH060-A-2
ENDORSEMENT Atwood & Mottill

Form QAL Rev. 4
6/10/77

8-11-78
Level II
A.M.I.
Q.C.B.
1

MSB
AMT
4P 12-8-78





Atwood
and
Morrill

MATERIAL
TEST
REPORT

13540-03
DISC

QUAKER ALLOY CASTING CO.

TESTED BY		TEST NO.	TESTED BY	TEST NO.
ATWOOD	MORRILL	AM13187	DISCATION	16246
ASME SA216 GR. WCB	970			7-27-78

ADDITIONAL INFORMATION:

CONTROL NO.	84024	F3987-4	S1317
HEAT NUMBER			
BT NO.			

CHEMICAL COMPOSITION

C	.26 ✓
Mn	.73 ✓
Si	.39 ✓
P	.015 ✓
S	.015 ✓
Cr	.015 ✓
Ni	
Mo	
Co	

REPORT OF
CHEMICAL & PHYSICAL
TESTS
ACCEPTED
W. D. Goff

DATE 8/31/78

MECHANICAL PROPERTIES

TEMP. °F.	74.3
TEMP. °K.	23.8
ELONG. %	27.0
RED. OF AREA %	36.6
ENERGY IN BTU	
LAT. 1/2 P. min.	
SHRINK. %	
TEST TEMP. °F.	
TEST TEMP. °K.	

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

1.0 12241 P.O. NO. 6884-20
MARK NO. KCb6060-A-2
VENDOR'S NAME Atwood & Morrill

I HEREBY CERTIFY THAT THE ABOVE INFORMATION IS CORRECT.

R. Chupack 8-11-78
R. Chupack

ABM 8-11-78
EBC
A
Lone

CUSTOMER Atwood & Mor

PURCHASE ORDER AM-131

CONTRACT NO.

SHOP ORDER G411-03

Q DESIGNATION Q70

PATTERN NO. 16246

MATERIAL SPEC. & GRADE ASME SA216 Gr. WCB

DESCRIPTION Disc

SIZE

HEAT NO. F3987

CASTING SERIAL NO. F3987-4

R.T. SERIAL NO. S1317

NUCLEAR CLASS 2

PCS. COVERED ON THIS REPORT

1 SOURCE INSPECTION A & M

S-2
Webs

HEAT TREATMENT RECORD

PROCESS*	W	T	
PROCEDURE		5 letter dated 8/17/78	
	Q&P-HT.P1.1 Rev.G Same		
DATE	5-26-78	5-31-78	
FURNACE	Flynn&drefinn	Gas Machine	
CHARGE NO.	FD-5-26-78-1	GM-5-31-78-2	
CHARGE TEMP.	255°F	175°F	
TIME TO EQUIL. TEMP.	3 hrs.40 min.	1 hr.15 min.	
HOLDING TEMP.(RANGE)	1700°-1725°F	1350°F	
TIME AT TEMP.	4 hrs.25 min.	5 hrs.55 min.	
COOLING DATA	Air	Air	
REMARKS			

ACTUAL HEAT TREAT CHARTS ARE RETAINED IN FILE FOR THE ABOVE.

- *H - Normalize or homogenize
- Q - Quench or harden
- T - Temper
- SA - Solution Anneal
- PWHT - Post Weld Heat Treat (Stress Relieve)

JG 12241 PU NO. 2BV-20

MARK NO. VCLW060-A-2

VENDOR'S NAME Atwood + Morell

PREPARED BY S. Ratee

Quaker Alloy Casting Co.

TITLE Q.C.Dept.

DATE 7-27-78

8.11-78
A&M
D&C
8
Level II

CERTIFIED TEST REPORT



JOS. DYSON & SONS INC./DEPENDABLE DIVISION

33320 LAKELAND BLVD. • EASTLAKE OHIO 44094 • TELEPHONE: (216) 844-4200

To: Atwood & Morrill Co.
285 Canal Street
Salem, Mass. 01970

DATE	DEPENDABLE ORDER NUMBER	CUSTO ORDER N
7-19-78	M3536-1-4N	AM14135

DUQUESNE LIGHT CO.

STONE & WEBSTER ENG.

BEAVER VALLEY UNIT 2

Description: Item 1) 51 pcs. 3/4-10 x 3-1/4 TBE Stud per dwg. 3730
 2) 50 pcs. 1-3/8-8 x 7-1/4 " " " "
 3) 51 pcs. 3/4-10 Hvy Hex Nut
 4) 50 pcs. 1-3/8-8 Hvy Hex Nut

ITEM	HEAT	TRACE	C	Min	P	S	Si	Ni	Cr	Mo	V	Ti	Au	Cu
1	578W7167	E97	.40	.89	.018	.016	.28		.96	.17				
2	10760	C89	.41	.84	.011	.024	.23		.93	.17				
3	577P3238	D01	.40	.90	.014	.012	.29		.98	.18				
4	5772636	D11	.42	.87	.030	.016	.24		1.07	.17				

ITEM NO.	TENSILE STRENGTH		YIELD STRENGTH		PROOF LOAD LBS.	ELONGATION PERCENT IN 2"	PERCENT RED. AREA	HARDNESS		MACH TEMP DEG. F.	
	PSI	PSI	PSI	PSI				ASTM HRB HRBT	RC28		
1	140,250		125,000			21.5	62.6			1100	
2	126,000		108,500			25.0	65.9			1100	
3				45,300					RC28	RC24	850
4				215,800					BHN302	BHN269	850

SPECIFICATIONS: ASME SA193 B7, SA194-2H, Sec.III CL.2, 74ED, S74 Add.
 DYSON PROCEDURE #D510, D515

REPUBLIC STEEL MILL CERT FOR TRACE D11 ATT.
 WESTERN COLD DRAWN STEEL MILL CERT FOR TRACE D01, E97 ATT.
 COPPERWELD STEEL MILL CERT FOR TRACE C89 ATT.
 HENDERSHOT & SMITH HEAT TREAT CERT #17170, 17566 & CHARTS ATT.
 NETTLETON HEAT TREAT CERT #641 & CHARTS ATT.

HERRON TEST LAB REPORT #K0367, K5834 ATT.
 CROBAUGH TEST LAB REPORT #F1068 ATT.

BEAVER VALLEY UNIT 2

APR 4 1978
741 P.O. NO. 2BV-20

1. VCHW060-A-2

2. Atwood & Morrill



REPORT OF
 CHEMICAL & PHYSICAL
 ACCEPTED

BY L. Sharp
 DATE 8/14/78

ATWOOD & MORRILL CO. LTD.
 Quality Assurance

THIS CERTIFICATE NOTARIZED ONLY WHEN REQUIRED

I, _____, a Notary Public do hereby certify that
 this affidavit was subscribed and sworn to before me by a duly authorized
 agent of Jos. Dyson & Sons, Inc., this _____ day of _____

We certify that the contents of this report are correct
 and that all operations performed by our
 or subcontractors are in compliance with the require-
 ments of the specifications stated above.

DEPENDABLE DIVISION
 JOS. DYSON & SONS INC.

L. A. S. J. Morrissey

HERRON TESTING LABORATORIES, INC.

113 HOWARD ROAD - CLEVELAND, OHIO 44118 - (216) 324-1428

CONTRACTUAL AND TESTING SINCE 1928

Purchase Order No. 1000

File No. X 0367

October 3, 1977

Test of 1-3/8"-8 Heavy Hex Nut, per ASME-SA 194, Gr. 7, Trace D11

Class DEPENDABLE DIVISION, JOSEPH DYSON & SONS, INC.

Attention Mr. L.A. Saley

BRINELL HARDNESS PER PARA.

AXIAL PROOF LOAD (215900 LB)

7.1.5.1

7.1.5.2

Satisfactory

302

269

Meets requirements of ASME-SA 194, Gr. 7. & 2H

0097

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

I.O. 12241 P.O. NO. 28V-20

MARK NO. VCW000-A-2

VENDOR'S NAME Atwood + Macmill

HERRON TESTING LABORATORIES, INC.

The above are the actual results obtained by us on the sample submitted

All Representations

Sworn and subscribed to before me this 3rd day of October 1977.

Lori A. Atkinson

LORI A. ATKINSON
Notary Public For Cuyahoga County, O.
My Commission Expires Feb. 21, 1982

Inspection Certification

NO. 17170

CUSTOMER JOS. DYSON DEPENDABLE DIV.

Purchase Order No.	<u>16364</u>	S.O. No.	<u>285700</u>	Date	<u>8-22-77</u>
Part No.	Description NUT BLANKS				
Quantity	<u>1863- 2534</u>	Weight	<u>839# - 2742#</u>		
	Operation HEAT TREATING				
Process Specification	Material Inspection Record				
	Operation	Specification	Inspection		
Heat No.					
<u>4140: HT PER ASME SA194 GR7-1100F</u>	Mat. Type	<u>4140</u>	<u>4140</u>		
<u>DRAW-248-352 BHN-RC 24-38-AIR COOL-</u>	Hardness	<u>RC 24-38</u>	<u>RC 33-36</u>		
<u>TRACE F-16- TRACE D-11</u>	PSL				
<u>6 TEST BARS</u>	Case Depth				
	Core Hardness				
	% of Inspection				
		Chief Inspector	<u>WRS</u>		
		Approved by	<u>John C. Miller</u>		

HENDERSHOT & SMITH, INC.

Wickliffe Division • 28910 Lakeland Blvd. • Wickliffe, Ohio
 Bedford Division • 7160 Krick Industrial Park • Bedford, Ohio
 Carolina Commercial Heat Treating, Inc.

Powder Co., S.C. Division
 Charlotte, N.C. Division
 Goldsboro, N.C. Division

DUQUESNE LIGHT CO.
 STONE & WEBSTER ENG.
 BEAVER VALLEY UNIT 2

J.O 12241 P.O NO. 2BV-20

MARK NO. VCLW060-A-2

VENIOR'S NAME Attwodds Mccoll

ITEMIZED ORDER NUMBER AND DATE
#12943 4/17/73

丁巳

B FALLS

22-7107

61675 ASSOCIATED TRUCK LINES

2 7678-822 DEPENDABLE DV PS 10454

DEPENDABLE DIV
OF JCS DYSON & SONS INC
P O BOX 4328
CLEVELAND OH 44132

DEPENDABLE DIV. OF JOS DYSON & SONS INC
33220 LAKELAND BLVD
EASTLAKE, OHIO 44094

Certificate of Tests

"SHIP TO" SAME AS "SOLD TO" UNLESS OTHERWISE INDICATED

151-4140 ANN COLD DRAWN STEEL EARS

2-3/16 IN HEX X 10/12 FT
65 BARS 4 LIFTS OO-6/21

第六章 治理与监督

PO: 12943
TRACE: D-11

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

01412241 P.D. 92 - 2334-26

MARK NO. YCFV01P-A-2

~~VENDOR'S NAME~~ Atwood + Maxill

I HEREBY CERTIFY THAT THE MATERIAL LISTED HEREIN HAS BEEN INSPECTED AND TESTED IN ACCORDANCE WITH THE METHODS PRESCRIBED IN THE GOVERNMENT SPECIFICATIONS AND PAPERS, UPON THE RESULTS OF SUCH INSPECTION AND TESTING HAS BEEN APPROVED FOR CONFORMANCE TO THE SPECIFICATIONS.

[W. A. Bishop]

PLANT METALLURGIST
UNION DRAWN IR.
BEAVER FALLS, PA.

EKT-PPP 405 02

ANALYSIS	HEAT NO.	C.H.P.	CARBON	MANG.	PHOS.	SUL.	CHLOR.	COPPER	NICKEL	CANTH.	W.L.	VAN.
	5772636		.42	.57	.030	.016	.24			.07	.17	

JUL 03 19

CROBAUGH LABORATORIES

RESEARCH • ANALYSIS • TESTING

3800 PERKINS AVENUE CLEVELAND, OHIO 44114

216 - 881-7320

Dependable Division
33220 Lakeland Boulevard
Eastlake, Ohio 44094

Attention: Mr. Saley

Reporting Date July 1, 1975.....

Lab. No. F 1068.....

Date Received June 25, 1975.....

Material A140 Steel.....

Marked 3/4-10" Heavy Hex Nut.....

P. O. 13117 M-2156-1-2.....

Heat F577P3238

Specification: ASME SA194 Gr. 7 & 2E

Traceability FD-01

I Proof Load

45,300 pounds Passed

II Heat Treatment 24 hours at 1100°F.

Hardness before R_C 28

Hardness after R_C 24

The material meets the requirements of the specification.

Respectfully submitted,

CROBAUGH LABORATORIES


Michael R. Gaydos

J.O 12241 P.O NO. 28V-20

MARK NO VCHW060-A-2

VENDOR'S NAME Atwood + Macmillan



COPPERWELD SPECIALTY STEEL COMPANY

CHICAGO'S PREMIER SUPPLY

021174 CHI

2951

103173

10-1

X

MAY

5/19/74

68269

 NPP

10 days net 30 days

STEEL BARS
HOLD NO.

NPP COL IMP VISA

DIAMETERS CORPORATION
3977 25TH AVENUE
SCHILLER PARK, ILLINOIS 60176

X

1468

NAME AS SOLD TO UNLESS OTHERWISE NOTED

P O 12417

TRACE C-89

000-006 CENTERLESS GRINDING

12/10¹ AIM 12¹

HT CO SR SHEAR CUT BOTH ENDS (26)

269/321 RHN

ASTM A 193 GR BZ

COPPERWELD
SPECIALTY STEEL COMPANY
P.O. BOX 381 / WARREN, OHIO 44483

TEST REPORT

ORDER NUMBER	
CUSTOMER	COPPERWELD
	68269

GRAN

MEAT NO.	CODE												SPECN / PRODUCT DESCRIPTION	DATE
	C	Mo	P	S	Si	Ni	C	Mo	Cr	Pb	Al	GRAIN		
10760	.41	.84	.011	.024	.23	.	.93	.17						10/14/74

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
	57	57	57	55	52	52	48	47		42	40		38		37	35	35	35	35	34						

TENSILE	YIELD	OFFSET	ELONG.	R.A.	HARDNESS*	OTHER DATA
126,000	102,500		25.0	65.9	269	Temper - 1100°
142,500	128,500		20.0	59.8	277	
130,000	114,000		21.0	62.3	269	
141,500	127,000		19.0	51.9	277	

*Surface unless otherwise noted

DUQUESNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

CERTIFICATE NOTARIZED WHEN REQUIRED

I, a Notary Public do hereby certify that this affidavit was subscribed and sworn to before me by a duly authorized representative of Copperweld Specialty Steel Company.

This _____ day of _____

10-12241 P.O. NO. 28V-20

MAP NO. VCV 0102-A-2

W. VENDOR'S NAME Attorney at law
contained in the records of Copperweld Specialty Steel Company.

R. DeLaney

HERRON TESTING LABORATORIES, INC.
305 SCHAFER ROAD - CLEVELAND, OHIO 44111 - 216/524-1190
CONSULTATION AND TESTING SINCE 1911

0106
MECHANICAL
TESTS

Purchase Order No. 16863

File No. K 5834

24 February 1978

3/4" Dia. Steel Bar, per ASME-SA193, Gr. B7, Trace No. E97, Item No. M3208-1-2

DEPENDABLE DIVISION: JOSEPH DYSON & SONS, INC.

ORIGINAL DIMENSIONS	AREA	YIELD		ULTIMATE STRENGTH		ELONGATION		REDUCED DIMENSIONS	REDUCED AREA	% REDUCTION	REMARKS
		POUNDS	POUNDS PER SQ. IN.	POUNDS	POUNDS PER SQ. IN.	IN 2"	%				
.505	.200	25000	125000	28050	140250	.43	21.5	.309	.0749	62.6	
Meets requirements of ASME-SA193, Gr. B7.											

BUTCHERNE LIGHT CO.
STONE & WEBSTER ENG.
BEAVER VALLEY UNIT 2

R.R. 12241 P.O. NO. 28V-720

MARK NO. PCW1060-A-2

VENDEUR'S NAME ATTWOOD MANUFACTURING

Strength at 2% offset

Tension under load Inches per inch

By *Michael R. Taylor*
The foregoing is expressly limited to findings based upon material, information, and/or specifications furnished by client and excludes any express or implied warranties as to the fitness of the material and/or process as subjected to examination and/or analysis for any particular purpose or use.

Inspection Certification

NO. 17566

CUSTOMER JOS. DYSON DEPENDABLE DIVISION

Purchase Order No.	<u>16815</u>	S.O. No.	<u>347180</u>	Date	<u>2/8/78</u>
Part No.		Description	<u>BOLTS TRACE E97</u>		
Quantity		Weight	<u>1741#</u>		
		Operation	<u>HEAT TREATING</u>		
Process Specification		Material Inspection Record			
		Operation	Specification	Inspection	
<u>4140: HEAT TREAT, QUENCH AND TEMPFR MINIMUM DRAW 1100 DEGREES F-OIL</u>		Heat No.			
<u>QUENCH PER ASTM A193-B7</u>		Mat. Type	<u>4140</u>	<u>4140</u>	
		Hardness		<u>269-285HRN</u>	
		PSL			
		Case Depth			
		Core Hardness			
		% of Inspection			
			Chief Inspector	<u>WRS</u>	
			Approved by	<u>Wm. C. Shultz</u>	

HENDERSHOT & SMITH, INC.

Wickliffe Division • 28910 Lakeland Blvd. • Wickliffe, Ohio
 Bedford Division • 7160 Krich Industrial Park • Bedford, Ohio
 Carolina Commercial Heat Treating, Inc.

Pittsburgh, Pa. Divisions
 Charlotte, N.C. Division
 Greenville, N.C. Division

DUQUESNE LIGHT CO.
 STONE & WEBSTER ENG.
 BEAVER VALLEY UNIT 2

J. O. 12241 P.O. NO. 2BV-20

MARK NO VCW060-A-2

VENNER'S NAME Attwood-McMill

SECTION 14

FORM NPV-1 IN CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Nuclear Valve Division of Borg Warner, 7500 Tyrone Ave., Van Nuys, CA
Name and Address of Certificate Holder
2. Manufactured for Duquesne Light Company, P.O. Box 2325, Boston, Mass. 02107
Name and Address of Purchaser or Owner
3. Location of Installation Beaver Valley Power Station, Shippingport, Beaver County, PA
Name and Address
4. Pump or Valve Feedwater Isolation Nominal Inlet Size 16x10x16 Inch) Outlet Size 10x10x16 Inch)

(a) Model No., (b) N Certificate Holder's Series No. or Type	(c) Canadian Serial No.	(d) Drawing Registration No.	(e) Class No. ✓	(f) Nat'l. Bd. No.	(g) Year Built
(1) 500# ✓	62752 ✓	N/A	435XAB5-001	2 ✓	N/A 1981
(2)					
(3)					
(4)					
(5)					
(6)					
(7)					
(8)					
(9)					
(10)					

- The valves are designed to handle a fluid media which includes steam, water
- condensate, borated water, etc., associated with a PWR and BWR. The

(Brief description of service for which equipment was designed)
Temperature pressure rating of the media is stated below.

- 2220 100
6. Design Conditions 1600 psi 500 °F or Valve Pressure Class N/A (1)
7. Cold Working Pressure 2220 psi at 100°F
8. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings			
Gate-Code 3E60	SA 351 CF8M	Pacific Metals	
DUQUESNE LIGHT COMPANY BEAVER VALLEY POWER STATION UNIT 2 P.O. 237-92 J.O. NO. 1221 FEEDWATER ISOLATION TRIP VALVE DIV OF BORG WARNER, 7500 TYRONE AVE VAN NUYS, CA 91409			
(b) forgings			
Body-Code 3L42	SA 105 ✓	Jorgensen Steel	
Bonnet-Code 3M92	SA 105 ✓	Compton Forge	
Neck-Code 3W94	SA 105 ✓	Compton Forge	
Retainer-Code 2X78	SA 105 ✓	Jorgensen Steel	

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*

- | | | | | | | |
|-----------------------------|---|---------------------|--------------------|-------------|-----------------------|-------------------|
| 1. Manufactured by | Nuclear Valve Division of Borg Warner, 7500 Tyrone Ave., Van Nuys, CA
(Name and Address of N Certificate Holder) | | | | | |
| 2. Manufactured for | Ducquesne Light Company, P.O. Box 1325, Boston, Mass. 02107
(Name and Address of Purchaser or Owner) | | | | | |
| 3. Location of Installation | Beaver Valley Power Station, Shippingport, Beaver County, PA
(Name and Address) | | | | | |
| 4. Pump or Valve | Feedwater Isolation | Nominal Inlet Size | 16x10x16
(inch) | Outlet Size | 16x10x16
(inch) | |
| (a) Model No. | (b) N Certificate Holder's | (c) Canadian | | | | |
| Series No.
or Type | Serial
No. | Registration
No. | (d) Drawing
No. | (e) Class | (f) Nat'l.
Id. No. | (g) Year
Built |
| (1) 900# | 63081 | N/A | 435XAB5-001 | 2 | N/A | 1981 |
| (2) | | | | | | |
| (3) | | | | | | |
| (4) | | | | | | |
| (5) | | | | | | |
| (6) | | | | | | |
| (7) | | | | | | |
| (8) | | | | | | |
| (9) | | | | | | |
| (10) | | | | | | |

The valves are designed to handle a fluid media which includes steam, water condensate, borated water, etc., associated with a PWR and BWR. The

Temperature pressure rating of the media is stated below.

6. Design Conditions 2220 psi 100 °F or Valve Pressure Class N/A
1600 (Pressure) 500 (Temperature)
7. Cold Working Pressure 2220 psi at 100°F
8. Pressure Retaining Pieces

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11", (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

FORM NPV-1 N CERTIFICATE HOLDERS' DATA REPORT FOR NUCLEAR PUMPS OR VALVES*
As Required by the Provisions of the ASME Code, Section III, Div. 1

1. Manufactured by Nuclear Valve Division of Borg Warner, 7500 Tyrone Ave., Van Nuys, CA
(Name and Address of N Certificate Holder)
2. Manufactured for Duquesne Light Company, P.O. Box 2325, Boston, Mass. 02107
(Name and Address of Purchaser or Owner)
3. Location of Installation Beaver Valley Power Station, Shippingport, Beaver County, PA
(Name and Address)
4. Pump or Valve Feedwater Isolation Nominal Inlet Size 10x10x10 (inch) Outlet Size 10x10x16 (inch)

(a) Model No., (b) N Certificate Holder's		(c) Canadian		(d) Drawing		(f) Nat'l.		(g) Year Built	
Series No. or Type	Serial No.	Registration No.	No.	No.	Clas-	Ed. No.			
(1) 900# ✓	63080 ✓	N/A	435KAB5-001	2		N/A			1981
(2)									
(3)									
(4)									
(5)									
(6)									
(7)									
(8)									
(9)									
(10)									

- The valves are designed to handle a fluid media which includes steam, water condensate, borated water, etc., associated with a PWR and BWR. The

(Brief description of service for which equipment was designed)
Temperature pressure rating of the media is stated below.

6. Design Conditions	2220 ✓	100 ✓							
	1600 ✓	500 ✓							
	(Pressure)	(Temperature)							
7. Cold Working Pressure	2220 ✓	psi at 100°F.							

6. Pressure Retaining Pieces

Mark No.	Material Spec. No.	Manufacturer	Remarks
(a) Castings Gate-Code 3E64	SA 351 CF8M ✓	Pacific Metals	

DUQUESNE LIGHT COMPANY
 BEAVER VALLEY POWER STATION UNIT 2
 P.O. 23V-92 C.O. No. 1111
 FEEDWATER ISOLATION TRIP VALVE
 MVD OF BORG WARNER, 7500 TYRONE AVE
 VAN NUYS, CA 91409

(b) forgings

Body-Code 3L42 ✓	SA 105 ✓	Jorgensen Steel
Bonnet-Code 3M92 ✓	SA 105 ✓	Compton Forze
Neck-Code 3W94	SA 105 ✓	Compton Forze
Retainer-Code 2X78	SA 105 ✓	Jorgensen Steel

(1) For manually operated valves only.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8-1/2" x 11"; (2) information in items 1, 2 and 5 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at top of this form.

EARLE M. JORGENSEN CO.

STEEL

FORGE DIVISION

2531 E. MARGINAL WAY SOUTH • PHONE 782-1100 (AREA 206)
MAILING ADDRESS: P.O. BOX 24026
SEATTLE, WASHINGTON 98124

CERTIFIED MATERIAL TEST REPORT

CUSTOMER

NUCLEAR VALVE DIVISION
BORG WARNER CORP.
P O BOX 2185
VAN NUYS, CALIF 91405

Date 6-24-78
Customer's Order No. 84234
Our Invoice No. 2398 FS
Contract No.

HEAT NO.	MATERIAL	DESCRIPTION	SPECS.
21155	SA105	8 ROUGH TURNED ROUNDS 22-1/2" DIA +1/4 -0 X 32" +1/2 -0 LG "ALL REQUIREMENTS OF SA105 HAVE BEEN MET"	ASME SA105

CHEMICAL ANALYSIS

HEAT NO.	MATERIAL	C	MN	P	S	SI	NI	CR	MO	V	CU	BN	G/S
21155	SA105	.23	1.00	.014	.018	.29							

HARDENABILITY - ROCKWELL

HEAT NO.	MATERIAL	1	2	3	4	5	6	7	8	9	10	11	12

N HEAT NO. 21155
IN CODE NO. 3442
S/O
P.C. 84234
QTY. 8
INSP DATE 8/14/78
VENDOR Jorgensen Steel

.2% OFFSET MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD LBS./SQ. IN.	TENSILE LBS./SQ. IN.	ELONG. %, IN.	RED. OF AREA %	FRACTURE	BEND	MACRO	IMPACT
LMR	21155	SA105	53,000	73,000	35.5	623	CUP			

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 2EV-92 J.O. NO. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

REMARKS:

"THIS IS TO CERTIFY THAT THE MATERIAL SUPPLIED ON THIS ORDER WAS MADE BY THE BASIC ELECTRIC FURNACE, DOUBLE SLAG METHOD AND IS FREE FROM MERCURY AND/OR ALPHA SOURCE CONTAMINATION".

NORMALIZE 1650° 24 HRS

INSPECTOR

REVIEWED BY
AUTHORIZED
INSPECTOR

C
DATE 8/21/78

...BED AND SWORN TO BEFORE ME

WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIREMENTS DESCRIBED HEREIN, AND TEST REPORTS ARE ON FILE SUBJECT TO EXAMINATION.

THIS DAY OF 19

NOTARY PUBLIC—SEATTLE

EARLE M. JORGENSEN CO.

BY R.L. Kinnar

EARLE M. JORGENSEN CO.
STEEL
FORGE DIVISION

SEATTLE, WASHINGTON 98124

PHONE (206) 762-1100
TELEX 3-2280

October 21, 1981

6521 EAST MARSHAL WAY SOUTH
MAILING ADDRESS: BOX 2000

Mr Warren Wheaton
Nuclear Valve Division
Borg-Warner Corporation
P.O. Box 2185
Van Nuys, California 91405

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 2BV-92 J.O. No. 11111
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

Dear Mr Wheaton:

The material furnished to NVD on the following orders were produced in accordance with ASME SA 105, ASME Boiler and Pressure Vessel Code Section III Division 1, Class 1.

<u>NVD P.O.</u>	<u>EMJ ORDER</u>	<u>HEAT NUMBER</u>
11316	9111 PS	20403
84008	7534 PS	18245
84234	2398 PS	21155 ✓

Should you require any additional information please call or write.

Sincerely

Daniel E. Wiegert, Jr.
Manager Quality Assurance

DEWEYSTLER:pc

RECEIVED
1981.

ENGINEERING

N HEAT NO. 21155
N CODE NO. 344Z
S/O _____
P.O. 84234
QTY. 8
INSP DATE 10/27/81
VENDOR JORGENSEN

REVIEWED BY
AUTHORIZED
INSPECTOR
A

DATE 10/27/81



METALS TECHNOLOGY, INC.
METALLURGICAL ENGINEERING CONSULTING & SERVICE
ENGINEERING REPRESENTATIVES
8955 QUARTZ AVENUE NORTHridge, CALIF. 91324
PHONES: (213) 882-6414 (213) 873-7144

No 1597

CERTIFIED TEST REPORT

DATE 2-16-82

HEAT NO.: 21155

N-Code: 3242

CUSTOMER NUCLEAR VALVE DIVISION

PART NO.:

YOUR P.O.: 68576-1

S/N: See Below

JOB NO.: Shipper #50698

SPECIFICATION: NPS 71864

NB2332A-1

ASME SA-105

MATERIAL: C/S

TENSILE TEST

SPECIMEN NO.	SIZE (IN)	AREA (IN ²)	YIELD* LOAD (LBS)	YIELD* (KSI)	ULTIMATE LOAD (LBS)	ULTIMATE (KSI)	ELON. GATION** (%)	RED. AREA (%)

Requirements:

HEAT NO. 21155
N CODE NO. 3242
S/N 50698
P.O. 68576-1
QTY. 2 lot
INSP DATE 2-16-82
VENDOR m.t.b. 7-26

*Yield at ____ % Offset

**In ____ inch Gage Length
.005 in/in./min./S.R.

CHARPY IMPACT TEST

SAMPLE NO.	TEST TEMP (°F.)	ENERGY (FT-LBS)	% SHEAR	LAT-EXP IN	REMARKS
#4	40°F	40	30%	.036	
#5	40°F	45	50%	.026	
#6	40°F	60	50%	.040	

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 1221
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TURONE AVE
VAN NUYS, CA 91409

Requirements:

.025 min.

Respectfully Submitted

S.J. Block
Vice-President of Operations
Metals Technology, Inc.

COMPTON FORGE, INC.

REPORT OF CHEMICAL AND PHYSICAL TESTS

P-1 No. 8105

SOLD TO:
NUCLEAR VALVE DIVISION
P.O. BOX 2185
VAN NUYS, CALIF. 91409

SHIPPED TO:

7500 TYRONE AVE.
VAN NUYS, CALIF. 91409

CUST. ORDER NO.
84026

SHIPPER NO.
8105

SPECIFICATION NO. NORMALIZED PER MIL-H 6875F AND
ASME SA-105, MAG. INSP. PER ASME B&PV CD. SEC.
III SURFACE NO. 2E4E & NDS 700/4 G

ITEM NO.

DESCRIPTION


1 8 PCS. P/N: T1207-000 C HEAT: 6025105 W/O: 1647-
1 TEST BAR

NUCLEAR CODE 3M92 ✓

REVIEWED BY
AUTHORIZED
INSPECTOR

[Signature] DATE p14h1

NICOLEAD



MAT'L ASME SA105 SIZE 8. 8.25/10 RND
1029

MILL REPUBLIC

HEAT NO. 6025105

N CODE NO. 3M92V

S/O

P.O. 84028

QTY. 5

DATE DEC 1 1978

N

INSP VENDOR

MECHANICAL PROPERTIES						
HEAT NO.	YIELD POINT P.S.I.	TENSILE STRENGTH P.S.I.	% ELONG. 2"	% RED. AREA	BRINELL	ROCKWELL
6025105	41,800 ^{DW}	73,900 ^{DW}	30.5	61.4		

COMPTON FORGE, INC. CERTIFIES THAT THE ABOVE FORGINGS WERE MANUFACTURED AND PROCESSED
IN ACCORDANCE WITH AND MEET THE REQUIREMENTS OF: ASME 7047D NUCLEAR VALVE P.O. 84028
DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

[Signature] 11-10-78

Date

CHEMICALS

HEAT NO.	C	MN	P	S	SI	NI	CR	CU	AL	MO	TI	*	*
6025105	.28	.85	.006	.032	.22								

SUBSCRIBED AND SWORN TO BEFORE ME THIS 27 DAY OF OCTOBER 1978

I CERTIFY THAT THESE ARE CORRECT
COPIES OF REPORTS NOW ON FILE AT

COMPTON FORGE, INC.

[Signature] QUALITY ANALYST



CERTIFICATION OF HEAT TREATMENT

HALL HEAT TREATING

DIVISION OF CERTIFIED ALLOY PRODUCTS, INC.
16623 ILLINOIS AVENUE • 531-7852
PARAMOUNT, CALIFORNIA 90723

CUSTOMER'S NAME Compton Forge Inc.PART NAME Forgings Nuc Code #3M92MATERIAL ASME SA-105 1029YOUR SPECIFICATION Normalize per MIL-H 6875F & ASME SA-105

NO. 65697
DATE 9-28-78
Nuc Valve P0#84028
CUSTOMER'S 1647-1
ORDER NO. R/C 75833
OUR SHIPPER 21515
NO. H1# 6025105
PART NO. P/N 71207-000 C
NO. PCS 9

TENSILE P.S.I.	OPERATION	TEMPERATURE	TIME AT TEMP	ROCKWELL	FURNACE COOL	AIR COOL	BRINELL	record
	NORMALIZE Furnace # 13	1650 ✓	1- hr			X		
	STRESS RELIEVE							
	SUB-CRITICAL ANNEAL							
	ANNEAL	DUQUESNE LIGHT COMPANY BEAVER VALLEY POWER STATION UNIT 2						
	PRE HEAT	P.O. 2BV-92 J.O. No. 12241 FEEDWATER ISOLATION TRIP VALVE						
	QUENCH	NVD OF BORG WARNER, 7500 TYRONE AVE VAN NUYS, CA 91409						
	TEMPER							
	HOMOGENIZE							
	TRANSFORMATION							
	SOLUTION ANNEAL							
	AGE							
	STRESS EQUALIZE							
	SUB-ZERO							

N

HEAT NO. 1025105
N CODE NO. 3M92
S/O _____
P.O. 85028
QTY. 8
INSP
VENDOR Compton Forge

CERTIFICATION

We certify that the above listed parts have been heat treated in accordance with Military Specification MIL-H 6875 and ASME SA-105

WE CERTIFY NO MERCURY CONTAMINATION

We further certify that the above statement is true and correct and that temperatures and test results were obtained with standard approved methods.
Hardness certified on parts in present state of completion.

FINAL HARDNESS: ROCKWELL 149 ✓ BRINELL BHV. 149 ✓ TENSILE 100% PERCENTAGE OF PARTS TESTED 100 %

Subscribed and sworn to before me this

day of September, 1978Notary Public
in and for the county of Los Angeles, State of CaliforniaMy Commission Expires December 31, 1980HALL HEAT TREATING
Division of Certified Alloy Products, Inc.
D. Schmalzried
Q.C. AUTHORIZED SIGNATURE

ORIGINAL

DICKSON TESTING Co., Inc.

11120 PALMER
SOUTH GATE, CALIF. 90280
PHONE (213) 773-5212

TO: Compton Forge, Inc
P. O. Box 4819
1721 No. Alameda
Compton, California 90224

N
HEAT NO. 6025105
N CODE NO. 3M92
S/O _____
P.O. 84028
QTY. 8
INSP DATE DEC 1 1978
VENDOR Compton Forge

DATE	PURCHASE ORDER NO.	YOUR JOB NO.	MATERIAL
11/3/78	1647-1		1029 Carbon Steel
SPECIFICATION	DESCRIPTION 1029-000 C P/N Nuclear Code #3M92, Nuclear Valve ASME-SA-105 P. O. #84028, H/N #6025105		
ASME-SA-105			

CERTIFIED REPORT OF PHYSICAL TEST

NUCLEAR

Identifi- cation #	Stressed Dimension	Stressed Area	Yield Strength		Tensile Strength		Elongation		Reduction of Area		Code	Lab N.
			Actual Load Lbs.	Pounds Per sq. in.	Actual Load Lbs.	Pounds Per sq. in.	in-in	Percent	Reduced Dimension	Percent		
TT												P126-21
Long.	.504	.1995	8340	41,800	14,750	73,900	.61	30.5	.313	61.4		
Charpy V-Notch Impact Strength at + 40°F.												
			Ft.-Lbs.			Lateral Expansion			% Shear Fracture			
1.		36					.035			40		
2.		44					.044			50		
3.		38					.036			50		
Note:	While being tested at Dickson Testing Co., Inc. this material was not in contact with any Mercury or Halogen bearing materials.											
Min												
MAXIMUM Requirements			36,000		70,000		22		30			
Minimum Requirements	Charpy			20 MILs, Lateral Expansion								

Yield Strength Determined By:

0.2% Offset ✓
Strain Rate .005 in/in/min to yield

Remarks:

ITS SPECIFICATION REQUIREMENTS.



- Fracture Code:
(F) Indicates Flaw.
(G) Indicates Broke Outside Gage Marks.
(g) Indicates Broke thru Gage Mark or
within specimen width of Gage Marks.

DICKSON TESTING Co., Inc.
James F. Scannell
Lab Superintendent
AUTHORIZED SIGNATURE

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 2 BV-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE.
VAN NUYS, CA 91409

PACIFIC METALS CO., LTD.

Nuclear Valve Division
BORG - MAHOG CORPORATION
MESSRS

HEAD OFFICE No. 6-1 Chuo Otemachi Chiyoda ku Tokyo Japan.
MAGETSU WORKS Minatocho Isotsu Megata Pref. Japan.

Date Apr. 22, 1970.

NAME OF ARTICLES Gate Valve Body

DRAWING NO. A3M6 SA351 Gr.CPOM

INSPECTION CERTIFICATE

SPECIFICATION ASME SA351 Gr.CPOM

Heat No.	Quantity	Tensile Test			Welds No.	Impact Test			Heat No.	Chemical Composition in %			Ferrite content (%)
		Yield Strength kg/mm²	Tensile Strength kg/mm²	Reduction of Area %		C	Si	Mn		P	N	Cr	
Standard	Number	Weight in kgs	kg/mm²	%	No.	kg/mm²	kg/mm²	kg/mm²	Batch	Max.	Max.	Max.	Max.
			kg/mm²	kg/mm²		kg/mm²	kg/mm²	kg/mm²		0.040	0.040	0.040	0.040
05042	(1)	30,000	70,000	20	153	0.063	0.07	1.34	REVIEWED BY	0.031	0.009	9.4%	19.7%
05055	(2)	42,010	76,090	52.0	154	0.066	0.072	1.35	AUTHORIZED INSPECTION	0.030	0.011	9.6%	10.3%
									DATE 02-02-70				

Part. No. Article
(1) 026-76 76604 12" x 300lb Gate Valve Body No. 14
(2) 018-77 76604 12" x 300lb Gate Valve Body No. 15
(2) 018-77 723/6-11 10" x 150lb Gate Casting No. 1,2,3,4,5,6,7,8,9,10,11,12

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT #2
P.O. 2BV-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE.
VAN NUYS, CA 91409

BY

PACIFIC METALS CO., LTD. MAGETSU WORKS.

K. Nishiya, M.M.

Chief of Inspection Section

HEAT NO. 85055-1 DATE 04-04-70
N/CODE NO. 3E574A-3E6K
S/O P.O. 1400 QTY. 12
INSP. (3) DATE 04-04-70
VENDOR ALTAI CHINA
Surveyor

COMPTON FORGE, INC.

No. W/O 4652

REPORT OF CHEMICAL AND PHYSICAL TESTS

TO: NUCLEAR VALVE DIVISION
P.O. BOX 2185
VAN NUYS, CALIF. 91409

SHIPPED TO:

7500 TYRONE AVE.
VAN NUYS, CALIF. 91409

CUST. ORDER NO.

84850

SHIPPER NO.

W/O 4652

SPECIFICATION NO. ASME SA 105 1029 CARBON
NORMALIZE, CLEAN, PENETRANT INSPECT, MAG. INSPECT,
MACHINE

ITEM NO.

DESCRIPTION

1 3 PCS.

SIZE: 20" OD X 10" ID X 11.635" LG.

HEAT NO.: 0151

NECK

NUCLEAR

ASME SA 105
MAT'L 1029 SIZE 13.5" RND

MILL

MECHANICAL PROPERTIES from Dickson Testing Co.

HEAT NO.	YIELD POINT P.S.I.	TELEL STRENGTH P.S.I.	% ELONG.	% RED. AREA	BRINELL	ROCK- WELL	BEND TEST	MACRO	EMBRIT- EMENT	1200 IMPACT	CHN. GRAN. TEST
0151	37,100	70,400	29	47.8							

COMPTON FORGE, INC. CERTIFIES THAT THE ABOVE FORGINGS WERE MANUFACTURED AND PROCESSED REVIEWED BY
IN ACCORDANCE WITH AND MEET THE REQUIREMENTS OF: NUCLEAR VALVE P/O: 84850 N. CODE: 3W94, AUTHORIZED
NMS 70478 AND ASME SECTION III (NA 3700) ✓

DAVE MILLER

b-4-70

Date

DATE/REV

HEAT NO. 0151

N. CODE NO. 3W94 ✓

S/O

P.O. 84850

QTY. 3.0

INSP DATE NOV 14 1973

VENDOR Compton Forge

SUBSCRIBED AND SWEARN TO BEFORE ME THIS 1 DAY OF JUNE 1970

I CERTIFY THAT THESE ARE CORRECT
COPIES OF REPORTS NOW ON FILE AT

COMPTON FORGE, INC.

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 2BV-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

QUALITY ANALYST



HALL HEAT TREATING

DIVISION OF CERTIFIED ALLOY PRODUCTS, INC.
16623 ILLINOIS AVENUE • 531-7882
PARAMOUNT, CALIFORNIA 90723

CUSTOMER'S NAME

Compton Forge Inc.

PART NAME

Rings 20 1/2" OD x 9 1/2" ID
test-1" x 1" x 12" Nuclear Code 3W94

MATERIAL

ASME SA-105

YOUR SPECIFICATION

Normalize per ASME SA-105 & MIL-H 8875F

TENSILE P.S.I.

ROCKWELL

BRINELL RECORD

HT#0151

OPERATION	FURN. NO.	TEMPERATURE	TIME AT TEMP.	FURANCE COOL	AIR COOL	OIL COOL	WATER COOL
STRESS RELIEVE							
ANNEAL							
SUB CRIT-ANNEAL							
PRE-HEAT	-						
NORMALIZE	18	1650	1 hr				
QUENCH							
TEMPER							
HOMOGENIZE							
SOLUTION ANNEAL							
STABILIZE							
AGE							
SUB-ZERO							

HEAT NO. 0151 ✓
 N CODE NO. 3W94 ✓
 S/O
 P.C. 4450
 QTY. 3.0
 INSP DATE NOV 1 1974
 VENDOR 100%

REVIEWED BY
 - AUTHORIZED
 INSPECTOR

DATE 11/1/74

CERTIFICATION

ASME SA-105 & MIL-H 8875F.

We certify that the above listed parts have been heat treated in accordance with ASME SA-105 & MIL-H 8875F.
 We further certify that the above statement is true and correct and that temperatures and test results were obtained with standard approved methods.
 Hardness certified on bars in present state of completion.

FINAL HARDNESS

ROCKWELL

BRINELL 137

NUMBER TESTED 1 pc

HALL HEAT TREATING
 Division of Certified Alloy Products, Inc.

D. Schmalzried

G.A./G.C. AUTHORIZED SIGNATURE

DUPLICATE



METALS TECHNOLOGY, INC.

METALLURGICAL ENGINEERING CONSULTING & SERVICE
ENGINEERING REPRESENTATIVES
8955 QUARTZ AVENUE NORTHridge, CALIF. 91324
PHONES: (213) 882-6414 (213) 873-7144

NO 1598

CERTIFIED TEST REPORT

DATE: 2-16-82

HEAT NO.: 0151

N-Code: 3W94

CUSTOMER NUCLEAR VALVE DIVISION

PART NO.:

YOUR P.O.: 68576-1

S/N: See Below

JOB NO.: Shipper #50698

SPECIFICATION: MPS 71864

NB2332A-1

ASME-SA-105

MATERIAL: C/S

TENSILE TEST

SPECIMEN NO.	SIZE (IN)	AREA (IN ²)	YIELD [*] LOAD (LBS)	YIELD [*] (KSI)	ULTIMATE LOAD (LBS)	ULTIMATE (KSI)	ELON-GATION** (%)	RED. AREA (%)	
DUQUESNE LIGHT COMPANY BEAVER VALLEY POWER STATION UNIT 2 P.O. 2BV-92 J.O. No. 12241 FEEDWATER ISOLATION TRIP VALVE M&D OF BORG WARNER, 7500 TYRONE AVE VAN NUYS, CA 91409									

Requirements:

HEAT NO. 0151
N CODE NO. 3W94
S/R 50698
P.C. 68576-1
QTY. 1
INSP DATE 2-16-82
VENDOR Metals Technology, Inc.

*Yield at _____ % Offset

**In _____ Inch Gage Length

.005 in/in./min./S.R.

CHARPY IMPACT TEST

SAMPLE NO	TEST TEMP (°F)	ENERGY (FT-LBS.)	% SHEAR	LAT-EXP (IN)	REMARKS
#1	40°F /	54	60%	.031	
#2	40°F /	48	40%	.039	
#3	40°F /	80	75%	.087	

Requirements:

.025 MIN.

Respectfully Submitted

S.J. Block
Vice-President of Operations
Metals Technology, Inc.

EARLE M. JORGENSEN CO.
STEEL

FORGE DIVISION
8531 E. MARGINAL WAY SOUTH • PHONE 762-1100 (AREA 206)
MAILING ADDRESS: P. O. BOX 24026
SEATTLE, WASHINGTON 98124

65
CERTIFIED MATERIAL TEST REPORT

C U S T O M E R

NUCLEAR VALVE DIVISION
BORG WARNER CORP
P O BOX 2185
VAN NUYS, CALIF 91409

Date 4-17-78
Customer's Order No. 84016
Our Invoice No. 7518 FS
Contract No.

1978

HEAT NO.	MATERIAL	DESCRIPTION	SPECS.
21048	SA105	2 ROUGH TURNED ROUNDS 13" DIA +1/8 -0 X 12 FT R/L 1 TEST REM NM 2X78 / RETAINER	ASME SA105

CHEMICAL ANALYSIS

HEAT NO.	MATERIAL	C	MN	P	S	SI	NI	CR	MO	V	CU	Sn	I	G/S
21048	SA105	.26	1.00	.023	.019	.26								

HARDENABILITY - ROCKWELL

HEAT NO.	MATERIAL	1	2	3	4	5	6	7	8	9	10

N

HEAT NO. 21048
IN CODE NO. 2X78 ✓
S/O _____
P.O. 84016
INSP 122 QTY. 25.4
VENDOR DATE 6/16/78
JORGENSEN STEEL

MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD LBS./SQ. INCHES	TENSILE LBS./SQ. INCHES	ELONG. %	RED. OF AREAS %	FRACTURE	BEND	MACRO	IMPACT
LMR	21048	SA105	60,000	80,000	30.0	51.1	CUP			

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

REMARKS: NORMALIZE 1700°F ✓ 32 HRS (AIR COOLED)

INSPECTOR: REVIEWED BY
AUTHORIZED INSPECTOR
DATE 6/19/78

WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN
INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIRE-
MENTS DESCRIBED HEREIN, AND TEST REPORTS ARE ON FILE SUBJECT TO
EXAMINATION.

EARLE M. JORGENSEN CO.

E. M. JORGENSEN

DESCRIBED AND SWORN TO BEFORE ME

THIS DAY OF 19

NOTARY PUBLIC—SEATTLE

BY

EARLE M. JORGENSEN CO.

STEEL

FORGE DIVISION

8531 E. MARGINAL WAY SOUTH • PHONE 782-1100 (AREA 206)

MAILING ADDRESS: P. O. BOX 24026

SEATTLE, WASHINGTON 98124

CERTIFIED MATERIAL TEST REPORT

CUSTOMER

NUCLEAR VALVE DIVISION
BORG WARNER CORP
P O BOX 2185
VAN NUYS, CALIF 91405

Date 4-17-78
Customer's Order No. 84016
Our Invoice No. 7520 FS
Contract No.

RECEIVED

4-17-78

HEAT NO.	MATERIAL	DESCRIPTION	SPECS.
21048	SA105	2 ROUGH TURNED ROUNDS 13" DIA +1/8 -0 X 12 FT R/L # 2X78	ASME SA105

CHEMICAL ANALYSIS

HEAT NO.	MATERIAL	C	MN	P	S	SI	NI	CR	MO	V	CU	BN	G/S
21048	SA105	.25	1.00	.023	.019	.26							

HARDENABILITY - ROCKWELL "

HEAT NO.	MATERIAL	1	2	3	4	5	6	7	8	9	10

N
HEAT NO. 21048
N CODE NO. 2X78
S/O _____
P.O. 84016
INSP AV 12 QTY. 25 FT.
VENDOR JORGENSEN STEEL DATE 6/16/78

MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD LBS./SQ. IN.	TENSILE LBS./SQ. IN.	ELONG. IN. / IN.	RED. OF AREA %	FRACTURE	BEND	MACRO	IMPACT
LMR	21048	SA105	60,000	80,000	30.0	51.1	CUP			

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

REMARKS
NORMALIZE 1700°F 32 HRS (AIR COOLED)

INSPECTOR [Signature] REVIEWED BY [Signature]
AUTHORIZED INSPECTOR [Signature]
DATE 6/19/78

WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN
INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIRE-
MENTS DESCRIBED HEREIN, AND TEST REPORTS ARE ON FILE SUBJECT TO
EXAMINATION.

EARLE M. JORGENSEN CO.

ISCRIBED AND SIGNED TO BEFORE ME
THIS 18 DAY OF APRIL 1978

BY [Signature]

NOTARY PUBLIC—SEATTLE

JORGENSEN CO.
STEEL

FORGE DIVISION

8531 E. MARGINAL WAY SOUTH • PHONE 762-1100 (AREA 206)

MAILING ADDRESS: P. O. BOX 24026

SEATTLE, WASHINGTON 98124

CERTIFIED MATERIAL TEST REPORT

CUSTO
MER

NUCLEAR VALVE DIVISION
BORG WARNER CORP
P O BOX 2185
VAN NUYS, CALIF 91409

Date 4-17-78
Customer's Order No. 84016
Our invoice No. 7519 FS
Contract No.

HEAT NO.	MATERIAL	DESCRIPTION	SPECS.
21048/	SA105/	2 ROUGH TURNED ROUNDS 13" DIA +1/8 -0 X12FT R/L	ASME SA105
		N# 2X78/	

CHEMICAL ANALYSIS

HEAT NO.	MATERIAL	C	MN	P	S	SI	NI	CR	MO	V	CU	SN	G/S
21048	SA105	.26	1.00	.023	.019	.26							

HARDENABILITY - ROCKWELL'

HEAT NO.	MATERIAL	1	2	3	4	5	6	7	8	9	10	

N HEAT NO. 21048
N CODE NO. 2X78V
S/O _____
P.C. 84016
INSP. QTY. 24.5 FT.
DATE 6/14/79
VENDOR JORGENSEN

MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD LBS./SQ. IN.	TELESTIC LBS./SQ. IN.	RED. OF AREA %	IFRACTURE	SEND	MACRO	IMPACT
LMR	21048	SA105	60,000	80,000	30.0	51.1	CUP		

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE.
VAN NUYS, CA 91409

REMARKS: INSPECTOR AUTHORIZED
NORMALIZE 1700°F 32 HRS (AIR COOLED) INSPECTOR
DATE 6/14/79


WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN
INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIRE-
MENTS DESCRIBED HEREIN, AND TEST REPORTS ARE ON FILE SUBJECT TO
EXAMINATION.

EARL R. JORGENSEN CO.

THIS DAY OF 1979

BY 11/14/79

NOTARY PUBLIC—SEATTLE



METALS TECHNOLOGY, INC.

METALLURGICAL ENGINEERING CONSULTING & SERVICE

ENGINEERING REPRESENTATIVES

8951 QUARTZ AVENUE NORTHRIDGE, CALIF. 91324

PHONES: (213) 882-6414 (213) 877-7144

No. 45774

CERTIFIED TEST REPORT

DATE: 2-28-79

HEAT NO.: 21048

N-Code 2X78✓

CUSTOMER: NUCLEAR VALVE DIVISION

PART NO.:

YOUR P.O.: 68576-1

S/N:

JOB NO.: Shipper #26154

SPECIFICATION: ASME-SA-105
NPS 71864

MATERIAL: _____

Metallography

Hardness

Chemistry

CHARPY IMPACT TESTS

<u>Sample No.</u>	<u>Test Temp.</u>	<u>Ft.-Lbs.</u>	<u>Shear</u>	<u>Lat.-Exp.</u>
1	+40° /	27	80	.028
2	+40° /	24	80	.027
3	+40°	27	80	.025

Requirements: .020 Lat.-Exp. Min.

MEETS SPECIFICATION REQUIREMENTS

N HEAT NO. 21048
N CODE NO. 2X78
S/O _____
P.O. 68576-1
INSP TEST DC DATE 3-13-79
VENDOR M.T.I.

REVIEWED BY
AUTHORIZED
INSPECTOR

✓

DATE 2/22/81

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 23V-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE.
VAN NUYS, CA 91409

Respectfully Submitted

S. J. Block

S. J. Block
Vice-Pres. of Operations
Metals Technology, Inc.

ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS. AUTHORIZATION FOR PUBLICATION OF OUR REPORTS CONCLUSIONS OR STATEMENTS MADE OR REGARDING THEM IS RESERVED PENDING OUR WRITTEN APPROVAL AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES.

EARLE M. JORGENSEN CO.
STEEL

FORGE DIVISION

2531 E. MARGINAL WAY SOUTH • PHONE 762-1100 (AREA 206)
MAILING ADDRESS: P. O. BOX 24005
SEATTLE, WASHINGTON 98124

CERTIFIED MATERIAL TEST REPORT

C
U
S
T
O
M
E
R

NUCLEAR VALVE DIVISION
BORG WARNER CORP
P O BOX 2185
VAN NUYS, CALIF 91409

Date 4-17-78
Customer's Order No. 84010
Our Invoice No. 7510 FS
Contract No.

HEAT NO.	MATERIAL	DESCRIPTION	SPEC.
21029	SA105	1 ROUGH TURNED ROUND 13" DIA +1/8 -0 X 8 FT R/L 1 TEST REM # 2W21	ASME SA105 HEAT TREATED

RETAINER

CHEMICAL ANALYSIS

HEAT NO.	MATERIAL	C	MN	P	S	SI	Ni	CR	MO	V	CU	BN	G/S
21029	SA105	.26	.87	.009	.013	.25							

HEAT NO. 21029
N CODE NO. 2W21
S/O _____
P.O. 84010

QTY. 8.4 FT.
INSP NV DATE 6/16/78
VENDOR JORGENSEN STEEL

HARDENABILITY - ROCKWELL "

HEAT NO.	MATERIAL	1	2	3	4	5	6	7	8	9	10	CHARPY V C	LOCF

MECHANICAL PROPERTIES

TEST NO.	HEAT NO.	MATERIAL	YIELD LBS./SQ. IN.	TENSILE LBS./SQ. IN.	ELONG. %	RED OF FRACTURE	BEND	MACRO	IMPACT
LMR	21029	SA105	58,500	79,500	32.0	68.6	CUP	LAT EXP IN MILS..... % SHEAR FRACTURE.....	28-28-24 ^{1/4} 29-28-26 25-25-20

DUQUESNE LIGHT COMPANY
BEAVER VALLEY POWER STATION UNIT 2
P.O. 2BV-92 J.O. No. 12241
FEEDWATER ISOLATION TRIP VALVE
NVD OF BORG WARNER, 7500 TYRONE AVE
VAN NUYS, CA 91409

REMARKS

NORMALIZED 1700°F ✓ 16 HRS (AIR COOLED)

INSPECTOR REVIEWED BY
AUTHORIZED
INSPECTOR

H
DATE 6/19/78

RECEIVED
MAY 03 1978

ACCOUNTS PAYABLE

SCRIBBED AND SIGNED TO BEFORE ME

DAY OF 19

NOTARY PUBLIC—SEATTLE

WE CERTIFY THAT THE MATERIAL COVERED BY THIS REPORT HAS BEEN
INSPECTED & TESTED IN ACCORDANCE WITH THE APPLICABLE REQUIRE-
MENTS DESCRIBED HEREIN, AND TEST REPORTS ARE ON FILE SUBJECT TO
EXAMINATION.

EARLE M. JORGENSEN CO.
RLK