

The Light company

Houston Lighting & Power P.O. Box 1700 Houston, Texas 77001 (713) 228-9211

August 2, 1985
ST-HL-AE-1316
File No.: G4.2

Mr. George W. Knighton, Chief
Licensing Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Meeting Notes from NRC MEB Audit
ASME Documentation Review Portion

Dear Mr. Knighton:

On June 26, 1985 representatives of the NRC Mechanical Engineering Branch (MEB) staff met with representatives of HL&P at the Houston office to discuss the mechanical design of the South Texas Project (STP). This meeting was conducted in two portions. Meeting notes covering the FSAR question responses were previously transmitted to you in our letter ST-HL-AE-1296 dated July 1, 1985 from M. R. Wisenburg to G. W. Knighton. Attached are the meeting notes from the portion of the meeting concerning review of STP ASME documentation and compliance for selected mechanical features.

This review covered five Nuclear Steam Supplier System (NSSS) scope items and four balance-of-plant items. Previous to the meeting the NRC had reviewed several documents that were transmitted to the NRC. The meeting on June 26, 1985 consisted of follow-up questions and corresponding requests for additional documents which addressed the follow-up questions. A summary of the results of each item is provided in Attachment A. Documents requested during the meeting (noted in the summary, Attachment A) are provided in Attachment B in the order that they are discussed in the summary.

Attachment C contains a list of attendees.


8508060302 850802
PDR ADOCK 05000498
A PDR

W2/NRC1/v

A047
11

If you should have any questions on this matter, please contact Mr. M. E. Powell at (713) 993-1328.

Very truly yours,



M. R. Wisenburg
Manager, Nuclear Licensing

CAA:yd

- Attachments:
- A. Summary of Results
 - B. Requested Documents
 - C. List of Attendees

cc:

*Hugh L. Thompson, Jr., Director
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert D. Martin
Regional Administrator, Region IV
Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

*N. Prasad Kadambi, Project Manager
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, MD 20814

Claude E. Johnson
Senior Resident Inspector/STP
c/o U.S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77414

M. D. Schwarz, Jr., Esquire
Baker & Botts
One Shell Plaza
Houston, TX 77002

J. R. Newman, Esquire
Newman & Holtzinger, P.C.
1615 L Street, N.W.
Washington, DC 20036

Director, Office of Inspection
and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

E. R. Brooks/R. L. Range
Central Power & Light Company
P. O. Box 2121
Corpus Christi, TX 78403

H. L. Peterson/G. Pokorny
City of Austin
P. O. Box 1088
Austin, TX 78767

J. B. Poston/A. vonRosenberg
City Public Service Board
P.O. Box 1771
San Antonio, TX 78296

Brian E. Berwick, Esquire
Assistant Attorney General for
the State of Texas
P. O. Box 12548, Capitol Station
Austin, TX 78711

Lanny A. Sinkin
3022 Porter Street, N.W. #304
Washington, D. C. 20008

Oreste R. Pirfo, Esquire
Hearing Attorney
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Charles Bechhoefer, Esquire
Chairman, Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dr. James C. Lamb, III
313 Woodhaven Road
Chapel Hill, NC 27514

Judge Frederick J. Shon
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Ray Goldstein, Esquire
1001 Vaughn Building
807 Brazos
Austin, TX 78701

Citizens for Equitable Utilities, Inc.
c/o Ms. Peggy Buchorn
Route 1, Box 1684
Brazoria, TX 77422

*Docketing & Service Section
Office of the Secretary
U.S. Nuclear Regulatory Commission
Washington, DC 20555

NOTE: All copies w/o Attachment B except
as noted above (*)

Attachment A

South Texas Project
Units 1 & 2
Summary of Results

Main Steam Piping

Comment:

1. Control of Minimum Wall Thickness

Spec. 4L020PS0100 (Shop Fabrication), 4.3.3B., defines what is meant by "minimum wall thickness". In 4.3.9, wall thickness measurements are required to be made. Please provide copies of those documents which show compliance with 4.3.9 for:

- (a) one elbow and one pipe length used in main steam Dwg. 2C369PMS446.
- (b) counterbored end of 32 x 30 reducer, Dwg. 2C369PMS446.

Response:

- 1. A copy of the NPP-1 Data Report for Mark No. 2C369P-MS-1001-GA2-1-A was provided along with a copy of Question No. 564 from Southwest Fabricating and Welding Co.

Comment:

2. Steam Hammer Analysis

Calc. NO. 2C159RC5038, page 32, indicates that $P_0 = 5580$ psi. This stress can be calculated by $P_0 = 1183 \times 27.25^2 / (30^2 - 27.25^2) = 5580$ psi. Page 11 of the calculation lists the maximum operating pressure as 1183 psi.

- (a) Does the 1183 psi operating pressure include the pressure wave due to the steam hammer?
- (b) Please describe the steam hammer analysis; e.g., source (turbine trip?), maximum moments and their locations, maximum pressures, support loads. (This may be given in Calculation No. 5N179RC9904; if so, please provide a copy of it.)

Response:

- 2. In response to Item (a), it was stated that the 1183 psi operating pressure does not include the pressure wave due to steam hammer.

In response to Item (b), a copy of Calculation No. 5N179RC9904 without appendices was provided. A hand calculation showing the maximum pressure caused by steam hammer was also provided.

Main Steam Supports

References

Calc. No. 2C159RC5038 (Pipe Calc.)
SWG. No. 2C369PMS446 (Dwg.)
Calc. No. JC-MS-9001-HL5016 (Support Calc.)

Comment:

1. The Pipe Calc., page 43, indicates a support MS-1001-HL5011 at Data Point 12B. The drawing identifies the support at Point 12B as HL-5016. Is the correct identification HL5011 or HL5016?

Response:

1. It was agreed that a data point versus mark numbers inconsistency existed. This will be corrected by revising the calculation.

Comment:

2. The Support Calc., page 3, shows forces which agree with those shown on pages 52 and 55 of the Pipe Calculation for Point 12B. The Support Calculation, page 8, shows forces for Data Point 12B which do not agree with those shown on pages 52 and 55 of the Pipe Calculation for either points 12B or 12A. Page 7 of the Support Calculation indicates page 8 is for Support HL5015, but the drawing indicates HL5015 is at Point 12A, not 12B. The Pipe Calculation, page 43, identifies the support at 12A as HL5010. Please explain.

Response:

2. A copy of the pages from the loop No. 2 piping calculation (RC5039) that gives loads corresponding to page 8 of Calculation No. JCMS9001HL5016 was provided.

Comment:

3. The Support Calculation., page 10, shows an allowable load for SMA-5501 of 50.6k for "upset", which agrees with CDRS No. SMY, page 4 of 9. However, we do not have that page of CDRS No. SMY which allows a load of 76.9k for faulted conditions. Please provide that page.

Response:

3. A copy of the pages from the CDRS number SMY which allows a load of 76.9 kips for the faulted condition was provided.

MS Safety Relief Valve

Reference Design Specification 42459ZS1006 and Dresser Stress Report, Dresser 3707R Main Steam Safety Valve, SR-370-15

Comment:

1. The specification identifies the valve as 3707RA while the Stress Report identifies it as 3707R. Is there a significant difference?

Response:

1. The extra "A" in the valve identification is only an indication that the valve will be used in saturated steam service. There is no significant difference.

Comment:

2. The specification identifies a back pressure of 157 psig; the Stress Report uses (for outlet design conditions) 140 psig at 400°F. Which should be used?

Response:

2. The vendor is in the process of preparing a new stress report. The new stress report will use a back pressure of 157 psig.

Comment:

3. The Stress Report states that "Allowable bolt stress at 600°F for SA193 Gr. B7 is 50000 psi (=2S)...". We believe the ASME Code allowable bolt stress, as a limit to the calculated (as indicated in App. B of the Stress Report) bolt stress, is S, not 2S. Please cite the Code portion which you think justifies using an allowable bolt stress of 2S.

Response:

3. It was agreed that the allowable bolt stress should be "S". Due to the conservative nature of the calculations for the MS Safety Relief Valve no problem was caused by the use of "2S" for these STP valves; however, STP must verify no other Dresser valves are used on STP, which use the incorrect stress allowable for bolts.

Comment:

4. Please provide a copy of those portions of the main steam piping analyses which show that the safety valve thrust of 27,000 lb has been evaluated.

Response:

4. A copy of sheet 20 of calculation RC6548 was provided. A copy of Drawing No. 5G369PMS646, sheet 3 was provided. A copy of the preliminary calculation for transient loads (RC9966) was provided.

Component Cooling Water Pumps

Comment:

1. Specification 3R209NS0011, 1.5.3, lists documents to be provided by the Seller.
 - (a) Please briefly describe (or provide a copy of) the document; "a. ASME Code Calculations".
 - (b) Please provide a copy of the document "f. Hydrostatic test results", including evidence that the tests were witnessed by an Authorized Nuclear Inspector.

Response:

1. In the response to Item (a), it was pointed out that the Vendor Seismic Analysis previously submitted contained the necessary ASME code calculations. Vendor Document 14926-4022-01018-BHT was provided which has the instructions for the pump seismic and ASME code analysis. In response to Item (b), a copy of the hydrostatic test certificate was provided (14926-4022-01055-AHT).

Comment:

2. Hayward Tyler Seismic Analysis Report, p. 10, cites loading criteria. Please indicate precisely where the cited "Maximum Nozzle Loads" are given in Specification 3R209NS0011 (e.g., page ____ of Appendix ____) and provide a copy of that page.

Response:

2. A copy of page B-1 from 3R209NS011-D was provided.

Comment:

3. Please provide a copy of those portions of the CCW piping system analysis which show that the maximum nozzle loads are not exceeded.

Response:

3. A copy of appropriate portions of calculations RC0034 and 35 were provided.

Reactor Coolant Pumps

Comment:

1. WEMD E. M. 5003, Table I, shows a calculated stress of 33,300 psi for "FAULTED". Table VII, for "Pipe Rupture (b)" indicates a moment resultant of

$$M_i = (87^2 + 103^2 + 63^2)^{1/2} \times 10^6 \text{ in-lb} = 149 \times 10^6 \text{ in-lb.}$$

The data on page 15 indicates that the end of the pump suction nozzle has an inside diameter of 31", outside diameter of 38.2". The section modulus of that section is:

$$Z_i = (D_o^4 - D_i^4) / (32D_o) = 3099 \text{ in}^3$$

and the maximum stress intensity due to M_i - only is:

$$S = M_i / Z = 149 \times 10^6 / 3099 = 48080 \text{ psi}$$

Further, from the load combination for Faulted shown in Table V, it appears that the stress intensity for the suction nozzle end might be around 55 ksi, rather than 33.3 ksi shown in Table I. If so, then the stress would exceed your limit of 49.7 ksi and would exceed the stress of 48700 psi (for discharge nozzle) shown in Table 7.3 of WEMD E.M. 5351 - the South Texas Stress Report.

Your response is requested.

Response:

1. Westinghouse will add a footnote to EM5003. A copy of a revised Westinghouse internal memo was provided.

Westinghouse Motor Operated Gate Valves

Comment:

1. Specification G-952850
 - (a) Please provide a copy of the documentation that shows compliance with hydrostatic tests, Paragraphs 6.3.1 and 6.3.2, for the valve identified by Drawing 8273D81 (8GM84).
 - (b) Paragraph 1.2.3 appears to be very restrictive for end moments that can be applied to the valves. For example, for a 304 stainless valve operating at 550F, $0.5S_y = 0.5 \times 18.8 = 9.4$ ksi. In contrast, Eq. (11) in ASME Code Subsection NC permits piping stresses due to moments to be up to 43.4 ksi. Please supply documentation which shows that the moment limits are being met; e.g., portion of a piping system calculation which shows both the calculated pipe moments at a valve covered by the specification and the allowable limit given in Paragraph 1.2.3D of the specification.

Response:

1. In response to Item (a), a copy of the hydrostatic test report was provided. In response to Item (b), a copy of Calculation RC0011, sheets 1 and 63, was provided.

Comment:

2. WEMD E.M. 5158 (Stress Report)

The Stress Report refers to Specification G-952850 (General) but not to Specification 952874 (South Texas specific). Is there anything in Specification 952874 (such as Appendix C) that would invalidate the Stress Report?

Response:

2. There is nothing in Specification 952874 that would invalidate the Stress Report.

Westinghouse Class 1 Piping

Comment:

1. The intent of this audit item is to obtain and review the Code-required Stress Report for the primary coolant loop piping of the South Texas plant. WCP-9135 appears to be a part of that Stress Report. Volume 3 (also WCAP-9135?) may be another part of the Stress Report. Please provide for our review a complete copy of what you deem to be the Code-required Stress Report for primary coolant loop piping of the South Texas plant; including certification by the N-Certificate Holder (presumably, Westinghouse) and documentation of review by the Owner (Houston Lighting and Power). Upon receipt of the Stress Report, we will review it and the Design Specification and attempt to close this audit item.

A copy of WCAP-9135, Vol. 1, was provided. Assuming that this is part of the Stress Report, we have the following comments.

- (a) We do not find any indication that the requirements of NB-3640, Pressure Design, have been considered or met. At the 5/17/85 Houston meeting, to expedite closing of this aspect, we agreed to review RPT-MED-PCE-577, "Reactor Coolant Loop Piping Pressure Design Calculations for Wolf Creek Unit No. 1", as representing what would be done for South Texas. However, Westinghouse (Rahe to Denton, May 30, 1985) did not provide the Wolf Creek report. When we receive the South Texas Stress Report, we will expect to find evidence that the requirements of NB-3640 have been met.
- (b) Design Specification 953385, Rev. 1, indicates that allowable nozzle loads for equipment (e.g., Steam Generator) must be established and the piping system analyses must show that these nozzle loads are not exceeded. We do not find any indication that allowable nozzle loads have been checked. Perhaps, this check is in Vol. 3. In any event, this is a check we will expect to find in the Stress Report.

(c) In general, we would like to have a Class 1 piping Stress Report that is at least as complete as calculation packages provided for Class 2 and 3 piping systems; e.g., Bechtel Calculation No. 2C159RC5038. Some of the information found in such calculation packages, but not in Vol. 1, are:

- (1) Material identification
- (2) Piping dimensions (e.g., diameters, wall thicknesses, axial lengths via Drawing NO. 2C369PMS446).
- (3) Clear indication of what is included in the analysis (e.g., does Vol. 1 cover the pressurizer surge line? Does it cover the welds between austenitic pipe and ferritic components?)
- (4) Nozzle loads and comparisons with allowable loads.
- (5) Support Load summary.
- (6) List of unusual stress intensification factors. For Vol. 1 and maybe Vol. 3, we would expect a list of stress indices which do not come directly from Code Table NB-3683.2.1; e.g., C₂ and K₂ indices for an elbow with instrument taps in the body thereof.
- (7) Appendix C of the Code states:

"the Report should include copies of sufficient computer printouts to justify the governing stress values used in the Design Report and enable independent review."

If Vol. 1 is intended to be part of the Stress Report, we view its contents inadequate from the standpoint of an "independent review". Presumably, Westinghouse has on file the detailed calculations which provide the basis for the stress values shown in Table 5-1 of Vol. 1. We believe that the Stress Report should include a comprehensive and understandable (to an independent reviewer) road map to the files in which the detailed results are filed, and a commitment to maintain those files for as long as the Stress Report is required to be kept.

Response:

1. The items mentioned in this question will be addressed in the Class 1 Stress Report at the time of issuance (including as-built reconciliation). We agree with the issues raised by this question and will provide clear confirmation, specifically or by reference, in the Volume 1, 2, and 3 Class 1 Stress Reports, which will be provided in the third quarter of 1986.

Westinghouse Primary System Supports

Comment:

1. The intent of this audit item is to obtain and review the Code-required Stress Report for primary system supports of the South Texas plant. Volume 2 (of WCAP-9135?) may be a part of that Stress Report. At the 5/17/85 Houston meeting, to expedite closing of this item, we agreed to review WCAP-10197, which (apparently) covers the structural analysis of primary system supports for the Comanche Peak plant; as representing what would be done for South Texas. However, Westinghouse (Rahe to Denton, May 30, 1985) did not provide that report. Accordingly, please provide for our review a complete copy of what you deem to be the Code-required Stress Report for primary system supports of the South Texas plant; including certification by the N-Certificate Holder (presumably, Westinghouse) and documentation of review by the Owner (Houston Lighting and Power). Upon receipt of the Stress Report, we will review it and the Equipment Specification 953533 (which, we assume, is meant to be the Code-required Design Specification) and attempt to close this audit item.

Response:

1. The items mentioned in this question will be addressed in the Class 1 Stress Report at the time of issuance (including as-built reconciliation). We agree with the issues raised by this question and will provide clear confirmation, specifically or by reference, in the Volume 1, 2, and 3 Class 1 Stress Report, which will be provided in the third quarter of 1986.

Roto-Lok Head Closure System

Comment:

1. Design

- (a) CENC-1332 appears to evaluate stresses in the studs. Please provide that portion of the South Texas Stress Report (Analytical Report?) that evaluates the stresses in the stud inserts.
- (b) CENC-1332 identifies the stud material as SA-540-B24. This is incomplete. What is the Class? (WCAP-8447 identifies the stud material as Class 2, with $S_m = 46.7$ ksi at 100°F, 37.5 ksi at 650°F.)
- (c) CENC-1332, page 3, indicates $S_m = 42$ ksi. What is the basis for $S_m = 42$ ksi?
- (d) CENC-1332, pages A138-A145: units shown in "tensile load" and "moment" columns appear to be incorrect.

- (e) CENC-1332, page A143, shows a tensile stress for Case 1 of 47.6 ksi. Dividing this by 1.1 gives a tensile stress of 43.3 ksi for design pressure (2500 psi) loading only. ASME Code, NB-3231(a), appears to require that the tensile stress due to design pressure be less than S_m at design temperature; i.e., less than 37.5 ksi. Please provide a response.
- (f) CENC-1332, page 3, states that "All stresses meet the appropriate allowables stated in the ASME Boiler and Pressure Vessel Code, Section III . . .". However, we do not find any mention of bearing loads (NB-3227.1), pure shear (NB-3227.2) or, more generally, the stress intensity limits due to pressure loading only. Why are these seemingly applicable portions of the Code not considered and discussed in CENC-1332?
- (g) The analysis described in CENC-1332 appears to involve the assumption of perfect axial matching between studs and stud inserts. Figure 7-10 of the Manual shows axial tolerances for the stud lugs of $+0.001"$. Presumably, tolerances on the stud insert are similar. What effect does machining tolerances have on the load distribution between the 7 sets of lugs?
- (h) CENC-1332, page 146, states that "Using a fatigue strength reduction factor . . .". The reader can deduce that the "fatigue strength reduction factor" used was 4, but the report should say that a factor of 4 was used. Our question concerning the validity of the fatigue elevation stems from footnote (4) to Code Table I-1.3:
- "These stress values may result in relaxation of the bolting materials after prolonged service at these temperatures and the designer is to investigate the effect of this relaxation on the application."
- During the 107 postulated boltup/unboltup cycles, the footnote suggests the possibility of ratcheting and the effect of this on fatigue is not apparent. Please provide a response.
- (i) CENC-1332 appears to address normal operating conditions and hydrostatic testing. Are any evaluations needed for upset, emergency or faulted conditions and, if so, where in the South Texas Stress Report are they described?

Response:

1. Items (a), (b), (c), (e), (f), and (i) are answered by the base document, CENC-1302, Analytical Report for South Texas Project No. 1. Portions of Book 1 of this document have been provided in a separate transmittal by Westinghouse identified as NS-NRC-85--3044 dated July 3, 1985 from E.P. Rahe, Jr. to H.R. Denton of the NRC.. Item (d) correctly identifies incorrect units in the heading; however, this did not affect the final results. Item (g) is answered as follows: The worst case tolerances are used to check shear stresses of the lugs. The nominal dimensions are used

in the structural and fatigue analysis. The margins between calculated values and the code allowables cover the manufacturing tolerance effects. Item (h) is answered as follows: The maximum operating temperature of these studs is below the temperature range of concern in the ASME Code. The material in the bolts is Class 3.

Comment:

2. Installation

- (a) One of our initial concerns was assurance that all studs would be rotated into locked position before bolt-tightening and operation. The Installation Instructions, Section 3 of the Manual, has eliminated this concern.
- (b) The Manual, page 3-9, says: "Caution, Maximum hydraulic pump pressure shall not exceed 9100 psi". We question whether this is a prudent limit. We presume that 5500 psi corresponds to the stud load used for evaluating operating loads in CENC-1332; hence, 9100 psi pump pressure would presumably correspond to $9100/5500 = 1.65$ times the assumed design loads. If the 9100 psi pressure were reached one or more times during each boltup/unboltup cycle, the usage factor calculated in CENC-1332 might be too low. A maximum pump pressure slightly above the pressures needed for the tightening process, perhaps controlled by relief valve, would appear to be more prudent.

In Section 6 of the Manual, which describes the unbolting procedure, we do not find any caution about maximum pump pressure.

Your comments are requested.

Response:

- 2. It was agreed that Item (a) is a statement and no response is required. In response to Item (b), it is noted that the Combustion Engineering instruction manual provides guidelines. Specific instructions addressing these comments on installation will be in the plant operating procedures. The comment provided by the NRC consultant relative to the "caution" note in the procedure will be reviewed and discussed with HL&P operations personnel.

Attachment B

FORM NPP-1 DATA REPORT FOR FABRICATED NUCLEAR PIPE SUBASSEMBLIES*
(As Required by the Provisions of the ASME Code Rules)

COPY

1. Fabricated by SOUTHWEST FABRICATING & WELDING CO. INC. 7525 SHERMAN, HOUSTON, TX 77011 S.O.#02657-MS 23.4
(Name and Address of Fabricator)

2. Fabricated for HOUSTON LIGHTING & POWER CO., HOUSTON, TX Order No. P.O.#35-1197-6014
HOUSTON LIGHTING & POWER CO.
3. Owner SOUTH TEXAS NUCLEAR UNIT I 4. Location of Plant WADSWORTH, TX.

5. Piping System Identification Main Steam, Serial #39270
(Brief description of intended use, main coolant etc.)
(a) Drawing No. Q2657-MS #1 Prepared by SOUTHWEST FAB. & WELDING CO., INC.
(b) National Board No. N/A

6. The material, design, construction, and workmanship complies with ASME Code Section III, Class 2
Edition 1974, Addenda Date WINTER 1975, Case No. _____

Remarks: Manufacturers' Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of this report:
PIPE - (P1) Ladish Co. S/N 40U;
(Name of Part - Item number, Manufacturer's name, and identifying stamp)
ELL - Item (A) Southwest Fabricating & Welding Co. Inc. S/N LR-9087;
RED. - Item (B) Southwest Fabricating & Welding Co. Inc. S/N CC-4008

7. Shop Hydrostatic Test N/A psi.

8. Description of piping inspected MK: 2C369P-MS-1001-GA2-1-A; SA-155 KCF-70 Wld'd CL. I,
(Include - mark no. - material spec. - nom. pipe size - schedule or thickness - length)
30" O.D. (1.375" W) 22 7/16" long; SA-420 WPL6 Wld'd, 30" O.D. (1.375" MW)
= fittings = flanges, etc.)
90° LR Ell; SA-420 WPL6 Wld'd, 32" O.D. X 30" O.D. (1.375" MW) Conc. Cone
Red.

Material machined to a minimum wall of 1.250".

RIP # 4457

We certify that the statements made in this report are correct and that the fabrication of the described piping conforms with the requirements of SECTION III of the ASME BOILER AND PRESSURE VESSEL CODE.

Date 8-11-84 Signed SEFWCO By (th) [Signature]
(Fabricator)
Certificate of Authorization Expires JULY 23, 1985 Certificate of Authorization No. N-1459

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of TEXAS and employed by H.S.B.I. & I. Co. HARTFORD, CT have inspected the piping described in this Data Report on 8-11-84, and state that to the best of my knowledge and belief, the Manufacturer has constructed this piping in accordance with the applicable Subsections of ASME Code, Section III.

By signing this certificate, neither the inspector nor his employer make any warranty, expressed or implied, concerning the piping in this Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-11-84 Inspector [Signature] Commission 702 370
(Inspector) National Board, State, Province and No.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2" x 11", (2) information in items 1, 2 and 5 on this data report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded in item 7, "Remarks".

COPY

S.O. No. Q2657MS

Sheet No. 1

Southwest Fabricating & Welding Co. Inc.
MAGNETIC PARTICLE INSPECTION REPORT

Date 8-27-84

CLIENT

Houston Lighting & Power

30" PIPE SPAOL

Procedure No. MT-3, R/S

Material Type

CARBON STEEL

A.C. CONTINUOUS

M/A

COLOR

SURFACE PREPARATION

MAGNETIC PA 607, R60

AS WELDED AND OR AS GRIND

EQUIPMENT

Y-6 Yoke (MAGNETFLUX) SN FIX 11

TECHNICIAN

W. J. Insler

ASNT Level

II

PIECE OR WELD NO.	ACCEPT	REJECT	LINEAR	ROUNDED
-------------------	--------	--------	--------	---------

W-7	✓			
W-8	✓			
W-9	✓			
W-10	✓			

N.A.D.
N.A.D.
N.A.D.
N.A.D.

DESCRIPTION OF INDICATIONS

RIP # 4457

BECHTEL
743

COPY

RADIOGRAPHIC INSPECTION REPORT

SOUTHWEST FABRICATING & WELDING CO. INC.

WELD OR BEAM	FILM LOCATION	ACCEPT	REJECT	POROSITY	SLAG	INC PENET	INC FUSION	CRACK	SURFACE	EXCESSIVE PENETRATION	REMARKS	WELD OR BEAM	FILM LOCATION	ACCEPT	REJECT	POROSITY	SLAG	INC PENET	INC FUSION	CRACK	SURFACE	EXCESSIVE PENETRATION	VIEWED		
																							SINGL	DOUBL	
W2	1-6	✓																							
	2-5	✓																							
	3-4	✓																							
	4-5	✓																							
	5-6	✓																							
	6-7	✓																							
	7-1	✓																							
W3	1-2	✓																							
	2-3	✓																							
	2-4	✓																							
	4-5	✓																							
	5-6	✓																							
	6-7	✓																							
	7-1	✓																							

RIP # 4457

CUSTOMER REVIEW
BECHTEL
743

INTERPRETED & CERTIFIED BY

Spencer

ASNT LEVEL

II

DATE

9-29-84

W TUNGSTEN
RF RETAKE
R REPAIR

U/C UNDERCUT
EDW EDGE OF WELD
WV WELD VALLEY

CONC CONCAVE ROOT
FM FOREIGN MATERIAL
OR CASSETTE CREASE

HM HANDLING ARTIFACT
PAF PROCESSING ARTIFACT
LS LONGITUDINAL SEAM

CS CIRCUMFERENTIAL SEAM
CLS CENTERLINE SHRINKAGE
IRR IRREGULARITY IN WELD PROFILE

RADIOGRAPHIC TECHNIQUE DATA

PROCEDURE NO RT-10 R/2

S O NO N 2657 MS-1 DATE 9-28-84

MATERIAL TYPE Carbon PIPE SIZE 30" THICKNESS 1.375"

WELD THICK 1.500" TYPE SEAM Girth COVERAGE PER FILM 13.5"

WELDING PROCEDURE USED SMAW SAW GTAW GMAW

KV USED N/A MA USED N/A


ISOTOPE TYPE Fe-57 CURIES 100 EFFECTIVE FOCAL SIZE 100"

S.F. DISTANCE 15" O.F. DISTANCE Contact SCREENS USED 1010"/1010"


FILM TYPE Kodak-M PEN. MAT'L & NO. 55/30 PEN FILM SIDE PEN SOURCE SIDE

FILM SIZE 4 1/2" X 17" No EXPOSURES 2 EXPOSURE TIME 3:45

FILM PROCESSING MAN AUTO WELD No 2E3 RADIOGRAPHER J.A. Spindler SS ASNT Lev.



RIP # 4457



REMARKS

BECHTEL 743

COPY

ASME SECTION III, 1974 EDITION AND
ADDENDA THRU WINTER 1975. CLASS 2.

**SOUTHWEST
FABRICATING**
S WELDING CO INC

30" 1.375" MW 90° Ekh

NO 3

HOUSTON, TEXAS July 29, 1980

DETAILED ANALYSIS REPORT

how temp WPL-6 w

ORDER NO MWO-06183-1

CUSTOMERS ORDER NO S.O. 06183

80

4

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO	SPECIFICATION OF MATERIAL FROM WHICH MADE
	TENSILE STRENGTH PER SQUARE INCH	YIELD POINT PER SQUARE INCH	ELONGATION PER INCH IN 2"	REDUCTION OF AREA PER CENT	WELD METAL	C	MN	P	S	SI	CR	NI	MO		
Made From: Phoenix Steel Corp., SA-516 Gr. 70, (Normalized).	50700	79000	25.0			.25	1.02	.015	.009	.24					8889626 Slab: 58051
(1) SA-420 WPL-6 (W), 30" (1.375" MW) LR 90° Ell.	Physicals and Chemicals same as shown above.														
Mark No. LR-9087	100% X-Ray Long Seam Weld per SA-51 and SFMCO Procedure: RT-4, R/2.														
	Results: Satisfactory.														
	Normalized at 1600°F. ± 50°F.														
	(Weld) Charpy V-Notch at -40°F. Impact Tested = 92-75-81 2 Shear = 70-50-70 Lateral Exp. = 78-72-76				(Base) Charpy V-Notch at +40°F. Impact Tested = 63-60-65 2 Shear = 40-40-40 Lateral Exp. = 57-53-58										

RIP # 4457



I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT
ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

Quay K. Sanders

BECHTEL
743

FORM NM-1 DATA REPORT FOR TUBULAR PRODUCTS AND FITTINGS WELDED WITH FILLER METAL
As required by the Provisions of the ASME Code Rules, Section III, Division 1

1. Manufactured by SOUTHWEST FABRICATING & WELDING CO., INC. HOUSTON, TEXAS
(Name and address of NPT Certificate Holder of tubular products)

2. Manufactured for SOUTHWEST FABRICATING & WELDING CO., INC. HOUSTON, TEXAS
(Name and address of purchaser)

3. Identification-NPT Certificate Holder's Serial No. LR-9087
(Lot, etc.) (CRN & Drawing No.)

N/A 1980
(Nat'l Board No.) (yr. mfg.)

4. (a) Manufactured according to Mat'l Spec SA-420 WPL-6 (W) Purchase Order No. MWO-06183-1
(SA or SB)

(b) Description of Product Inspected (1) 30" (1.375" MW) LR 90° Ell.

(c) Applicable ASME Code: Section III, Edition 1974 Addenda date W/1975 Case No. --- Class 2

5. Remarks: None.
(Brief Description of Fabrication)

CERTIFICATE OF COMPLIANCE

We certify the statements made in this report are correct and the products defined in this report conform to the requirements of the ASME Material Specification listed above on line 4 (a). The radiographic film and a radiographic report showing film locations are attached to the Certified Material Test Reports provided for the material covered by this report?

Date July 29, 1980 Signed SF&WCO By Judy K. Sanders
(NPT Certificate Holder)

ASME Certificate of Authorization No. N-1459 to use the NPT Symbol expires July 23, 1982
(NPT) (Date)

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by HSBI&ICO, of Hartford, Conn. have inspected the products described in this Partial Data Report on 7/29/ 1980, and state that to the best of my knowledge and belief, the NPT Certificate Holder has produced this product in accordance with the ASME Code Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the product described in this Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 7-31 1980 Commissions Texas 966
(Inspector's Signature) (National Board, State, Province and No.)

RIP # 4457

*Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information on items 1-a on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at the top of this form.



BECHTEL
743

COPY

Supplier Deviation Disposition Request

NOTE:

1. COMPLETE INSTRUCTIONS ON BACK OF THIS SHEET
2. Items 1-18 below to be completed by supplier
3. * Items, Bechtel entries only
4. Attach additional information whenever necessary
5. Bechtel must be notified within 5 days after detection of deviation
6. A copy of the completed SDDR form shall be included by the supplier in the quality verification data package for each item to which this SDDR applies

SUPPLIER COMPLETED

FOR SUPPLIER USE		PROJECT <u>SOUTH TEXAS</u>	FOR BECTHEL USE	
Supplier SDDR No. <u>17</u>	Date Submitted <u>1/9/84</u>		Bechtel SDDR No. <u>0591</u>	Date Received <u>1-9-84</u>

1. Supplier Name EMERSON FABRICATING
EMERSON CO. INC. Address 7525 SHERMAN City & State HOUSTON TX Zip 77012

2. Supplier's Order No. <u>2657-2659</u>	3. Supplier's Part No. <u>Q2637MS-1,8</u> <u>-15,23</u> <u>Q2637MS-1,5-13-22</u>	4. Supplier's Part Name <u>FABRICATED</u> <u>PIPE SPOOL</u>	5. Deviation Detected <u>1/4/84</u> <u>REVIEW</u> Date Method	6. All Previous SDDR (No. & Date's) <u>4/0431</u> <u>5/1/83</u>
---	---	---	---	---

7. Bechtel P.O. & Rev. No. <u>35-1197-6014</u> <u>c/o 24</u>	8. Bechtel Part No. <u>SEE</u> <u># 12</u>	9. Bechtel Part Name <u>FABRICATED</u> <u>PIPE SPOOL</u>	10. Bechtel SQR Notified <u>N/A</u> <u>**</u> Date Method	11. Bechtel Engrg Notified <u>1/18/84</u> <u>VERBAL</u> Date Method
--	--	--	---	---

12. Deviation Description (Attach extra sheets, photographs, sketches, etc. as necessary and identify quantity and serial No.'s as applicable)
BEG ISOMETRICS 2636SP-MS-1001 THRU 1004 S#75 1 1/2 INCS
A REQUIRE A TOTAL OF (8) 32" OD X 30" OD 1.375 INK CONC
REDUCERS - 24" LONG AT THE STEAM GENERATOR NOZZLES.
VENOZES REFER STRAIGHT TAPER CONE REDUCERS

13. Suppliers Proposed Disposition Use-As-Is Repair Modify Bechtel Requirement

14. Cost Impact ADVICE SDR TO CUSTOMER 15. Schedule Impact 4 WK DELAY

16. Proposal Disposition and Technical (plus Cost/Schedule if applicable) Justification: Attach extra sheets, sketches, etc. as necessary
ACCEPT STRAIGHT TAPER CONE REDUCERS. USE IS NOT
INITIATED BY THE SPECIFICATION - COST SAVINGS AND
IMPROVED SCHEDULE WILL RESULT.

17. Associated Supplier Document Change(s)
SHIP # DETAIL SHEETS

RIP # 4457

18. Suppliers Authorized Representative
 Name R.C. Gallow Jr Title PROJECT MANAGER
 Signature R.C. Gallow Jr Date 1-4-84

19. Bechtel Engrg. Action
 Accepted Rejected
 Engrg. Dwg Change (Bechtel Supplier) Licensing Doc. Change
 Followup Spec/Req. Change (Bechtel Supplier) Price Adjustment
 Other Suppliers Affected Other

20. Bechtel Disposition Statement including Justification (Attach extra sheets, sketches, etc. as necessary)
THE SUBSTITUTION OF A 32" OD X 30" OD STRAIGHT TAPER CONE REDUCER
FOR THE SPECIFIED CONCENTRIC REDUCER IS ACCEPTABLE TO BECTHEL.
THE STRAIGHT TAPER CONE REDUCER IS SIMILAR IN CONFIGURATION AND
DESIGN WITH THE SAME STRESS INTENSIFICATION FACTOR. ADDITIONALLY,
THE STRAIGHT TAPER CONE REDUCER WILL NOT AFFECT THE FLOW. THIS
REVISION WILL BE INCORPORATE INTO BECTHEL DRAWINGS
2636SP-MS-1001 THRU 1004, SHEET 1
BY BECTHEL SQR, K. BELTER, NOTIFIED PER TELECON 1-30-84 P.M.

21. Bechtel Acceptance/Signature _____ Date 1/24/84
 Construction Action Required YES NO

22. Supplier <u>Harold W. Knapp</u>	Date <u>2-9-84</u>
23. Bechtel Supplier Quality Representative <u>[Signature]</u>	Date <u>[Signature]</u>

COPY

COPY

Section III, 1974 edition
addenda thru Winter 1975.
2:

81

SOUTHWEST
FABRICATING
G WELDING CO. INC.

44

NO 3

HOUSTON TEXAS June 6, 1984

ORDER NO MWD 2657N-245

CUSTOMERS ORDER NO 2657N-245

DETAILED ANALYSIS REPORT

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO	SPECIFICATION OF MATERIAL FROM WHICH MADE	
	YIELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	PERCENT ELONGATION	PERCENT REDUCTION OF AREA		C	MN	P	S	SI	CR	NI	MO			CB
Steel from Luken Steel Co. Conforms to SA-516 GR-70	52,200	80,200	28			.22	1.20	.018	.006	.23					D-6817 SL #3H	SA-516 GR-70
(8) 32" x 30" (1.375" MW) Concentric Cone Reducers	Physicals and chemicals same as shown above.															
SA-420 WPL-6 (W)	Heat treat per procedure 10-120 R/1 @ 1620° F, for 1 hr 30 min.															
	Charpy V-notch tested @ +40°F.															
	(Size: 10mm x 10mm)															
	Weld															
	Ft. Lbs. Lat. Exp. % Shear															
	48.0 42 40															
	44.0 41 40															
	44.0 42 40															
Mfg. S/N CC-4003 thru CC-4010	HAZ															
	50.5 47 40															
	63.0 55 50															
	66.0 56 50															
	Base															
	99.0 75 85															
	97.0 70 80															
	96.0 70 80															
	X-Ray long seam per procedure RT-11 R/4															
	Results - Satisfactory															

RIP #
A457
2657

S.F. & W. CO.
QA
2

BECHTEL
749

This material was manufactured and supplied in accordance with the SF&W Co. Quality Assurance Manual Rev. #4, meeting the requirements of NCA-3800.

I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

M. Fiore

COPY

SOUTHWEST FABRICATING & WELDING CO INC

HO-3

HOUSTON, TEXAS June 6, 1984

ORDER NO MWO 2657N-245


CUSTOMERS ORDER NO 2657N-245

DETAILED ANALYSIS REPORT

CONTINUED

Table with columns: DESCRIPTION, PHYSICALS OF MATERIALS FROM WHICH MADE (TENSILE STRENGTH, YIELD POINT, PERCENT ELONGATION, PERCENT REDUCTION IN AREA), CHEMICAL ANALYSIS (C, MN, P, S, SI, CR, NI, MO, CU), HEAT OR LOT NO, SPECIFICATION OF MATERIAL FROM WHICH MADE. Rows include 1/8" Page AS-25 Carbon Steel Weld Wire, .035" Airco Carbon Steel Weld Wire, and 3/32" Page AS-25 Carbon Steel Weld Wire.

RIP # 4457



I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

M. Fine

BECHTEL 743

13

FORM NM-1 DATA REPORT FOR TUBULAR PRODUCTS AND FITTINGS WELDED WITH FILLER METAL
As required by the Provisions of the ASME Code Rules, Section III, Division 1

1. Manufactured by Southwest Fabricating & Welding Co. Inc., 7525 Sherman, Houston, TX
(Name and address of NPT Certificate Holder of tubular products)
2. Manufactured for Southwest Fabricating & Welding Co. Inc., 7525 Sherman, Houston, TX
(Name and address of purchaser)
3. Identification-NPT Certificate Holder's Serial No. CC-4003 thru CC-4010
(Lot, etc.) (CRN & Drawing No.)
4. (a) Manufactured according to Mat'l Spec SA-420 WPI-6 (W) N/A 1984
(SA or SB) (Nat'l Board No.) (yr. mfg.) Purchase Order No. 2657N-245
- (b) Description of Product Inspected 32" x 30" (1.375" MW) Conc Cone Red. (24" lg)
- (c) Applicable ASME Code: Section III, Edition 1974 Addenda date W/75 Case No. -- Class 2
5. Remarks: N/A
(Brief Description of Fabrication)

CERTIFICATE OF COMPLIANCE

We certify the statements made in this report are correct and the products defined in this report conform to the requirements of the ASME Material Specification listed above on line 4 (a). The radiographic film and a radiographic report showing film locations are attached to the Certified Material Test Reports provided for the material covered by this report.

Date June 6 19 84 Signed S F & W Co. By M. Fire
(NPT Certificate Holder)

ASME Certificate of Authorization No. N-1459 to use the NPT Symbol expires 7-23-85
(NPT) (Date)

RIP # 4457

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Texas and employed by H S B I & I Co. of Hartford, Conn. have inspected the products described in this Partial Data Report on 6-12 19 84, and state that to the best of my knowledge and belief, the NPT Certificate Holder has produced this product in accordance with the ASME Code Section III.

By signing this certificate, neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the product described in this Partial Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 6-12 19 84
D. E. Ferguson Commissions Texas 370
(Inspector's Signature) National Board, State, Province and No.

* Supplemental sheets in form of lists, sketches or drawings may be used provided (1) size is 8 1/2 in. x 11 in., (2) information on items 1-4 on this Data Report is included on each sheet, and (3) each sheet is numbered and number of sheets is recorded at the top of this form.



BECHT
743

COPY (79)

LADISH CO. - Material Analysis Report METALLURGICAL DEPARTMENT

30" (1.375) PIPE

PURCHASER: Southwest Fab & Weld Co. PURCHASER'S ORDER NO. 6181 N-6 ADDRESS P.O. Box 9449 - Houston, Texas 77011

SA-155 KCF-70 CL-1 C.S.

CIDAHY, WIS., October 24, 19 78 LSO NO. B21172 INVOICE NO.

Table with columns: DESCRIPTION AND SPECIFICATION, HEAT NO. AND CODE, CHEMICAL COMPOSITION (C, MN, P, S, SI, NI, CR, MO), PHYSICAL PROPERTIES (YIELD STRENGTH, ULTIMATE STRENGTH, ELONG., RED. OF AREA). Includes item #1: 30" C.D. x 1.375 N/W Pipe Sq. Cut Ends.

VEE notch Charpy impacts at +40°F. - Full Size

Table with columns: Ft. Lbs., % Shear, Lateral Expansion. Rows: C.W., P.M., H.A.Z.

Manufactured from ASME SA 516 Grade 70 plate. Guided weld bend test - satisfactory.

SUBSCRIBED AND SWORN TO BEFORE ME THIS 24th DAY OF October 19 78 Lorraine Zajac NOTARY PUBLIC MY COMMISSION EXPIRES August 17, 1980

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

Handwritten signature

RIP # 4457 BECHTEL 743



COPY

material analysis report
METALLURGICAL DEPARTMENT

PURCHASER Southwest Fab & Weld Co.

CUDAHY, WIS., October 24, 19 78

PURCHASER'S ORDER NO. 6181 N-6

LSO NO. B21172

ADDRESS P.O. Box 9449 - Houston, Texas 77011

INVOICE NO. _____

Center weld impacts were taken with their longitudinal axis transverse to the longitudinal axis of the pipe, 1/2" from the outer surface. The axis of the notch is centered on the welded joint and perpendicular to the surface.

Parent metal impacts were taken with their longitudinal axis transverse to the longitudinal axis of the pipe, 1/2" from outer surface. The axis of the VEE is perpendicular to the surface.

Heat Affected Zone impacts were taken with their longitudinal axis transverse to the longitudinal axis of the pipe, 1/2" from the outer surface. The axis of the notch is centered on the fusion line and perpendicular to the surface.

Pipe was welded per 16-F-115 Rev. 9 dtd. 12-8-77 using Page AS-15, Heat No. 60403 weld wire and Lincoln 860 Lot 47E flux.

Procedure qualification record no. YR 489 dtd. 11-16-77.

Pipe was heat treated per (L) Procedure 13-N-628 dtd. 5-3-77. Stress relieved at 1125°F. Air cooled.

Welds were radiographically inspected and accepted per (L) Procedure 9-Q-216 Rev. 5 dtd. 12-8-77.

Pipe was hydrostatically tested and approved per (L) Procedure 19-Q-010 dtd. 1-17-77 at 2612 psi.

PIPE IS IDENTIFIED AS FOLLOWS:

- Ladish ASME SA 155 KCF 70
- Class 1 SA 516 Gr. 70 - L - JY4UH
- Weld No. 40U 2612 psi
- Identification includes NPT Stamp Cl. 2 1978.
- Partial Data Reports attached.

BECHTEL
743

RIP # 4457



SUBSCRIBED AND SWORN TO BEFORE ME THIS
24th DAY OF October 19 78

Lorraine Zajac
NOTARY PUBLIC
MY COMMISSION EXPIRES August 17, 1980

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

[Signature]

COPY

LADISH CO.
Material Analysis Report
METALLURGICAL DEPARTMENT

PURCHASER Southwest Fab & Weld Co.

PURCHASER'S ORDER NO. 6181 N-6

ADDRESS P.O. Box 9449 - Houston, Texas 77011

CUDAHY, WIS., February 27, 19 79

LSO NO. B21172

INVOICE NO. _____

SUPPLEMENT TO ORIGINAL REPORT DTD. 10-24-78

Weld was repaired per Procedure 16-F-020 Rev. 7 dtd. 6-22-78 using Chemetron E7018 heat no. 421W9081 electrodes.

Procedure qualification record no. YR 490 dtd. 12-29-77.

Pipe was heat treated per (L) Procedure 13-N-628 dtd. 5-3-77. Stress relieved at 1125°F. Air cooled.

Weld was radiographically inspected and accepted per (L) Procedure 9-Q-216 Rev. 5 dtd. 12-8-77.

Pipe was hydrostatically tested and approved per (L) Procedure 19-Q-010 dtd. 1-17-77 at 2612 psi.

BECHTEL
743

RIP # 4457



SUBSCRIBED AND SWORN TO BEFORE ME THIS

27th DAY OF February 19 79

Lorraine Zajac
NOTARY PUBLIC

I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE ABOVE REPORT IS TRUE AND CORRECT.

[Signature]

FORM NM-1 DATA REPORT FOR TUBULAR PRODUCTS AND FITTINGS WELDED WITH FILLER METAL
As required by the Provisions of th ASME Code Rules

1. Manufactured by Ladish Co., 5481 S. Packard Ave., Cudahy, Wis. 53110
(Name and address of Manufacturer of tubular products)

2. Manufactured for Southwest Fab & Weld Co., PO Box 9449, Houston, Texas 77011
(Name and address of purchaser)

3. Identification-Manufacturer's Serial No. 40U 62-38809
(Lot, etc.) (CRN & Drawing No.)

4. (a) Manufactured according to Mat'l Spec SA155 KCF70 Cl. 1 Purchase Order No. 6181 N-6
(SA or SB) (Nat'l Board No.) (yr. mfg.)

(b) Description of Product Inspected 30" O.D. x 1.375 N/W Pipe

(c) Applicable ASME Code: Section III, Edition 1974 Addenda date W75 Case No. - Class 2

5. Remarks: ***
(Brief Description of Fabrication)
Welded with filler metal and produced in accordance with
ASME Sec. III Class 2 to SA155 KCF 70 specifications.

CERTIFICATE OF COMPLIANCE

We certify the statements made in this report are correct and the products defined in this report conform to the requirements of the ASME Material Specification listed above on line 4 (a). The radiographic film and a radiographic report showing film locations are attached to the Certified Material Test Reports provided for the material covered by this report.

Date October 31, 1978 Signed Ladish Co. By Frank D. Bell
(Manufacturer)

ASME Certificate of Authorization No. N1600 to use the NPT Symbol expires 1-10-80
(Date)

Frank D. Bell 2/27/79

RIP # 4457

CERTIFICATE OF INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and the State or Province of Wisconsin and employed by *** of Waltham, Mass. have inspected the products described in this Manufacturer's Partial Data Report on Nov 3, 1978 and state that to the best of my knowledge and belief, the Manufacturer has produced this product in accordance with the ASME Code Section III.

By signing this certificate, neither the inspector nor his employer makes any warranty, expressed or implied, concerning the product described in this Manufacturer's Partial Data Report. Furthermore, neither the inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Nov 3, 1978 Commissions 7452
D. S. Oakley (Inspector's Signature) National Board, State, Province and No.

7/76

This form (E00080) may be obtained from the Order Dept., ASME, 345 E. 47th St., New York, N.Y. 10017

*** Arkwright Boston Manufacturers Mutual Insurance Co.
Mutual Boiler Division, Factory Mutual System

*** Weld was repaired per Procedure 16-F-020 Rev. 7 dtd. 6-22-78 using Chemetron E7018 Heat No. 421W9081 electrodes. Procedure Qualification record no. YR 490 dtd. 12-29-77. Pipe was heat treated per (L) Procedure 13-N-623 dtd. 5-3-77. Stress relieved at 1125 F. Air cooled. Weld was radiographically inspected and accepted per (L) Procedure 9-Q-216 Rev. 5 dtd. 12-8-77. Pipe was hydrostatically tested and approved on 2-27-79 per (L) Procedure 19-Q-010 dtd. 1-17-77 at 2612 psi.

BECHTEL
743



COPY

Tensile Test (QW-150)

Ring was normalized at 1650°F weld; stress relieved @ 1125° F. @ temp.

Specimen No.	Weld	Thickness	Area	Ultimate Total Load lb.	Ultimate Unit Stress KSI *	Character of Failure & Location
QWL62.1(d)	CW 1T	.5045"Ø		15,975	79.9	#1 Part. Cup&Cone/
QWL62.1(d)	CW 1B	.505"Ø		15,450	77.1	#2 Part. Cup&Cone/
QWL62.1(d)	CW 2T	.5045"Ø		15,700	78.5	#3 Part. Cup&Cone/
QWL62.1(d)	CW 2B	.5045"Ø		15,500	77.5	#4 Part. Cup&Cone/
QWL62.1(d)	PM (Long.)	.504"Ø		15,250	76.4	#5 Cup&Cone/Cente
QWL62.1(d)	PM (Circum.)	.504"Ø		15,250	76.4	#6 Part. Cup&Cone/

Toughness Tests (QW-170)

Specimen No.	Weld	Notch Type	Test Temp.	Impact Values Ft-Lbs.	Lateral Exp.		Drop Weight	
					% Shear	Min	Break	No. Break
SA370								
Fig. 11a								
	CW	Vee	+30°F	86.0	72	69		
	CW	Vee	+30°F	86.0	62	73		
	CW	Vee	+30°F	83.0	55	74		
	HAZ	Vee	+30°F	39.0	55	38		
	HAZ	Vee	+30°F	52.0	69	46		
	HAZ	Vee	+30°F	46.0	62	46		
	PM (Long.)	Vee	+30°F	57.0	57	52		
	PM (")	Vee	+30°F	49.0	45	44		
	PM (")	Vee	+30°F	57.0	50	54		

RIP # 4457

Other Tests

CHARGE NO. 51-12089
MO 64-02365

Type of Test Radiographic Satisfactory to ASME Sec. VIII Para. UW51 Z50

Deposit Analysis C Mn P S Si Ni Cu
+ Other (L) Weld .10 1.86 .024 .016 .27 .02 .13
+ Deposit chemistry as-welded per 16 F 115 R9 (2-3/16" thick A516 plate) from SFA 5.17 EH14 (Page AS15, Ht. 60403) wire, 5/32"Ø, & Lincoln-860 flux, Lot 47E.

Welder's Name R. Kateley
Tests conducted by R. Wells
Chart No. 12888
Stamp No. L88

Laboratory Test No. YR489
We certify that the specimens in this record are correct and that the test welds were prepared, welded and tested in accordance with the requirements of Section IX of the ASME Code.

Date 11/8/77
Manufacturer LABI3W CO
By W. L. Williams

	YLD. STR. KSI 2% OFFSET	% EL.	% RA	
#1-CW	60.5	14	52	Fract. outside gage mark.
#2-CW	49.9	24	56	
#3-CW	53.7	16	52	Fract. in gage mark.
#4-CW	49.9	33	57	
#5-PM (Long.)	49.6	33	66	
#6-PM (Circum.)	49.9	31	59	




BECHTEL
743

Z50
Ht. Y54538
Code JJ4Z

Company Name Ladish Co.
Procedure Qualification Record No. YRL90 ✓ Date 12/28/77
WPS No. 16 F 020 LR and 16F008 Rev. 8
Welding Process(es) SMAW
Type(s) (Manual, Automatic, Semi-Auto.) Manual (L) Unit AC394582

JOINTS (QW-402)



Groove Design Used

RIP # 4457

BASE METALS (QW-403)

Material Spec. A516
Type or Grade 70
P No. 1 to P No. 1
Thickness 2-1/2"
Diameter _____
Other Range 3/16" to 5"

Ht. No. Y54538, Code JJLZ (Z50)

POSTWELD HEAT TREATMENT (QW-407)

Temperature See Individual Test Result
Time _____
Other _____

GAS (QW-408)

Type of Gas or Gases _____
Composition of Gas Mixture _____
Other _____

FILLER METALS (QW-404)

Weld Metal Analysis A No. 1
Size of Electrode 3/16"
Filler Metal F No. 4
SFA Specification 5.1
AWS Classification E7018 ✓
Other Chemtron E7018, Ht. #421W90-1

ELECTRICAL CHARACTERISTICS (QW-409)

Current DC
Polarity Reverse
Amps. * _____ Volts * _____
Other _____
*See Attached Welding Record

POSITION (QW-405)

Position of Groove Flat
Weld Progression (Uphill, Downhill) Horizontal
Other _____

TECHNIQUE (QW-410)

Travel Speed _____
String or Weave Bead String
Oscillation _____
Multipass or Single Pass (per side) Multipass
Single or Multiple Electrodes Single
Other _____

PREHEAT (QW-406)

Preheat Temp. 60-250°F
Interpass Temp. 60-600°F
Other _____

BECHTEL
743

((QW-43) (Back) Test section (normalized prior welding, welded, stress relieved @ 112, +0 -25, 2-1/2 hrs. @ t
Tensile Test (QW-150)

Specimen No	Symbol	Thickness	Area	Ultimate Total Load lb	Ultimate Unit Stress KSI	*	Character of Failure & Location
QWL62, 1(d)	CW	1E	.505"Ø	15,000	74.9	#1	Cup&Cone/Weld
QWL62, 1(d)	CW	1E	.504"Ø	14,550	72.9	#2	Cup&Cone/Weld
QWL62, 1(d)	CW	2E	.5045"Ø	15,050	75.3	#3	Cup&Cone/Weld
QWL62, 1(d)	CW	2E	.504"Ø	14,650	73.4	#4	Cup&Cone/Weld
QWL62, 1(d)	PM (Long)		.505"Ø	16,125	80.5	#5	Cup&Cone/Cente
QWL62, 1(d)	PM (Circum)		.505"Ø	15,800	78.9	#6	Cup&Cone/Cente

Toughness Tests (QW-170)

Specimen No	Notch Location	Notch Type	Test Temp.	Impact Values	Lateral Exp.		Drop Weight	
					% Shear	Mils	Break	No Break
SA370				ft-Lbs.				
Fig. 11a	CW	Vee	+30°F	184.5	100	92		
	CW	Vee	+30°F	190.0	100	89		
	CW	Vee	+30°F	194.0	100	77		
	HAZ	Vee	+30°F	56.0	95	49		
	HAZ	Vee	+30°F	52.0	89	47		
	HAZ	Vee	+30°F	48.0	80	43		
	PM (Long.)	Vee	+30°F	101.0	75	65		
	PM (")	Vee	+30°F	129.0	100	82		
	PM (")	Vee	+30°F	106.0	82	76		



RIP # 4457

Other Tests CHARGE NO. 51-12090
MO 64-02371

Type of Test Radiographic Satisfactory to ASME Sec. VIII Para. UW51, LW171

Deposit Analysis	C	Mn	P	S	Si	Ni	Cr	Mo	Cu	Sn	Al	V
Other (L)Weld	.05	1.20	.015	.016	.38	.02	.05	.01	.06	.01	<.01	.01
Mill - PM	.26	1.05	.011	.017	.24							

Welder's Name S. Thompson Clock No. 12660 Stamp No. L50
 Tests conducted by: R. Wells Laboratory Test No. YRL90

We certify that the statements in this record are correct and that the test welds were prepared, welded and tested in accordance with the requirements of Section IX of the ASME Code.


Date 12/30/73

Manufacturer W. R. L. LAMISH CO.
By W. R. L. Lamish

	YLD. STR. KSI .2% OFFSET	% EL.	% RA
-CW	52.4	26	73
-CW	52.4	24	75
-CW	51.0	27	74
-PM (Long.)	55.6	25	74
-PM (Circum)	53.7	32	66
	52.7	30	58

BECHTEL
743

COPY



Combustion Engineering, Inc.
C-E Wire
4224 Shackelford Road
Norcross, Georgia 30093

MANUFACTURERS OF HIGH QUALITY NICKEL ALLOY,
STAINLESS STEEL AND LOW ALLOY WIRE FOR
WELDING, FORMING AND OTHER APPLICATIONS.
CERTIFIED TO ASTM, ASME, AWS, SECTION II
AND SECTION III NUCLEAR SPECIFICATIONS.

SHIP TO: Southwest Fabricating & Welding
7525 Sherman
Houston, Texas 77011

DATE SHIPPED: 12-23-76
Corrective Copy 5-4-82
MARKED:

CERTIFICATE OF QUALITY CONFORMANCE TESTS

CUSTOMER PURCHASE ORDER NO. _____ SHOP ORDER NO.: 2076
SPECIFICATIONS SFA 5.9 This material was manufactured and supplied in accordance with Quality Assurance manual revision Dated: 11/1/76 accepted by Southwest Fabricating.

ITEM	HEAT NUMBER	SIZE	TYPE	POUNDS SHIPPED
1	74649	.035" Dia.	ER309/ER309L	
2		.094" Dia.		
3		.125" Dia.		
4				

RIP # 4457

CHEMICAL ANALYSIS

ITEM	C	Mn	Si	S	P	Cr	Ni	Cu	Al	Mo	N ₂
1	.02	1.51	.25	.005	.018	24.05	12.80	.05		.10	.05
2											
3											
4											



ITEM	TENSILE STRENGTH	YIELD STRENGTH	ELONGATION	ADDITIONAL TESTS
1	Welding Temper			
2				
3				
4				

BECHTEL
743

WE HEREBY CERTIFY THAT MATERIAL REFERRED TO ABOVE CONFORMS TO THE PHYSICAL AND CHEMICAL TESTS AND IS IN ACCORDANCE WITH SPECIFICATIONS.

Notary Public, Georgia, State at Large
My Commission Expires Aug. 15, 1989

Lucy Cox
NOTARY

Combustion Engineering, Inc.

Lucy Cox
AUTHORIZED OFFICIAL

COPY

COPY



SOUTHWEST FABRICATING & WELDING CO INC

NO 5

HOUSTON, TEXAS 5/3/84

AN-TECH LAB REPORT NO. 84-1618-1 & 2

TEST ORDER NO. 02183

DETAILED ANALYSIS REPORT

CUSTOMERS' ORDER NO.

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO.	SPECIFICATION OF MATERIAL FROM WHICH MADE	
	# & HEAT TREATMENT	YIELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	PERCENT ELONGATION IN 2"	PERCENT REDUCT TION IN AREA	C	MN	P	S	SI	CR	NI	MO			CU & CB
3/32" & 1/8" PAGE AS-25		REPORTED				.095	1.29	.012	.007	.52	.10	.10	.023	.18	40911	
CARBON STEEL WELD WIRE						Va = .002										
SPECIFICATION SFA-5.18						AS WELDED										
CLASS ER70S-3/E70S-3		72,500	90,500	28.0	73.0	.078	1.20	.012	.010	.46	.07	.10	.01	.27		
						Va = .01										
						"V" NOTCH CHARPY IMPACT AT -20°F										
						FT.LBS. 64.0 - 76.0 - 97.0										
						LAT. EXP. 46 - 55 - 69										
						% SHEAR 50 - 60 - 70										
						STRESS RELIEVED AT 1150 °F FOR 8 HOURS										
		63,700	106,100	27.0	75.0	CHEMISTRY SAME AS ABOVE.										
						"V" NOTCH CHARPY IMPACT AT -20°F										
WELDED PER 01.01.037 R/5						FT.LBS. 150.0 - 151.0 - 155.5										
HEAT TREATED PER HT-P1-2 R/4						LAT. EXP. 80 - 82 - 83										
X-RAY SATISFACTORY						% SHEAR 100 - 100 - 100										

RIP # 4457



I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

W. Russell


BECHTEL
743

PAGE-WILSON CORPORATION

PAGE WELDING DIVISION

205 LAY SCHILL BOULDER ROAD HOUSTON, TEXAS 77058

CHEMICAL ANALYSIS REPORT



Date: 4/11/84

Customer's Order: 2442

Shipped To: CHAMPION INDUSTRIAL SALES., HOUSTON, TX

FOR: SOUTHWEST FABRICATING & WELDING HOUSTON, TX

S.W. Fab P.O. #84-0194

Via: UNIBRAZE-PAGE

Our Register: 1300-122-133
1300-138-095
Net: 3000

Pallets: 2

Gross: 3114

Material: 3/32 AS-25 #2 COIL *
1/8 AS-25 #2 COIL **
ASME Boiler & Pressure Vessel Code
Section II, Part C
Specification SFA 5.17, Classification EM-13K
and Specification SFA 5.18, Classification ER70S-3/E70S3

ACTUAL CHEMISTRY

Heat No.	C	Mn	P	S	Si	Mo	Cu	Al	Ni	Cr	V
40911	.095	1.29	.012	.007	.52	.023	.184* TOTAL*		.10	.10	<.002
							.176** TOTAL**				

RIP # 4457

We certify that these chemical test results are correct as contained in the records of the company.

~~XXXXXXXXXXXXXXXXXXXX~~
A. Stamps, Q.C. Dept.

This material was manufactured in accordance with the Quality Assurance Manual, revision dated March 31, 1983, accepted by Southwest Fabricating and Welding Co., as meeting the requirements of NCA-3800.

A. Stamps / PK 2
A. STAMPS



BECHTEL
743

COPY



CHAMPION INDUSTRIAL SALES CO. • 6420 Navigation • P. O. Box 9130 • Houston, Texas 77011 • Phone 713-921-7183

JUNE 1, 1984

SOUTHWEST FABRICATING & WELDING CO., INC.
P.O. BOX 9449
HOUSTON, TEXAS 77011

RE: P.O.#84-0194 (Ht. #40911)

1/8 AND 3/32 PAGE AS-25 MATERIAL WAS MANUFACTURED AND SUPPLIED IN ACCORDANCE WITH THE QUALITY ASSURANCE MANUAL, REVISION III, DATED 1/02/83, ACCEPTED AND APPROVED BY SOUTHWEST FABRICATING & WELDING CO., INC., MEETING THE REQUIREMENTS OF NCA 3800.

CHAMPION INDUSTRIAL SALES CO.

AMOS STIBORIK

AS/jt

RIP # 4457



BECHTEL
743



COPY

ALLOY RODS, INC.

CERTIFICATE OF ANALYSIS

P.O. BOX 517 HANOVER, PA 17331 717/637-8911

CERTIFIED MATERIALS TEST REPORT



IWECO, INC.
P.O. BOX 12668
8350 MOSLEY
HOUSTON, TX 77017
ATTN: QA MANAGER

Customer Order No. N84363
Order No. 228759-1

This Material Conforms to Specification
ASME SFA 5.1 Sec. II Part C & ASME Sec
III, NB-2400 1983 Ed. thru Summer 1983
Add. 10 CFR Part 21 applies.

Trade Name
or Trademark: Atom Arc 7018
Diameter Size: 3/32"
Weight: 2,500 lbs.
Lot Number: 2J311AA02
Heat Number: 411X0991

Type: E7018
Test No. 2-2945-00
Control No. JJ043
X-Rays Satisfactory

Moisture @ 1800° F. 0.08%
Concentricity 3%
Type Steel A-285

Carbon .05
Manganese 1.07
Chromium .03
Nickel .03
Silicon .40
Columbium+
Tantalum
Molybdenum .01
Tungsten
Copper .02
Titanium
Phosphorus .016
Sulphur .013
Vanadium .01
Cobalt

Test No.	Full	Split	Volts	Amps
Tensiles & Impacts	1	3	22	100 D

Test Results:	As Welded	Stress Relieved
Yield	70,500	8 hrs. @ 1150° F. 62,600
Tensile	84,000	77,000
Elongation	34.0%	34.0%
Red. of Area	75.6%	76.0%

Charpy V-Notch Impacts Tested @ -20° F.
Ft. Lbs. 90-92-96 140-120-134
Lat. Exp. 64-66-71 82-82-83
% Shear 30-30-30 60-40-40

Ferrite:

Filletts: OK Vertical/Overhead Tensile Specimen .252"
Impact Specimen .394" x .394"

RIP # 4457

Location & Orientation of Charpy-
V-Notch/Tensile Specimens is I/A/W
ASME NX-2322 and/or AWS/SFA
specifications as applicable.

Quality Systems Certificate No. QSC-22
Expiration Date: September 8, 1984

State of Pennsylvania }
County of York } SS

The undersigned certifies that the
contents of this report are correct
and accurate and that all operations
performed by the undersigned or sub
contractors are in compliance with
requirements of the material speci-
fication and ASME Boiler and Pressure
Vessel Code Section III Division I
Subsection NCA-3800

Subscribed and sworn to before me
this 5th day of December, 1983

Kay Kildwin
SEAL.....
Notary Public

ALLOY RODS, INC.

BY.....*D. E. Lebo*.....
D. E. Lebo
Quality Assurance Specialist



BECHTEL
743



P.O. Box 12668
Houston, Texas 77017

8350 Mosley
Houston, Texas 77075

IWECO, INC.

713 - 943-2000

Distributors For

Union Carbide - Linde, Chemetron - Atom Arc,
Steady, Aronson, Reid - Avery, Pandjiris,
Westinghouse, Arcos, All - State, Arcair, Tweco



CERTIFICATE OF COMPLIANCE

SOUTHWEST FABRICATING & Weld. P. O. NO. 83-1282

Material Specification E-7018, SFA 5.1, Sec II, C

Heat No. 411X0991

Lot No. 2J311AA02

Control JJ043

RIP # 4457

This material was manufactured and supplied in accordance with the Quality Assurance Manual Revision NO. 2, 11-3-80

Accepted by SOUTHWEST FABRICATING, meeting the requirements of NCA-3800. ✓



Joe Morgan
Joe Morgan
Q.A. Mgr.

BECHTEL
743

COPY

64

SOUTHWEST FABRICATING
WELDING CO. INC.

(4)

HO-5

HOUSTON, TEXAS 3/22/84
Test
RRR55 NO 02161
CUSTOMERS' ORDER NO

An-Tech Lab. Report No. 84-1080-1 & 2
DETAILED ANALYSIS REPORT

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO.	SPECIFICATION OF MATERIAL FROM WHICH MADE	
	88 HEAT TREATMENT	YIELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	PERCENT ELONGATION IN 2"	PERCENT REDUCTION IN AREA	C	MN	P	S	SI	CR	NI	MO			CU
615 Alloy Rod			Reported			.09	1.46	.006	.013	.85	.04	.04	.01	.05	12132	
Spoolarc 88 Carbon Steel						Va = .01										
Weld Wire						As Welded										
Specification: SFA-5.18		66,400	86,100	23	61.3	.11	1.47	.005	.012	.80	.05	.05	.01	.25		
Class E70S-6/ER70S-6						Va = <.01										
						"V" Notch Charpy Impact at 0° F.										
						Ft. Lbs.	33.0	-	35.0	-	53.0					
						Lat. Exp.	25	-	28	-	42					
						% Shear	30	-	30	-	40					
						Stress Relieved at 1150° F for 8 Hrs										
		58,600	74,800	28.0	70.9	Chemistry same as above										
						"V" Notch Charpy Impact at 0° F.										
						Ft. Lbs.	71.5	-	74.0	-	76.5					
						Lat. Exp.	56	-	57	-	63					
						% Shear	70	-	70	-	70					

RIP # 4457

S. & W. CO.
QA
2

BECHTEL
743

I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

David K. Hartman

P.O. BOX 517 HANOVER, PA 17331 71 7-8911

CERTIFIED MATERIALS TEST REPORT

SOUTHERN ALLOY & EQUIP.
6620 FULTON
REF. P.O. 0739
HOUSTON, TX 77022

Customer Order No. 1461

Order No. 232119-1

Shipped:

This Material Conforms to Specification
ASME SFA 5.18 Sec. II Part C & ASME B&PV
Sec. III NB-2400 1983 Ed. thru Summer
1983 Add. 10 CFR Part 21 applies.

Type: ER 70S-6

Test No. 2-3380-00

Trade Name
or Trademark: Spoolarc 88
Diameter Size: .035"
Weight: 1,020 lbs.
Lot Number:
Heat Number: 12132

Carbon	.09
Manganese	1.46
Chromium	.04
Nickel	.04
Silicon	.85
Columbium+	
Tantalum	
Molybdenum	.01
Tungsten	
Copper	.05
Titanium	
Phosphorus	.006
Sulphur	.013
Vanadium	.01
Cobalt	

RIP # 4457

Quality Systems Certificate No. QSC-221
Expiration Date: September 8, 1984

The undersigned certifies that the
contents of this report are correct
and accurate and that all operations
performed by the undersigned or sub
contractors are in compliance with
requirements of the material speci-
fication and ASME Boiler and Pressure
Vessel Code Section III Division I
Subsection NCA-3800

State of Pennsylvania }
County of York } SS

Subscribed and sworn to before me
this 22nd day of March, 1984


[Signature]
SEAL.....
Notary Public

My Commission expires: 03/16/87

ALLOY RODS, INC.

BY.....
[Signature]
J. L. Starner
Q.A. Supervisor

APPROVED
[Signature]
BY Q.A. DATE 3-26-84
SOUTHERN ALLOY & EQUIPMENT, INC.



BECHTEL
743

SOUTHERN ALLOY & EQUIPMENT, INC.

382 GARDEN OAKS BLVD. • P. O. BOX 10208

HOUSTON, TEXAS 77206

(713) 691-5513

March 20, 1984

Re: SF&WCO P.O. Number 84-0163 dated 2-8-84

1020# Chemtron .035" Dia. "Spoolarc 88" Mild Steel Mig Wire
AWS-SFA 5.18 Class ER-70S-6 Heat #12132

THIS MATERIAL WAS MANUFACTURED AND SUPPLIED IN ACCORDANCE WITH THE
QUALITY ASSURANCE MANUAL REV.3 DATED 3-24-80 ACCEPTED BY SF & WCO,
MEETING THE REQUIREMENTS OF NCA-3800.

Southern Alloy & Equipment, Inc.



C.A. Hardin
Mgr. Q.A.

Kir' 4457



BECHTEL
743

COPY

COPY

04

SOUTHWEST FABRICATING & WELDING CO. INC

(15)

NO 3

HOUSTON, TEXAS 8-10-84

AN-TECH LAB. REPORT NO. 84-3057-1 & 2
DETAILED ANALYSIS REPORT

TEST NO 02212

CUSTOMER'S ORDER NO

DESCRIPTION	PHYSICALS OF MATERIALS FROM WHICH MADE					CHEMICAL ANALYSIS								HEAT OR LOT NO	SPECIFICATION OF MATERIAL FROM WHICH MADE	
	W B HEAT TREATMENT	YIELD POINT PER SQUARE INCH	TENSILE STRENGTH PER SQUARE INCH	PERCENT ELONGATION IN 2"	PERCENT REDUCTION IN AREA	C	MN	P	S	SI	CR	NI	MO			CU
3/32" PAGE AS-25 CARBON		REPORTED				.13	1.18	.013	.009	.58	.046	.041	.007	.16	40925	
STEEL WELD WIRE						V=	.002									
SPECIFICATION: SFA 5.17		72,900	85,800	26.0	64.9		-	AS WELDED	-							
CLASS EM13K WITH						.13	1.15	.024	.010	.60	.06	.07	.02	.22		
LINCOLN 860 FLUX LOT#						V=	< .01									
137S CLASS F70-						"V" NOTCH	CHARPY IMPACT @ 0° F.									
EM13K F7A0-EM13K						FT. LBS.	39.0	36.0	38.0							
OR F7PO-EM13K						LAT. EXP	38	31	35							
						% SHEAR	40	40	40							
						STRESS RELIEVED @ 1150° F. FOR 8 HOURS										
		64,400	81,400	27.0	66.1	CHEMISTRY SAME AS ABOVE										
						"V" NOTCH	CHARPY IMPACT @ 0° F.									
WELDED PER 01.01.040 R/7						FT. LBS.	45.0	44.0	45.0							
HEAT TREATED PER HT-P1-2 R/4						LAT. EXP	43	42	43							
X-RAY SATISFACTORY						% SHEAR	40	40	40							

RIP # 4457

S.F. & W. CO.
QA
2

I HEREBY CERTIFY THIS REPORT TO BE TRUE AND CORRECT ACCORDING TO RECORDS IN THE POSSESSION OF THIS CORPORATION

M. C. Russell

BECHTEL
743

UNIBRAZE-PAGE CORPORATION

205 CLAY STREET, BOX 1839
 BOWLING GREEN, KENTUCKY 42102-1839 (502) 781-5560 TELEX 554357

CHEMICAL ANALYSIS REPORT

Date: 8-9-84

Shipped To: CHAMPION INDUSTRIAL SALES
 HOUSTON, TX

Customer's Order: 2637

FOR: SOUTHWEST FABRICATION & WELDING
 HOUSTON, TX.

S.W. Fab. P.O. 84-0597

Via: CUSTOMER PICK UP

Our Register: 1300-208-128

Pallets: 2

Gross: 2928#

Net: 2816#

Material: 3/32" AS-25 #2 Coils


ASME Boiler & Pressure Vessel Code
 Section II, Part C
 Specification SFA 5.17, Classification EM-13K
 and Specification SFA 5.18, Classification ER70S-3/E70S-3

Heat No.	C	Mn	P	S	Si	Mo	Cu	Al	Ni	CR	V
40925	.13	1.18	.013	.009	.58	.007	.16 TOTAL		.041	.046	.002
RIP # 4457											

We certify that these chemical test results are correct as contained in the records of the company.

A. Stamps, Q.C. Dept.


This material was manufactured in accordance with the Quality Assurance Manual, revision dated march 31, 1983, accepted by Southwest Fabrication and Welding Co. as meeting the requirements of NCA-3800.



A. Stamps
 A. Stamps, Q.C. Department

BECHTEL
 743

COPY



CHAMPION INDUSTRIAL SALES CO. • 6420 Navigation • P. O. Box 9130 • Houston, Texas 77011 • Phone 713-921-7183

August 10, 1984

Southwest Fabricating & Welding Co.
P. O. box 9449
Houston, Texas 77011

Re: PO#84-0697 Chg. 1 (40925)

3/32 Page AS-25 material was manufactured and supplied in accordance with the Quality Assurance Manual, revision III/ dated 01/02/83, accepted and approved by Southwest Fabricating and Welding Co., Inc, meeting the requirements of NCA 3800.

Amos Stiborik

RIP # 4457



BECHTEL
743



COPY

PRODI IDENTITY RECORD FOR COATING MATERIALS

(By Seller / Subcontractor)

PROJECT NAME : SOUTH TEXAS NUCLEAR PROJECT
 PROJECT NUMBER: P.O./SUBCONTRACT NO: 3-5749
 SELLER : CUSTOM BLAST, 2550 Genoa Red Bluff, Houston, Texas 77571
 FOR ITEM/AREA :

(By Coating Material Supplier)

MANUFACTURER : AMERON PROTECTIVE COATINGS DIVISION
 LOCATION : 201 NORTH BERRY STREET
 BREA, CALIFORNIA 92621

PRODUCT NAME : DIMETCOTE 6 PRIMER
 GENERIC TYPE : SOLVENT BASED INORGANIC ZINC PRIMER

ORDER NO. : 7004483 CUST. PO # : 3-5749 GALS SHIPPED: SEE COMPONENTS

COMPONENTS	BATCH NO.	DATE OF MFG.	SHELF LIFE EXPIRES
A. Powder (27 x 5 gals)	108126	3/29/84	3/29/86
B. Liquid (80 x 5 gals)	108382	4/16/84	4/16/86

Provide batch and standard test data for all components.

TEST	METHOD	A - COMPONENT		B - COMPONENT	
COMPONENTS	ASTM or OTHER	BATCH	STANDARD	BATCH	STANDARD
WEIGHT-lbs./gal.:	D 1475	58.6	58.6	8.35	8.24-8.64
VISCOSITY-CPS :	Fed #4287	1000	200-2000	600	200-600
WT. SOLIDS-% :	Formula	(info only)	100	(info only)	29.2-35.2
GRIND :	N/A				
FLASH POINT :	D 1310	(info only)	77 Deg. F	(mixed, as applicable)	
MIXING RATIO :	14.9 Lbs. Powder : 6.3 Lbs. Liquid				
MIXED MATERIAL	ASTM or OTHER	BATCH		STANDARD	

VISCOSITY : N/A
 RECOAT TIME : 24 HRS. at 77 Deg. F
 FULL CURE TIME : 2 HRS. at 77 Deg. F / 50% Relative Humidity

RIP # 4457

ZINC PIGMENT	ASTM or OTHER	BATCH	STANDARD
METALLIC ZINC-% :	Formula	(info only)	69.4
SIEVE ANALYSIS :	N/A		


We hereby certify that the coating materials described above were manufactured with the same formulation, raw materials, production methods, and quality control standards as the coating materials on which the original acceptance was granted by Bechtel.

QUALITY CONTROL CHEMIST:

SIGNED: 

DATE : May 15, 1984


QUALITY ASSURANCE MANAGER:

SIGNED: 

DATE : May 15, 1984

BECHTEL
743

201 North Berry
Post Office Box 10
Brew, California 92821
(714) 529-1961 Telex: 655342



May 17, 1984

Purchasing Department
Custom Blast
2550 Genoa Red Bluff
Houston, Texas 77571

Reference: Purchase Order 3-5750
Ameron Order 7004482

CERTIFICATE OF COMPLIANCE

This is to certify that the following Ameron product

Amercoat 101 Thinner
2 x 50 gallons
Batch Number B510844H

was manufactured in accordance with the standard Ameron Protective Coatings Division quality control procedures applicable to this Amercoat product.

RIP # 4457

David L. Berry
Quality Assurance Supervisor

DLB:s

cc: Ameron Houston

BECHTEL
743

COPY

CLEANING AND COATING VERIFICATION RECORD

PROJECT NAME Santa Texas Project NO. Lot A 9-11-84
 PO/SUBCONTRACT NO. 2057/2659 ITEM/AREA 0 N/A

INSTRUCTIONS

1. Use a separate Cleaning and Coating Verification Record Form for each item, lot or area.
2. Record all readings, tests, and other data in appropriate boxes on this form for the item, lot or area identified above. If an appropriate box cannot be found, record data under "Comments".
3. Provide all inspection and test data required by the specification. Mark other boxes "N/A" if the data is not required by the specification.
4. Use a separate Coating Record - Part II sheet for each coat applied to the same item, lot or area.

RIP # 4457

CLEANING RECORD - PART I											
Witness Point		Date	Time	Released	Initials	Comments					
AMBIENT CONDITIONS											
Spec'd. Air/Surface Temp., °F:		40-10.5°		RH, %:		35-95°		Dew Point, °F:			5°
Date	Time	Dry/Wet Bulb	RH	Dew Point	Surf. Temp.	Comp. Air Test	Abrasive Test	Operation Permitted	Initials	Comments	
9-11	8:00	80/76	93	75	96	ok	ok	yes	AS		
9-11	12:00	91/78	36	74	98	ok	ok	N/A	AS	Final readings	
SURFACE PREPARATION											
Substrate:		Steel Pipe									
Type Abrasive:		Steel Abrasive / Silica Sand									
Spec'd. Surface Preparation Std:		SSPC-SP10 Profile, mils: 10-3.0									
Size/Grit:		40-90 #3 Inspection Instruments: SSPC-101-107 (1971)									
Date	Time	Readings		Comments	Date	Time	Readings		Comments		
		Vis 1	Profile				Vis 1	Profile			
9-11	8:15	CSA2h	2.5								
9-11	8:15	CSA2h	2.5						BEUNTEL		
9-11	8:30	CSA2h	2.5						743		
9-11	8:30	CSA2h	2.5								
9-11	9:00	CSA2h	2.5		Total	CSA2h	2.5	Released	Initials	Date	
		Average					2.5	yes	AS	9-11	

COPY

CLEANING AND COATING VERIFICATION RECORD - CONT'D.

Lot A 9-11-84

COATING RECORD - PART II

(Circle One): touch-up, 1st, 2nd, 3rd Coat. Manufacturer: Ameron
 Color/No: Reddish Gray
 Product/No: D6N & A101
 Date/Time Started: 9-11-84 @ 8:00 Date/Time Completed: 9-11-84 @ 12:00
 Comments: RIP # 4457

Witness Points

AMBIENT CONDITIONS

Spec'd. Air/Surface Temp., °F: 40-103 RH, %: 35-95 Dew Point, °F: 50
 Comments: _____

Date	Time	Dry/Wet Bulb	RH	Dew Point	Surf. Temp.	Comp. Air Test	Operation Permitted	Initials	Comments
9-11	8:00	90/76	83	75	86	OK	yes	J.S.	
9-11	12:00	91/78	86	74	98	OK	NA	J.S.	Final readings

MIXING RECORD


Spec'd. Material Temp., °F: N/A Pot Life: 24 hrs @ 70°F
 Mixing Time: 5 min

Date	Time	Product No.	Batch No.	Material Temp.	Mix Time	Initials	Date	Time	Product No.	Batch No.	Material Temp.	Mix Time	Initials
9-11	8:30	D6N	108126	N/A	5	J.S.							
9-11	8:30	D6N	108982	N/A	5	J.S.							
9-11	8:30	A101	85244	N/A	5	J.S.							

INSPECTION RECORD

Spec'd. Wet Film, mils: N/A Dry Film, mils: 1.3-6.0 Run Sags %: 150 max. 80
 Inspection Instrument: Magnete Thickness Gauge

Date	Time	Thickness		Comments	Date	Time	Thickness		Comments
		Wet	Dry				Wet	Dry	
9-12	11:00		3.5		9-12	11:00		4.0	BE
9-12	11:00		3.5		9-12	11:00		3.75	
9-12	11:00		3.0		9-12	11:00		2.75	
9-12	11:00		4.5		9-12	11:00		3.0	
9-12	11:00		3.0					3.35	Released
9-12	11:00		12.75					3.3	yes



NOTES: (DF-329)

- (1) SEE SPECIAL BEND NOTES
- (2) MIG. WELDING ALLOWED ON .375"W THK. OR LESS.
- (3A) MIG. WELDING LIMITED TO ROOT PASS ON ALL WALL THK. OVER .375"W THRU 1.500"W.
- (3B) NO MIG WELDING ALLOWED OVER 1-1/2" WALL THK.
- (4) NO E-6010 ALLOWED.
- (5) FCAW LIMITED TO 1-1/2" WALL THK. AND LESS.
- (6) ALL SHOP WELDS REQUIRE "C" BORES.
- (7) DISTANCE BETWEEN WELDS SHALL BE 2T + 4" OR 6", WHICHEVER IS GREATER.
- (8) FOR WELD MAPPING, SEE PROCEDURE 2657 R/O
- (9) GRIND ALL BW'S PER EP-8210 R/O
- (10) TOTAL WEIGHT OF SPOOL TO BE INCLUDED WITH OTHER MARKINGS ON SPOOL. IF TOTAL THEORETICAL WEIGHT EXCEEDS 10,000#, PIECE MUST BE WEIGHED AND RECORDED.
- (11) SILICA-GEL DESSICANT REQUIRED 5 BAGS.
- (12) RECORD MEASURED MIN. WALL ON SPECIFIED MIN. WALL FTGS. AND PIPE-4 PLACES AT END-90° APART AT ALL BW'S AND OPEN ENDS.
- (13) NOTIFY BECHTEL INSPECTOR FOR INSPECTION OF MATERIAL SURFACE AFTER REMOVAL OF ALL TEMPORARY ATTACHMENTS
- (14) ATTACH SUPPLIERS DEVIATION DISPOSITION REQUEST #17-05'91

SOUTH TEXAS UNIT 1 BECHTEL JOB #14926-001 SYSTEM MAIN STEAM


MK: 2C369P-MS-1001-GA2-1-A		SOQ 2657-MS
CLEANING & SHIPPING PREP: PROC. EP-8212 R/O		COLOR CODE NONE
MT	YES	OR PT O.D. & ACCESSIBLE I.D. OF ALL WELDS NOT R.T. EXAMINED & TEMPORARY ATTACH. AREAS
PT	YES	SEE MT
RT	YES	ALL GIRTH & LONG. BW'S: ALL BRANCH TO HDR WELDS GREATER THAN 4" NPS.
UT	NO	
PREHEAT	200°F MIN	SURF PREP SOLVENT CLEAN (SSPC-SP-1) ANY OIL OR GREASE PRIOR TO NEAR WH BLAST (SSPC-SP-10) PER APPROVED PROCEDURE 1002-NUC-83 R/1.
PWHT		PAINT (INORGANIC) DIMETCOTE #6N PER APPROVED PROCEDURE 1002-NUC-83 R/1.

MF	QUA	DESCRIPTION	UNIT	WT	QUA	UNIT	TOTAL	DISC	COPY
		ALL BEVELS 37 1/2° (XAW)							
		SA420-WPLG CHARPY V- NOTCH TEST @ +40 F° OR LESS PER NC2300 LAT- ERAL EXP. 25 MILS MIN.							
A	1	30" O.D. 30° (1.375" MIN. W) LR ELL W/IMBE C= 27.250" ±.010" TM= 1.250" D= 1/4" MIN ±.002" IMBE PER 88400 C= 27.250" TM= 1.250" D= 1/4" MIN. HT# 8889626 SN LR-9087							
B	k	32" O.D. X 30" O.D. (1.375" M.W) CONC. CONE RED. X 24" LG. 1/32" END MBE PER DET. A THIS DWG. C= 29.365" ±.010" ±.033" TM= 1.3125" D= 2.750" & 30" END MBE C= 27.250" ±.010" TM= 1.250" D= 1/2" HT# D6817 SN CC-4009							
		(1.375" W) SA155 KCF-70 CL.1 WLOD (CHARPY V- NOTCH TEST @ 40°F OR LESS PER NC2300 LAT- ERAL EXP. 25 MILS MIN.)							
D	1	30" O.D. 22 7/16" 2MBE C= 27.250" ±.010" TM= 1.250" D= 2.750" HT# JY4UH SN 404							
		1. 32" OPEN END PROTECTOR 1. 30" OPEN END PROTECTOR							

RIP # 4457

BECHTEL
743

<p>DF-329</p> <p>≤ 4" ————— > 4" (2)</p>				<p>TOTAL 34 R.5</p>		
<p>8/16/64 ADDED AS BUILT DATA JH</p>	<p>8/3/84 REVISED C-BORE TM PER Q.#564 (S.C.C.) LB</p>	<p>6/27/84 ISSUED FOR FAB 67 SD P HK</p>	<p>WT FLG</p>	<p>WT FTGS 3350</p>	<p>WT PIPE 807</p>	<p>TOTAL 4157 SF</p>
<p>REV DATE DESCRIPTION T BY CK</p>			<p>FAB CODE ASME III</p>		<p>CLASS 2 (ISI)</p>	
<p>EDITION 1974</p>			<p>ADDENDA WINTER 1975</p>			
<p>SPEC GA</p>		<p>REF DWG 20369P-MS-1001-17</p>		<p>DATE BY CUST HOUSTON LIGHTING & POWER</p>		
<p>CK</p>		<p>PO 35-1197-6014</p>		<p>SO Q 2657-MS</p>		
<p>CK</p>		<p>SHT</p>		<p>1</p>		



MANUFACTURING RECORD SHEET

CL 2 CARBON MR COPY

DATA, OPERATIONS, OR DOCUMENTATION					ITEM NO.	ITEM ROD	S.P.A.V.	U.C. INSP.	ATH. P. 7	REPORT REQUIRED	1	2	3	
S.F. & W. WELDING PROCEDURE (SHOW LINE NO. OF APP'D. PROCEDURE)					1	✓	✓				H	CDE	CDE	
WELDER SYMBOL	GTAW:				2	✓	✓				03 12	03	03	
	SMAW				3	✓	✓							
	GMAW				4	✓	✓					3	3	
	SAW				5	✓	✓					N	N	
	GTAW WIRE:				6	✓	✓				74649	40911	40911	
HEAT NUMBERS	SMAW ELECTRODE:				9	✓	✓							
	GMAW WIRE:				12	✓	✓					12132	12132	
	SAW WIRE:				15	✓	✓					40925	40925	
	SAW FLUX (TYPE) 860				17	✓	✓					1375	1375	
	WELD DOCUMENTATION BY:				19	✓	✓				8/24/84 ^H	8/17/84 ^H	8/17/84 ^H	
	BEND	COLD BENDING PER PROCEDURE : 4-106 R/5 S/1				20								
		HOT BENDING PER PROCEDURE : 4-108 R/4				21								
	NONDESTRUCTIVE EXAM. & INSPECTION	FIT UP :				22	✓	✓				8/15/84 ^{WR}	8/15/84 ^{WR}	8/15/84 ^{WR}
		ROOT PASS :				23								
		FINAL : (A1)				24	✓	✓	✓			8/21/84 ^{SWG DF}	8/21/84 ^{SWG DF}	8/21/84 ^{SWG DF}
LIQUID PENETRANT PER PROCEDURE : PT-5 R/4				25	✓	✓	✓			8/25/84 ^{SWG}				
MAGNETIC PARTICLE : MT-3 R/5				27	✓	✓	✓							
CHECK AND RECORD WALL THK OF BENDS PER PROC. : UT-1 R/6 S/1				28										
RADIOGRAPH PER PROCEDURE : RT-10 R/7 (A1)				29	✓	✓	✓	✓			8/29/84 ^{SWG DF}	8/29/84 ^{SWG DF}		
MIN WALL CHECK OF "C" BORE :				30										
OPERATION ON FABRICATED PIECE		PREHEAT : 200 °F MIN				31	✓	✓				8/24/84 ^H	8/17/84 ^H	8/17/84 ^H
		HEAT TREAT PER PROCEDURE : HT-P1-2 R/4				32								
	DIMENSIONAL CHECK (FINAL) :				35	✓	✓				8/25/84 ^{TR}			
	HYDRO TEST PER PROCEDURE : 10-101 R/1				36									
	CORRECTED DOCUMENTATION ENTRY :				39									
	REPORT OF NONCONFORMANCE :				41									
	CERTIFIED MATERIAL TEST REPORTS				42	✓	✓					8/31/84 ^{JH}		
	DATA REPORT & RECORDS OF HEAT TREATMENT EXAMINATIONS, TESTS, & INSPECTIONS :				43	✓	✓					8/31/84 ^{JH}		
APPROVED WELD'G. PROCEDURES	LINE NO.	PROCEDURE NO.	REV.	SUPP.	MAX HT. CYCLE	LINE NO.	PROCEDURE NO.	REV.	SUPP.	MAX HT. CYCLE	LINE NO.			
	A	01.01.030	2	1	540	J	9-103	3	-	-	S			
	B	01.01.031	3	1	540	K					T			
	C	01.01.037	5	1	540	L					U			
	D	01.01.038	7	3	540	M					V			
	E	01.01.040	7	1	540	N					W			
	F	01.01.044	4	1	540	P					X			
	G					Q					Y			
H	01.08.006	4	1	-	R					Z				

4	5	6	7	8	9	10			
			C E-B	E	E	C			
			12			03			
			1						
			1	1	1				
			40911			40911			
			411x0991						
			40925	40925	40925				
			1375	1375	1375				
			8/29/84 ^D H						
			8/13/84 ^D H	8/13/84 ^D H	8/13/84 ^D H	8/15/84 ^D H			
			8/27/84 Sm DF	8/29/84 Sm DF	8/29/84 Sm LF	8/29/84 Sm DF			
			8/27/84 Sm Jm	8/27/84 Sm Jm	8/27/84 Sm Jm	8/27/84 Sm Jm			
			8/29/84 ^L H	8/13/84 ^L H	8/13/84 ^L H	8/15/84 ^L H			

Also calculate by 1.550

RIP # 4457

BECHTEL
743

PROCEDURE NO.	REV.	SUPP.	MAX. MT. CYCLE

SOUTHWEST FABRICATING & WELDING CO. INC.

P.O. BOX 9449 HOUSTON, TEXAS 77011 713/928-3451

AUTH. INSP.	DATE	S.F. & Q.A.	DATE
<i>L. J. ...</i>	8-31-84	<i>Mar. Penney</i>	8/31/84

PC. MK.	S.O.	SHT. NO.	REV.
20369P-MS-1001-GA2-1-A	02657-MS	1	2

SEE

APERTURE

CARDS

*OVERSIZED DRAWINGS

(ADDITIONAL DOCUMENT PAGES FOLLOW)

- APERTURE CARD NO# 8508060314

AVAILABILITY PDR CF HOLD

NUMBERS OF PAGES. 1

QUESTIONS ON MATERIAL OR DIMENSIONS

QUEST. NO. ASKED BY RCGR DATE 7/19/84 APPROVED BY AC

564) 30" MAIN STEAM PIPING UNDER SPECIFICATION GA2 REQUIRES 30" 1.375" NOM WALL PIPE AND 1.375" MIN WALL FITTINGS. WE ARE HOLDING A MINIMUM WALL OF 1.365" ON ALL FABRICATION OTHER THAN MIN WALL REQUIREMENT OF 1.375" ON FITTING WALLS. WITH THE C-BORE REQUIREMENTS SET BY BECHTEL AND ISI 2^d COUNTERBORES, AN EXCESSIVE AMOUNT OF WELD METAL BUILDUP IS REQUIRED TO HOLD MANUFACTURER'S MINIMUM WALL OF 1.365. PLEASE REVIEW YOUR DESIGN WALL REQUIREMENTS AND ADVISE IF A WALL THICKNESS LESS THAN 1.365 WOULD BE PERMITTED. A SIMILAR SITUATION EXISTS IN SPECIFICATIONS JC AND EG. SFEW WILL REVIEW THESE AND ADVISE IF REVISED MIN WALL REQUIREMENTS WOULD BE DESIRED.

ANSWERS TO QUESTIONS

ANSWER NO. ANSWERED BY R. SHIELDS DATE 7-31-84 APPROVED BY Robert K. Shields

BECHTEL HAS REVIEWED THE MIN. WALL REQUIREMENTS FOR THE MAIN STEAM SYSTEM UNDER MATERIAL CLASS "GA". WE CAN PERMIT A MIN. WALL REQUIREMENT TO 1.25" TO THE MAIN STEAM PIPING IN THE "GA" MATERIAL CLASS



LOS ANGELES
POWER DIVISION

CALCULATION COVER SHEET

PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001 SHEET 1 OF 1
 SUBJECT MAIN STEAM PIPING - STEAM HAMMER ANALYSIS TOTAL NO. OF SHEETS 1
 ORIGINATOR SIG. N/A DISCIPLINE PSSG DATE _____ FILE NO. N/A
 CHECKER SIG. N/A DATE _____ CALC. NO. 5N179 RC 0004
 QUALITY CLASSIF. 5

RECORD OF ORIGINAL ISSUE AND REVISIONS

REV. NO.	REVISION DESCRIPTION	DATE	ORIG	CKR	GL	GS	CHIEF
0	REVIEWED AND ACCEPTED FOR USE	2/10/84	N/A	N/A	2015	177	N/A

RESULTS OF CHECKER REVIEW

ITEM DESCRIPTION	ORIG. ISSUE	REVISION NO.					
		1	2	3	4	5	6
MUST INITIAL ONE FINAL RESULT NUMERICAL DIFFERENCES ARE NOT SIGNIFICANT; NO CORRECTIONS NECESSARY	INITIAL	N/A					
	DATE						
MUST INITIAL ONE FINAL RESULT NUMERICAL DIFFERENCES ARE SIGNIFICANT; NECESSARY CORRECTIONS HAVE BEEN MADE.	INITIAL						
	DATE						
CHECK MADE BY ATTACHED ALTERNATE CALCULATIONS.	INITIAL						
	DATE						

COMMITTED

This calculation is for Unit 1; Unit 2; Units 1 & 2

CALCULATION NO. 5N179 RC0004 IS ASSIGNED FOR MAIN STEAM PIPING - STEAM HAMMER ANALYSIS WHICH WAS PREPARED BY LOS ANGELES POWER DIVISION - PLANT DESIGN.

NOTE: THE STEAM HAMMER LOADS FROM THIS ANALYSIS WILL BE COMBINED WITH THE LOADS FROM STRESS CALC. # 2015 RC 5032, 2015 RC 5033, 2015 RC 5040, 2015 RC 5041, 5N102 RC 002 & 5N100 RC 001



LOS ANGELES
WATER DIVISION

CALCULATION TITLE SHEET

PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001 DISCIPLINE Plant Design
 SUBJECT MAIN STEAM LINES INSIDE AND OUTSIDE CONTAINMENT FILE NO. _____
STEAM HAMMER ANALYSIS CALC. NO. STP-MS
 ORIGINATOR SIG. Harold H. Wagner DATE 11/10/83 QUALITY CLASSIF. 0
 CHECKER SIG. S. H. DATE 11/11/83 NO. LAST PAGE 13
 Sheet 1 of 11

PE STAMP IF REQ'D

ORIGINAL ISSUE

	NAME	ACTION REQ'D	DATE	SIGNATURE
GROUP LEADER	R. Qashu	Approval	10/20/83	[Signature]
GS	S. Mohamed	Approval	11/23/83	[Signature]
SPECIALIST	J. Lee	Review	11/23/83	[Signature]
CHIEF	L. R. Brown	Approval	11/28/83	[Signature]
OTHER				

RECORD OF REVISIONS

NO	REVISION	DATE	ENG.	CKR	GL	GS	SPEC	CHIEF
△								
△								
△								
△								
△								
△								

Issue to project for implementation in the design.

LAD-9815 (7)



CALCULATION SHEET

CALC. NO. STP-MS

SIGNATURE M. W. Jines DATE 11/10/83 CHECKED F. J. Jol DATE 11/11/83
 PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
 SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 11 OF 11 SHEETS

TABLE OF CONTENTS

<u>Description</u>	<u>Page</u>
1.0 INTRODUCTION	1
2.0 SYSTEM DESCRIPTION	3
3.0 METHOD OF ANALYSIS	5
4.0 DISCUSSION OF ANALYSIS	8
5.0 DISCUSSION OF RESULTS	9
6.0 COMPUTER RUNS LOG	12
7.0 REFERENCES	13
Appendix A - Stress Isometrics and Input Data	A1
Appendix B - Results of Main Steam Lines MS-01 and MS-02 Inside Containment Analysis	B1
Appendix C - Results of Main Steam Line MS-03 Inside Containment Analysis	C1
Appendix D - Results of Main Steam Line MS-04 Inside Containment Analysis	D1
Appendix E - Results of Main Steam Lines Outside Containment Analysis	E1
Appendix F - Reference Material	F1

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36



CALCULATION SHEET

LAO 0513 B-73

CALC. NO. STP-MS

SIGNATURE H. W. J. [Signature] DATE 11/10/83 CHECKED F. [Signature] DATE 11/11/83
PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 1 OF 13 SHEETS

1.0 INTRODUCTION

This report prepared by the Plant Design Staff of Bechtel Power Corporation, Los Angeles Power Division, for South Texas Project describes the analysis performed to determine the dynamic structural response of the main steam piping systems. The analysis evaluates effects of the steam hammer loadings resulting from closure of the turbine stop valves.

The analysis described in this report covers each main steam line piping system from the steam generator to the turbine stop valves. Dynamic loading on the piping systems can be induced during a turbine trip event by a sudden closure of the turbine stop valves which are located in the turbine valve chest. Closure of these valves creates pressure and momentum transients throughout the piping systems, resulting in a significant time-varying force at points of the piping system direction change (elbows) until steady-state flow is achieved.

The purpose of the analysis reported herein is to evaluate the maximum dynamic response, i.e., stresses, displacements, support reactions and nozzle loads in the subject piping systems due to the steam hammer loadings. Transient dynamic force histories were generated (Reference 1) and applied to the piping systems. The response of the piping systems was then evaluated by developing a three-dimensional structural model and performing a dynamic time-history analysis. The worst case loading was assumed to occur for the condition of simultaneous closure of all four stop valves in the main steam supply system.

Section 2.0 of this report describes the configuration and important parameters of the main steam supply system. Section 3.0 provides a general description of the analytical approach used. Details of the analysis assumptions and procedures are discussed in Section 4.0, and the results are discussed in Section 5.0.



CALCULATION SHEET

LAO 0513 & 73

CALC. NO. STP-MS

SIGNATURE M. Wajner DATE 11/10/83

CHECKED F. Hol DATE 11/11/83

PROJECT SOUTH TEXAS PROJECT

JOB NO. 14926-001

SUBJECT MSL STEAM HAMMER ANALYSIS

SHEET 2 OF 13 SHEETS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36

In summary, the displacements and stresses of the main steam supply system under the steam hammer loadings are found to be well within the acceptable design limits.

It is noted that the results presented herein should be combined with those obtained for other applicable simultaneous loading cases and evaluated for compliance with relevant criteria in the ASME Section III Code (Reference 2), and the PSAR/FSAR of the South Texas Project.



CALCULATION SHEET

LAG 0513 B-73

CALC. NO. STP-MSSIGNATURE M. Weijer DATE 11/10/83CHECKED F. J. L. DATE 11/11/83PROJECT SOUTH TEXAS PROJECTJOB NO. 14926-001SUBJECT MSL STEAM HAMMER ANALYSISSHEET 3 OF 13 SHEETS

2.0 SYSTEM DESCRIPTION

The main steam piping system for the South Texas Project consists of four (4) main steam lines designed for the primary function of delivering steam from the steam generators to the turbine. The piping systems under consideration, support locations and orientations are shown on the following drawings supplied by the South Texas Project:

- (A) Main Steam System MS-01 Stress Isometric No. 1-R-0505-2
- (B) Main Steam System MS-02 Stress Isometric No. 1-R-0506-5
- (C) Main Steam System MS-03 Stress Isometric No. 1-R-0507-4
- (D) Main Steam System MS-04 Stress Isometric No. 1-R-0508-2
- (E) Composite Piping - Isolation Valves Cubicle, Plan at El. 50'-0", Area II, Drawing No. 5G-15-9-P-0054, Rev. 0, (Appendix F)
- (F) Main Steam Stress Isometric No. 1-R-0004-F, Sheet 2
- (G) Main Steam Bypass (MS-2) Stress Isometric No. 1-R-0005-L, Sheet 1
- (H) Main Steam Bypass (MS-3) Stress Isometric No. 1-R-0006-I, Sheet 2
- (I) Piping Fabrication Drawing Nos. 2G369P-MS-1001, Sheet 3, Rev. 1; 2G369P-MS-1002, Sheet 2, Rev. 1; 2G369P-MS-1003, Sheet 3, Rev. 1; and 2G369P-MS-1004, Sheet 3, Rev. 1

Pipe properties and support stiffnesses used in the computer model were also supplied by the South Texas Project (References 6 and 7).

Analysis of each main steam line was divided into two independent problems, separated by an anchor-containment wall penetration. The two different problems are:



CALCULATION SHEET

LAO 0513 & 73

CALC. NO. STP-MS

SIGNATURE H. Wainer DATE 11/10/83

CHECKED F. Job DATE 11/11/83

PROJECT SOUTH TEXAS PROJECT

JOB NO. 14926-001

SUBJECT MSL STEAM HAMMER ANALYSIS

SHEET 4 OF 13 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

(A) Main steam line inside the containment building, from the steam generator to the containment wall penetration.

(B) Main steam line outside the containment building, from the containment wall penetration to the turbine stop valves including bypass lines to the condenser.

Since the layout of the main steam line MS-02 inside the containment is a mirror image of the main steam line MS-01 layout with identical pipe support types and locations, only one dynamic analysis using higher steam hammer forces was performed for those two piping systems.



CALCULATION SHEET

LAO 0513 8-73

CALC. NO. STP-MS

SIGNATURE M. W. Jones DATE 11/10/83 CHECKED Z. J. Jof DATE 11/11/83
PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 5 OF 13 SHEETS

3.0 METHOD OF ANALYSIS

The analysis to obtain the structural response of the main steam piping system following the sudden closure of the four turbine stop valves consists of the thermal hydraulic analysis (Reference 1) to obtain force histories acting on the piping system, and dynamic structural analysis to determine response to these transient forces. Since the distortion of the piping is relatively small, the interaction between the structural response and the fluid forces is not significant, and the overall analysis can be performed in two distinct phases — thermal hydraulic and structural analysis.

The method of analysis consists of the following steps:

- (A) Development of thermal-hydraulic model of the system.
- (B) Performance of the thermal-hydraulic analysis using program GAFT to determine transient state histories at discrete locations throughout the piping system.
- (C) Integration of the transient state histories to develop force histories applicable to different sections of the piping systems.
- (D) Development of a lumped mass structural model of the piping system.
- (E) Utilizing program ME-101 to perform the structural dynamic analysis of the system with forces developed in Step (C).

Steps (A), (B) and (C) above comprise the thermal-hydraulic analysis phase discussed in Reference 1. Steps (D) and (E) comprise the structural analysis phase which is discussed in the following subsection.



CALCULATION SHEET

LAO 0513 & 73

CALC. NO. STP-MSSIGNATURE H. Wajner DATE 11/10/83CHECKED J. J. J. DATE 11/11/83PROJECT SOUTH TEXAS PROJECTJOB NO. 14926-001SUBJECT MSL STEAM HAMMER ANALYSISSHEET 6 OF 13 SHEETS

3.1 Method of Structural Response Analysis

In order to evaluate the dynamic structural response of the main steam lines due to the transient steam hammer forces, a time-history analysis was performed. The time-history analysis is based upon the normal mode superposition method using a closed form integration technique for the evaluation of the responses associated with each mode. A finite element model consisting of lumped masses connected by three-dimensional elastic piping elements was developed to represent the structural piping system. The lumped masses correspond to the data points which were located at carefully selected locations in order to adequately represent the dynamic behavior of the system, and the beam elements were provided with elastic properties equivalent to the actual elastic properties of the pipe.

The time varying forcing functions, representing the transient thermal-hydraulic forces developed as described in Reference 1, were applied at the locations of direction changes in the piping model (elbows and tees). Location and direction of these forces is schematically illustrated by arrows in Figures A2, A4, A6, A9 and A16 representing forces on MS-01, MS-02, MS-03, MS-04 and MS-Common, respectively. Each of these forces represents the net unbalanced force per pipe segment between two elbows. A positive value indicates a force acting on the pipe in the direction opposite of the steady-state flow (Reference 8).

Bechtel's proprietary program ME-101, References 3 and 4, was used to perform the dynamic time-history analysis. A description of the program features is covered in the User's Manual listed in Appendix F. Finite element modeling procedure allows to write the equations of motions of the system as a finite set of the following simultaneous ordinary differential equations:



CALCULATION SHEET

LAO 0513 B-73

CALC. NO. STP-MS

SIGNATURE MW Jiner DATE 11/10/83

CHECKED F Jol DATE 11/11/83

PROJECT SOUTH TEXAS PROJECT

JOB NO. 14926-001

SUBJECT MSL STEAM HAMMER ANALYSIS

SHEET 7 OF 13 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

$$M\ddot{u}(t) + C\dot{u}(t) + Ku(t) = F(t)$$

where M, C and K are the system mass, damping and stiffness matrices, respectively, and F(t) is the time dependent vector of the externally applied loads. $\ddot{u}(t)$, $\dot{u}(t)$ and u(t) are the structural system time dependent vectors of acceleration, velocity and displacement, respectively. The solution to the above equations is based upon the normal mode superposition method. A description of the procedure of the integration method is presented in Reference 4.



CALCULATION SHEET

LAG 0513 B-73

CALC. NO. STP-MS

SIGNATURE MWigner DATE 11/10/83 CHECKED F Hol DATE 11/11/83
PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 8 OF 13 SHEETS

1
2 4.0 DISCUSSION OF ANALYSIS
3

4 The lumped mass structural model of each main steam line is shown on the
5 following figures:
6

7 MS-01 Figure A1 - Inside Containment
8 MS-02 Figure A3 - Inside Containment
9 MS-03 Figure A5 - Inside Containment
10 MS-04 Figure A7 - Inside Containment
11 MS - Common Figures A9
12 through A15- Outside Containment
13

14 These figures show the piping layout of each system, location of the
15 structural nodes (lumped masses) and location of supports for the piping
16 systems. The integration time step for the time-history analysis was
17 selected to be fine enough to include accurately the structural response
18 to the highest frequency components noted in the load history. For all
19 piping systems inside the containment building, a time step of .001
20 seconds was used, which is considered to be accurate for evaluation of
21 structural modes with maximum frequency of 125 cps. Similarly, for the
22 main steam lines outside the containment building, a time step of .00164
23 second was used which is considered to be accurate for structural modes
24 with maximum frequency of 76 cps. The structural response was analyzed
25 for a minimum duration of 1.7 seconds and 7.5 seconds for piping located
26 inside and outside the containment, respectively.

27
28 Since in all cases the transient shock loads reached a steady-state condi-
29 tion at much earlier time, it was reasonable to expect that no significant
30 excitation of the system could occur after the time period analyzed; and
31 that the structural response has been accurately obtained.
32

33 For all analyses, a critical damping value of two percent was used for all
34 modes of piping system vibration. This is based on the recommendations
35 of Regulatory Guide 1.61 (Reference 6).
36



CALCULATION SHEET

LAG 0513 B-73

CALC. NO. STP-MSSIGNATURE H.W. [Signature] DATE 11/10/83CHECKED Z. [Signature] DATE 11/11/83PROJECT SOUTH TEXAS PROJECTJOB NO. 14926-001SUBJECT MSL STEAM HAMMER ANALYSISSHEET 9 OF 13 SHEETS

5.0 DISCUSSION OF RESULTS

The results of the dynamic structural analysis of the main steam lines are presented in the following appendices:

MS-01 and MS-02	Appendix B
MS-03	Appendix C
MS-04	Appendix D
MS - Common	Appendix E

From the time-history analysis of each main steam line, the maximum pipe displacements, stresses at all nodal points, support and anchor reactions were obtained and are summarized in Tables B.1, C.1, D.1 and E.1 for MS-01 and MS-02, MS-03, MS-04 and MS - Common, respectively.

To facilitate a realistic combination of the containment penetration loads from both sides, the following figures provide the time dependent load plottings for each penetration reactions:

Penetrations M3	Figures B2 through B7 Figures E2 through E7
Penetration M2	Figures B2 through B7 Figures E8 through E13
Penetration M4	Figures C2 through C7 Figures E14 through E19
Penetration M1	Figures D2 through D7 Figures E20 through E25

Caution should be taken in combining the penetration loads because two different global coordinate systems were used in modeling the main steam lines inside and outside the containment building according to drawings provided by the project.

The peak responses of the main steam piping systems are summarized below:



CALCULATION SHEET

LAG 0513 8-73

CALC. NO. STP-MS

SIGNATURE M. Wejner DATE 11/10/83 CHECKED E. J. Jol DATE 11/11/83
PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 10 OF 13 SHEETS

1
2 MS-01 and MS-02

3 Maximum displacement is .0434 inch in the -y direction at data
4 point C02E,

5 Maximum pipe stress is 1860 psi at data point 54,

6 Maximum support reaction is 24,434 lbs at data point 18A
7

8
9 MS-03

10 Maximum displacement is .043 inch in the -y direction at data
11 point C02E,

12 Maximum pipe stress is 1382 psi at data point 1B,

13 Maximum support reaction is 18,445 lbs. at data point 33A.
14

15
16 MS-04

17 Maximum displacement is .0446 inch in the -y direction at data
18 point C02E,

19 Maximum pipe stress is 1444 psi at data point 1B,

20 Maximum support reaction is 20,064 lbs. at data point 33A.
21

22
23 MS - Common

24 Maximum displacement is .831 inch in the -y direction at data
25 point 183,

26 Maximum pipe stress is 7215 psi at data point 940,

27 Maximum support reaction is 58,472 lbs. at data point 938.
28

29
30 The above maximum responses are considered to be within acceptable design
31 limits for the system; however, in order to get a complete evaluation,
32 the results reported herein should be combined with other applicable
33 concurrent loadings being considered for the system in accordance with
34 the South Texas Project PSAR and PSAR.
35
36



CALCULATION SHEET

LAO 0513 B-73

CALC. NO. STP-MS

SIGNATURE MW Zinner DATE 11/10/83 CHECKED J. J. L. DATE 11/11/83
PROJECT SOUTH TEXAS PROJECT JOB NO. 14926-001
SUBJECT MSL STEAM HAMMER ANALYSIS SHEET 11 OF 13 SHEETS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

Some selected response time-history plots of displacements, accelerations and support reactions are presented in Figures B8 through B13 for MS-01 and MS-02, in Figures C8 through C11 for MS-03, in Figures D8 through D14 for MS-04 and in Figures E25 through E29 for MS - Common. They all indicate that the maximum response occurs well within the time duration for which the analysis was performed.

From discussion with mechanical group, the steam hammer transient loads on branch lines from bypass line 24" MS-1013-HC on isometric Nos. 1-R-0004-F and 1-R-0005-L are insignificant during the transient period under consideration. Therefore, those branch lines were not included in the time-history analysis.



CALCULATION SHEET

LAO 0513 B-73

CALC. NO. STP-MSSIGNATURE M. W. J. [Signature] DATE 11/10/83CHECKED J. [Signature] DATE 11/11/83PROJECT SOUTH TEXAS PROJECTJOB NO. 14926-001SUBJECT MSL STEAM HAMMER ANALYSISSHEET 12 OF 13 SHEETS6.0 COMPUTER RUNS LOG

CALCULATION	TYPE OF ANALYSIS	PROGRAM	SNUM NO.	DATE
MS-01 & MS-02 Inside Cont.	Time- History	ME-101	NA 755	10/26/83
MS-01 & MS-02 Inside Cont.	Post Run	ME-101	NA 771	10/27/83
MS-03 Inside Cont.	Time- History	ME-101	NA 756	10/26/83
MS-03 Inside Cont.	Post Run	ME-101	NA 788	10/27/83
MS-04 Inside Cont.	Time- History	ME-101	NA 778	10/27/83
MS-04 Inside Cont.	Post Run	ME-101	NA 794	10/27/83
MS - Common Outside Cont.	Time- History	ME-101	X 7129	11/8/83
MS - Common Outside Cont.	Post Run	ME-101	X 9094	11/9/83



CALCULATION SHEET

LAG 0513 & 73

CALC. NO. STP-MSSIGNATURE MWagner DATE 11/10/83CHECKED F. Holt DATE 11/11/83PROJECT SOUTH TEXAS PROJECTJOB NO. 14926-001SUBJECT MSL STEAM HAMMER ANALYSISSHEET 13 OF 13 SHEETS1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

7.0 REFERENCES

1. Mechanical Discipline, LAPD, "South Texas Project Transient Analysis of Main Steam Line due to Valve Closure" dated October 20, 1983.
2. ASME Boiler and Pressure Vessel Code, Section III.
3. Bechtel User's Manual ME-101 "Linear Elastic Analysis of Piping System", Rev. J4-28, 6/20/83.
4. Theoretical Manual ME-101 "Linear Elastic Analysis of Piping System", Rev. 4, Nov. 1982.
5. U.S. Nuclear Regulatory Commission "Damping Values for Seismic Design of Nuclear Power Plants", Regulatory Guide 1.61, October 1973.
6. South Texas Project "Criteria for Piping Design" 5L019PS004, Rev. 2, dated 5/12/83.
7. South Texas Project "Piping Stress Analysis Criteria" 5L010RQ1002, Rev. 1, dated 9/2/83.
8. Memorandum from K. C. Chiang of Mechanical Group to S. A. Mohamed, dated October 27, 1983.



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. _____

SUBJECT PRESSURE SURGE IN MS DUE TURBINE TRIP

SHEET NO. _____

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
	BYC	6/26/85	vd	6/26					

PURPOSE :

TO CALCULATE PRESSURE SURGE IN MAINSTEAM LINES CAUSED BY STEAM HAMMER DUE TO TURBINE TRIP. (main stop valve closure).

REFERENCE : CALCULATION 55109MC5667, REV 0, "TRANSIENT ANALYSIS OF MAIN STEAM LINE DUE TO VALVE CLOSURE."

CALCULATION :

- MAXIMUM PEAK FORCE IN PIPE IS 38400 LB @ PIPE RUN 16 (REF. FIG 31 ON SHEET 69)

- PIPE OD = 30", t = 1.375", ID = 27.25"
OPERATING PRESSURE = 1100 PSI

- PRESSURE SURGE

$$\Delta P = \frac{F}{A} = \frac{38400}{\frac{\pi}{4} (27.25)^2} = 66 \text{ PSI}$$

- TOTAL (PEAK) PRESSURE

$$P_{\text{PEAK}} = 1100 + 66 = 1166 \text{ PSI}$$

CALCULATION SHEET

CALC. NO. 55109/MC/167

SIGNATURE Chit H. Chen DATE 10-10-83


CHECKED APW DATE 10/26/83

PROJECT STP

JOB NO. 14026-001

SUBJECT Transient Analysis of Main Steam
Line Pipe Valves

SHEET 69 OF 112 SHEETS



△ : Pipe Run No.

Fig. 31 Locations of Pipe Runs and Peak Forces (in Kips) (Part 1)

Note: Forces shown are acting on pipes.

Continued on next sheet



CALCULATION SHEET

LAO 0513 873

CALC. NO. CS109MCC65

SIGNATURE P. H. Chan DATE 10-10-63


CHECKED AW DATE 10/26/63

PROJECT S.T.P.

JOB NO. 14976-001

SUBJECT Transient Analysis of Main Steam Line Duct. Valves etc.

SHEET 70 OF 112 SHEETS



△ : Pipe Run No.

Fig 32 Locations of Pipe Runs and Pres. Forces (in Kips) (Part 1)

Not: Forces shown are acting on pipes

CALCULATION SHEET

CALC. NO. 55109/MC 9667

SIGNATURE Ch. H. Cho. DATE 15-10-83

CHECKED J. Dew DATE 10/26/83

PROJECT STP

JOB NO. 14976-001

SUBJECT Transient Analysis of Main Steam

SHEET 71 OF 112 SHEETS




Fig. 33 Locations of Pipe Runs and Peak Forces (in kips) (Part 1)

Note: Forces shown are acting on pipes

DO NOT SCALE



CALCULATION SHEET

LAO 0512 & 72

CALC. NO. 55109MC5667

SIGNATURE [Signature] DATE 10-11-83


CHECKED [Signature] DATE 10/26/83

PROJECT STP

JOB NO. 14976-001

SUBJECT Transient Analysis of Main steam line to ct. valve


SHEET 72 OF 112 SHEETS



9.34 Locations of Pipe Runs and Link Forces (in kips) (Part 2)

Note: Forces shown are acting on pipes

▽ : Pipe Can No.



STP MAIN STEAM STEAMHAMMER
CASE=1 PIPE RUN NO. 16

LINKU=18 (XRUNU=0.00 FT) LINKD=18 (XRUND=103.00 FT)

CALCULATION SHEET CALC NO. 55 109 MC 5667

SIGNATURE [Signature] DATE 10/22/51 1424/5
PROJECT STP JOB NUMBER 1000000000 SHEET 4 OF 10
SUBJECT Force & Impulse of Steam Hammer

TIME IN MILLISECONDS • 10

FIG. 2A



**SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET**

CALC NO. 14926
SHEET NO. 19

SUBJECT SEE THE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	Keckelstrom	9/17/84	Spencer	10-1-84					

4.8 SUPPORT DATA SUMMARY

* THIS VALUE WAS ESTIMATED PER PRELIMINARY SUPPORT DESIGN CALCULATION.

DATA PT.	DIR	TYPE	SUPT. MARK NO.	CLASS	PIPE SIZE	PIPE SCH.	OPER TEMP	INS. THK	MATERIAL	STIFFNESS	REF.
12A	Z	SNB	N3-1002	HL5016	2	30	80	567	3" SAISI-KCF-70	6.0E5 *	2.24
12A	X	SNB	N3-1002	HL5016						6.0E5 *	2.24
14	SEWED	RAD		-HL5009						1.3E6	2.5
18A	X,Y,Z	SNB		-HL5007						7.8349E5	2.24
18	Y	SPD		-HL5008						-	-
29A	LAT.	RAD		-HL5006						1.3E6	2.5
32A	Y	SNB		-HL5004						4.3832E5	2.24
40A	X	RAD		-HL5003						1.3E6	2.5
41A	Y	SPD		-HL5017						-	
46	X	RAD		-HL5001						1.390348E6	2.24
45	Z	RAD		-HL5002						1.3E6	2.5
										** AA = 1.3E6	2.5
										AB = 1.3E6	
1	ALL	ANC	ST. GEN. NOZLE	-	32	80	567	3"	SAISI-KCF-70	AC = 1.3E6	
										ADA = 1.9E9	
										ADB = 1.9E9	
										ADC = 1.9E9	
										AA = 1.37E7	2.25
										AB = 1.37E7	
60	ALL	ANC	CMT. PEN. M-3	-	30	-	567	3"	SAISI-KCF-70	AC = 1.37E7	
										ADA = 8.32E9	
										ARB = 8.32E9	
										ARC = 8.32E9	

** SEE GENERAL ASSUMPTIONS SHEET # B

HOUSTON OFFICE ISSUED
INFORMATION ONLY
STP 14926



nps Industries, Inc.
an nps group company

NPS INDUSTRIES, INC.
COMPONENT SUPPORT
CERTIFIED DESIGN REPORT SUMMARY

CDRS No. SMY
PAGE 7 OF 9
REV. 0 DATE 8-1-83

Subjects covered by this Certified Design Report Summary are included in S Section
of NPS Industries' Bechtel LEQ-323°F
Comment

Design Level C/D @ 1g side load - snubber size - load in (KIPS) @ 300°F

Size No.	40	70	150	500	1600	5500	12000	
Min. C-C (in)	18-1/2	21-5/16	24-3/8	30-1/8	34-3/8	50-5/16	66-3/16	SMA*
C-C (in)	11-1/8	13-5/16	16-1/8	20-1/4	22-7/8	31-9/16	42-3/16	SMF
10	.53/.6	.93/1.05	1.995/ 2.25					
20	.57/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5	21./24.			
30	.53/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5	21./24.	67.5/ 82.5		
40	.53/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5	21./24.	67.5/ 82.5	163./ 187.5	
50	.53/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5	21./24.	67.5/ 82.5	163./ 187.5	
60	.53/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5	21./23.2	67.5/ 82.5	163./ 187.5	
66	.53/.6	.93/1.05	1.995/ 2.25	6.65/ 7.5			163./ 187.5	
70				6.65/ 7.5	20.8	67.5/ 81.1	163./ 187.5	
80				6.65/ 6.7	17.8	67.5/ 79.2	163./ 187.5	
86				5.70			163./ 187.5	
90					14.7	67.5/ [redacted]	163./ 187.5	
100					12.3	67.5/ 73.8	163./ 187.5	
110						67.5/ 70.9	163./ 187.5	
120						67.2	163./ 187.5	
FOR INFORMATION ONLY								
JOB 14926								
<i>see p. 2</i>								
Max. C-C Length (in)	18-1/2 65	21- /16 66	24-3/8 65	30-1/8 86	34-3/8 100	50-5/16 120	66-3/16 120	SMF SMA

* SMA Min. C-C dimensions are with no adjustment.

FOR INFORMATION ONLY

JOB 14926

8



CALCULATION SHEET

P. O. BOX 2166
HOUSTON, TEXAS 77252-2166

CALC. NO. RC6548-0

SIGNATURE [Signature]

DATE 7-24-84

CHECKED S. Shen

DATE 8/1/84


PROJECT STP

JOB NO. 14926-001

SUBJECT See Calc. Cover Sh.

SHEET 20 OF SHEETS

4.2A Relief Valve Loading



A Steady State: Steady state blowdown loads due to hydraulic forces will be zero. This is a net load neglecting tension resulting from balanced, opposing fluid forces in both legs of the blowdown piping. Loads due to Fluid Friction are also considered negligible due the small lengths of pipe involved and the nature of the fluid itself (steam).

B. Transient: Due to the small lengths of run pipe involved, a pressure wave would travel the length of the longer leg in approximately 3 milliseconds. Since the valve takes considerably longer than this to open, conditions favorable to creation of a transient loading condition do not exist.

These conclusions were reached jointly with the Mechanical Group as reflected by the signature of the Responsible Engineer for the Main Steam System.

V. Starks
R.E.

Date 6-6-84



SOUTH TEXAS PROJECT
 JOB NO. 14926
 CALCULATION COVER SHEET

SHEET 1

CALC. NO. SLC29RC9966

SUBJECT MAIN STEAM SAFETY VALVES - TRANSIENT LOADS & FILE NO. N/A

PISTON - T ASSEMBLY DESIGN CHECK DISCIPLINE PLANT DESIGN / STRESS

RECORD OF ISSUE

REV. NO.	DESCRIPTION	TOTAL NO. OF SHEETS	ORIG	CKR	GL	GS	CHIEF	DATE
0	ISSUED FOR USE COMMITTED DESIGN		NLS	<i>[Signature]</i>	JSS			

- INFORMATION ENTERED IN THIS SPACE:
- SHOW PROFESSIONAL ENGINEER STAMP, IF REQUIRED.
 - ENTER REFERENCE TO INCLUSION OF CHECKER'S ALTERNATE CALCULATIONS, IF USED.
 - PROVIDE ANY NOTES TO ASSIST CHECKING AND APPROVAL.
 - MAY LIST STANDARD COMPUTER PROGRAM (SCP) IDENTIFICATION INCLUDING VERSION AND OPTION USED.

FOR INFORMATION ONLY

JOB 14926



SUBJECT SEE THE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	N. KUMAR	6-25-85	[Signature]	6-26-85					

FOR INFORMATION ONLY

JOB 14926

1. INTRODUCTION:

THE SECONDARY SIDE OF EACH STEAM GENERATOR IS PROVIDED WITH 5 SAFETY VALVES INSTALLED ON EACH MAIN STEAM HEADER. THIS CALCULATION PROVIDES THE TRANSIENT ^{DYNAMIC} FORCES FOR THE VALVE INLET (FV) AND VALVE DISCHARGE (FH).

2. REFERENCES:

- (1) Stress Report
 Dresser 3707R Main Steam Safety Valve SR-370-15
 Bechtel log # 14926-4034-01032-ADI
 Dresser's document # SR-370-15 Rev 0
- (2) Bechtel's "MS" Mainsteam drawing #
 5G 369P-MS-646 Sht 03 Rev 2
- (3) Valve Drawing # Bechtel's log #
 Dresser's No.
- (a) 3N C1012 Sht 4 Rev 9 14926-4034-01004-BDI
- (b) 3N C1012 Sht 6 Rev 8 14926-4034-01006-ADI
- (4) Pipe Line List 5L229P60001 Rev 9
- (5) ANSI B 31.1 - 1973 APPENDIX II, WINTER 1975
 ADDENDA
- (6) THERMODYNAMICS BY Van WYLEN, G. J.
 JOHN WILEY & SONS INC.
- (7) CRANE TECHNICAL PAPER NO. 410



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE THE COVER SHEET

SHEET NO. 3

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	<u>MLK</u>	6-25-85	<u>John L. Am.</u>	6-26-85					

FOR INFORMATION ONLY

3. DESIGN DATA:

JOB 14926

VALVE #	SIZE	SET PRESSURE (REF. 3b) PSIG	FLOW RATE, LBM/HR (REF. 3b)	OPERATING TEMP. °F	REMARK
1	6" N0 (REF. 3b)	1325	1.032845 x 10 ⁶	585 °F	
2	↓	1315	↓	↓	
3	↓	1305	↓	↓	
4	↓	1295	↓	↓	
5	↓	1285	↓	↓	

NOTE:

FORCE ANALYSIS FOR VALVE #1 WILL BE DONE. FORCES OBTAINED FROM THIS ANALYSIS WILL BE USED FOR ALL THE VALVES IN THE MAIN STEAM PIPING STRESS ANALYSIS.

4. FORCE ANALYSIS:

WHEN THE SAFETY VALVE IS BLOWING, A SIGNIFICANTLY LARGE REACTION FORCE (STEADY STATE) "FR" IS ACTING ON THE DISCHARGE PIPE. IN ORDER TO AVOID UNDESIRABLE STRESSES IN THE PIPING AND THE MAIN STEAM HEADER VALVE CONNECTION, THE DESIGN SHOWN ON THE FOLLOWING PAGE IS UTILIZED. THIS DESIGN HELPS TRANSFER THE REACTION FORCE "FR" TO THE SUPPORTING STRUCTURE THRU PISTON.

THE METHODOLOGY USED FOR CALCULATING TRANSIENT FORCES, FH & FV, IS BASED ON SIMPLIFICATION OF THE FLOW PROCESS. FH & FV DO NOT REACH MAXIMUM AT THE SAME TIME. HOWEVER, THEY WILL BE CONSIDERED SIMULTANEOUS IN CHECKING STRESSES ^{AT} THE ~~EX~~ EXTRUSION.




REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NULL	6-25-85	<i>John L. Kelly</i>	6-26-85					

FOR INFORMATION ONLY

JOB 14926

METHODOLOGY

SAFETY VALVES OPEN 70% OF THE VALVE LIFT IN 40 MILLISECOND,
(REF. 1 PAGE # 1 OF 3 OF APPENDIX A).
JUST PRIOR TO VALVE OPENING, THE STEAM FLOW AT POINTS A, B AND C IS ZERO IN THE DIRECTION SHOWN. WHEN THE SAFETY VALVE POPS OPEN, THE FLOW AT THESE THREE POINTS INCREASES GRADUALLY UNTIL STEADY-STATE FLOW IS REACHED. IT SHOULD BE NOTICED, HOWEVER, THAT DURING THE TRANSIENT $\dot{W}_A > \dot{W}_B > \dot{W}_C$. THIS IS OBVIOUSLY DUE TO THE TIME REQUIRED FOR THE STEAM TO TRAVEL FROM A TO B TO C. SINCE FLOW VARIATION WITH TIME IS NOT AVAILABLE, THE FLOW RATE-TIME RELATION IS ASSUMED LINEAR. THIS IS APPLICABLE AT ALL THREE POINTS, NAMELY A, B, & C. THE VARIATION OF FLOW RATE \dot{W} WITH TIME t AT THESE LOCATIONS IS SHOWN BELOW.



\dot{W}_A FLOW RATE AT 'A'
 \dot{W}_B FLOW RATE AT 'B'
 \dot{W}_C FLOW RATE AT 'C'

FIGURE 1

FOR THE INLET PIPE A-B

$$\Delta t_{AB} = \frac{L_{AB}}{V_i}$$

WHERE L_{AB} IS THE DISTANCE BETWEEN A & B. SIMILARLY, FOR THE DISCHARGE PIPE B-C

$$\Delta t_{BC} = \frac{L_{BC}}{V_e^*}$$




FIGURE 2



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966
SHEET NO. 5

SUBJECT SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NK	6-25-85	John A. [unclear]	6-26-85					

WHERE L_{BC} IS THE DISTANCE BETWEEN B & C. V_e^* IS THE SONIC VELOCITY AT THE ORIFICE. IT IS ASSUMED THAT VELOCITY INCREASE DUE TO INCREASED SPECIFIC VOLUME IS MINIMAL. LOWER VELOCITY (V_e^*) WILL GIVE CONSERVATIVE RESULTS.

\dot{W}_A , \dot{W}_B AND \dot{W}_C ARE GIVEN BY THE FOLLOWING:

POINT A $t < 40 - \Delta t_{AB}$ $\dot{W}_A = \frac{t}{40 - \Delta t_{AB}} \dot{W}_m$

$t \geq 40 - \Delta t_{AB}$ $\dot{W}_A = \dot{W}_m$

POINT B $t < 40$ $\dot{W}_B = \frac{t}{40} \dot{W}_m$

$t \geq 40$ $\dot{W}_B = \dot{W}_m$

POINT C $t < 40 + t_{BC}$ $\dot{W}_C = \frac{t}{t_{BC} + 40} \dot{W}_m$

$t \geq 40 + t_{BC}$ $\dot{W}_C = \dot{W}_m$

\dot{W}_m IS THE STEADY STATE FLOW RATE

THE FLOW PROCESS IS SHOWN ON THE MOLLIER DIAGRAM IN FIGURE 3.

THE POINTS 1, 2, 3, 4 & 5 ARE EXPLAINED ON THE NEXT PAGE.




FIGURE-3

FOR INFORMATION ONLY

JOB 14926



SOUTH TEXAS PROJECT
 JOB NO. 14926
 CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE COVER SHEET

SHEET NO. 6

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	MLL	6-25-85	W. H. ...	6-26-85					

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36

POINT 1 : REPRESENTS THE STEAM CONDITION AT THE ENTRANCE OF INLET PIPE

POINT 2 : STEAM CONDITION AT THE VALVE ORIFICE INLET. THE PRESSURE DROP ($P_i - P_i'$) IS DUE TO THE FRICTION LOSSES IN THE INLET PIPE AND THE VALVE PASSAGES. VELOCITY OF STEAM V_i' IS SLIGHTLY LARGER THAN V_i DUE TO INCREASED SPECIFIC VOLUME.

POINT 3 : IS THE STEAM CONDITION DIRECTLY AFTER EXPANSION TAKES PLACE IN THE VALVE THROAT (ORIFICE) WHERE PRESSURE DROPS FROM P_i' TO P_{cr} . THE CRITICAL PRESSURE $P_{cr} = 0.577 P_i'$ FOR SATURATED STEAM (REFERENCE 6 P. 373 EQ 13.48). DUE TO ENTHALPY DROP, THE KINETIC ENERGY INCREASES AND THE VELOCITY AT THIS POINT IS V_e^* .

POINT 4 : REPRESENTS THE STATE OF STEAM DIRECTLY WHEN IT STARTS FLOWING THRU THE DISCHARGE PIPE. NOTE THAT THERE IS NO ENTHALPY DROP. THE PRESSURE DROP FROM P_{en} TO P_e IS DUE TO INCREASE OF FLOW AREA (THROTTLING PROCESS). THE VELOCITY OF STEAM IS CONSTANT AT V_e^* SINCE THE INCREASE IN FLOW AREA IS SUBSTITUTED BY A HIGHER SPECIFIC VOLUME.

POINT 5 : STEAM CONDITION AT DISCHARGE TO THE STACK. SLIGHT PRESSURE DROP ($P_4 - P_5$) DUE TO FRICTION LOSSES IN THE DISCHARGE PIPE AND SLIGHT INCREASE IN VELOCITY DUE TO HIGHER SPECIFIC VOLUME.

FOR INFORMATION ONLY



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966
SHEET NO. 7

SUBJECT SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NB	6-25-85	Michael S.H.	6-26-85					

FOR INFORMATION ONLY
JOB 14926

FORMULAS FOR F_V & F_H

FOR THE INLET PIPE A-B, THE TRANSIENT FORCE F_V AT TIME t IS GIVEN BY THE RELATION

$$F_V = \frac{\dot{W}_A V_A}{g} - \frac{\dot{W}_B V_B}{g} + \Delta P_{AB} A_i \quad \text{---(1)}$$

WHERE THE FIRST AND SECOND TERMS REPRESENT THE CHANGE IN ~~OR~~ MOMENTUM AND THE THIRD TERM IS FRICTION FORCE. THE FORMULA IS BASED ON FORCE EQUILIBRIUM ON A CONTROL VOLUME IN THE INLET PIPE.

$$V_A = V_i = \frac{\dot{W}_A U_i}{A_i}$$

$$V_B = \frac{\dot{W}_B U_i'}{A_i} \approx \frac{\dot{W}_B U_i}{A_i} = \frac{\dot{W}_B V_i}{\dot{W}_A}$$

NOTE THAT IN THE ABOVE EQUATION U_i' IS ASSUMED EQUAL TO U_i . SINCE U_i' IS SLIGHTLY LARGER THAN U_i , THE ABOVE ASSUMPTION RESULTS IN LARGER F_V , SEE EQ. 1.

THE PRESSURE DROP ΔP_{AB} IS GIVEN BY

$$\Delta P_{AB} = \frac{0.00000336 f L_{AB} \dot{W}_A^2 U_i}{d_i^5} \quad \text{(REF. 7)}$$

WHERE f = FRICTION FACTOR

L_{AB} = EQUIVALENT LENGTH OF THE INLET PIPE INCLUDING INLET LOSSES AND VALVE LOSSES.

THE MAXIMUM TRANSIENT FORCE IN THE INLET PIPE A-B, F_V , IS DEVELOPED AT $t = 40 - \Delta t_{AB}$. F_V IS ALWAYS IN THE VERTICAL DOWNWARD DIRECTION.



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE COVER SHEET

SHEET NO. 8

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NLS	6-25-85	Michael J. J.	6-26-85	FOR INFORMATION ONLY				

JOB 14926

FOR THE HORIZONTAL PIPE B-C, THE HORIZONTAL FORCE, F_H , IS CALCULATED ON THE BASIS OF FORCE BALANCE ON CONTROL VOLUME IN THE DISCHARGE PIPE. F_H IS GIVEN BY,

$$F_H = \underbrace{\frac{\dot{W}_B}{g} V_e^* - \frac{\dot{W}_C V_e^*}{g}}_{(1)} + \underbrace{\frac{\dot{W}_B}{\dot{W}_m} P_e A_e - \frac{\dot{W}_C}{\dot{W}_m} P_e A_e}_{(2)} + \underbrace{\Delta P_{bc} A_e}_{(3)} \quad (2)$$

TERMS IN (1) REPRESENT CHANGE IN MOMENTUM

TERMS IN (2) REPRESENT CHANGE IN PRESSURE FORCE

TERM (3) REPRESENT THE FRICTION FORCE

WHERE P_e IS THE EXIT PRESSURE IN THE DISCHARGE PIPE AND IS CALCULATED FROM REF. 5 AND IS GIVEN BY

$$P_e = \frac{\dot{W}_m}{A_e} \frac{(b-1)}{b} \sqrt{\frac{2(h_0 - a)J}{g_c(2b-1)}}$$

\dot{W}_m = ACTUAL MASS FLOW RATE lbm/sec

A_e = EXIT AREA OF DISCHARGE PIPE

h_0 = STAGNATION ENTHALPY AT INLET OF VALVE

J = 778 $\text{ft} \cdot \text{lb}/\text{Btu}$

g = 32.2

$a = 251$ } FUEL WET STEAM FROM REF. 5

$b = 11$ }

$$\Delta P_{bc} = 0.00000336 f \frac{\text{LBC} \dot{W}_B^2 V_e}{d_e^5}$$

V_e IS THE SPECIFIC VOLUME AT EXIT

F_H WILL BE MAXIMUM AT $t = 40$ MILLISECONDS



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966


SHEET NO. 9

SUBJECT SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NW	6-28-85	Mohamed Ali	6-26-85					

SAFETY VALVE & VENT
STACK DETAILS

FOR INFORMATION ONLY
JOB 14926



$P = 11.188''$, $E = 16.062''$

$H = 60.56''$

FORCE IS CALCULATED FOR MAX. SET PRESSURE.

SET PRESSURE $P_s = 1325$ PSIG

INLET PRESSURE TO SAFETY VALVE, P_i

$P_i = 1.03 P_s + P_a = 1.03 \times 1325 + 14.7 = 1379.5$ PSIA

P_i : MAX INLET PRESSURE AT PRESSURE POINT #1

P_s : SET GAUGE PRESSURE, PSIG

3%: ACCUMULATION

P_a : ATMOSPHERIC PRESSURE, PSIA



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC9966

SHEET NO. 10

SUBJECT

SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NBA	6-25-85	M.A. L. S.	6-26-85					

CALCULATION OF FV
SUBSTITUTING FOR V_A, V_B, \dot{W}_B AT $t = 40 - t_{AB}$ IN EQ. 1

$$FV = \frac{\dot{W}_A V_i}{g} - \frac{\dot{W}_B^2 V_i}{g \dot{W}_A} + \Delta P_{AB} A_i$$

$$= \frac{\dot{W}_A V_i}{g} \left(1 - \frac{\dot{W}_B^2}{\dot{W}_A^2} \right) + \Delta P_{AB} A_i$$

$$= \frac{\dot{W}_A V_i}{g} \left(1 - \frac{(40 - t_{AB})^2}{40^2} \right) + \Delta P_{AB} A_i \quad \text{--- (1A)}$$

$$\dot{W}_A = \dot{W}_m \text{ AT } t = 40 - t_{AB}$$

$$\dot{W}_A = \dot{W}_m = 1.11 \times 1.032845 \times 10^6 / 3600 \quad (\text{REF. 5})$$

$$= 318.46 \text{ lbm/SEC}$$

INLET PIPE SIZE

$$ID = 6" \Rightarrow A_i = 28.26 \text{ IN}^2$$

STEAM CONDITION (ASSUMED SATURATED) AT

$$P_i = 1379.5 \text{ PSIA}$$

$$T = 585 \text{ }^\circ\text{F}$$

$$h_i = 1175.2 \text{ Btu/LB}$$

$$v_i = 0.3072 \text{ ft}^3/\text{LB}$$

STEAM VELOCITY AT POINT #1

$$V_i = \frac{\dot{W}_A v_i}{A_i} \times 144 = \frac{318.46 \times 0.3072 \times 144}{28.26}$$

$$= 498.5 \text{ ft/SEC}$$

$$t_{AB} = t_{i2} = \frac{L_{i2}}{V_i} \times \frac{1000}{12} = \frac{33.5 \times 1000}{12 \times 498.5} = 5.6 \text{ MILLI SEC}$$

FOR INFORMATION ONLY

JOB 14926



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE COVER INGET

SHEET NO. 11

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NR	6-25-85	Normand Selt	6-26-85					

FOR INFORMATION ONLY
JOB 14926

CALCULATION OF ΔP_{AB}

AT $P = 1379.5$ PSIA , $T = 585^{\circ}F$

$\mu = 0.047$ CENTIPOSE FROM REF. 7 A-2 .

REYNOLDS NO. , Re ,

$$Re = \frac{6.31 \times \dot{W}_A \times 3600}{d_i \mu} = \frac{6.31 \times 318.46 \times 3600}{6 \times 0.047} = 2.56 \times 10^7$$

$\therefore f = 0.015$ (REF. 7 A-25)

(REF. 7, 3-2)

ENTRANCE LOSSES

$$L_e = (K \times D) / f$$

WHERE $K = 0.44$ ON THE BASIS OF $\frac{d_1}{d_2} = \frac{6}{26.875} = 0.2233$
(REF. 7 A-27)

\swarrow (33.875-7)
= 26.875 FOR
STEAM HEADER

$$L_e = \frac{0.44 \times 6}{12 \times 0.015} = 15 \text{ ft}$$

$$v_1 = 0.3072 \text{ ft}^3/\text{lb}$$

$$L'_{AB} = L_e + \frac{L_{12}}{12} = 15 + \frac{33.5}{12} = 17.79'$$

$$\Delta P_{AB} = \frac{3.36 \times 10^{-6} \times f \times L'_{AB} \times (3600 \dot{W}_A)^2 \times v_1}{d_i^5} \quad (\text{REF. 7 3-2})$$

$$= \frac{3.36 \times 10^{-6} \times 0.015 \times 17.79 \times (3600 \times 318.46)^2 \times 0.3072}{(6)^5}$$

$$= 46.56 \text{ PSI}$$



SOUTH TEXAS PROJECT

JOB NO. 14926

CALCULATION SHEET

CALC NO. RC 9966

SUBJECT

SEE COVER SHEET

SHEET NO. 12

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	MLL	6-25-85	MR. L. G. H.	6-26-85					

$$V_3 = V_e^* = \left[\frac{2gJ(h_0 - a)}{(2b-1)} \right]^{1/2} \quad (\text{REF. 5})$$

$$= \left[\frac{2 \times 32.174 \times 778.16 (1180.16 - 251)}{(22-1)} \right]^{1/2}$$

$$= 1488.46 \text{ ft/sec}$$

V_e^* REMAINS CONSTANT AS EXPLAINED IN POINT 4

ABSOLUTE STATIC PRESSURE AT POINT 4

$$P_4 = \frac{\dot{W}_A}{A_e} \times \frac{b-1}{b} \times \left[\frac{2J(h_0 - a)}{g(2b-1)} \right]^{1/2} \quad (\text{REF. 5})$$

$$= \frac{318.46}{78.54} \times \frac{(11-1)}{11} \times \left[\frac{2 \times 778.16 (1180.16 - 251)}{32.174 (22-1)} \right]^{1/2}$$

$$= 170.53 \text{ PSIA}$$

A_e IS BASED ON DISCHARGE PIPE SIZE OF 10", $t = 0.365$ "

$$P_e = P_4 - 14.7 = 170.53 - 14.7 = 155.83 \text{ PSIG} \quad (\text{REF. 5})$$

CALCULATION OF ΔP_{BC}

AT $P_4 = 170.53 \text{ PSIA}$, AND SATURATED STEAM $T = 368^\circ\text{F}$

$$\mu = 0.0152 \quad (\text{REF. 7 A-2})$$

$$Re = \frac{6.31 \times \dot{W}_A \times 3600}{d_i \mu} = \frac{6.31 \times 318.46 \times 3600}{10.02 \times 0.0152} = 4.75 \times 10^7$$

$$f = 0.014 \quad (\text{REF. 7 A-25})$$

$$U_3 = 2.6738 \text{ ft}^3/\text{lb}$$

FOR INFORMATION ONLY
JOB 14926



REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NU	6-25-85	NU	6-26-85					

USING EQ. 1A, WE GET

$$F_V = \frac{\dot{W}_A V_L}{g} \left(1 - \left(\frac{40 - t_{AB}}{40} \right)^2 \right) + \Delta P_{AB} \times A_i$$

$$= \frac{318.46 \times 498.5}{32.174} \left(1 - \left(\frac{40 - 5.6}{40} \right)^2 \right) + 46.56 \times 28.26$$

$$= 1284.86 + 1315.79$$

$$= 2601 \text{ lbs}$$

FOR INFORMATION ONLY
JOB 14926

USE DLF = 2.0

$$F_{VD} = 2601 \times 2 = \underline{5202 \text{ lbs}}$$

CALCULATION OF F_H

EQ. 2 GIVES THE FORMULA FOR CALCULATING F_H

$$F_H = \frac{\dot{W}_B V_e^*}{g} - \frac{\dot{W}_C V_e^*}{g} + \frac{\dot{W}_B}{\dot{W}_m} P_e A_e - \frac{\dot{W}_C}{\dot{W}_m} P_e A_e + \Delta P_{BC} A_e$$

P_e IS CALCULATED AT POINT 4

V_e^{*} = V₄ SEE EXPLANATION OF POINT 4 STEAM PROPERTIES

F_H IS MAXIMUM AT t = 40 MILLISECONDS

$$\dot{W}_B = \dot{W}_A = \dot{W}_m$$

$$\dot{W}_C = \frac{40}{t_{BC} + 40} \dot{W}_m$$

$$F_H = \frac{\dot{W}_A V_e^*}{g} \left(1 - \frac{40}{t_{BC} + 40} \right) + P_e A_e \left(1 - \frac{\dot{W}_C}{\dot{W}_B} \right) \frac{\dot{W}_B}{\dot{W}_m} + \Delta P_{BC} A_e$$

$$F_H = \left(\frac{t_{BC}}{t_{BC} + 40} \right) \left(\frac{\dot{W}_A V_e^*}{g} + P_e A_e \right) + \Delta P_{BC} A_e - \underline{2A}$$



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT

SEE COVER SHEET

SHEET NO. 14

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	MLL	6-25-85	John L. ...	6-26-85					

$$\Delta P_{45} = \frac{3.36 \times 10^{-6} \times 0.014 \times L_{45} \times (3600 \times 318.46)^2 \times 2.6738}{12 \times (10.02)^5}$$

$\rightarrow = 45.625'$

$$= 6.23 \text{ PSI}$$

$$t_{BC} = t_{45} = \frac{L_{45} \times 1000}{12 \times V_e} = \frac{45.625}{12} \times \frac{1000}{1488.46}$$

$$t_{45} = 2.55 \text{ MILLISEC ONDS}$$

SUBSTITUTING IN EQ. 2A

$$F_H = \left(\frac{2.55}{2.55 + 40} \right) \left(\frac{318.46 \times 1488.46}{32.174} + 155.83 \times 78.54 \right) + 6.23 \times 78.54$$

$$= 2105.7 \text{ lbs}$$

ASSUMING DLF = 2.0

$$F_{HD} = 2105.7 \times 2 = \underline{4211 \text{ lbs}}$$

$$F_{VD} = \underline{5202 \text{ lbs}}$$

FOR INFORMATION ONLY
JOB 14926



SOUTH TEXAS PROJECT
 JOB NO. 14926
 CALCULATION SHEET



CALC NO. RC 9966
 SHEET NO. 15

SUBJECT SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	Jim Skiles	6-25-85	Michael Skiles	6-26-85					

CALCULATIONS FOR PISTON-T ASSEMBLY

FOR INFORMATION ONLY
 JOB 14926





SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE COVER SHEET

SHEET NO. 16

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	Am Stuh	6-25-85	Not a L.H.	6-26-85					

STRESS CHECK FOR PISTON

$FR = 27813 \text{ LBS}$


1. COMPRESSIVE STRESS IN THE PISTON

$$\begin{aligned} \text{COMPRESSIVE AREA} &= (9.92 - 12 \times \frac{1}{8}) \times 1" + \\ & \quad (9.92 - 2 \times \frac{1}{2} - 1) \times 1" \\ &= 9.67 + 8.67 \\ &= 18.34 \text{ IN}^2 \end{aligned}$$

$$\begin{aligned} \text{COMPRESSIVE STRESS} &= \frac{27813}{18.34} = 1516.5 \text{ PSI} \\ &= 1517 \text{ PSI} < 18860 \text{ PSI OK} \\ & \quad (\text{SEE SHT. 4}) \end{aligned}$$

2. SHEAR STRESSES IN THE STACK BOTTOM PLATE

SHEAR AREA FOR 1" THICK STACK BOTTOM PLATE



$$\begin{aligned} &= (1+1+1) \times 1 + (8.67 \times 4) \times 1 \\ &= 38.68 \text{ IN}^2 \end{aligned}$$

$$\text{SHEAR STRESS} = \frac{27813}{38.68}$$

FOR INFORMATION ONLY = 719 PSI < 0.45Y = 13120 PSI

JOB 14926

O.K.



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET


CALC NO. RC9966

SUBJECT SEE COVER SHEET

SHEET NO. 17

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	JN Patrino	6.25.85	Richard H	6.26.85					

FOR INFORMATION ONLY
JOB 14926



$$I_{xx} = \frac{(1)(9.67)^3}{12} + \frac{2 \times 4.34(1)^3}{12}$$

$$= 75 + 0.72 = 75.72 \text{ in}^4$$

$$I_{yy} = \frac{(1)(4.34)^3 \times 2}{12} + 1 \times 4.34 \times \left(\frac{4.34}{2} + 0.5\right)^2 \times 2 + (9.67) \frac{(1)^3}{12}$$

$$= (13.6 + 61.87 + 0.81) = 76.28 \text{ in}^4$$

$$\therefore r_{xx} = r_{yy} = \sqrt{\frac{I}{A}} = \sqrt{\frac{75.72}{18.34}} = 2.03$$

Length of composite section = $(8 - \frac{1}{2}) = 6.5$
Assume section as cantilever

(For Fig. see detail
1 sht. 15)

$$\therefore K = 2.1$$

$$\therefore \frac{KL}{r_{xx}} = \frac{KL}{r_{yy}} = \frac{2.1 \times 6.5}{2.03} = 6.72$$



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC 9966

SUBJECT SEE COVER SHEET

SHEET NO. 18

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	JN PASTIGA	6-25-85	ALLBY	6-26-85					

Assumed A-36 Material

FOR INFORMATION ONLY

JOB 14926

Assume 310°F

for $KL/r = 6.72$

$$F_{a, \text{allow.}} = 18.86 \text{ KSI} >> 1.52 \text{ KSI}$$

CHECK $\frac{2}{3}$ CRITICAL BUCKLING

$$F_{a,cr} = \frac{2}{3} \left[1 - \frac{(KL/r)^2}{2 C_c^2} \right] F_y = \frac{2}{3} \left[1 - \frac{(6.72)^2}{2 \times (130.3)^2} \right] \times 31.8$$

$$= \frac{2}{3} [1 - .0013] \times 31.8 = 21.09 > 1.52 \text{ KSI}$$

$$C_c = \sqrt{\frac{2 \pi^2 E}{F_y}} = \left(\frac{2 \times 9.14^2 \times 27360}{31.8} \right)^{\frac{1}{2}} = 130.3$$

WELD DESIGN.

(FOR FIG. SEE DETAIL)
1 SH. 15


weld between $\frac{1}{2}$ " Horizontal PL & Vertical $\frac{1}{2}$ " PL

Force $F_R = 27813 \text{ lbs}$

Length of weld = $8 \times 4.34 = 34.72$

\therefore force per inch = $\frac{27.82}{34.72} = 0.8 \text{ K/in}$

\therefore w size reqd = $\frac{0.8}{.4 \times 31.8} = 0.063$ "





SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC9966

SHEET NO. 19

SUBJECT SEE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
0	NLP/INP	6-25-85	M.H. 2/11	6-26-85					

1
2
3
4
5
6
7

$$w \text{ size reqd} = \frac{0.8}{.707 \times 21} = 0.053''$$

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29


USE $5/16''$ fillet min. reqd per AISC.

Weld between 1" vertical PL

length of weld = $4 \times 6 = 24''$

Force transferred through this weld = $\frac{27.8}{2} = 13.9^k$

$\therefore \text{force} / \parallel = \frac{13.9}{4 \times 6} = 0.58$ ^{← / ||}
 No of welds ↑ ← length of weld.



$\therefore w \text{ size reqd} = \frac{0.58}{.707 \times 21} = 0.04''$

OR

$\frac{0.58}{.4 \times 31.8} = 0.05''$ governs

Use $1/4''$ fillet weld

CONCLUSIONS:

- 30
31
32
33
34
35
36
37
1. THE STACK DESIGN IS SIZED CORRECTLY
 2. FHD & FVD SHOULD BE CONSIDERED SIMULTANEOUSLY IN CALCULATIONS FOR MAIN STEAM HEADER

FOR INFORMATION ONLY



SEISMIC ANALYSIS REPORT

Load	Specified Load			Load Used in Calculation		
	Running	OBE	DBE	Running	OBE	DBE
Design Pressure						
Gland Pressure						
Test Pressure						
Design Temp.						
Q-Rated						
Q-BEP						
Suction Pressure						
TDH						
BHP						
RPM						
Pump Weight						
Base Weight						
Motor Weight						
Class						

DISTRIBUTION TO	FOR RE	A	INFO
<input type="checkbox"/> MECHANICAL	_____	_____	_____
<input type="checkbox"/> BALANCE OF PLANT	_____	_____	_____
<input type="checkbox"/> BOILER/NESS	_____	_____	X
<input type="checkbox"/> PLANT UTILITIES	_____	_____	_____
<input type="checkbox"/> PLANT DESIGN	_____	_____	_____
<input type="checkbox"/> CONTROL SYSTEMS	_____	_____	_____
<input type="checkbox"/> ELECTRICAL	_____	_____	_____
<input type="checkbox"/> WIRING	_____	_____	_____
<input type="checkbox"/> CONDUIT	_____	_____	_____
<input type="checkbox"/> MOB	_____	_____	_____
<input type="checkbox"/> PAINTING & COATINGS	_____	_____	_____
<input type="checkbox"/> CIVIL/STRUCTURAL	_____	_____	_____
<input type="checkbox"/> NUCLEAR	_____	_____	_____
<input type="checkbox"/> STRESS	_____	_____	_____
<input type="checkbox"/> ARCHITECTURAL	_____	_____	_____
<input type="checkbox"/> STARTUP	_____	_____	_____
<input type="checkbox"/> CONSTRUCTION	_____	_____	_____
<input type="checkbox"/> NOT REQ'D BY ENGRG	_____	_____	_____
<input type="checkbox"/> CLIENT	_____	_____	_____
IDENTIFYING TITLE OF THIS DOCUMENT			

PKG.# 1634

4022-01055-AHT
 Batched Log No
 14926-2022-01055-AHT

IMPORTANT Permission to proceed does not constitute acceptance or approval of design details, calculations, analysis methods or materials developed or selected by the supplier and does not relieve supplier from full compliance with contractual obligations.	
DATE RECEIVED 5-14-82	Signed  Date 4/29/82
DOCUMENT STATUS 1 <input checked="" type="checkbox"/> WORK MAY PROCEED. 2 <input type="checkbox"/> REVISE AND RESUBMIT WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES INDICATED. 3 <input type="checkbox"/> REVISE AND RESUBMIT. WORK MAY NOT PROCEED 4 <input type="checkbox"/> REVIEW NOT REQUIRED WORK MAY PROCEED INFORMATION ONLY <input type="checkbox"/> DISTRIBUTION REQ'D	 H09601213/781

Hydramatic Pump Company

HYDROSTATIC TEST CERTIFICATE

R209XR.241AHT
HT-BR-1051

HTC-1

EQUIPMENT/ASSEMBLY <i>Casing Assembly</i>		CONTRACT <i>2-0173-86.1</i>
PROJECT NAME <i>18x20x26 NHDJ</i>	SERIAL NUMBER <i>8041-01</i>	DATE <i>3/2/78</i>
CUSTOMER P.O.	PART NUMBER <i>01-500-021</i>	TEST PROCEDURE <i>2.3.7/3-1 Rev 4</i>
		DATE <i>2/3/77</i>

ITEM	PARTS INCLUDED	PART NUMBER	BATCH/SERIAL
<i>Casing Assy</i>	<i>upper & lower</i>	<i>01-500-021</i>	<i>E979-001. E979-002</i>
<i>Gland</i>	<i>Gland</i>	<i>20-151133</i>	<i>E871-002 E875-002</i>
<i>Tubing</i>	<i>seal flush tubing</i>	<i>01-500-04</i>	<i>G071</i>

START TIME <i>10:05 AM</i>	FINISH TIME <i>10:35 AM</i>	DURATION <i>30 MIN</i> MIN.
TEST MEDIUM <i>Cold WATER</i>	TEMPERATURE <i>45 DEGREES F</i>	TEST PRESSURE <i>232</i> PSIG
GAUGE NO. <i>HTS 21-011</i>	RANGE <i>0-400</i>	CALIBRATED BY <i>3/2/78 RP</i>

DEVIATIONS NOTED DURING TEST
NONE

Received by STP RMS	<i>5-14-82</i> DATE
at Revision	<i>20</i> RMS

Q.A.
22

TEST ACCEPTANCE OF THE ABOVE PARTS TO THE ABOVE PROCEDURE

APPROVED BY <i>[Signature]</i>	DATE <i>3/2/78</i>	CUSTOMER	DATE
OPERATOR <i>[Signature]</i>	DATE <i>3/2/78</i>	INSPECTOR <i>[Signature]</i>	DATE <i>3/2/78</i>

14926-4022-01055 AHT
14926-8022-01055 AHT TURNOVER

R209XR.241AHT

Maximum AllowableNozzle Loads

Nozzle	Conditions	Force (lbs.)			Moment (ft.-lb.)		
		Fx	Fy	Fz	Mx	My	Mz
Suction	Normal	8000	8000	8000	20,000	20,000	20,000
Discharge	Normal	6500	6500	6500	16,000	16,000	16,000
Suction	Faulted	10,000	10,000	10,000	25,000	25,000	25,000
Discharge	Faulted	8000	8000	8000	20,000	20,000	20,000

PUMP SUCTION

SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION COVER SHEET

SHEET 1



CALC. NO. 5R209RCC034

SUBJECT STRESS ANALYSIS FOR COMPONENT COOLING WATER SYSTEM
FROM ANCHOR CH-1020-11,5002 TO PENET M-26, M-34 AND FILE NO. N/A
CCW PUMPA, FROM 30" CC-1435 HEADER TO CCW PUMP 1B & 1C, AND
PENET M-28, M-29, M-30 & M-28 DISCIPLINE PSSG

RECORD OF ISSUE

REV. NO.	DESCRIPTION	TOTAL NO. OF SHEETS	ORIG	CKR	GL	GS	CHIEF	DATE
0	COMMITTED CALC. ISSUED FOR USE		SEE	MICRO	FICHE		N/A	
1	COMMITTED CALC. REVISED DUE TO RELOCATION OF SUPPORTS	311		G.Z.	JSS	gxp	N/A	6/14/85
							N/A	

- INFORMATION ENTERED IN THIS SPACE:
- SHOW PROFESSIONAL ENGINEER STAMP, IF REQUIRED.
 - ENTER REFERENCE TO INCLUSION OF CHECKER'S ALTERNATE CALCULATIONS, IF USED.
 - PROVIDE ANY NOTES TO ASSIST CHECKING AND APPROVAL
 - MAY LIST STANDARD COMPUTER PROGRAM (SCP) IDENTIFICATION INCLUDING VERSION AND OPTION USED.

This calculation is for Unit 1; Unit 2; Units 1 & 2

ME 101 Version: K2
 Date Released: March 21, 1985
 SNUM Nos.: VX060 , VX153B
 Date of Run: 5/25/85 , 5/25/85



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-0034

SUBJECT SEE THE COVER SHEET

SHEET NO. 100

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>J. J. King</i>	5/29/85	G.Z.	6/13/85					

5.2 Nozzle Load Summary


EQUIPMENT/TPNS # CCW PUMP 1A (3R20INPA101A)
SUCTION

PIPE SIZE & NOZZLE DESCRIPTION 20"

REFERENCE FOR NOZZLE ALLOWABLES 3R209NS011-D

DATA POINT 295 MEETS THE ALLOWABLE (YES/NO) -

CAD/FAB ISO NO. 5MB69PCC207 LINE NO. 20"CC-1110-WAB



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)			
	Fa	Fb	Fc	Fv or Fr	Ma	Mb	Mc	Ma or Mr
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING	
NORMAL (P)								
NORMAL (N)								
UPSET (P)								
UPSET (N)								
FAULTED (P)								
FAULTED (N)								
NORMAL	CALC.	419	2681	1954		2135	5216	7451
	ALLOW	8000	8000	8000		20,000	20,000	20,000
UPSET	CALC.							
	ALLOW				N/A			
FAULTED	CALC.	3709	7240	7014		9244	15249	18861
	ALLOW	10,000	10,000	10,000		25,000	25,000	25,000
	CALC.							
	ALLOW							

NOTES:

1. Fv = SRSS of two shear components
Mb = SRSS of two bending components
2. Fr = SRSS of all three force components
Mr = SRSS of all three moment components
3. Local 'a' is towards GLOBAL - X (NORTH)
4. NORMAL AND FAULTED LOAD COMBINATIONS
SEE NEXT PAGE



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-0034

SHEET NO. 101

SUBJECT SEE THE COVER SHEET

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	Sp. Cheng Feng	5/28/85	G.Z.	6/13/85					

5.2 NOZZLE LOAD SUMMARY (CONT'D)

DATA POINT : 295

LOAD CASE	FORCES (LB)			MOMENTS (FT-LB)		
	F _a	F _b	F _c	M _a	M _b	M _c
	AXIAL	SHEAR	SHEAR	TORSION	BENDING	BENDING
WEIGHT	67	-619	-295	-270	831	18
THRM1	93	-2041	-1164	-1117	3562	-7124
THRM2	344	292	385	2234	2831	-633
THRM3	327	95	457	2085	2402	-1167
THRM4	89	-1829	-1659	-1677	4385	-6845
THRM5	66	-2062	-1577	-1865	3868	-7469
THRM6	352	366	355	2266	2967	-446
NORMAL	419	2681	1954	2135	5216	7451
THRM7	-4	-2526	-2840	-3605	5744	-9231
MRS2 (S.S.E)*	3290	4095	3879	5369	8674	9648
SAM2 (S.S.E)	1	7	5	7	4	16
FAULTED	3709	7240	7014	9244	15249	18861

NOTE : 1. NORMAL = THERMAL + WEIGHT

2. FAULTED = THERMAL + WEIGHT + $[(S.S.E)^2 + SAM2(S.S.E)^2]^{1/2}$

* FROM ME101 RUN# VX153B, DATED 5/25/85



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-0034

SUBJECT SEE THE COVER SHEET

SHEET NO. 102

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>J. J. [unclear]</i>	5/28/85	G.Z.	6/13/85					

5.2 Nozzle Load Summary


EQUIPMENT/TPNS # CCW PUMP 1B (3R20INPA101B)
SUCTION

PIPE SIZE & NOZZLE DESCRIPTION 20"

REFERENCE FOR NOZZLE ALLOWABLES 3R209NS011-D

DATA POINT 435 MEETS THE ALLOWABLE (YES/NO)

CAD/FAB ISO NO. EMB69 PCC 207 LINE NO. 20"CC-1210-WA3
SHT. 22 REV. 4



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)			
	Fa	Fb	Fc	Fv or Fr	Ma	Mb	Mc	Ma or Mr
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING	
NORMAL (P)								
NORMAL (N)								
UPSET (P)								
UPSET (N)								
FAULTED (P)								
FAULTED (N)								
NORMAL	CALC.	925	2092	3075		2082	10550	2652
	ALLOW	8000	8000	8000		20000	20000	20000
UPSET	CALC.							
	ALLOW				N/A			
FAULTED	CALC.	3951	5773	9073		8113	23633	9135
	ALLOW	10000	10000	10000		25000	25000	25000
	CALC.							
	ALLOW							

NOTES:

1. Fv = SRSS of two shear components
M_B = SRSS of two bending components
2. Fr = SRSS of all three force components
Mr = SRSS of all three moment components
3. Local 'a' is towards GLOBAL -X (NORTH)
4. NORMAL AND FAULTED LOAD COMBINATIONS
SEE NEXT PAGE



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-0034

SHEET NO. 103

SUBJECT SEE THE COVER SHEET

J.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>J. Cheng Feig</i>	<i>5/28/85</i>	<i>G.Z.</i>	<i>4/13/85</i>					

5.2. NOZZLE LOAD SUMMARY (CONT'D)

DATA POINT = 435

LOAD CASE	FORCES (LB)			MOMENTS (FT-LB)		
	F _a	F _b	F _c	M _a	M _b	M _c
	AXIAL	SHEAR	SHEAR	TORSION	BENDING	BENDING
WEIGHT	99	16	-527	-729	1016	1473
THRM1	-652	220	96	1910	3481	994
THRM2	-928	-2108	-2069	-918	7671	-3915
THRM3	-505	161	48	1413	2802	749
THRM4	-1024	-1495	-2488	-729	9534	-2407
THRM5	-647	301	81	2008	3625	1179
THRM6	-841	-1565	-2548	-1353	8681	-2706
NORMAL	925	2092	3075	2082	10550	2652
THRM7	-1142	-1806	-3812	-1779	12933	-2917
MRS2 (S.S.E) *	2908	3681	4734	5605	9684	7691
SAM2 (S.S.E)	8	18	31	30	59	35
FAULTED	3951	5773	9073	8113	23633	9135

NOTE: 1. NORMAL = THERMAL + WEIGHT

2. FAULTED = THERMAL + WEIGHT + [(S.S.E)² + SAM2(S.S.E)²]^{1/2}

* FROM ME101 RUN# VX153B, DATED 5/25/85



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-0034

SUBJECT SEE THE COVER SHEET

SHEET NO. 104

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>J. Cheng</i>	<i>5/28/85</i>	<i>G.Z.</i>	<i>6/13/85</i>					

5.2 Nozzle Load Summary


EQUIPMENT/TPNS # CCW PUMP IIC (3R20INPA10IC)
SUCTION

PIPE SIZE & NOZZLE DESCRIPTION 20"

REFERENCE FOR NOZZLE ALLOWABLES 3R209NS011-D

DATA POINT 750 MEETS THE ALLOWABLE (YES/NO)

CAD/FAB ISO NO. EM365PCC207 LINE NO. 20"CC-1310-WA3
CHT. 01 REV. 2



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)			
	Fa	Fb	Fc	Fv or Fr	Ma	Mb	Mc	Ma or Mr
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING	
NORMAL (P)								
NORMAL (N)								
UPSET (P)								
UPSET (N)								
FAULTED (P)								
FAULTED (N)								
NORMAL	CALC.	501	3762	1930		2361	4728	6599
	ALLOW	8000	8000	8000		20000	20000	20000
UPSET	CALC.							
	ALLOW				N/A			
FAULTED	CALC.	4544	9825	5660		7252	14652	20089
	ALLOW	10000	10000	10000		25000	25000	25000
	CALC.							
	ALLOW							

NOTES:

1. Fv = SRSS of two shear components
M_B = SRSS of two bending components
2. Fr = SRSS of all three force components
Mr = SRSS of all three moment components
3. Local 'a' is towards GLOBAL -X (NORTH)
4. NORMAL, AND FAULTED LOAD COMBINATIONS
SEE NEXT PAGES



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RF-0034

SUBJECT SEE THE COVER SHEET

SHEET NO. 105

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>Jim Chang Fung</i>	5/28/85	G.Z.	6/3/85					

5.2 NOZZLE LOAD SUMMARY (CONT'D)

DATA POINT : 750

LOAD CASE	FORCES (LB)			MOMENTS (FT-LB)		
	F _a	F _b	F _c	M _a	M _b	M _c
	AXIAL	SHEAR	SHEAR	TORSION	BENDING	BENDING
WEIGHT	103	-87	-623	-758	1372	1230
THRM1	-147	399	-233	142	1293	1109
THRM2	-62	514	-309	-88	1057	1278
THRM3	-542	-3675	-1131	-1523	2647	-7829
THRM4	-152	629	-315	261	1660	1658
THRM5	-604	-3661	-1217	-1313	3356	-7699
THRM6	-498	-3528	-1307	-1603	3046	-7512
NORMAL	501	3762	1930	2361	4728	6599
THRM7	-715	-4795	-1994	-2021	5129	-10115
MRS2 (S.S.E) *	3932	4943	3043	4473	8151	11203
SAM2 (S.S.E)	15	52	18	18	58	130
FAULTED	4544	9825	5660	7252	14652	20089

NOTE: 1. NORMAL = THERMAL + WEIGHT

2. FAULTED = THERMAL + WEIGHT + [(S.S.E)² + SAM2 (S.S.E)²]^{1/2}

* FROM ME101 RUN# VX1538, DATED 5/25/85

PUMP DISCHARGE

SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION COVER SHEET

SHEET 1

CALC. NO. 3R209RC0035

SUBJECT STRESS ANALYSIS OF COMPONENT COOLING WATER FILE NO. N/A
FROM 30" HEADER TO HEAT EXCHANGER IA IB IC & PUMPS IA, IB & IC DISCIPLINE PSSG

RECORD OF ISSUE								
REV. NO.	DESCRIPTION	TOTAL NO. OF SHEETS	ORIG	CKR	GL	GS	CHIEF	DATE
0	COMMITTED CALC. ISSUED FOR USE		SEE	MICROFICHE			N/A	
1	COMMITTED CALC. REANALYSED DUE TO RELOCATION OF SUPPORTS	200	<i>Wade</i>	<i>Wade</i>	G.Z. <i>MR</i>	<i>MR</i>	N/A	3/15/85
2	COMMITTED CALC. SHEETS 54 THRU 58 REVISED	200	<i>Wade</i>	G.Z.	<i>MR</i>	<i>MR</i>	N/A	5/10/85

- INFORMATION ENTERED IN THIS SPACE:
- SHOW PROFESSIONAL ENGINEER STAMP, IF REQUIRED.
 - ENTER REFERENCE TO INCLUSION OF CHECKER'S ALTERNATE CALCULATIONS, IF USED.
 - PROVIDE ANY NOTES TO ASSIST CHECKING AND APPROVAL.
 - MAY LIST STANDARD COMPUTER PROGRAM (SCP) IDENTIFICATION INCLUDING VERSION AND OPTION USED.

This calculation is for Unit 1; Unit 2; Units 1 & 2

ME 101 Version: K1**

Date Released: April 15, 1984

SNUM Nos.: VX 661 & VX 663

Date of Run: 2/14/85 & 2/15/85 RESPY.

** Version K1 was loaded on Univac System B on July 10, 1984



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-035

SUBJECT SEE THE COVER SHEET

SHEET NO. 48

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>J.S.P.2</i>	2/21/85	<i>McGee</i>	2/15/85					

5.2 Nozzle Load Summary


EQUIPMENT/TPNS # 3R201NPA101A/R209X001EHT

PIPE SIZE & NOZZLE DESCRIPTION 18" PUMP DISCHARGE

REFERENCE FOR NOZZLE ALLOWABLES 3R209NS011-D

DATA POINT 910 MEETS THE ALLOWABLE (YES/NO) (YES)

CAD/FAB ISO NO. 5M369PCC2075H.10 LINE NO. 18"-CC-1101-WA3



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)			
	Fa	Fb	Fc	Fv or F _r	M _a	M _b	M _c	M _a or M _r
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING	
NORMAL (P)	51	0	690		1677	0	250	
NORMAL (N)	83	2480	0		815	3849	2751	
UPSET (P)	1359	1659	2644		4567	3635	5762	
UPSET (N)	1392	4772	1905		3705	9038	8264	
FAULTED (P)	1914	2299	3232		5873	5697	7439	
FAULTED (N)	1947	5412	2494		5011	11099	9941	
NORMAL	CALC.	83	2480	690	1677	3849	2751	
	ALLOW	6500	6500	6500	16000	16000	16000	
UPSET	CALC.							
	ALLOW							
FAULTED	CALC.	1947	5412	3232	5873	11099	9941	
	ALLOW	8000	8000	8000	20000	20000	20000	
	CALC.							
	ALLOW							

NOTES:

1. F_v = SRSS of two shear components
M_b = SRSS of two bending components
2. F_r = SRSS of all three force components
M_r = SRSS of all three moment components
3. Local 'a' is towards GLOBAL X



**SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET**

CALC NO. RC-035

SUBJECT SEE THE COVER SHEET

SHEET NO. 49

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	<i>A.P.M.</i>	2/21/85	<i>McDesm</i>	3/15/85					

5.2 Nozzle Load Summary


EQUIPMENT/TPNS # 3R201NPA101B/R209X001EHT

PIPE SIZE & NOZZLE DESCRIPTION 18" PUMP DISCHARGE

REFERENCE FOR NOZZLE ALLOWABLES 3R209NS011-D

DATA POINT 645 MEETS THE ALLOWABLE (YES/NO) (YES)

CAD/FAB ISO NO. 3M369PCC2075M13LINE NO. 18"-CC-1201-WA9



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)				
	Fa	Fb	Fc	Fv or F _r	Ma	Mb	Mc	M _a or M _r	
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING		
NORMAL (P)	15	0	1339		7954	0	371		
NORMAL (N)	114	3100	0		0	285	5685		
UPSET (P)	1618	2018	3057		10608	4602	5007		
UPSET (N)	1717	5471	1640		2575	5041	10321		
FAULTED (P)	1931	2527	3529		11445	5998	6191		
FAULTED (N)	2029	5979	2111		3412	6437	11505		
NORMAL	CALC.	114	3100	1339		7954	285	5685	
	ALLOW	6500	6500	6500		16000	16000	16000	
UPSET	CALC.								
	ALLOW								
FAULTED	CALC.	2029	5979	3529		11445	6437	11505	
	ALLOW	8000	8000	8000		20000	20000	20000	
	CALC.								
	ALLOW								

NOTES:

- F_v = SRSS of two shear components
M_B = SRSS of two bending components
- F_r = SRSS of all three force components
M_r = SRSS of all three moment components
- Local 'a' is towards GLOBAL X



SOUTH TEXAS PROJECT
JOB NO. 14926
CALCULATION SHEET

CALC NO. RC-035


SUBJECT SEE THE COVER SHEET

SHEET NO. 50

REV.	ORIGINATOR	DATE	CHECKER	DATE	REV.	ORIGINATOR	DATE	CHECKER	DATE
1	A.S. Perz	2/21/85	mcderau	3/15/85					

5.2 Nozzle Load Summary

EQUIPMENT/TPNS # 3R201 NPA 101C / R209 X001 EHT
 PIPE SIZE & NOZZLE DESCRIPTION 18" PUMP DISCHARGE
 REFERENCE FOR NOZZLE ALLOWABLES 3R209 NS011-D
 DATA POINT 410 MEETS THE ALLOWABLE (YES/NO) (YES)
 CAD/FAB ISO NO. 4M369PCC207 SH.9 LINE NO. 18" CC-1301-WA3



LOAD CASE	FORCES (LB)				MOMENTS (FT-LB)			
	Fa	Fb	Fc	Fv or Fr	Ma	Mb	Mc	Ma or Mr
	AXIAL	SHEAR	SHEAR		TORSION	BENDING	BENDING	
NORMAL (P)	45	0	870		4582	576	300	
NORMAL (N)	0	1623	0		0	469	2808	
UPSET (P)	1076	2407	1825		6098	2921	6366	
UPSET (N)	998	4395	823		1450	2814	8873	
FAULTED (P)	1419	3237	2230		6624	4079	8192	
FAULTED (N)	1341	5225	1228		1976	3972	10700	
NORMAL	CALC.	45	1623	870		4582	576	2808
	ALLOW	6500	6500	6500		16000	16000	16000
UPSET	CALC.							
	ALLOW							
FAULTED	CALC.	1419	5225	2230		6624	4079	10700
	ALLOW	8000	8000	8000		20000	20000	20000
	CALC.							
	ALLOW							

NOTES:

- Fv = SRSS of two shear components
 M_b = SRSS of two bending components
- Fr = SRSS of all three force components
 Mr = SRSS of all three moment components
- Local 'a' is towards GLOBAL X

June 26, 1985
~~June 25, 1985~~

TO: Bill Guerin, Licensing

REF: Conversation with Mr. E. Rodabaugh on 6/25/85 regarding faulted stresses in the TGX RCP casing suction nozzle, Table I of E.M. 5003, Rev. 1.

REPLY: We repeated the calculation performed by Mr. Rodabaugh and have resolved the difficulty as follows:

1. E.M. 5003, Rev. 1, Table VII, does not contain the footnote (2) on safe-end evaluation found in Table V of Interim Rev. 2 to G-952342-2, Rev. 2, which defines the nozzle loads. This was not clearly defined in the report, which has the effect of eliminating the pipe rupture cases (labeled "a" and "b" in Table VII) from consideration at the safe-end. Therefore, the stresses reported in Table I of E.M. 5003, Rev. 1, do not include any contribution from the safe-end Elements 1 and 2 for rupture cases "a" and "b." *The footnote discussed above will be added to EM 5003 in a subsequent revision*
2. The reported 33,000 psi stresses in E.M. 5003, Rev. 1, are generated from the remaining case "a" blowdown. We generated, manually, for Element 1, the same values generated by the computer after 1) combining the applied moments and forces per the rules of specifications (or Table V of E.M. 5003, Rev. 1) and 2) calculating tensile and shear stresses. We used the 3099 in.³ section modulus obtained by treating the nozzle safe-end (Element 1) as a simple pipe. Combining all the tensiles and shears, the loading generates, approximately, a 29,000 psi stress intensity. The reported 33,000 value is obtained by combining casing hoop stresses (generated by pressure in the casing) with the shear stress due to loading on the nozzle.

Our conclusion is that there is nothing wrong with the reported values. Admittedly, the report is unclear on the treatment of the safe-end of the nozzle. We trust that this explanation will be sufficient at this time.

I can be reached at 412/963-5565 if there are any questions.

Bill Guerin
Bill Guerin

WESTINGHOUSE ELECTRO-MECHANICAL DIVISION
MOTOR OPERATED GATE VALVE TEST REPORT

SHEET 1 OF 1
PAGE 1

WEMD VALVE ID 08000GM24FE80D005W750001
CUSTOMER IDENTIFICATION VALVE F.V. B-6474FCA
ASME PRESSURE CLASS 316 DESIGN PRESSURE 600 PSI AT 400°F
VALVE SIZE 8 INCHES SHOP ORDER H048 ASME CLASS I
MOTOR OP MFG. LIMITREVE MODEL 5B NO. 246634
TESTED IN ACCORDANCE WITH TEST SPECIFICATION 75099 REV. H

TEST INSTRUCTIONS PER: ROUTING
 VTP NO. 10 REV. _____

HYDROSTATIC
SHELL TEST

TEST GAGE INSTRUMENT # 3441 CALIBRATION DATE 11-7-77
TEST PRESSURE 1220 (PSIG) TEST DURATION 10 (MIN)

AUTHORIZED INSPECTOR [Signature] DATE 11-9-77
SIGNATURE

IDENT. STAMP



TEST COMPLETED BY [Signature] DATE 11-9-77
SIGNATURE

BACKSEAT
LEAKAGE TEST

TEST DURATION 10 MINUTES MINIMUM
TEST PRESSURE 1220 (PSIG) LEAK RATE 0.6 (CC/HR)

TEST COMPLETED BY [Signature] DATE 11-9-77
SIGNATURE

PACKING
LEAKAGE TEST

TEST DURATION 10 MINUTES MINIMUM
TEST PRESSURE 615 (PSIG) LEAK RATE 0.0 (CC/HR)

TEST COMPLETED BY [Signature] DATE 11-9-77
SIGNATURE

DISC
HYDROSTATIC
LEAKAGE TEST

TEST GAGE INSTRUMENT # 3431 CALIBRATION DATE 10/20/77
TEST DURATION 10 (MINUTES EACH SEAT)

TEST PRESSURE 920 (PSIG) LEAK RATE "A" SEAT 1.2 (CC/HR)
TEST PRESSURE 920 (PSIG) LEAK RATE "B" SEAT 1.2 (CC/HR)

AUTHORIZED INSPECTOR [Signature] DATE 11-9-77
SIGNATURE

IDENT. STAMP



TEST COMPLETED BY [Signature] DATE 11-9-77
SIGNATURE

COMMENTS

VDP-PAGE 6 OF _____



LOS ANGELES POWER DIVISION

CALCULATION COVER SHEET

3

PROJECT South Texas Project JOB NO. 14926-001 SHEET 1 OF —

SUBJECT Containment Spray Pump Discharge Train A TOTAL NO. OF SHEETS 25

ORIGINATOR SIG. Charles R. Hill DISCIPLINE PSSG DATE 6/22/82 FILE NO. N/A CALC. NO. 5N129RC0011

CHECKER SIG. R. D. Dulos DISCIPLINE PSSG DATE 7/12/82 QUALITY CLASSIF. 2

RECORD OF ORIGINAL ISSUE AND REVISIONS

REV. NO.	REVISION DESCRIPTION	DATE	ORIG	CKR	GL	GS	CHIEF
0	Issued For use.	7/12/82	CH	R. Dulos	R. Dulos	JP/MK	—
1	Revised & issued for use	6/25/83	CH	U. Dulos	L. Syd	JP	—
2	Revised Sh's 34, 58, 59, 61, 63. New Support numbers.	10/20/83	CH	CH	L. Syd	JP	—
3	Added value and incorporated support changes	4/12/84	CH	E.S.	LS/MK	JP	—

RESULTS OF CHECKER REVIEW

ITEM DESCRIPTION	ORIG. ISSUE	REVISION NO.							
		1	2	3					
MUST INITIAL ONE FINAL RESULT NUMERICAL DIFFERENCES ARE NOT SIGNIFICANT; NO CORRECTIONS NECESSARY	INITIAL	ekd	U. Dulos	CH	E.S.				
	DATE	7/12/82	6/25/83	10/20/83	4/8/84				
FINAL RESULT NUMERICAL DIFFERENCES ARE SIGNIFICANT, NECESSARY CORRECTIONS HAVE BEEN MADE.	INITIAL								
	DATE								
CHECK MADE BY ATTACHED ALTERNATE CALCULATIONS.	INITIAL								
	DATE								

This calculation is for Units 1 & 2.
 ME101 Version J5
 Released 12/15/83
 SNUM: X2002, X2024
 Run Date: 4/2/84, 4/2/84
 Open Items: See Sheet 8.

3

COMMITTED



CALCULATION SHEET

P. O. BOX 2166
HOUSTON, TEXAS 77252-2166

CALC. NO. PCD011
DATE 4/3/82

SIGNATURE [Signature]

DATE 4/2/84

CHECKED E. Shen

PROJECT SOUTH TEXAS PROJECT

JOB NO. 14926-001

SUBJECT See Calc. Cover Sh.

SHEET 63 OF — SHEETS

5.7 PIPING END LOADS FOR ACTIVE VALVES - (WESTINGHOUSE VALVES ONLY)

Valve No. XCS001A Pipe Size, OD = 8.625 IN
 Data Pt. 36, 42 Metal Area, A = 8.4 IN²
 Piping Mat. SA312TP304L Section Modulus, Z = 16.81 IN³
 Yield Strength $\sigma_y =$ 19870 Rf2.19 Thickness, t = 0.322 IN
 (at Max. OP TEMP)

LOADING CONDITION	FORCES (LB)			MOMENTS (IN-LB)		
	Fa	Fb	Fc	Ma	Mb	Mc
	Axial	Shear	Shear	Torsion	Bending	Bending
(t) Thermal	1225	117	-286	4382	-45777	-22156
(1) Gravity	-10	-1448	0	1171	113	⁹⁰²¹ / ₋₁₁₇₈₆
(2) SSE	336	259	185	2214	6129	11471
(3) SAM (SSE)	166	20	69	810	12409	3545
(4) DBA	13	-13	-7	-141	-1350	2313
Other (Note: 2)	—	—	—	—	—	—
(5) Total (Note: 3)	1603	1721	490	7911	60854	45948
					$\sqrt{M_b^2 + M_c^2} = 76253$	
(6) Allowables (Note: 1)	X			167,000	167,000	
(7) Maximum Principal Stresses	$\sigma_{max} = 7500$			Ratio = $(\sigma_{max} / .75 \sigma_y) = 0.50$		

Notes: (1) Torsional Moment = $0.5 \sigma_y Z$ (IN-LB) (3) Load combination in accordance with Table 4 of piping stress analysis criteria
 Bending Moment = $0.5 \sigma_y Z$ (IN-LB)
 Design Pressure P = 400 PSIG
 (2) Other: (Specify) Water Hammer, Steam Hammer, Thrust Load, etc.

Fa/A	$\sqrt{F_b^2 + M_c^2} / Z$	$\sqrt{F_b^2 + F_c^2} / A$	Ma/2Z	PD/4t	$\sigma_a = (a) + (b) + (e)$	$\sigma_\phi = \frac{PD}{2t}$	T = (c) + (d)
(a)	(b)	(c)	(d)	(e)	(f)	(h)	(j)
191	4536	213	235	2679	7406	5357	448
Principal Stresses $\sigma_1, \sigma_2, \sigma_3$			$\sigma_1, \sigma_2 = 0.5 [(\sigma_a + \sigma_\phi) \pm \sqrt{(\sigma_a - \sigma_\phi)^2 + 4T^2}]$				$\sigma_3 = P$
$\sigma_{max} = \text{Max of } (\sigma_1, \sigma_2, \sigma_3)$			$\sigma_1 = 7500, \sigma_2 = 5263$				$\sigma_3 = 400$

Attachment C

LIST OF ATTENDEES

N. P. Kadambi	USNRC Project Manager
Y. C. (Renne) Li	USNRC MEB
E. Rodabaugh	USNRC MEB Consultant
S. E. Moore	USNRC MEB Consultant
M. R. Wisenburg	HL&P Manager, Nuclear Licensing
C. A. Ayala	HL&P Licensing
J. G. White	HL&P Engineering
G. D. Purdon	HL&P Engineering
C. R. Allen	HL&P Engineering
A. B. Poole	HL&P Engineering
S. D. Antonio	HL&P Engineering
R. A. Witthauer	Bechtel Engineering
R. Singh	Bechtel Engineering
J. Shiu	Bechtel Engineering
M. V. Contaoi	Bechtel Engineering
R. Qasha	Bechtel Engineering
C. Chern	Bechtel Engineering
M. Khallafallah	Bechtel Engineering
D. Getman	Bechtel Engineering
M. Jante	Bechtel Engineering
G. Borden	Bechtel Engineering
W. F. Guerin	Westinghouse
A. T. Paterson	Westinghouse
T. Matty	Westinghouse
D. Tome	Westinghouse
C. Boyd	Westinghouse
D. J. Roarty	Westinghouse

DISTRIBUTION TO:	FOR REVIEW	INFO.
<input checked="" type="checkbox"/> MECHANICAL		<input checked="" type="checkbox"/>
<input type="checkbox"/> BALANCE OF PLANT		
<input type="checkbox"/> BOILER/HESS		
<input type="checkbox"/> PLANT UTILITIES		
<input type="checkbox"/> PLANT DESIGN		
<input type="checkbox"/> CONTROL SYSTEMS		
<input checked="" type="checkbox"/> Electrical E.Q. (2)		<input checked="" type="checkbox"/>
<input type="checkbox"/> WIRING		
<input type="checkbox"/> CONDUIT		
<input type="checkbox"/> MGS		
<input type="checkbox"/> PAINTING & COATINGS		
<input type="checkbox"/> CIVIL/STRUCTURAL		
<input type="checkbox"/> NUCLEAR		
<input type="checkbox"/> STRESS		
<input type="checkbox"/> ARCHITECTURAL		
<input type="checkbox"/> STARTUP		
<input type="checkbox"/> CONSTRUCTION		
<input type="checkbox"/> NOT REQ'D BY ENGRG		
<input checked="" type="checkbox"/> CLIENT S. NEW/E.B. (1)		<input checked="" type="checkbox"/>


IDENTIFYING TITLE OF THIS DOCUMENT
SECT. 2.3.8/1-1
PUMP SEISMIC AND
A.S.M.E. CODE ANALYSIS -

PKG.# 4637

14926-4022-01018-BHT

Bechtel Log No.

14926-8022-01018-BHT

IMPORTANT	
Permission to proceed does not constitute acceptance or approval of design details, calculations, analysis, test methods or materials developed or selected by the supplier and does not relieve supplier from full compliance with contractual obligations.	
DATE RECEIVED 10/4/83	Signed ROR
DOCUMENT STATUS	Date 11/8/83
<input checked="" type="checkbox"/> 1 WORK MAY PROCEED. REVISIONS AND RESUBMIT. WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES REVISIONS.	
<input type="checkbox"/> 2 REVISIONS AND RESUBMIT.	
<input type="checkbox"/> 3 REVISIONS AND RESUBMIT.	
<input type="checkbox"/> 4 REVIEW NOT REQUIRED.	
<input type="checkbox"/> WORK MAY PROCEED. <input type="checkbox"/> INFORMATION ONLY <input type="checkbox"/> DISTRIBUTION REQ'D	NO 66012/78

SD
2/20/15

①

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 1
Date: March 31, 1976
Supersedes:
Dwg. No.:
XX-BR-291

^{SEISMIC}
~~SIBONIC~~ PUMP AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS
_{10/17/73}
_{App.} (DTQ)

ISSUE	PAGES REVISED	SUPERSEDES	ISSUED BY	APPROVED	DATE
0	Initial Issue		CFK	CFK	3/31/76

R209XPX110

BROWN & ROOT, INC.
APPROVAL PRINT
JOB NO. CR-0241

APPROVED
APPROVED PARTS REPRODUCIBLE FOR DISTRIBUTION

APPROVED AS NOTED
MAKE NOTED CORRECTIONS AND SUBMIT CORRECTED REPRODUCIBLES

NOT APPROVED
RESUBMIT FOR APPROVAL

J. H. [Signature] 3/31/76
SIGNED DATE

APPROVAL DOES NOT RELIEVE THE SELLER FROM ANY RESPONSIBILITY FOR ERRORS OR DEVIATIONS FROM THE CONTRACT REQUIREMENTS.

CONTROLLED

FOR APPROVAL

TURNOVER

Received by STP RMS 5-14-82
DATE

at Revision — LB
RMS

14926-4022-01018 ^B AHT ^{10/17/73} DISTRIBUTION: X, B
14926-8022-01018 AHT

~~SUPERSEDED~~ 0

1012 P. Ltd.

Standard Issued by: *[Signature]* Approved by: *[Signature]* 1934

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

1.0 Object

To show that structural integrity and operability will not be impaired during or after a seismic event.

2.0 General Approach

2.1 Horizontal Pumps

On all horizontal pumps, the pump and motor are separately analysed, the motor being analysed by the motor vendor. The only interface between the pump and the motor is the coupling. It is realized that the only time any load, other than torsional, can be carried across the coupling, is if there is permanent set in some component. Thus, by assuring there is no permanent set in any component we can assure there will be no axial load interaction between the pump and the motor.

All pump and support component stresses are calculated per section 5.0.

All pump and support component deflections are calculated per section 5.0.

The motor supports are modelled as pump supports and analysed per section 5.0.

2.2 Vertical Pumps

Vertical pumps are modelled as beams and analysed by finite element methods using the NASTRAN program. The motor is analysed as a beam mounted above the pump. The pump is assumed to be rigidly attached at the mounting plate and to be simply supported at the radial supports.

The stiffness is based on only the outer shell minus the corrosion allowance. The mass is based on the total weight including the corrosion allowance, shafting, enclosing tubes and water.

The NASTRAN analysis is not duplicated here as it is publically available.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

3.0 Structural Integrity

3.1 Criteria

3.1.1 Allowable Stress

If the specified material is an A.S.M.E. Code material, allowable stresses are taken from the A.S.M.E. Code Section III, Appendix I. If the specified material is not a Code material, the allowable stress is taken as 60% of yield. The allowable stresses for half and full earthquake loadings are modified only as stated in the customers specification.

3.1.2 Code Criteria

Where applicable all parts are analysed to the A.S.M.E. Code Section III. See section 5.0 below for specific references.

3.2 Loadings

All nozzle loads are as given in the customers specification or greater. If the loadings are greater, a comparison of the specified load to the loads used in the calculations is given in section 6.3.0. If the direction of the nozzle load is uncertain, the most conservative direction is assumed.

Flange loadings are calculated based on an equivalent pressure as given in section 5.1.7 .

Seismic loadings are as given in the customers specification or greater. If the loadings are greater a comparison of the specified load to the load used in the calculation is given in section 6.0 .

NOTE: Any modifications of the specified loads are always done in such a way as to produce conservative results.

3.2 Methods

3.3.1 Nozzle Stresses

Nozzle stresses are calculated according to the A.S.M.E. Code Section III Article A 2212 and the methods shown in section 5.2.1 below. The nozzles are modelled as cylinders and an equivalent pressure is used to calculate the load, as calculated in section 5.1.7 below.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

3.3.2 Casing Stresses

3.3.2.1 Horizontal Pumps

The minimum casing thickness is calculated by the methods of A.S.M.E. Code Section III NB 3442 as is shown in section 5.2.2.1. below.

The casing flange stresses are calculated by the methods of A.S.M.E. Code Section III Article ND 3442 as is shown in section 5.2.2.1 below.

The casing is modelled as a cylinder and analysed by the methods of the A.S.M.E. Code Section III Article A 2212 as shown in section 5.2.1 below.

3.3.2.2 Vertical Pumps

The casing is modelled as a cylindrical beam, fixed at one end. The stresses are analysed according to the A.S.M.E. Code Section III Article A 2212 and using the methods shown in section 5.2.2.2 below.

3.3.3 Flange Stresses

The suction and discharge flange stresses are calculated, by the methods of section 5.2.3 below, according to the A.S.M.E. Code Section III Appendix XI and, an equivalent pressure, according to the A.S.M.E. Code Section III NB 3647 as is shown in section 5.1.7 below.

3.3.4 Backcover and Gland Stresses

Since the calculations involving these two items are identical they are both listed together. These items are analysed in accordance with the A.S.M.E. Code, Section III NC 3325 and ND 3325 by the methods shown in section 5.2.4 below.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

3.3.5 Bolt Stresses

3.3.5.1 Horizontal Pumps

There are six different sets of bolts which are separately analysed by four different programs. The bolts are analysed according to the following sections of the A.S.M.E. Code Section III:

Casing Bolts	ND 3442
Gland Bolts	ND 3325
Flange Bolts	NB 3647

The attachment, pedestal and foundation bolts are analysed according to the methods outlined in section 5.2.5 below.

3.3.5.2 Vertical Pumps

All bolts are analysed according to DESIGN OF MACHINE ELEMENTS, V. M. Faïres, using the methods shown in section 5.2.5 below.

3.3.6 Shaft Stresses

The pump shaft is modelled as a simply supported beam with concentrated masses for hydraulic loads, impeller weight and coupling weight; and uniform loading for the shaft weight. It is analysed by the methods shown in section 5.2.6 below. All the hydraulic loads are calculated in accordance with CENTRIFUGAL & AXIAL FLOW PUMPS, A. J. Stepanoff. Keyway stress concentration factors are taken from STRESS CONCENTRATION FACTORS, R. C. Peterson.


3.3.7 Pedestal Stresses

The pedestals are modelled as vertical beams with all loads acting at the centroid of the attachment bolts. The pedestals are analysed by standard beam analysis using the equations for stress from FORMULAS FOR STRESS AND STRAIN, R. J. Roark, and the methods shown in section 5.2.7 below.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

3.3.8 Weld Stresses

The welds are modelled as beams with cross-sectional areas equal to the effective area across the weld throat.



The welds are analysed according to the methods of section 5.2.8 below.

4.0 Operability

4.1 Criteria

The reed natural frequency and the critical speed shall not be within $\pm 25\%$ of the operating speed.

The deflections of pumps and components will be deemed acceptable if they are such that no permanent set remains after a seismic event; as calculated in section 5.2.

The missalignment of the coupling will be deemed to be acceptable if the missalignment does not exceed manufacturers specifications for the coupling in use.

Shaft deflections and wear ring clearances will be deemed to be acceptable if it is shown that no interference occurs before or during a seismic event and that no permanent set remains after a seismic event; as calculated in section 5.2.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 7

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

4.2 Loadings (as 3.2)

4.3 Methods



4.3.1 Natural Frequencies

4.3.1.1 Shaft Natural Frequency

The shaft is modelled as a simply supported beam and the critical speed is calculated using an energy balance method. Calculations are done in accordance with the methods shown in section 5.3.1.1.

4.3.1.2 Pedestal Natural Frequency

If there are two pedestals in the axis of concern the pedestal is modelled as a guided cantilever with a concentrated mass on top. Otherwise it is modelled as a simple cantilever with a concentrated mass on top.



The natural frequency is calculated by the methods of: MECHANICAL VIBRATIONS, J. P. DenHartog and using the equations of FORMULAS FOR STRESS AND STRAIN, R. S. Roark as shown in section 5.3.1.2.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

4.3.1.3 Vertical Pump Columns

The column is modelled as a cylindrical beam which is rigidly attached at the mounting flange and simply supported at the radial stiffeners. Credit is not taken for the corrosion allowance in the calculation of rigidity but is included, along with the water, in calculation of the mass.

The pump natural frequency is calculated using the "NASTRAN" general finite element computer program.

4.3.2 Shaft Deflections

The shaft is modelled as a beam with static and operating loads superimposed. The hydraulic loads are calculated in accordance with "CENTRIFUGAL & AXIAL FLOW PUMPS, A. J. Stepanoff. The deflections are calculated by numerical integration as per: KINEMATICS AND DYNAMICS OF MACHINES, G. H. Martin.

4.3.3 Bearing Analysis

For anti-friction bearings the B-10 bearing life is calculated according to the specifications listed in the manufacturer's manual.

For sleeve bearings the load is calculated by a simple summation of forces and moments by the methods of section 5.3.5.


4.3.4 Fatigue Analysis

Evaluation of fatigue life and safety factors for shafting follows the methods outlined in: MECHANICAL ENGINEERING DESIGN, J. E. Shigley.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.0 Calculation Methods

All calculations are based on the following co-ordinate system except cylindrical stresses which are based on the system as illustrated in section 5.2.1.



5.1 Loading

Generally, the following loads are given:

1. Nozzle Loads
2. Seismic Loads
3. Nozzle Loads for Seismic Conditions
4. Shaft Horsepower
5. Design Pressure
6. Hydrostatic Test Pressure

These loads must then be converted to the appropriate values such that they are useful for calculations. This is done by the methods illustrated in this section.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.1.1 Nozzle Loads

For calculation of bolt loads, the forces and moments are transformed by the following equations:

$$F_{x_c} = \sum F_{x_1}$$

$$F_{y_c} = \sum F_{y_1}$$

$$F_{z_c} = \sum F_{z_1}$$

$$M_{x_c} = \sum M_x + \sum (F_{y_1} (Z_c - Z_1) + F_{z_c} (Y_c - Y_1))$$

$$M_{y_c} = \sum M_y + \sum (F_{x_1} (Z_c - Z_1) + F_{z_c} (X_c - X_1))$$

$$M_{z_c} = \sum M_z + \sum (F_{x_1} (Y_c - Y_1) + F_{y_c} (X_c - X_1))$$

Where 1 = 1, 2, 3, etc. for each loading point, i.e. nozzles, C. of G., etc.

5.1.2 Seismic Loads

Seismic loads are calculated by the following equations:

$$F_x = \text{Horizontal Acceleration (g)} * \text{Weight (lb. f)}$$

$$F_y = \text{Horizontal Acceleration (g)} * \text{Weight (lb. f)}$$

$$F_z = \text{Vertical Acceleration (g)} * \text{Weight (lb. f)}$$

Note that these forces are assumed to act at the centre of gravity of the pump.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 11

Date:

Supersedes:

Dwg. No.:


PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.1.3 Nozzle Loads for Seismic Conditions

When stated in the Customers specification, all nozzle loads are multiplied by the multipliers for seismic conditions.

5.1.4 Shaft Horsepower

In the motor pedestal analysis the motor is modelled as a pump with the only nozzle load being M_x . The moment, M_x , is calculated from the shaft horsepower and the shaft speed (N) by the standard conversion equation shown below:



$$M_x = \frac{\text{Horsepower} \times 550 \times 60 \text{ ft.-lbs.}}{2\pi \times N}$$

5.1.5 Design Pressure

The design pressure is calculated as the maximum shut off pressure plus the maximum suction pressure.

5.1.6 Hydrostatic Test Pressure

The hydrostatic test pressure is calculated as 1.5 times the design pressure times the ratio of the code allowable stress cold over the code allowable stress at design temperatures.


$$P_{HYD \text{ TEST}} = 1.5 \times PDES \times \left(\frac{\sigma_{allow, cold}}{\sigma_{allow, hot}} \right)$$

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.1.7 Equivalent Pressure

In the analysis of flanged joints the nozzle loads must be combined with the pressure to form an equivalent pressure. This is done by the following equation from A.S.M.E. Code Section III Article NB 3647:

$$P_{\text{equiv.}} = P + \frac{16 M}{\pi G^3} + \frac{4F}{\pi G^2}$$



Where: F is the force perpendicular to the face of the flange

M is the bending moment in in-lbf.

$$M = \sqrt{M_y^2 + M_z^2}$$

G is the diameter at the effective gasket load

5.2 Integrity Calculations

5.2.1 Stress in a Cylinder

This analysis applies to nozzles, vertical pump columns, and casings.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page:
Date:
Supersedes:
Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS


Ref Article A2212, ASME III

$$\sigma_t = P(1+Z^2)/(Y^2-1)$$

$$\sigma_1 = P/(Y^2-1) + F_z/A + \sqrt{\eta_x^2 + \eta_y^2} * R/I$$

$$\sigma_r = P(1-Z^2)/(Y^2-1)$$

$$T_{1t} = M_z * R/J$$



R = Radius to test point

I = Moment of inertia about transverse axis

J = Torsional Moment of inertia

A = Area of nozzle

P, Z, Y, σ_t , σ_1 , σ_r are as defined in Article 2000.

T_{1t} is shear stress across the face of the nozzle.

From these principal stresses are calculated

$$\sigma_1, \sigma_2 = \frac{\sigma_t + \sigma_1}{2} \pm \sqrt{\left(\frac{\sigma_t - \sigma_1}{2}\right)^2 + T_{1t}^2}$$

$$\sigma_3 = \sigma_r$$

The maximum shear stress is the greater of

$$SS = \frac{\sigma_1 - \sigma_2}{2}, \frac{\sigma_2 - \sigma_3}{2}, \frac{\sigma_3 - \sigma_1}{2}$$

This is compared to the code allowable stress divided by 2 to obtain a safety factor.

$$SAF = \frac{S_{allow}}{SS * 2}$$


PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.2.2 Casing Stresses

5.2.2.1 Horizontal Pumps

The casing minimum wall thickness is:

Ref: ASME III NB 3442



$$\text{Casing wall minimum thickness } t_m = \frac{0.63 \times P \times A}{S_m}$$

$$\text{Minimum Volute and Casing flat wall} = t_m$$

$$\text{Crotch radius } t_c = 0.3 \times t_m$$

$$\text{Cutwater and splitter radius } t_s = 0.05 \times t_m$$

$$\text{Fillet Radius } 0.1 t_m \text{ or } .25 \text{ in.}$$

The casing is analysed per section 5.2.1.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.2.2.2 Vertical Pumps

The cylindrical sections of a vertical pump are analysed per section 5.2.1.

The stress in the pressure loaded top plate is analysed as shown below.

The pump column is modelled as a beam and analysed by the "NASTRAN" finite element computer program. The column is assumed to be rigidly attached at the mounting bracket and simply supported at the radial supports.

Any corrosion allowance is not included in the calculation of the rigidity but is included in the calculation of the weight. The applicable loads include weight, nozzle loads and seismic loads. These are then combined by the "NASTRAN" program to obtain the internal forces and moments. These internal loads are then used to calculate column stresses by the methods of section 5.2.1 and flange stresses by methods of 5.2.3.

Flat plates used as closure for cylindrical walls such as suction covers and top covers are analysed in accordance with A.S.M.E. Code Section III Article NC 3225.

5.2.3 Flange Stresses

Flange stresses are calculated according to A.S.M.E. Code Section III Appendix XI based on an equivalent pressure calculated according to A.S.M.E. Code Section III Article NB 3647.

Nozzle loads are taken into account by calculating an equivalent pressure in accordance with NB 3647.1

$$P_{eg} = P + \frac{16M}{\pi G^3} + \frac{4F}{\pi G^2}$$

M = Bending Moment in in-lbs.
F = Axial Force in lbs.
G = Diameter of Effective Gasket Load

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 16

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

The bolt loads are calculated as

For Operating Conditions

$$W_{m1} = .785 \times G^2 \times P + 2 \times b \times 3.14 \times G \times m \times P$$

For Gasket Seating

$$W_{m2} = 3.14 \times b \times G \times y$$

The bolt area required is the greater of:

$$A_{m1} = W_{m1} / S_b$$

$$A_{m2} = W_{m2} / S_a$$

The flange bolt load is the greater of:

$$W = W_{m1}$$

$$W = \frac{(A_m + A_b) S_a}{2}$$

The stress is given by:

$$\text{Longitudinal hub stress } S_H = \frac{f \times M_0}{L \times g_1^2 \times B} + \frac{P \times B}{4 \times g_0}$$

$$\text{Radial flange stress } S_R = \frac{(1.33 \times t \times e \times l) \times M_0}{L \times t^2 \times B}$$

$$\text{Tangential flange stress } S_T = \frac{Y \times M_0}{t^2 \times B} - Z \times S_R$$

Ref. NB 3647.1 (d)

The design safety factors are:

$$\text{Longitudinal Hub Stress } SF_H = \frac{1.5 \times S_m}{S_H}$$

$$\text{Radial Flange Stress } SF_R = \frac{1.5 \times S_m}{S_R}$$

$$\text{Tangential Flange Stress } SF_T = \frac{1.5 \times S_m}{S_T}$$

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:

2.3.8/1-0

Page: 17

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND ASME CODE ANALYSIS


5.2.4 Backcover and Gland Stresses

Reference:


The calculations are done in accordance with articles NC 3325 and ND 3325.

Since the analysis is identical for the covers in question; the nomenclature of NC 3325 will be used.

COVER



GLAND PLATE



PUMP SEISMIC AND ASME CODE ANALYSIS

For Operating Conditions:

$$t = d \sqrt{C \cdot P / S} = 1.78 \cdot W \cdot hg / S \cdot d^3 \quad (1)$$

where $C = .3$ (Fig. NC 3325-1-d and e)

P = design pressure

S = allowable stress at Design Temp.
(Table I - 7.0, Appendix I)

W = total bolt load (XI-3223 (3) and (4))
= W_{mI} (for operating conditions)

For a grooved peripheral gasket, the minimum cover plate thickness under the groove or between the groove and the outer edge shall be,

$$t_m = d \sqrt{1.78 \cdot W \cdot hg / S \cdot d^3}$$

For gasket Seating:

E_q^n (I) above shall be used

and P = design pressure = 0

S = allowable stress at atmospheric temp. (Table I - 7.0, Appendix I)

$$W = (A_n + A_b) S_a / 2$$

Where S_a = allowable stress of bolts at atmospheric temp.

A_b = total basic min. minor area of bolts (in.²)

$$W_{mI} = .785 \cdot G^2 P + 2b \cdot G \cdot m \cdot P \cdot 3.4$$

Where P = design pressure

M = gasket factor (Table XI - 3221.1-2)

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:

2.3.8/1-0

Page:

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND ASME CODE ANALYSIS

b_o = basic gasket seating width (Table XI - 3221.1-2)

For $b_o \leq .25$ in., $b = b_o$ and $G = d$

For $b_o > .25$ in., $b = \frac{b_o}{2}$ and $G = d - 2b$

$$W_{m2} = 3.14 b * G * Y$$

A_m = the greater of $\frac{W_{m1}}{S_b}$ or $\frac{W_{m2}}{S_a}$

where Y = gasket seating pressure (Table XI - 3221.1-1)

S_a = allowable stress of bolts at atmospheric temp.

S_b = allowable stress of bolts at design temp.

Note - tables XI-3221.1-1 and XI-3221.1-2 are attached as Appendix I and II.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

5.2.5 Bolt Loading (Attachment, Pedestal & Foundation)

Foundation and attachment bolt loading is analysed by the methods shown below.

It is assumed that the baseplate is rigid with respect to the attachment bolting.

The load absorbed by each bolt is directly proportional to the distance from the axis of the resultant bending moment. (M_R)

Where: $M_R = \sqrt{M_x^2 + M_y^2}$

M_x is the resultant moment in the x-direction as calculated in section 5.1 .

Therefore: the force in the bolt is:


$$F_i = K h_i$$

Where: h_i is the perpendicular distance from the bolt to the axis of the resulting bending moment.

$$K = M_R \sum h_i^2$$

Therefore: the vertical reaction is:

$$F_{z_i} = \frac{-F_z}{4} - K * h_i$$



For circular bolt distribution, i.e. mounting flanges, this load becomes:

$$F_i = \frac{4 M_R}{3 N R} + \frac{F_z}{N}$$

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 21


Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

To calculate the horizontal reactions it is assumed that plane horizontal forces are shared equally by each bolt and that the reaction to the vertical moment is proportional to the distance from the centroid to the bolt. This reaction acts in a direction perpendicular to the line from the centroid to the bolt.



$$F_i = K D_i = K (x_i - x_c)^2 + (y_i - y_c)^2$$

$$\text{Where: } K = M_2 / D_i^2$$

$$F_{X_{\text{total}}} = F_i + F_x / N$$

Hayward Tyler

PUMP COMPANY ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 22
Date:
Supersedes:
Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.2.5.1 Bolt Stress (Attachment, Pedestal and Foundation Bolts)

Ref: Faies, Design of Machine Elements
Macmillan, New York, 1965.

Load F_x, F_y, F_z where Z is along the axis of the bolt.

$$\text{Initial Bolt Force } F_i = 1.5 * (K_n / (K_p + K_b)) * F_z$$

$$\text{Where } K = \frac{E A}{L}$$

Where E = Young's Modulus

A = Bolt or part stress area

L = Effective length

K_n = K for part

K_b = K for the bolt

$$\text{Initial Torque } T = .2 * \text{Bolt Size} * F_i / 12. \text{ ft.-lbs.}$$

Bolt size = Nominal size in inches.

$$\text{Bolt Axial Stress } S = (F_i + F_z * K_b / (K_b + K_p)) / A \text{ psi}$$

$$\text{Shear Stress } SS = \sqrt{F_x^2 + F_y^2} / A$$

Note for gaskets present

$$K_p = \frac{1}{\frac{L_n}{E_p A_p} + \frac{L_g}{E_g A_g}}$$

Principal Stresses

$$\sigma_1, \sigma_2 = \frac{S}{2} \pm \sqrt{\left(\frac{S}{2}\right)^2 + SS^2}$$

$$\text{Max. Shear Stress } (\tau_{\text{max}}) = \frac{\sigma_1 - \sigma_2}{2}$$

$$\text{Safety Factor} = \frac{S_{\text{allow}}}{2 \tau_{\text{max}}}$$

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

NOTE: The allowable bolt stress is as given in the A.S.M.E. Code Section III Appendix XI for all code bolting and in 60% of yield for all other parts as specified in the A.S.M.E. Code Section III, NF.

5.2.6 Shaft Stress

The pump shaft analysis is based on modelling the rotating shaft as a simply supported beam under the influence of static and operating loads, and applies to all pump types.

The loads applied include: static weight, hydraulic thrusts - radial and axial, and seismic loads.

For conservative results the seismic loads are taken to act in the same direction as the resultant of the static and hydraulic loads.

Calculations made include: bearing loads, shaft deflection, critical speed, and stresses.

For all of these the hydraulic load on the impellers are calculated in accordance with: A. J. Stepanoff, - Centrifugal & Axial Flow Pumps,
John Wiley & Sons,
New York, 1967.

Shaft stresses include axial stress due to thrust and bending, tangential stresses due to keyways, and shear stress due to torque.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS


Multistage Vertical Pump shafts may be analysed by the "NASTRAN" finite element computer program, in which case the bearings are modelled as springs.

The allowable stress for shafts is 60% of the yield stress.


5.2.7

Pedestal Stresses

This applies to pumps with centreline support.



- The pump is assumed to be rigid.
 - Misalignment in the pump axis is neglected.
 - When two pedestals are in the axis of deflection, the pedestal act as a guided centreline.
 - When only one pedestal is in the axis of deflection, the pedestal act as a simple cantilever.
- i.e. for 2-pedestal systems the deflections in the x-direction are as simple cantilever and those in the y-direction are as guided cantilevers. For 4-pedestal systems all horizontal deflections are guided cantilevers.




PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

5.2.8 Weld Stresses

The weld stress is calculated the same as the pedestal stress; that is

$$\sigma = \frac{M_{xx} Y}{I_{xw} * N} + \frac{M_{yy} Y}{I_{yw} * N} + \frac{F}{WAREA * N}$$

where I_{xw} = the weld moment of inertia per pedestal (x-direction)
 I_{yw} = the weld moment of inertia per pedestal (y-direction)
WAREA = the effective cross-sectional area of the weld



Hayward Tyler

PUMP COMPANY ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 26

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.3 Operability Calculations

5.3.1 Natural Frequencies

5.3.1.1 Shaft Natural Frequencies

The pump shaft is analysed by numerical integration using the "SHAFT" program assuming stiff bearings. Multistage vertical pump shafts may be analysed by the "NASTRAN" finite element computer program, in which case the bearings are modelled as springs.

The critical speed is calculated using an energy balance method in accordance with: KINEMATICS AND DYNAMICS OF MACHINES, G. H. Martin.

The effect of axial thrust is not taken into account.

The general equation used is:

$$w_c^2 = \frac{g \sum W y}{\sum W y^2} \quad \text{Rad/sec}$$



Where W is the concentrated weight and y is the deflection at this weight.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.3.1.2 Pedestal Natural Frequency

The pump is modelled as a rigid mass mounted on top of the pedestal.

- (a) When two pedestals are in the axis of deflection the pedestals act as guided cantilevers.
- (b) When only one pedestal is in the axis of deflection, the pedestal acts as a simple cantilever.



i.e. for 2-pedestal systems the deflections in the x-direction are as simple cantilever and those in the y-direction are as guided cantilevers. For 4-pedestal systems all horizontal deflections are as guided cantilevers.

Natural frequency for simple cantilevers is given by:

$$W_n = \frac{1}{2\pi} \sqrt{\frac{3EI_0}{WL^3}} \text{ cps}$$

Where I is the total moment of inertia.

Natural frequency for guided cantilevers is given by:

$$W_A = \frac{1}{2\pi} \sqrt{\frac{12EI_0}{WL^3}} \text{ cps}$$

Natural frequency in the z-direction is given by:

$$W_n = \frac{1}{2\pi} \sqrt{\frac{A E g}{W L}}$$

Where A is equal to the total cross-sectional area of the pedestals.

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

5.3.1.3 Vertical Pump Columns

The casing is modelled as a beam, fixed at one end and simply supported at the radial stiffeners. The corrosion allowance is not included in the calculation of the rigidity but is included in the weight along with the water and the enclosing tube.

The natural frequency is calculated by use of the "NASTRAN" finite element computer program.

The motor is modelled as a cantilever supported above the pump. It is also assumed to be rigidly attached at the mounting flange and analysed by the "NASTRAN" program.

The stiffness of parts with equally spaced radial stiffeners is calculated by:

$$I = I_{\text{cylinder}} + \frac{N}{2} \cdot \frac{bh^3}{12} + bh \cdot R^2$$

Where: R is the distance from the centre of the cylinder to the centroid of the radial stiffeners.

N is the number of radial supports.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 29

Date:

Supersedes:

Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.3.2 Shaft Deflections

The loads applied include: static weight, hydraulic thrusts - radial and axial, and seismic loads.

For all of these the hydraulic load on the impellers are calculated in accordance with: A. J. Stepanoff, CENTRIFUGAL & AXIAL FLOW PUMPS, John Wiley & Sons, New York, 1967.

Shaft deflection is calculated by a double integration method.

$$y = \iint \frac{M}{EI} dx$$

where M is the applied bending moment and is a function of X .

y is the deflection at point X

I is the shaft moment of inertia in bending

For this integration axial loads intermediate bushing and wear ring support are not taken into account.

5.3.3 Coupling Missalignment

Pedestal deflections are calculated as shown below:

Two pedestals

The deflection at the pump centreline in the x-direction is given by:

$$V_x = \frac{(F_x + M_z/(D_y/2))L^3}{3EI} + \frac{M_y L^3}{2EI}$$

The deflection at the pump centreline in the y-direction is given by:

$$V_y = \frac{F_y L^3}{12EI}$$

Four pedestals


The deflection at the pump centreline is given by:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

5.3.3 Coupling Misalignment (Cont'd)

$$V = \frac{F_i L^3}{12 E I}$$

Where F_i is the sum of the appropriate horizontal force (F_x or F_y) and the force due to the vertical moment (M_z).



Two pedestals

The horizontal angle of rotation of the pedestals is given by:


$$\theta = \frac{(F_x + M_z / (D_y / 2)) L^2}{2 E I} + \frac{M_y L}{E I}$$

The vertical angle of rotation of the pedestals is given by:

$$\phi = \text{ARCTAN} (2 V_x / (D_y / 2))$$

The total misalignment is given by:

$$\text{Misalignment} = \sqrt{(H \text{TAN} \theta)^2 + (V_y + H \text{TAN} \phi)^2}$$



PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS - ISSUE & REVISIONS

Four Pedestals

The horizontal angle of rotation of the pedestal is given by:

$$\theta = \text{ARCTAN} \left(\frac{F_x L^3}{12 EI_y} * \frac{1}{D_y} \right) + \text{ARCTAN} \left(\frac{F_y L^3}{12 EI_x} * \frac{1}{D_x} \right)$$

This creates a displacement equal to:

$$\text{Displacement}_H = H \text{ TAN } \theta$$

The vertical displacement is given by:

$$\text{displacement}_V = \frac{L^3 M_y}{D_x EA} * \frac{H}{D_x/2}$$

The total misalignment equals:

$$\text{misalignment} = \sqrt{\text{displacement}_V^2 + \text{displacement}_H^2}$$

NOTE: Motor pedestals are analysed similarly and the coupling misalignment due to the shaft deflection.

5.3.5 Bearing Analysis

Bearing loads are the reactions at two support points to the loads applied to the shaft, and are calculated by a simple summation of forces and moments.

The B - 10 bearing life is calculated in accordance with the bearing manufacturers manual based on all normal operating loads, and based on peak loads including the Design Base Earthquake.

5.3.6 Fatigue Analysis

For shafts a system of alternating and mean stress components is assumed and a safety factor based on an endurance limit is calculated using method outlined in: MECHANICAL ENGINEERING DESIGN, J. E. Shigley.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: 32
Date:
Supersedes:
Dwg. No.:

PUMP SEISMIC AND A.S.M.E. CODE ANALYSIS

6.0 Report

The Seismic Analysis Report shall contain the following:

- 6.1 Issue and Revision Sheet plus table of contents using the form of Appendix I.
- 6.2 Summary of Analysis using the form of Appendix I.
- 6.3 Summary of Loadings using the form of Appendix I.
- 6.4 Detailed calculations including Computer input/output.
- 6.5 Computer program description including a sample run plus parallel verification calculation.
- 6.6 Any other required support Engineering Standards.

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:

2.3.8/1-0

Page: Appendix 1 part

Date:

Supersedes:

Dwg. No.:

SEISMIC ANALYSIS REPORT

REPORT No. _____

<u>Revision</u>	<u>Issue Date</u>	<u>Replaces</u>	<u>Pages Revised</u>	<u>Issued By</u>	<u>Approved</u>
-----------------	-------------------	-----------------	----------------------	------------------	-----------------

TABLE OF CONTENTS

Standard issued by:

Approved by:

SEISMIC ANALYSIS REPORT

1.0 Summary of Analysis Results

1.1 Structural Integrity

The unit has been shown to satisfy all the Structural requirements of A.S.M.E. Section III and the Contract Specification under the defined loading conditions.

All stress levels are within the allowable limits. Details of results maybe found in section 6.4 .

1.2 Operability

The pump has been shown to maintain operability through all the operational and environmental events defined in the contract specification.

Maximum Coupling Misalignment

	Running	OBE	DBE
Pump Misalignment			
Motor Misalignment			
Shaft Misalignment			
Total Misalignment			
Allowable Misalignment			
Safety Factor			

Minimum Wear Ring Clearances

Clearances at wear rings (Unloaded)

Deflections at wear rings	Running
	OBE
	DBE

Hayward Tyler

PUMP COMPANY

ENGINEERING STANDARDS

SECTION:
2.3.8/1-0

Page: Appendix 1 pag

Date:

Supersedes:

Dwg. No.:

SEISMIC ANALYSIS REPORT

Bearing Loads

<u>Location</u>	<u>Running</u>	<u>OBE</u>	<u>DBE</u>
-----------------	----------------	------------	------------

The bearing B-10 life has been shown to be _____
The maximum bearing load pressure has been shown to be _____
PSI.

Shaft Stress

Axial

Alternating

Endurance Limit

2.0

Loading Summary

Load	Specified Load			Load Used in Calculation		
	Running	OBE	DBE	Running	OBE	DBE
Suction	Fx					
	Fy					
	Fz					
	Mx					
	My					
Discharge	Mz					
	Fx					
	Fy					
	Fz					
	Mx					
Accelerations	My					
	Mz					
	OBE	H	V			
	DBE	H	V			

The PSC superintendent of operations committed to provide the SRI with the results of this investigation and corrective actions taken by the PSC electricians and contract personnel to restore the control room panels to the proper level of cleanliness.

From a review of CWP 85-331, "Reorganization Etc. of Instrumentation Components and Systems on I-01/02 (Tasks 9A, 9B, 10, 11, 12, and 13)," the SRI determined that housekeeping requirements were not specified within the body of the PITR as required by the CWPM Attachment 6.11.1, "Practices Governing Housekeeping During Modification and Special Maintenance Activities." The "Checklist of General Planning Considerations" used by the CWP preparer for CWP 85-331 was marked "General" in the applicability column for Column I housekeeping requirements. This was contrary to the CWPM, which states:

"5.3.1.3. Using the four checklists (Attachments 6.7, 6.8, 6.9, and 6.10) review each subject/item in column I and remark, as required, in the last column as to its applicability to the CWP effort. Using the ANSI reference or PSC reference shown, go to the CWP Manual Attachments, under Attachment 6.11, for specific or general comments that need to be included in the PITR."

This was also contrary to the licensee's response dated November 21, 1984 (P-84494), to a previous violation (8426-02) for the failure to follow the CWPM checklist requirements which stated, in part:

"(1) The corrective steps which have been taken and the results achieved:

* * *

"Action

"Site Engineering issued a memorandum, dated September 27, 1984, Subject: CWP Writing, to the Coordinator, Nuclear Site Construction. The memo stressed the importance of using the "Planning Consideration Checklists" contained in the CWP Manual. Distribution was made to the CWP preparation group and the subject of the memo discussed with the personnel involved.

"Result

"CWP Planning Checklists are reviewed, filled out for applicability and incorporated into the review process for all CWPs. As an interim measure until formal procedure revision, all CWPs are independently reviewed, after initial preparation, to ensure that appropriate, special instructions are included."

This review was extended to CN 1907 and the CWPs that modified System 11, which is a purified helium gas system. In accordance with FSV STD-3, "Cleaning of Fluid Systems at Fort St. Vrain," Issue 1, dated October 10, 1983, System 11 is a Grade G-1 "Pure Gas," Category D.1 system requiring a high velocity air purge prior to placing the system in service. FSV STD-3 required work instructions (PITR) to specify purge paths, purge medium, and purge velocities as well as necessary precautions and acceptance criteria. The SRI determined that CN 1907 CWP PITRs did not incorporate specific cleanliness work instructions.

The licensee was informed that the failure to comply with the above CWPM procedure requirements is considered a violation (8514-03) for which corrective actions from a previous violation did not prevent a further violation.

The SRI had no further comments in this area.

7. Operational Safety Verification

The SRI reviewed licensee activities to ascertain that the facility is being operated safely and in conformance with regulatory requirements and that the licensee's management control system is effectively discharging its responsibilities for continued safe operation. The review was conducted by direct observation of activities, tours of the facility, interviews and discussions with licensee personnel, independent verifications of safety system status and limiting conditions for operations, and review of facility records.

Logs and records reviewed included:

- . Auxiliary Operator Logs
- . Clearance Log
- . Equipment Operator Logs
- . Operations Deviations Reports
- . Operations Order Book
- . Reactor Operator Logs
- . Shift Supervisor Logs
- . Shift Turnover Checklists
- . Station Service Requests (SSR)
- . Technical Specification Compliance Logs
- . Temporary Configuration Reports

Plant tours indicated the following types of deficiencies, which were brought to the attention of the licensee:

- . LN₂ storage tank room used for storage of flammable material.
- . Trash located in various areas of the reactor building (e.g., levels 12, 10, and 8).
- . Expansion joint for vacuum jacket around LN₂ line was broken above PE 2523-67.
- . Wire laying in bottom of A-4601 demineralizer.
- . Auxiliary status tag laying on the deck of Level 10 of the reactor building.

On May 16, 1985, the SRI observed/monitored a radiological emergency exercise drill initiated at 8:30 a.m. MDT and terminated at 11:15 a.m. MDT. The SRI provided comments during the licensee's post-drill critique.

The SRI had no further comments in this area.

8. Periodic-Special Report

The SRI Reviewed the following reports for content, reporting requirement, and adequacy:

- . Monthly Operations Report for the month of April 1985
- . Radiological Environmental Monitoring Program Annual Summary Report for 1984

No violations or deviations were identified.

9. Exit Interview

Exit interviews were conducted at the end of various segments of this inspection with MR. J. W. Gahm, Manager Nuclear Production, and/or other members of the PSC staff as identified in paragraph 1. At the interviews, the NRC inspectors discussed the findings indicated in the previous paragraphs. The licensee acknowledged these findings.